

**Summary of Chemistry Results**  
**Zone A2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID:		A2-DAUN4918		A2-KAME4946		A2-OKLA4675			
		Location Type:		Residence		Residence		Residence			
		Address:		4918 Dauntless Drive		4946 Kamehameha Loop		4675 Oklahoma Avenue			
		Field Sample ID:		A2-TW-0001840-24092-N-WQI	A2-TW-0001840-24092-N-H-WQI	A2-TW-0001904-25091-N	A2-TW-0002021-24092-N-WQI	A2-TW-0002021-24092-3-N-WQI	A2-TW-0002021-24092-N-H-WQI	A2-TW-0002021-24092-3-N-H-WQI	A2-TW-0002021-24092-N-WQI-R1
		Sample Date:		2025-11-18	2025-11-18	2025-04-02	2025-11-12	2025-11-12	2025-11-12	2025-11-12	2025-11-15
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	--	Absent	Absent	--	--	Present
	E. coli	--	--	Absent	--	--	Absent	Absent	--	--	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	1.00	19.0	--	23.0	60.0	48.0	52.0	12.0
Field Test (ppb)	Free Chlorine	4000	MCL	760	460	1050	770	--	720	--	830
Field Test (pH)	pH	--	--	7.27	7.38	7.33	7.23	--	7.15	--	7.36
Field Test (ms/cm)	Specific Conductivity	--	--	0.263	0.274	0.260	0.246	--	0.308	--	0.260
Field Test (degrees Celcius)	Temperature	--	--	25.9	43.5	26.6	25.9	--	41.8	--	22.9
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.108	0.844	0.00	0.530	--	0.00	--	0.337
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51500	--	58500	50300	51100	--	--	54800
	Total Organic Carbon	--	--	ND	--	ND	220	ND	--	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	ND	ND	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	ND	ND	--	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	--	ND	ND	ND	--	--	ND
	Petroleum Hydrocarbons, Total	--	--	ND	--	ND	ND	ND	--	--	ND
Metals (ppb)	Copper	1300	MCL	22.6	--	71.4	22.5	22.8	--	--	54.0
	Lead	15	MCL	0.230	--	0.250	0.230	0.170	--	--	0.290
	Mercury	2	MCL	ND	--	ND	ND	ND	--	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	--	ND	ND	ND	--	--	ND
	2-Methylnaphthalene	--	--	ND	--	ND	ND	ND	--	--	ND
	Acenaphthylene	--	--	ND	--	ND	ND	ND	--	--	ND
	Anthracene	--	--	ND	--	ND	ND	ND	--	--	ND
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	ND	ND	--	--	ND
	Benzo(b)fluoranthene	--	--	ND	--	ND	ND	ND	--	--	ND

**Summary of Chemistry Results**  
**Zone A2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-DAUN4918		A2-KAME4946		A2-OKLA4675					
		Residence		Residence		Residence					
		4918 Dauntless Drive		4946 Kamehameha Loop		4675 Oklahoma Avenue					
		Field Sample ID: A2-TW-0001840-24092-N-WQI	A2-TW-0001840-24092-N-H-WQI	A2-TW-0001904-25091-N	A2-TW-0002021-24092-N-WQI	A2-TW-0002021-24092-3-N-WQI	A2-TW-0002021-24092-N-H-WQI	A2-TW-0002021-24092-3-N-H-WQI	A2-TW-0002021-24092-N-WQI-R1		
		Sample Date: 2025-11-18	2025-11-18	2025-04-02	2025-11-12	2025-11-12	2025-11-12	2025-11-12	2025-11-15		
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	--	ND	ND	ND	--	--	ND
	Benzo(k)fluoranthene	--	--	ND	--	ND	ND	ND	--	--	ND
	Chrysene	--	--	ND	--	ND	ND	ND	--	--	ND
	Dibenz(a,h)anthracene	--	--	ND	--	ND	ND	ND	--	--	ND
	Fluorene	--	--	ND	--	ND	ND	ND	--	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	--	ND	ND	ND	--	--	ND
	Naphthalene	--	--	ND	--	ND	ND	ND	--	--	ND
	Phenanthrene	--	--	ND	--	ND	ND	ND	--	--	ND
	Pyrene	--	--	ND	--	ND	ND	ND	--	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	1,3,5-Trimethylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	Benzene	5	MCL	ND	--	ND	ND	ND	--	--	ND
	Ethylbenzene	700	MCL	ND	--	ND	ND	ND	--	--	ND
	Isopropylbenzene (Cumene)	--	--	ND	--	ND	ND	ND	--	--	ND
	m,p-Xylene	--	--	ND	--	ND	ND	ND	--	--	ND
	n-Butylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	n-Propylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	o-Xylene	--	--	ND	--	ND	ND	ND	--	--	ND
	sec-Butylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	tert-Butylbenzene	--	--	ND	--	ND	ND	ND	--	--	ND
	Toluene	1000	MCL	ND	--	ND	ND	ND	--	--	ND
	Xylenes, Total	10000	MCL	ND	--	ND	ND	ND	--	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	--	ND	ND	ND	--	--	ND

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-DAUN4918		A2-KAME4946		A2-OKLA4675					
		Residence		Residence		Residence					
		4918 Dauntless Drive		4946 Kamehameha Loop		4675 Oklahoma Avenue					
		Field Sample ID:	A2-TW-0001840-24092-N-WQI	A2-TW-0001840-24092-N-H-WQI	A2-TW-0001904-25091-N	A2-TW-0002021-24092-N-WQI	A2-TW-0002021-24092-3-N-WQI	A2-TW-0002021-24092-N-H-WQI	A2-TW-0002021-24092-3-N-H-WQI	A2-TW-0002021-24092-N-WQI-R1	
		Sample Date:	2025-11-18	2025-11-18	2025-04-02	2025-11-12	2025-11-12	2025-11-12	2025-11-12	2025-11-15	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Bromoform	--	--	0.400	--	ND	ND	ND	--	--	0.320
	Chloroform	--	--	ND	--	ND	ND	ND	--	--	ND
	Dibromochloromethane	--	--	0.280	--	ND	ND	ND	--	--	0.310
	Total Trihalomethanes	80	MCL	0.680	--	ND	ND	ND	--	--	0.630

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-OKLA4675		A2-OKLA4675							A2-TOMA4912
		Location Type: Residence		Residence							Residence
		Address: 4675 Oklahoma Avenue		4675 Oklahoma Avenue							4912 Tomahawk Street
		Field Sample ID:	A2-TW-0002021-24092-N-H-WQI-R1	A2-TW-0002021-24092-N-1-WQI	A2-TW-0002021-24092-N-1-H-WQI	A2-TW-0002021-25305-N-WQI	A2-TW-0002021-25305-N-H-WQI	A2-TW-0002021-25305-N-1-WQI	A2-TW-0002021-25305-N-H-1-WQI	A2-TW-0002066-24092-N-WQI	
		Sample Date:	2025-11-15	2025-11-15	2025-11-15	2026-01-27	2026-01-27	2026-01-27	2026-01-27	2025-06-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Bacterial Test (in 100 mL)	Coliform	--	--	--	Present	--	Absent	--	Absent	--	Absent
	E. coli	--	--	--	Absent	--	Absent	--	Absent	--	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	1.00	9.00	3.00	71.0	300	3.00	ND	2.00
Field Test (ppb)	Free Chlorine	4000	MCL	440	830	740	770	710	880	670	830
Field Test (pH)	pH	--	--	7.33	7.31	7.42	7.09	7.26	7.28	7.31	7.55
Field Test (ms/cm)	Specific Conductivity	--	--	0.290	0.310	0.281	0.266	0.277	0.253	0.276	0.280
Field Test (degrees Celcius)	Temperature	--	--	39.0	23.9	39.3	25.2	41.9	25.5	43.9	26.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.472	0.311	0.768	1.27	1.60	1.22	1.70	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	51800	--	54600	--	54500	--	60400
	Total Organic Carbon	--	--	--	ND	--	ND	--	ND	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons, Total	--	--	--	ND	--	ND	--	ND	--	ND
Metals (ppb)	Copper	1300	MCL	--	38.9	--	16.7	--	22.9	--	21.0
	Lead	15	MCL	--	0.270	--	0.140	--	0.230	--	0.340
	Mercury	2	MCL	--	ND	--	ND	--	ND	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	ND	--	ND	--	ND	--	ND
	2-Methylnaphthalene	--	--	--	ND	--	ND	--	ND	--	ND
	Acenaphthylene	--	--	--	ND	--	ND	--	ND	--	ND
	Anthracene	--	--	--	ND	--	ND	--	ND	--	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	--	ND	--	ND	--	ND
	Benzo(b)fluoranthene	--	--	--	ND	--	ND	--	ND	--	ND

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-OKLA4675		Residence					A2-TOMA4912		
		Location Type: Residence		4675 Oklahoma Avenue					Residence		
		Address: 4675 Oklahoma Avenue							4912 Tomahawk Street		
		Field Sample ID:	A2-TW-0002021-24092-N-H-WQI-R1	A2-TW-0002021-24092-N-1-WQI	A2-TW-0002021-24092-N-1-H-WQI	A2-TW-0002021-25305-N-WQI	A2-TW-0002021-25305-N-H-WQI	A2-TW-0002021-25305-N-1-WQI	A2-TW-0002021-25305-N-H-1-WQI	A2-TW-0002066-24092-N-WQI	
		Sample Date:	2025-11-15	2025-11-15	2025-11-15	2026-01-27	2026-01-27	2026-01-27	2026-01-27	2025-06-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	--	ND	--	ND	--	ND	--	ND
	Benzo(k)fluoranthene	--	--	--	ND	--	ND	--	ND	--	ND
	Chrysene	--	--	--	ND	--	ND	--	ND	--	ND
	Dibenz(a,h)anthracene	--	--	--	ND	--	ND	--	ND	--	ND
	Fluorene	--	--	--	ND	--	ND	--	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	ND	--	ND	--	ND	--	ND
	Naphthalene	--	--	--	ND	--	ND	--	ND	--	ND
	Phenanthrene	--	--	--	ND	--	ND	--	ND	--	ND
	Pyrene	--	--	--	ND	--	ND	--	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	Benzene	5	MCL	--	ND	--	ND	--	ND	--	ND
	Ethylbenzene	700	MCL	--	ND	--	ND	--	ND	--	ND
	Isopropylbenzene (Cumene)	--	--	--	ND	--	ND	--	ND	--	ND
	m,p-Xylene	--	--	--	ND	--	ND	--	ND	--	ND
	n-Butylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	n-Propylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	o-Xylene	--	--	--	ND	--	ND	--	ND	--	ND
	sec-Butylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	tert-Butylbenzene	--	--	--	ND	--	ND	--	ND	--	ND
	Toluene	1000	MCL	--	ND	--	ND	--	ND	--	ND
Xylenes, Total	10000	MCL	--	ND	--	ND	--	ND	--	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	ND	--	ND	--	ND	--	0.310

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-OKLA4675		A2-OKLA4675								A2-TOMA4912	
		Location Type: Residence		Residence								Residence	
		Address: 4675 Oklahoma Avenue		4675 Oklahoma Avenue								4912 Tomahawk Street	
		Field Sample ID:		A2-TW-0002021-24092-N-H-WQI-R1	A2-TW-0002021-24092-N-1-WQI	A2-TW-0002021-24092-N-1-H-WQI	A2-TW-0002021-25305-N-WQI	A2-TW-0002021-25305-N-H-WQI	A2-TW-0002021-25305-N-1-WQI	A2-TW-0002021-25305-N-H-1-WQI	A2-TW-0002066-24092-N-WQI		
		Sample Date:		2025-11-15	2025-11-15	2025-11-15	2026-01-27	2026-01-27	2026-01-27	2026-01-27	2025-06-27		
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Trihalomethanes (ppb)	Bromoform	--	--	--	ND	--	ND	--	ND	--	0.380		
	Chloroform	--	--	--	ND	--	ND	--	ND	--	ND		
	Dibromochloromethane	--	--	--	ND	--	ND	--	ND	--	0.550		
	Total Trihalomethanes	80	MCL	--	ND	--	ND	--	ND	--	1.24		

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A2-TOMA4912			Location ID: A2-TOMA4965
				Field Sample ID	Sample Date	Sample Type	Field Sample ID
				Residence			Residence
				4912 Tomahawk Street			4965 Tomahawk Street
				A2-TW-0002066-24092-N-H-WQI	A2-TW-0002066-25305-N-WQI	A2-TW-0002066-25305-N-H-WQI	A2-TW-0002095-25091-N
				2025-06-27	2025-12-03	2025-12-03	2025-04-03
				N (Normal)	N (Normal)	N (Normal)	N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	--	Absent	--	--
	E. coli	--	--	--	Absent	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	6.00	1.00	3.00	--
Field Test (ppb)	Free Chlorine	4000	MCL	540	830	690	510
Field Test (pH)	pH	--	--	7.36	7.21	7.29	7.25
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.237	0.257	0.260
Field Test (degrees Celcius)	Temperature	--	--	36.6	25.8	41.3	25.5
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0380	0.475	0.670	0.180
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	52100	--	54900
	Total Organic Carbon	--	--	--	ND	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	--	ND	--	ND
	Petroleum Hydrocarbons, Total	--	--	--	ND	--	ND
Metals (ppb)	Copper	1300	MCL	--	22.5	--	35.7
	Lead	15	MCL	--	ND	--	0.190
	Mercury	2	MCL	--	ND	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	ND	--	ND
	2-Methylnaphthalene	--	--	--	ND	--	ND
	Acenaphthylene	--	--	--	ND	--	ND
	Anthracene	--	--	--	ND	--	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	--	ND
	Benzo(b)fluoranthene	--	--	--	ND	--	ND

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A2-TOMA4912			Location ID: A2-TOMA4965
				Location Type: Residence	Location Type: Residence	Location Type: Residence	Location Type: Residence
				Address: 4912 Tomahawk Street			Address: 4965 Tomahawk Street
				Field Sample ID: A2-TW-0002066-24092-N-H-WQI	Field Sample ID: A2-TW-0002066-25305-N-WQI	Field Sample ID: A2-TW-0002066-25305-N-H-WQI	Field Sample ID: A2-TW-0002095-25091-N
				Sample Date: 2025-06-27	Sample Date: 2025-12-03	Sample Date: 2025-12-03	Sample Date: 2025-04-03
				Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	--	ND	--	ND
	Benzo(k)fluoranthene	--	--	--	ND	--	ND
	Chrysene	--	--	--	ND	--	ND
	Dibenz(a,h)anthracene	--	--	--	ND	--	ND
	Fluorene	--	--	--	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	ND	--	ND
	Naphthalene	--	--	--	ND	--	ND
	Phenanthrene	--	--	--	ND	--	ND
	Pyrene	--	--	--	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	--	ND	--	ND
	Benzene	5	MCL	--	ND	--	ND
	Ethylbenzene	700	MCL	--	ND	--	ND
	Isopropylbenzene (Cumene)	--	--	--	ND	--	ND
	m,p-Xylene	--	--	--	ND	--	ND
	n-Butylbenzene	--	--	--	ND	--	ND
	n-Propylbenzene	--	--	--	ND	--	ND
	o-Xylene	--	--	--	ND	--	ND
	sec-Butylbenzene	--	--	--	ND	--	ND
	tert-Butylbenzene	--	--	--	ND	--	ND
	Toluene	1000	MCL	--	ND	--	ND
Xylenes, Total	10000	MCL	--	ND	--	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	0.400	--	ND

**Summary of Chemistry Results**

**Zone A2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

**Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone A2**

		Location ID: A2-TOMA4912		A2-TOMA4965			
		Location Type: Residence		Residence			
		Address: 4912 Tomahawk Street		4965 Tomahawk Street			
		Field Sample ID: A2-TW-0002066-24092-N-H-WQI	A2-TW-0002066-25305-N-WQI	A2-TW-0002066-25305-N-H-WQI	A2-TW-0002095-25091-N		
		Sample Date: 2025-06-27	2025-12-03	2025-12-03	2025-04-03		
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Trihalomethanes (ppb)	Bromoform	--	--	--	0.680	--	ND
	Chloroform	--	--	--	ND	--	ND
	Dibromochloromethane	--	--	--	0.740	--	0.260
	Total Trihalomethanes	80	MCL	--	1.82	--	0.260