

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D2-13TH0212A		Location ID: D2-19TH0127		Location ID: D2-4TH0106		Location ID: D2-BEED0302		Location ID: D2-BOQU0503	
				Location Type: Residence	Address: 212A 13th Street	Location Type: Residence	Address: 127 19th Street	Location Type: Residence	Address: 106 4th Street	Location Type: Residence	Address: 302 Beedle Street	Location Type: Residence	Address: 503 Boquet Boulevard
				Field Sample ID: D2-TW-0008406-25091-N	Field Sample ID: D2-TW-0008406-25091-3-N	Field Sample ID: D2-TW-0008307-25091-N	Field Sample ID: D2-TW-0008210-25305-N-WQI	Field Sample ID: D2-TW-0008210-25305-N-H-WQI	Field Sample ID: D2-TW-0007657-24092-N-1-WQI	Field Sample ID: D2-TW-0007657-24092-N-1-H-WQI	Field Sample ID: D2-TW-0007674-24092-N-WQI	Field Sample ID: D2-TW-0007674-24092-N-WQI	Field Sample ID: D2-TW-0007674-24092-N-WQI
				Sample Date: 2025-04-01	Sample Date: 2025-04-01	Sample Date: 2025-04-01	Sample Date: 2026-02-17	Sample Date: 2026-02-17	Sample Date: 2025-04-24	Sample Date: 2025-04-24	Sample Date: 2025-10-31	Sample Date: 2025-10-31	Sample Date: 2025-10-31
				Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	--	Absent	--	Absent	--	Absent	--	Absent
	E. coli	--	--	--	--	--	Absent	--	Absent	--	Absent	--	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	--	--	--	98.0	ND	10.0	2.00	5.00	--	5.00
Field Test (ppb)	Free Chlorine	4000	MCL	680	--	470	920	500	730	830	680	--	680
Field Test (pH)	pH	--	--	7.29	--	7.33	7.37	7.39	7.24	7.40	6.55	--	6.55
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	--	0.260	0.254	0.284	0.230	0.240	0.252	--	0.252
Field Test (degrees Celcius)	Temperature	--	--	25.4	--	24.2	23.5	44.7	23.4	38.5	25.4	--	25.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	0.00	1.56	1.42	0.0230	0.590	0.600	--	0.600
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54600	56200	52600	57600	--	58400	--	53100	--	53100
	Total Organic Carbon	--	--	ND	ND	ND	ND	--	220	--	ND	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
Metals (ppb)	Copper	1300	MCL	17.7	18.5	60.2	25.3	--	22.2	--	36.6	--	36.6
	Lead	15	MCL	ND	ND	ND	ND	--	0.190	--	ND	--	ND
	Mercury	2	MCL	ND	ND	ND	ND	--	ND	--	ND	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Anthracene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	--	ND	--	ND	--	ND

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

		Location ID: D2-13TH0212A		D2-19TH0127		D2-4TH0106		D2-BEED0302		D2-BOQU0503	
		Residence		Residence		Residence		Residence		Residence	
		212A 13th Street		127 19th Street		106 4th Street		302 Beedle Street		503 Boquet Boulevard	
		D2-TW-0008406-25091-N		D2-TW-0008406-25091-3-N		D2-TW-0008307-25091-N		D2-TW-0008210-25305-N-WQI		D2-TW-0008210-25305-N-H-WQI	
		2025-04-01		2025-04-01		2025-04-01		2026-02-17		2026-02-17	
		N (Normal)		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Chrysene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Fluorene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Naphthalene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Phenanthrene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Pyrene	--	--	ND	ND	ND	ND	--	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Benzene	5	MCL	ND	ND	ND	ND	--	ND	--	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	--	ND	--	ND
	Isopropylbenzene (Cumene)	--	--	ND	ND	ND	ND	--	ND	--	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	--	ND	--	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	o-Xylene	--	--	ND	ND	ND	ND	--	ND	--	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	--	ND
	Toluene	1000	MCL	ND	ND	ND	ND	--	ND	--	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	--	ND	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	--	ND	--	ND
	Bromoform	--	--	ND	ND	ND	0.350	--	ND	--	ND
	Chloroform	--	--	ND	ND	ND	ND	--	ND	--	ND

Summary of Chemistry Results

Zone D2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-13TH0212A		D2-19TH0127	D2-4TH0106		D2-BEED0302		D2-BOQU0503																
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:
				D2-TW-0008406-25091-N	D2-TW-0008406-25091-3-N	D2-TW-0008307-25091-N	D2-TW-0008210-25305-N-WQI	D2-TW-0008210-25305-N-H-WQI	D2-TW-0007657-24092-N-1-WQI	D2-TW-0007657-24092-N-1-H-WQI	D2-TW-0007674-24092-N-WQI																
				2025-04-01	2025-04-01	2025-04-01	2026-02-17	2026-02-17	2025-04-24	2025-04-24	2025-10-31																
				N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)																
Trihalomethanes (ppb)	Dibromochloromethane	--	--	ND	ND	ND	0.250	--	ND	--	ND																
	Total Trihalomethanes	80	MCL	ND	ND	ND	0.600	--	ND	--	ND																

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-CORN1219					D2-FOXB1823		D2-GEMIO617
				D2-BOQU0503	Residence					Residence		Residence
				503 Boquet Boulevard	1219 Cornet Avenue					1823 Fox Boulevard		617 Gemini Avenue
				D2-TW-0007674-24092-N-H-WQI	D2-TW-0008040-25091-N-WQI-R1	D2-TW-0008040-25091-N-2-WQI	D2-TW-0008040-25091-N-1-WQI	D2-TW-0008040-25091-N-3-WQI	D2-TW-0007414-24092-N-WQI	D2-TW-0007414-24092-N-H-WQI	D2-TW-0007153-24092-N-1-WQI	
				2025-10-31	2025-06-27	2025-06-27	2025-06-27	2025-06-27	2025-04-04	2025-04-04	2025-07-11	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	--	--	--	Absent	--	Absent	
	E. coli	--	--	--	--	--	--	--	Absent	--	Absent	
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	ND	--	--	--	--	5.00	2.00	ND	
Field Test (ppb)	Free Chlorine	4000	MCL	260	680	870	700	700	610	700	520	
Field Test (pH)	pH	--	--	7.30	7.44	7.54	7.40	7.40	7.20	7.13	7.22	
Field Test (ms/cm)	Specific Conductivity	--	--	0.348	0.250	0.300	0.240	0.240	0.250	0.270	0.260	
Field Test (degrees Celcius)	Temperature	--	--	42.8	27.1	25.2	24.8	24.8	25.5	36.0	28.2	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.340	0.00	0.00	0.00	0.00	0.00	0.00	0.310	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	--	--	--	--	54100	--	59400	
	Total Organic Carbon	--	--	--	--	--	--	--	ND	--	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	--	--	--	--	ND	--	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	--	ND	ND	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons, Total	--	--	--	ND	ND	ND	ND	ND	--	ND	
Metals (ppb)	Copper	1300	MCL	--	--	--	--	--	76.3	--	11.6	
	Lead	15	MCL	--	--	--	--	--	0.230	--	0.140	
	Mercury	2	MCL	--	--	--	--	--	ND	--	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	--	--	--	--	ND	--	ND	
	2-Methylnaphthalene	--	--	--	--	--	--	--	ND	--	ND	
	Acenaphthylene	--	--	--	--	--	--	--	ND	--	ND	
	Anthracene	--	--	--	--	--	--	--	ND	--	ND	
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	--	ND	--	ND	
	Benzo(b)fluoranthene	--	--	--	--	--	--	--	ND	--	ND	
	Benzo(g,h,i)perylene	--	--	--	--	--	--	--	ND	--	ND	

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

		Location ID:	D2-BOQU0503	D2-CORN1219					D2-FOXB1823		D2-GEMIO617
		Location Type:	Residence	Residence					Residence		Residence
		Address:	503 Boquet Boulevard	1219 Cornet Avenue					1823 Fox Boulevard		617 Gemini Avenue
		Field Sample ID:	D2-TW-0007674-24092-N-H-WQI	D2-TW-0008040-25091-N-WQI-R1	D2-TW-0008040-25091-N-2-WQI	D2-TW-0008040-25091-N-1-WQI	D2-TW-0008040-25091-N-3-WQI	D2-TW-0007414-24092-N-WQI	D2-TW-0007414-24092-N-H-WQI	D2-TW-0007153-24092-N-1-WQI	
		Sample Date:	2025-10-31	2025-06-27	2025-06-27	2025-06-27	2025-06-27	2025-04-04	2025-04-04	2025-07-11	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	--	--	--	--	--	ND	--	ND
	Chrysene	--	--	--	--	--	--	--	ND	--	ND
	Dibenz(a,h)anthracene	--	--	--	--	--	--	--	ND	--	ND
	Fluorene	--	--	--	--	--	--	--	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	--	--	--	--	ND	--	ND
	Naphthalene	--	--	--	--	--	--	--	ND	--	ND
	Phenanthrene	--	--	--	--	--	--	--	ND	--	ND
	Pyrene	--	--	--	--	--	--	--	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	--	--	--	--	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	--	--	--	--	--	ND	--	ND
	Benzene	5	MCL	--	--	--	--	--	ND	--	ND
	Ethylbenzene	700	MCL	--	--	--	--	--	ND	--	ND
	Isopropylbenzene (Cumene)	--	--	--	--	--	--	--	ND	--	ND
	m,p-Xylene	--	--	--	--	--	--	--	ND	--	ND
	n-Butylbenzene	--	--	--	--	--	--	--	ND	--	ND
	n-Propylbenzene	--	--	--	--	--	--	--	ND	--	ND
	o-Xylene	--	--	--	--	--	--	--	ND	--	ND
	sec-Butylbenzene	--	--	--	--	--	--	--	ND	--	ND
	tert-Butylbenzene	--	--	--	--	--	--	--	ND	--	ND
	Toluene	1000	MCL	--	--	--	--	--	ND	--	ND
Xylenes, Total	10000	MCL	--	--	--	--	--	ND	--	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	--	--	ND	--	ND
	Bromoform	--	--	--	--	--	--	--	ND	--	ND
	Chloroform	--	--	--	--	--	--	--	ND	--	ND

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-CORN1219					D2-FOXB1823		D2-GEMI0617
				D2-BOQU0503	Residence					Residence		Residence
				503 Boquet Boulevard	1219 Cornet Avenue					1823 Fox Boulevard		617 Gemini Avenue
				D2-TW-0007674-24092-N-H-WQI	D2-TW-0008040-25091-N-WQI-R1	D2-TW-0008040-25091-N-2-WQI	D2-TW-0008040-25091-N-1-WQI	D2-TW-0008040-25091-N-3-WQI	D2-TW-0007414-24092-N-WQI	D2-TW-0007414-24092-N-H-WQI	D2-TW-0007153-24092-N-1-WQI	
				Sample Date:	2025-10-31	2025-06-27	2025-06-27	2025-06-27	2025-06-27	2025-04-04	2025-04-04	2025-07-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Trihalomethanes (ppb)	Dibromochloromethane	--	--	--	--	--	--	--	--	ND	--	ND
	Total Trihalomethanes	80	MCL	--	--	--	--	--	--	ND	--	ND

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-GEM10617	D2-JUL10204	D2-LEWA0394	D2-PORT1910		D2-TINK0116
				Location Type:	Residence	Residence	Residence	Residence		Residence
				Address:	617 Gemini Avenue	204 Julian Avenue	394 Lewahana Loop	1910 Porter Avenue		116 Tinker Drive
				Field Sample ID:	D2-TW-0007153-24092-N-1-H-WQI	D2-TW-0007262-25091-N	D2-TW-0007277-25091-N	D2-TW-0007744-24092-N-1-WQI	D2-TW-0007744-24092-N-1-H-WQI	D2-TW-0008251-25091-N
				Sample Date:	2025-07-11	2025-04-07	2025-04-01	2025-07-22	2025-07-22	2025-04-02
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	--	--	Absent	--	--
	E. coli	--	--	--	--	--	--	Absent	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	3.00	--	--	--	3.00	51.0	--
Field Test (ppb)	Free Chlorine	4000	MCL	80.0	720	700	570	560	440	
Field Test (pH)	pH	--	--	7.34	7.21	7.31	7.23	7.51	7.04	
Field Test (ms/cm)	Specific Conductivity	--	--	0.330	0.230	0.260	0.290	0.260	0.270	
Field Test (degrees Celcius)	Temperature	--	--	46.0	24.9	24.0	25.4	36.4	29.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.68	0.00	0.00	0.610	0.340	1.25	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	56900	54800	56800	--	58100	
	Total Organic Carbon	--	--	--	ND	ND	ND	--	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	--	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons, Total	--	--	--	ND	ND	ND	--	ND	
Metals (ppb)	Copper	1300	MCL	--	10.7	4.70	34.2	--	46.5	
	Lead	15	MCL	--	ND	0.140	0.340	--	ND	
	Mercury	2	MCL	--	ND	ND	ND	--	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	ND	ND	ND	--	ND	
	2-Methylnaphthalene	--	--	--	ND	ND	ND	--	ND	
	Acenaphthylene	--	--	--	ND	ND	ND	--	ND	
	Anthracene	--	--	--	ND	ND	ND	--	ND	
	Benzo(a)pyrene	0.2	MCL	--	ND	ND	ND	--	ND	
	Benzo(b)fluoranthene	--	--	--	ND	ND	ND	--	ND	
	Benzo(g,h,i)perylene	--	--	--	ND	ND	ND	--	ND	

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

		Location ID:	D2-GEM10617	D2-JUL10204	D2-LEWA0394	D2-PORT1910		D2-TINK0116	
		Location Type:	Residence	Residence	Residence	Residence		Residence	
		Address:	617 Gemini Avenue	204 Julian Avenue	394 Lewahana Loop	1910 Porter Avenue		116 Tinker Drive	
		Field Sample ID:	D2-TW-0007153-24092-N-1-H-WQI	D2-TW-0007262-25091-N	D2-TW-0007277-25091-N	D2-TW-0007744-24092-N-1-WQI	D2-TW-0007744-24092-N-1-H-WQI	D2-TW-0008251-25091-N	
		Sample Date:	2025-07-11	2025-04-07	2025-04-01	2025-07-22	2025-07-22	2025-04-02	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	--	ND	ND	ND	--	ND
	Chrysene	--	--	--	ND	ND	ND	--	ND
	Dibenz(a,h)anthracene	--	--	--	ND	ND	ND	--	ND
	Fluorene	--	--	--	ND	ND	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	ND	ND	ND	--	ND
	Naphthalene	--	--	--	ND	ND	ND	--	ND
	Phenanthrene	--	--	--	ND	ND	ND	--	ND
	Pyrene	--	--	--	ND	ND	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	ND	ND	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	--	ND	ND	ND	--	ND
	Benzene	5	MCL	--	ND	ND	ND	--	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	--	ND
	Isopropylbenzene (Cumene)	--	--	--	ND	ND	ND	--	ND
	m,p-Xylene	--	--	--	ND	ND	ND	--	ND
	n-Butylbenzene	--	--	--	ND	ND	ND	--	ND
	n-Propylbenzene	--	--	--	ND	ND	ND	--	ND
	o-Xylene	--	--	--	ND	ND	ND	--	ND
	sec-Butylbenzene	--	--	--	ND	ND	ND	--	ND
	tert-Butylbenzene	--	--	--	ND	ND	ND	--	ND
	Toluene	1000	MCL	--	ND	ND	ND	--	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	ND	ND	ND	--	ND
	Bromoform	--	--	--	ND	ND	ND	--	ND
	Chloroform	--	--	--	ND	ND	ND	--	ND

Summary of Chemistry Results

Zone D2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone D2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-GEM10617	D2-JUL10204	D2-LEWA0394	D2-PORT1910		D2-TINK0116
				Location Type:	Residence	Residence	Residence	Residence		Residence
				Address:	617 Gemini Avenue	204 Julian Avenue	394 Lewahana Loop	1910 Porter Avenue		116 Tinker Drive
				Field Sample ID:	D2-TW-0007153-24092-N-1-H-WQI	D2-TW-0007262-25091-N	D2-TW-0007277-25091-N	D2-TW-0007744-24092-N-1-WQI	D2-TW-0007744-24092-N-1-H-WQI	D2-TW-0008251-25091-N
				Sample Date:	2025-07-11	2025-04-07	2025-04-01	2025-07-22	2025-07-22	2025-04-02
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Trihalomethanes (ppb)	Dibromochloromethane	--	--	--	ND	ND	ND	ND	--	ND
	Total Trihalomethanes	80	MCL	--	ND	ND	ND	ND	--	ND

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Other Buildings in Zone D2

		Location ID: D2-BLDG0017		Location Type: Non-Residence			
		Address: Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd					
		Field Sample ID:		D2-TW-0015546-25305-N-WQI	D2-TW-0015546-25305-N-H-WQI	D2-TW-0015546-25305-N-1-WQI	D2-TW-0015546-25305-N-1-H-WQI
		Sample Date:		2025-12-18	2025-12-18	2025-12-18	2025-12-18
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	Absent	--
	E. coli	--	--	Absent	--	Absent	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	18.0	2.00	8.00	173
Field Test (ppb)	Free Chlorine	4000	MCL	30.0	590	700	80.0
Field Test (pH)	pH	--	--	7.31	7.31	7.29	8.35
Field Test (ms/cm)	Specific Conductivity	--	--	0.235	0.235	0.236	0.279
Field Test (degrees Celcius)	Temperature	--	--	23.0	36.5	24.2	41.9
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.400	0.400	0.470	0.570
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56600	--	54300	--
	Total Organic Carbon	--	--	ND	--	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	--	ND	--
	Petroleum Hydrocarbons, Total	--	--	ND	--	ND	--
Metals (ppb)	Arsenic	10	MCL	ND	--	ND	--
	Copper	1300	MCL	139	--	32.4	--
	Lead	15	MCL	ND	--	ND	--
	Mercury	2	MCL	ND	--	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	--	ND	--
	2-Methylnaphthalene	--	--	ND	--	ND	--
	Acenaphthylene	--	--	ND	--	ND	--
	Anthracene	--	--	ND	--	ND	--

Summary of Chemistry Results
Zone D2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Other Buildings in Zone D2

		Location ID: D2-BLDG0017					
		Location Type: Non-Residence					
		Address: Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd					
		Field Sample ID:	D2-TW-0015546-25305-N-WQI	D2-TW-0015546-25305-N-H-WQI	D2-TW-0015546-25305-N-1-WQI	D2-TW-0015546-25305-N-1-H-WQI	
		Sample Date:	2025-12-18	2025-12-18	2025-12-18	2025-12-18	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	--	ND	--
	Benzo(b)fluoranthene	--	--	ND	--	ND	--
	Benzo(g,h,i)perylene	--	--	ND	--	ND	--
	Benzo(k)fluoranthene	--	--	ND	--	ND	--
	Chrysene	--	--	ND	--	ND	--
	Dibenz(a,h)anthracene	--	--	ND	--	ND	--
	Fluorene	--	--	ND	--	ND	--
	Indeno(1,2,3-c,d)pyrene	--	--	ND	--	ND	--
	Naphthalene	--	--	ND	--	ND	--
	Phenanthrene	--	--	ND	--	ND	--
	Pyrene	--	--	ND	--	ND	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	--	ND	--
	Benzene	5	MCL	ND	--	ND	--
	Ethylbenzene	700	MCL	ND	--	ND	--
	Isopropylbenzene (Cumene)	--	--	ND	--	ND	--
	m,p-Xylene	--	--	ND	--	ND	--
	n-Butylbenzene	--	--	ND	--	ND	--
	n-Propylbenzene	--	--	ND	--	ND	--
	o-Xylene	--	--	ND	--	ND	--
	sec-Butylbenzene	--	--	ND	--	ND	--
tert-Butylbenzene	--	--	ND	--	ND	--	

Summary of Chemistry Results

Zone D2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Other Buildings in Zone D2

				Location ID: D2-BLDG0017			
				Location Type: Non-Residence			
				Address: Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd			
				Field Sample ID: D2-TW-0015546-25305-N-WQI	D2-TW-0015546-25305-N-H-WQI	D2-TW-0015546-25305-N-1-WQI	D2-TW-0015546-25305-N-1-H-WQI
				Sample Date: 2025-12-18	2025-12-18	2025-12-18	2025-12-18
				Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Volatile Organic Compounds (ppb)	Toluene	1000	MCL	ND	--	ND	--
	Xylenes, Total	10000	MCL	ND	--	ND	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	--	ND	--
	Bromoform	--	--	0.320	--	ND	--
	Chloroform	--	--	ND	--	ND	--
	Dibromochloromethane	--	--	ND	--	ND	--
	Total Trihalomethanes	80	MCL	0.320	--	ND	--