

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

		Location ID: Location Type: Address:		F2-ARIZ3004 Residence 3004 Arizona Road				F2-DORI2271C Residence 2271C Doris Miller Loop		F2-KILM5438 Residence 5438 Kilmer Lane	
		Field Sample ID:		F2-TW-0011026-24092-N-WQI	F2-TW-0011026-24092-3-N-WQI	F2-TW-0011026-24092-N-H-WQI	F2-TW-0011026-24092-3-N-H-WQI	F2-TW-0011414-25091-N	F2-TW-0011414-25091-3-N	F2-TW-0011765-25305-N-WQI	F2-TW-0011765-25305-N-H-WQI
		Sample Date:		2025-08-26	2025-08-26	2025-08-26	2025-08-26	2025-04-01	2025-04-01	2026-01-05	2026-01-05
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	Absent	--	--	--	--	Absent	--
	E. coli	--	--	Absent	Absent	--	--	--	--	Absent	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	1.00	ND	ND	ND	--	--	ND	4.00
Field Test (ppb)	Free Chlorine	4000	MCL	720	--	600	--	610	--	760	690
Field Test (pH)	pH	--	--	7.29	--	7.40	--	7.07	--	7.29	7.23
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	--	0.290	--	0.330	--	0.233	0.252
Field Test (degrees Celcuis)	Temperature	--	--	27.0	--	43.7	--	24.5	--	22.7	33.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.28	--	0.610	--	0.00	--	0.629	0.854
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	59900	56500	--	--	55000	56200	56600	--
	Total Organic Carbon	--	--	ND	ND	--	--	ND	ND	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	--	ND	ND	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	--	ND	ND	ND	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	--	--	ND	ND	ND	--
	Petroleum Hydrocarbons, Total	--	--	ND	ND	--	--	ND	ND	ND	--
Metals (ppb)	Copper	1300	MCL	2.20	2.30	--	--	33.2	30.4	29.6	--
	Lead	15	MCL	ND	ND	--	--	ND	ND	ND	--
	Mercury	2	MCL	0.0250	ND	--	--	ND	ND	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	--	--	ND	ND	ND	--
	2-Methylnaphthalene	--	--	ND	ND	--	--	ND	ND	ND	--
	Acenaphthylene	--	--	ND	ND	--	--	ND	ND	ND	--
	Anthracene	--	--	ND	ND	--	--	ND	ND	ND	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	--	--	ND	ND	ND	--
	Benzo(b)fluoranthene	--	--	ND	ND	--	--	ND	ND	ND	--

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

				Location ID: Location Type: Address:				F2-ARIZ3004 Residence 3004 Arizona Road				F2-DORI2271C Residence 2271C Doris Miller Loop		F2-KILM5438 Residence 5438 Kilmer Lane	
				Field Sample ID:	F2-TW-0011026-24092-N-WQI	F2-TW-0011026-24092-3-N-WQI	F2-TW-0011026-24092-N-H-WQI	F2-TW-0011026-24092-3-N-H-WQI	F2-TW-0011414-25091-N	F2-TW-0011414-25091-3-N	F2-TW-0011765-25305-N-WQI	F2-TW-0011765-25305-N-H-WQI			
				Sample Date:	2025-08-26	2025-08-26	2025-08-26	2025-08-26	2025-04-01	2025-04-01	2026-01-05	2026-01-05			
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)			
				DOH Project Screening Level	Basis of Project Screening Level										
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level												
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Benzo(k)fluoranthene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Chrysene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Dibenz(a,h)anthracene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Fluorene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Naphthalene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Phenanthrene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Pyrene	--	--	ND	ND	--	--	ND	ND	ND	--				
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	1,3,5-Trimethylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Benzene	5	MCL	ND	ND	--	--	ND	ND	ND	--				
	Ethylbenzene	700	MCL	ND	ND	--	--	ND	ND	ND	--				
	Isopropylbenzene (Cumene)	--	--	ND	ND	--	--	ND	ND	ND	--				
	m,p-Xylene	--	--	ND	ND	--	--	ND	ND	ND	--				
	n-Butylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	n-Propylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	o-Xylene	--	--	ND	ND	--	--	ND	ND	ND	--				
	sec-Butylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	tert-Butylbenzene	--	--	ND	ND	--	--	ND	ND	ND	--				
	Toluene	1000	MCL	ND	ND	--	--	ND	ND	ND	--				
	Xylenes, Total	10000	MCL	ND	ND	--	--	ND	ND	ND	--				
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.260	ND	--	--	ND	ND	ND	--				

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

				Location ID: F2-ARIZ3004				F2-DORI2271C		F2-KILM5438		
				Location Type: Residence				Residence		Residence		
				Address: 3004 Arizona Road				2271C Doris Miller Loop		5438 Kilmer Lane		
				Field Sample ID:	F2-TW-0011026-24092-N-WQI	F2-TW-0011026-24092-3-N-WQI	F2-TW-0011026-24092-N-H-WQI	F2-TW-0011026-24092-3-N-H-WQI	F2-TW-0011414-25091-N	F2-TW-0011414-25091-3-N	F2-TW-0011765-25305-N-WQI	F2-TW-0011765-25305-N-H-WQI
				Sample Date:	2025-08-26	2025-08-26	2025-08-26	2025-08-26	2025-04-01	2025-04-01	2026-01-05	2026-01-05
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Trihalomethanes (ppb)	Bromoform	--	--	0.600	0.370	--	--	0.340	0.390	0.410	--	
	Chloroform	--	--	ND	ND	--	--	ND	ND	ND	--	
	Dibromochloromethane	--	--	0.690	0.430	--	--	0.300	0.350	0.320	--	
	Total Trihalomethanes	80	MCL	1.55	0.800	--	--	0.640	0.740	0.730	--	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

				Location ID:	F2-KOEL5301		F2-MURR0956		F2-SHIE5228			
				Location Type:	Residence		Residence		Residence			
				Address:	5301 Koelsch Lane		956 Murray Drive		5228 Shields Street			
				Field Sample ID:	F2-TW-0009847-25091-N	F2-TW-0009847-25091-3-N	F2-TW-0010183-24092-N-WQI	F2-TW-0010183-24092-N-H-WQI	F2-TW-0010906-25091-N	F2-TW-0010906-25091-3-N	F2-TW-0010906-25091-N-WQI-R1	F2-TW-0010906-25091-3-N-WQI-R1
				Sample Date:	2025-04-02	2025-04-02	2025-04-01	2025-04-01	2025-04-01	2025-04-01	2025-04-09	2025-04-09
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Bacterial Test (in 100 mL)	Coliform	--	--	--	--		Absent	--	--	--	--	--
	E. coli	--	--	--	--		Absent	--	--	--	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	--	--		14.0	52.0	--	--	--	--
Field Test (ppb)	Free Chlorine	4000	MCL	610	--		660	560	310	--	660	--
Field Test (pH)	pH	--	--	7.31	--		7.08	7.30	7.13	--	7.04	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	--		0.330	0.350	0.330	--	0.250	--
Field Test (degrees Celcuis)	Temperature	--	--	28.5	--		25.7	34.6	30.8	--	25.6	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--		0.00	0.00	0.00	--	0.00	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58700		54600	56600	--	52500	55000	--	--
	Total Organic Carbon	--	--	ND		ND	ND	--	ND	ND	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND		ND	ND	--	ND	53.0	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND		ND	ND	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND		ND	ND	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND		ND	ND	--	ND	53.0	ND	ND
Metals (ppb)	Copper	1300	MCL	28.2		29.8	1.90	--	87.2	84.1	--	--
	Lead	15	MCL	0.130		0.140	ND	--	0.360	0.330	--	--
	Mercury	2	MCL	ND		ND	ND	--	ND	ND	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND		ND	ND	--	ND	ND	--	--
	2-Methylnaphthalene	--	--	ND		ND	ND	--	ND	ND	--	--
	Acenaphthylene	--	--	ND		ND	ND	--	ND	ND	--	--
	Anthracene	--	--	ND		ND	ND	--	ND	ND	--	--
	Benzo(a)pyrene	0.2	MCL	ND		ND	ND	--	ND	ND	--	--
	Benzo(b)fluoranthene	--	--	ND		ND	ND	--	ND	ND	--	--
	Benzo(g,h,i)perylene	--	--	ND		ND	ND	--	ND	ND	--	--

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

		Location ID:	F2-KOEL5301		F2-MURR0956		F2-SHIE5228			
		Location Type:	Residence		Residence		Residence			
		Address:	5301 Koelsch Lane		956 Murray Drive		5228 Shields Street			
		Field Sample ID:	F2-TW-0009847-25091-N	F2-TW-0009847-25091-3-N	F2-TW-0010183-24092-N-WQI	F2-TW-0010183-24092-N-H-WQI	F2-TW-0010906-25091-N	F2-TW-0010906-25091-3-N	F2-TW-0010906-25091-N-WQI-R1	F2-TW-0010906-25091-3-N-WQI-R1
		Sample Date:	2025-04-02	2025-04-02	2025-04-01	2025-04-01	2025-04-01	2025-04-01	2025-04-09	2025-04-09
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	--	ND	ND	--
	Chrysene	--	--	ND	ND	ND	--	ND	ND	--
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	--	ND	ND	--
	Fluorene	--	--	ND	ND	ND	--	ND	ND	--
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	--	ND	ND	--
	Naphthalene	--	--	ND	ND	ND	--	ND	ND	--
	Phenanthrene	--	--	ND	ND	ND	--	ND	ND	--
	Pyrene	--	--	ND	ND	ND	--	ND	ND	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	Benzene	5	MCL	ND	ND	ND	--	ND	ND	--
	Ethylbenzene	700	MCL	ND	ND	ND	--	ND	ND	--
	Isopropylbenzene (Cumene)	--	--	ND	ND	ND	--	ND	ND	--
	m,p-Xylene	--	--	ND	ND	ND	--	ND	ND	--
	n-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	n-Propylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	o-Xylene	--	--	ND	ND	ND	--	ND	ND	--
	sec-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	tert-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--
	Toluene	1000	MCL	ND	ND	ND	--	ND	ND	--
	Xylenes, Total	10000	MCL	ND	ND	ND	--	ND	ND	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	--	ND	ND	--
	Bromoform	--	--	ND	ND	0.590	--	ND	ND	--
	Chloroform	--	--	ND	ND	ND	--	ND	ND	--

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

		Location ID:		F2-KOEL5301		F2-MURR0956		F2-SHIE5228			
		Location Type:		Residence		Residence		Residence			
		Address:		5301 Koelsch Lane		956 Murray Drive		5228 Shields Street			
		Field Sample ID:		F2-TW-0009847-25091-N	F2-TW-0009847-25091-3-N	F2-TW-0010183-24092-N-WQI	F2-TW-0010183-24092-N-H-WQI	F2-TW-0010906-25091-N	F2-TW-0010906-25091-3-N	F2-TW-0010906-25091-N-WQI-R1	F2-TW-0010906-25091-3-N-WQI-R1
		Sample Date:		2025-04-02	2025-04-02	2025-04-01	2025-04-01	2025-04-01	2025-04-01	2025-04-09	2025-04-09
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Dibromochloromethane	--	--	ND	ND	0.470	--	ND	ND	--	--
	Total Trihalomethanes	80	MCL	ND	ND	1.06	--	ND	ND	--	--

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

				Location ID:	F2-SHIE5228				F2-SNYD3172	
				Location Type:	Residence				Residence	
				Address:	5228 Shields Street				3172 Snyder Court	
				Field Sample ID:	F2-TW-0010906-25091-N-1-WQI	F2-TW-0010906-25091-N-2-WQI	F2-TW-0010906-25091-N-3-WQI	F2-TW-0010906-25091-N-4-WQI	F2-TW-0010587-25091-N	F2-TW-0010587-25091-3-N
				Sample Date:	2025-04-09	2025-04-09	2025-04-09	2025-04-09	2025-04-01	2025-04-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Field Test (ppb)	Free Chlorine	4000	MCL	810	790	710	520	660	--	
Field Test (pH)	pH	--	--	7.14	7.21	7.12	7.10	7.17	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	0.250	0.250	0.270	--	
Field Test (degrees Celcuis)	Temperature	--	--	26.0	26.2	26.1	26.3	26.1	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	0.00	0.00	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	--	--	--	53900	52600	
	Total Organic Carbon	--	--	--	--	--	--	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	--	--	--	--	24.5	23.4	
	Lead	15	MCL	--	--	--	--	ND	ND	
	Mercury	2	MCL	--	--	--	--	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	--	--	--	ND	ND	
	2-Methylnaphthalene	--	--	--	--	--	--	ND	ND	
	Acenaphthylene	--	--	--	--	--	--	ND	ND	
	Anthracene	--	--	--	--	--	--	ND	ND	
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	ND	ND	
	Benzo(b)fluoranthene	--	--	--	--	--	--	ND	ND	
	Benzo(g,h,i)perylene	--	--	--	--	--	--	ND	ND	
	Benzo(k)fluoranthene	--	--	--	--	--	--	ND	ND	
	Chrysene	--	--	--	--	--	--	ND	ND	
	Dibenz(a,h)anthracene	--	--	--	--	--	--	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Drinking Water Samples Collected in April 2025 - March 2026 from Residences in Zone F2

				Location ID:	F2-SHIE5228				F2-SNYD3172	
				Location Type:	Residence				Residence	
				Address:	5228 Shields Street				3172 Snyder Court	
				Field Sample ID:	F2-TW-0010906-25091-N-1-WQI	F2-TW-0010906-25091-N-2-WQI	F2-TW-0010906-25091-N-3-WQI	F2-TW-0010906-25091-N-4-WQI	F2-TW-0010587-25091-N	F2-TW-0010587-25091-3-N
				Sample Date:	2025-04-09	2025-04-09	2025-04-09	2025-04-09	2025-04-01	2025-04-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Fluorene	--	--	--	--	--	--	--	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	--	--	--	--	ND	ND
	Naphthalene	--	--	--	--	--	--	--	ND	ND
	Phenanthrene	--	--	--	--	--	--	--	ND	ND
	Pyrene	--	--	--	--	--	--	--	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	--	--	--	--	ND	ND
	1,3,5-Trimethylbenzene	--	--	--	--	--	--	--	ND	ND
	Benzene	5	MCL	--	--	--	--	--	ND	ND
	Ethylbenzene	700	MCL	--	--	--	--	--	ND	ND
	Isopropylbenzene (Cumene)	--	--	--	--	--	--	--	ND	ND
	m,p-Xylene	--	--	--	--	--	--	--	ND	ND
	n-Butylbenzene	--	--	--	--	--	--	--	ND	ND
	n-Propylbenzene	--	--	--	--	--	--	--	ND	ND
	o-Xylene	--	--	--	--	--	--	--	ND	ND
	sec-Butylbenzene	--	--	--	--	--	--	--	ND	ND
	tert-Butylbenzene	--	--	--	--	--	--	--	ND	ND
	Toluene	1000	MCL	--	--	--	--	--	ND	ND
	Xylenes, Total	10000	MCL	--	--	--	--	--	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	--	--	ND	ND
	Bromoform	--	--	--	--	--	--	--	ND	ND
	Chloroform	--	--	--	--	--	--	--	ND	ND
	Dibromochloromethane	--	--	--	--	--	--	--	ND	ND
	Total Trihalomethanes	80	MCL	--	--	--	--	--	ND	ND