

Summary of Chemistry Results

Zone G1

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Hydrants in Zone G1

		Location ID:		G1-HYD879	
		Location Type:		Hydrant	
		Address:		FH ID: 3	
		Field Sample ID:		G1-DL-0000616-24183-N	G1-DL-0000616-24183-3-N
		Sample Date:		2024-07-31	2024-07-31
		Sample Type:		N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	Absent
	E. coli	--	--	Absent	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	ND	ND
Field Test (ppb)	Free Chlorine	4000	MCL	200	--
Field Test (pH)	pH	--	--	7.16	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	--
Field Test (degrees Celcius)	Temperature	--	--	25.5	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.400	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56100	56500
	Total Organic Carbon	--	--	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND
	2-Methylnaphthalene	--	--	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Naphthalene	--	--	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND
	Benzene	5	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND

Summary of Chemistry Results

Zone G1

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Hydrants in Zone G1

		Location ID:	G1-HYD879		
		Location Type:	Hydrant		
		Address:	FH ID: 3		
		Field Sample ID:	G1-DL-0000616-24183-N	G1-DL-0000616-24183-3-N	
		Sample Date:	2024-07-31	2024-07-31	
		Sample Type:	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	o-Xylene	--	--	ND	ND
	Toluene	1000	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	2.60	2.40
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	0.960	0.810
	Total Trihalomethanes	80	MCL	3.56	3.21