

Summary of Chemistry Results
Zone H2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-MAHO5491		Location ID: H2-NAUP6205					
				Residence		Residence		Residence		Residence	
				Address: 5491 Mahogany Lane		Address: 6205 Naupaka Street					
				Field Sample ID: H2-TW-0013610-24092-A	Field Sample ID: H2-TW-0013610-24092-A-H	Field Sample ID: H2-TW-0011882-24092-A-1	Field Sample ID: H2-TW-0011882-24092-A-1-H	Field Sample ID: H2-TW-0011882-24092-A-2	Field Sample ID: H2-TW-0011882-24092-A-2-H	Field Sample ID: H2-TW-0011882-24092-A-3	Field Sample ID: H2-TW-0011882-24092-A-3-H
				Sample Date: 2024-07-16	Sample Date: 2024-07-16	Sample Date: 2024-07-15	Sample Date: 2024-07-15	Sample Date: 2024-07-15	Sample Date: 2024-07-15	Sample Date: 2024-07-15	Sample Date: 2024-07-15
				Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	Absent	--	Absent	--	Absent	--
	E. coli	--	--	Absent	--	Absent	--	Absent	--	Absent	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	2.00	ND	4.00	2.00	ND	ND	65.0	74.0
Field Test (ppb)	Free Chlorine	4000	MCL	830	180	650	590	1060	590	630	640
Field Test (pH)	pH	--	--	6.99	6.76	7.10	7.16	7.12	7.22	7.21	7.22
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.330	0.220	0.250	0.220	0.250	0.230	0.240
Field Test (degrees Celcius)	Temperature	--	--	26.4	55.2	25.8	41.1	25.9	39.6	25.4	37.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0220	0.120	0.0930	0.880	0.0880	0.850	0.0760	0.770
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56100	--	--	--	--	--	--	--
	Total Organic Carbon	--	--	ND	--	--	--	--	--	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	--	--	--	--	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	--	--	--	--	--	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	--	--	--	--	--	--	--
	Petroleum Hydrocarbons, Total	--	--	ND	--	--	--	--	--	--	--
Metals (ppb)	Copper	1300	MCL	19.9	--	--	--	--	--	--	--
	Lead	15	MCL	2.60	--	--	--	--	--	--	--
	Mercury	2	MCL	ND	--	--	--	--	--	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	--	--	--	--	--	--	--
	2-Methylnaphthalene	--	--	ND	--	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	--	--	--	--	--	--	--
	Naphthalene	--	--	ND	--	--	--	--	--	--	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	--	--	--	--	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	--	--	--	--	--	--	--

Summary of Chemistry Results

Zone H2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-MAHO5491		Location ID: H2-NAUP6205													
				Field Sample ID	Sample Date	Field Sample ID	Sample Date	Field Sample ID	Sample Date	Field Sample ID	Sample Date	Field Sample ID	Sample Date						
Volatile Organic Compounds (ppb)	Benzene	5	MCL	H2-TW-0013610-24092-A	2024-07-16	H2-TW-0013610-24092-A-H	2024-07-16	H2-TW-0011882-24092-A-1	2024-07-15	H2-TW-0011882-24092-A-1-H	2024-07-15	H2-TW-0011882-24092-A-2	2024-07-15	H2-TW-0011882-24092-A-2-H	2024-07-15	H2-TW-0011882-24092-A-3	2024-07-15	H2-TW-0011882-24092-A-3-H	2024-07-15
	Ethylbenzene	700	MCL	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
	m,p-Xylene	--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
	o-Xylene	--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Toluene	1000	MCL	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Xylenes, Total	10000	MCL	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND
Bromoform		--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
Chloroform		--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
Dibromochloromethane		--	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--
Total Trihalomethanes		80	MCL	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--	ND	--

Summary of Chemistry Results
Zone H2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	H2-NAUP6205				H2-NAUP6210				
				Residence 6205 Naupaka Street				Residence 6210 Naupaka Street				
				Field Sample ID:	H2-TW-0011882-24092-A-R1	H2-TW-0011882-24092-A-H-R1	H2-TW-0011882-24092-A-4	H2-TW-0011882-24092-A-4-H	H2-TW-0013497-24092-A	H2-TW-0013497-24092-3-A	H2-TW-0013497-24092-A-H	H2-TW-0013497-24092-3-A-H
				Sample Date:	2024-07-15	2024-07-15	2024-07-15	2024-07-15	2024-07-16	2024-07-16	2024-07-16	2024-07-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	Absent	--	Absent	Absent	--	--	--
	E. coli	--	--	Absent	--	Absent	--	Absent	Absent	--	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	738	738	ND	ND	ND	ND	ND	ND	ND
Field Test (ppb)	Free Chlorine	4000	MCL	640	640	590	640	590	--	500	--	--
Field Test (pH)	pH	--	--	7.09	7.19	7.14	7.09	6.97	--	6.44	--	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.250	0.230	0.250	0.270	--	0.300	--	--
Field Test (degrees Celcius)	Temperature	--	--	24.3	38.8	26.5	40.7	27.6	--	39.2	--	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0540	0.810	0.0940	0.490	0.640	--	0.520	--	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	--	--	--	57300	59400	--	--	--
	Total Organic Carbon	--	--	--	--	--	--	ND	ND	--	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	--	--	--	ND	ND	--	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	--	--	--	ND	ND	--	--	--
	Petroleum Hydrocarbons (as Oil)	--	--	--	--	--	--	ND	ND	--	--	--
	Petroleum Hydrocarbons, Total	--	--	--	--	--	--	ND	ND	--	--	--
Metals (ppb)	Copper	1300	MCL	--	--	--	--	23.8	24.0	--	--	--
	Lead	15	MCL	--	--	--	--	0.440	0.440	--	--	--
	Mercury	2	MCL	--	--	--	--	ND	ND	--	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	--	--	--	ND	ND	--	--	--
	2-Methylnaphthalene	--	--	--	--	--	--	ND	ND	--	--	--
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	ND	ND	--	--	--
	Naphthalene	--	--	--	--	--	--	ND	ND	--	--	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	--	--	--	--	ND	ND	--	--	--
	1,3,5-Trimethylbenzene	--	--	--	--	--	--	ND	ND	--	--	--

Summary of Chemistry Results

Zone H2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-NAUP6205				Location ID: H2-NAUP6210			
				Location Type: Residence				Location Type: Residence			
				Address: 6205 Naupaka Street				Address: 6210 Naupaka Street			
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				H2-TW-0011882-24092-A-R1	H2-TW-0011882-24092-A-H-R1	H2-TW-0011882-24092-A-4	H2-TW-0011882-24092-A-4-H	H2-TW-0013497-24092-A	H2-TW-0013497-24092-3-A	H2-TW-0013497-24092-A-H	H2-TW-0013497-24092-3-A-H
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				2024-07-15	2024-07-15	2024-07-15	2024-07-15	2024-07-16	2024-07-16	2024-07-16	2024-07-16
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Volatile Organic Compounds (ppb)	Benzene	5	MCL	--	--	--	--	ND	ND	--	--
	Ethylbenzene	700	MCL	--	--	--	--	ND	ND	--	--
	m,p-Xylene	--	--	--	--	--	--	ND	ND	--	--
	o-Xylene	--	--	--	--	--	--	ND	ND	--	--
	Toluene	1000	MCL	--	--	--	--	ND	ND	--	--
	Xylenes, Total	10000	MCL	--	--	--	--	ND	ND	--	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	--	0.340	0.370	--	--
	Bromoform	--	--	--	--	--	--	0.970	1.10	--	--
	Chloroform	--	--	--	--	--	--	ND	ND	--	--
	Dibromochloromethane	--	--	--	--	--	--	0.790	0.920	--	--
	Total Trihalomethanes	80	MCL	--	--	--	--	2.10	2.39	--	--

Summary of Chemistry Results

Zone H2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

		Location ID: H2-PLUM6655		Residence			
		Location Type: Residence		6655 Plumeria Loop			
		Address: 6655 Plumeria Loop					
		Field Sample ID:	H2-TW-0013640-24092-A	H2-TW-0013640-24092-3-A	H2-TW-0013640-24092-A-H	H2-TW-0013640-24092-3-A-H	
		Sample Date:	2024-07-31	2024-07-31	2024-07-31	2024-07-31	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	Absent	--	--
	E. coli	--	--	Absent	Absent	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	ND	ND	ND	ND
Field Test (ppb)	Free Chlorine	4000	MCL	500	--	320	--
Field Test (pH)	pH	--	--	7.03	--	7.04	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	--	0.260	--
Field Test (degrees Celcius)	Temperature	--	--	28.0	--	40.3	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	0.00	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53800	53400	--	--
	Total Organic Carbon	--	--	ND	ND	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	--	--
	Petroleum Hydrocarbons, Total	--	--	ND	ND	--	--
Metals (ppb)	Copper	1300	MCL	9.70	9.70	--	--
	Lead	15	MCL	0.780	0.750	--	--
	Mercury	2	MCL	ND	ND	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	--	--
	2-Methylnaphthalene	--	--	ND	ND	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	--	--
	Naphthalene	--	--	ND	ND	--	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	--	--

Summary of Chemistry Results
Zone H2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Residences in Zone H2

		Location ID:		H2-PLUM6655			
		Location Type:		Residence			
		Address:		6655 Plumeria Loop			
		Field Sample ID:	H2-TW-0013640-24092-A	H2-TW-0013640-24092-3-A	H2-TW-0013640-24092-A-H	H2-TW-0013640-24092-3-A-H	
		Sample Date:	2024-07-31	2024-07-31	2024-07-31	2024-07-31	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Volatile Organic Compounds (ppb)	Benzene	5	MCL	ND	ND	--	--
	Ethylbenzene	700	MCL	ND	ND	--	--
	m,p-Xylene	--	--	ND	ND	--	--
	o-Xylene	--	--	ND	ND	--	--
	Toluene	1000	MCL	ND	ND	--	--
	Xylenes, Total	10000	MCL	ND	ND	--	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	--	--
	Bromoform	--	--	0.360	ND	--	--
	Chloroform	--	--	ND	ND	--	--
	Dibromochloromethane	--	--	ND	ND	--	--
	Total Trihalomethanes	80	MCL	0.360	ND	--	--

Summary of Chemistry Results

Zone H2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Hydrants in Zone H2

		Location ID:	H2-HYD0377A	H2-HYD1331A	H2-HYD1646A	
		Location Type:	Hydrant	Hydrant	Hydrant	
		Address:	Hydrant 377	Hydrant 1331	Hydrant 1646	
		Field Sample ID:	H2-DL-0017757-24183 -A	H2-DL-0017758-24183 -A	H2-DL-0000688-24183 -A	
		Sample Date:	2024-07-16	2024-07-16	2024-07-16	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	Absent	Absent
	E. coli	--	--	Absent	Absent	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	ND	ND	ND
Field Test (ppb)	Free Chlorine	4000	MCL	460	570	570
Field Test (pH)	pH	--	--	7.15	7.00	7.02
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.260	0.260
Field Test (degrees Celcius)	Temperature	--	--	26.7	24.9	28.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.720	0.950	0.920
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	60000	54300	56200
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND

Summary of Chemistry Results

Zone H2

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in July 2024 from Hydrants in Zone H2

		Location ID:	H2-HYD0377A	H2-HYD1331A	H2-HYD1646A	
		Location Type:	Hydrant	Hydrant	Hydrant	
		Address:	Hydrant 377	Hydrant 1331	Hydrant 1646	
		Field Sample ID:	H2-DL-0017757-24183 -A	H2-DL-0017758-24183 -A	H2-DL-0000688-24183 -A	
		Sample Date:	2024-07-16	2024-07-16	2024-07-16	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	o-Xylene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.500	ND	ND
	Bromoform	--	--	1.50	ND	0.420
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	1.30	ND	0.260
	Total Trihalomethanes	80	MCL	3.30	ND	0.680