

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-BALS5225		Location ID: H2-CROS6512		Location ID: H2-CROS6520	Location ID: H2-CROS6526		Location ID: H2-CROS6530
				Location Type: Residence	Address: 5225 Balsa Lane	Location Type: Residence	Address: 6512 Crossandra Street	Location Type: Residence	Address: 6520 Crossandra Street	Location Type: Residence	Address: 6526 Crossandra Street
				Field Sample ID: H2-TW-0013576-24092-A	Field Sample ID: H2-TW-0013576-24092-3-A	Field Sample ID: H2-TW-0013466-24092-A	Field Sample ID: H2-TW-0013466-24092-A-H	Field Sample ID: H2-TW-0013469-24092-A	Field Sample ID: H2-TW-0013471-24092-A	Field Sample ID: H2-TW-0013471-24092-A-H	Field Sample ID: H2-TW-0013472-24092-A
				Sample Date: 2024-12-31	Sample Date: 2024-12-31	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-11-22	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-10-15
				Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	Absent	--	--	Absent	--	Absent
	E. coli	--	--	--	--	Absent	--	--	Absent	--	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	--	--	8.00	ND	--	4.00	6.00	22.0
Field Test (ppb)	Free Chlorine	4000	MCL	650	--	850	720	760	530	420	850
Field Test (pH)	pH	--	--	7.05	--	6.95	7.15	7.02	7.03	7.11	6.73
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	--	0.250	0.260	0.270	0.260	0.260	0.260
Field Test (degrees Celcius)	Temperature	--	--	24.7	--	24.0	28.9	23.6	27.1	29.7	29.0
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.920	--	0.00	0.00	0.370	0.330	0.0170	0.940
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55100	57400	56400	--	57000	57200	--	55900
	Total Organic Carbon	--	--	ND	ND	ND	--	ND	ND	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	--	ND	ND	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	--	ND	ND	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	--	ND	ND	--	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	--	ND	ND	--	ND
Metals (ppb)	Copper	1300	MCL	10.5	10.0	16.7	--	11.7	41.7	--	140
	Lead	15	MCL	0.870	0.850	0.210	--	0.180	0.170	--	0.290
	Mercury	2	MCL	ND	ND	ND	--	ND	ND	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	--	ND	ND	--	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Acenaphthylene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Anthracene	--	--	ND	ND	ND	--	ND	ND	--	ND

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-BALS5225		Location ID: H2-CROS6512		Location ID: H2-CROS6520	Location ID: H2-CROS6526		Location ID: H2-CROS6530
				Location Type: Residence	Address: 5225 Balsa Lane	Location Type: Residence	Address: 6512 Crossandra Street	Location Type: Residence	Address: 6520 Crossandra Street	Location Type: Residence	Address: 6526 Crossandra Street
				Field Sample ID: H2-TW-0013576-24092-A	Field Sample ID: H2-TW-0013576-24092-3-A	Field Sample ID: H2-TW-0013466-24092-A	Field Sample ID: H2-TW-0013466-24092-A-H	Field Sample ID: H2-TW-0013469-24092-A	Field Sample ID: H2-TW-0013471-24092-A	Field Sample ID: H2-TW-0013471-24092-A-H	Field Sample ID: H2-TW-0013472-24092-A
				Sample Date: 2024-12-31	Sample Date: 2024-12-31	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-11-22	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-10-15
				Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	ND	ND	--	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Chrysene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Fluorene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Naphthalene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Phenanthrene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Pyrene	--	--	ND	ND	ND	--	ND	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Benzene	5	MCL	ND	ND	ND	--	ND	ND	--	ND
	Cumene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Ethylbenzene	700	MCL	ND	ND	ND	--	ND	ND	--	ND
	m,p-Xylene	--	--	ND	ND	ND	--	ND	ND	--	ND
	n-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND
	n-Propylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND
	o-Xylene	--	--	ND	ND	ND	--	ND	ND	--	ND
sec-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND	

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-BALS5225		Location ID: H2-CROS6512		Location ID: H2-CROS6520	Location ID: H2-CROS6526		Location ID: H2-CROS6530
				Location Type: Residence	Address: 5225 Balsa Lane	Location Type: Residence	Address: 6512 Crossandra Street	Location Type: Residence	Address: 6520 Crossandra Street	Location Type: Residence	Address: 6526 Crossandra Street
				Field Sample ID: H2-TW-0013576-24092-A	Field Sample ID: H2-TW-0013576-24092-3-A	Field Sample ID: H2-TW-0013466-24092-A	Field Sample ID: H2-TW-0013466-24092-A-H	Field Sample ID: H2-TW-0013469-24092-A	Field Sample ID: H2-TW-0013471-24092-A	Field Sample ID: H2-TW-0013471-24092-A-H	Field Sample ID: H2-TW-0013472-24092-A
				Sample Date: 2024-12-31	Sample Date: 2024-12-31	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-11-22	Sample Date: 2024-10-15	Sample Date: 2024-10-15	Sample Date: 2024-10-15
				Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Volatile Organic Compounds (ppb)	tert-Butylbenzene	--	--	ND	ND	ND	--	ND	ND	--	ND
	Toluene	1000	MCL	ND	ND	ND	--	ND	ND	--	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	--	ND	ND	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	0.470	--	0.320	0.500	--	ND
	Bromoform	--	--	0.760	ND	1.30	--	1.10	1.50	--	0.350
	Chloroform	--	--	ND	ND	ND	--	ND	ND	--	ND
	Dibromochloromethane	--	--	0.530	ND	1.20	--	0.890	1.20	--	ND
	Total Trihalomethanes	80	MCL	1.29	ND	2.97	--	2.31	3.20	--	0.350

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-ISHI6416		H2-KOBA4477	H2-KOBA4489		H2-MAHO5432	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				H2-CROS6530 Residence 6530 Crossandra Street	6416 Ishibashi Lane		4477 Kobashigawa Street	4489 Kobashigawa Street		5432 Mahogany Lane	
				H2-TW-0013472-24092-A-H	H2-TW-0013586-24092-A	H2-TW-0013586-24092-A-H	H2-TW-0013489-24092-A	H2-TW-0013493-24092-A	H2-TW-0013493-24092-A-H	H2-TW-0013594-24092-A	H2-TW-0013594-24092-A-H
				2024-10-15	2024-10-15	2024-10-15	2024-12-27	2024-10-15	2024-10-15	2024-10-15	2024-10-15
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Bacterial Test (in 100 mL)	Coliform	--	--	--	Absent	--	--	Absent	--	Absent	--
	E. coli	--	--	--	Absent	--	--	Absent	--	Absent	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	11.0	3.00	8.00	--	4.00	4.00	7.00	1.00
Field Test (ppb)	Free Chlorine	4000	MCL	150	730	650	590	590	390	480	720
Field Test (pH)	pH	--	--	6.76	7.01	7.07	6.98	7.08	7.17	7.12	7.05
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.280	0.310	0.250	0.270	0.300	0.270	0.280
Field Test (degrees Celcius)	Temperature	--	--	33.3	31.4	40.3	25.8	26.1	47.2	24.8	39.7
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.430	0.620	0.580	0.400	0.670	0.570	0.530	0.460
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	--	56600	--	56800	55500	--	54500	--
	Total Organic Carbon	--	--	--	ND	--	ND	ND	--	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	--	ND	ND	--	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	--	ND	ND	--	ND	--
	Petroleum Hydrocarbons (as Oil)	--	--	--	ND	--	ND	ND	--	ND	--
	Petroleum Hydrocarbons, Total	--	--	--	ND	--	ND	ND	--	ND	--
Metals (ppb)	Copper	1300	MCL	--	11.8	--	16.0	96.8	--	10.0	--
	Lead	15	MCL	--	0.510	--	0.260	ND	--	0.680	--
	Mercury	2	MCL	--	ND	--	ND	ND	--	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	--	ND	--	ND	ND	--	ND	--
	2-Methylnaphthalene	--	--	--	ND	--	ND	ND	--	ND	--
	Acenaphthylene	--	--	--	ND	--	ND	ND	--	ND	--
	Anthracene	--	--	--	ND	--	ND	ND	--	ND	--



**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-ISHI6416		H2-KOBA4477	H2-KOBA4489		H2-MAHO5432		
				Location Type:	Residence		Residence	Residence		Residence		
				Address:	6416 Ishibashi Lane		4477 Kobashigawa Street	4489 Kobashigawa Street		5432 Mahogany Lane		
				Field Sample ID:	H2-TW-0013472-24092-A-H	H2-TW-0013586-24092-A	H2-TW-0013586-24092-A-H	H2-TW-0013489-24092-A	H2-TW-0013493-24092-A	H2-TW-0013493-24092-A-H	H2-TW-0013594-24092-A	H2-TW-0013594-24092-A-H
				Sample Date:	2024-10-15	2024-10-15	2024-10-15	2024-12-27	2024-10-15	2024-10-15	2024-10-15	2024-10-15
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	tert-Butylbenzene	--	--	--	ND	--	ND	ND	--	ND	--	
	Toluene	1000	MCL	--	ND	--	ND	ND	--	ND	--	
	Xylenes, Total	10000	MCL	--	ND	--	ND	ND	--	ND	--	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	0.340	--	ND	ND	--	ND	--	
	Bromoform	--	--	--	1.10	--	0.900	0.750	--	0.370	--	
	Chloroform	--	--	--	ND	--	ND	ND	--	ND	--	
	Dibromochloromethane	--	--	--	0.890	--	0.470	0.360	--	0.300	--	
	Total Trihalomethanes	80	MCL	--	2.33	--	1.37	1.11	--	0.670	--	

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-MAHO5457		Location ID: H2-MAHO5464		Location ID: H2-MAHO5475		Location ID: H2-MAHO5476	
				Field Sample ID	Sample Date						
				Residence 5457 Mahogany Lane		Residence 5464 Mahogany Lane		Residence 5475 Mahogany Lane		Residence 5476 Mahogany Lane	
				H2-TW-0013597-24092-A	H2-TW-0013597-24092-A-H	H2-TW-0013600-24092-A	H2-TW-0013600-24092-A-H	H2-TW-0013603-24092-A	H2-TW-0013603-24092-A-H	H2-TW-0011886-24092-A	H2-TW-0011886-24092-A-H
				2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15
				N (Normal)	N (Normal)						
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	Absent	--	Absent	--	Absent	--
	E. coli	--	--	Absent	--	Absent	--	Absent	--	Absent	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	36.0	20.0	6.00	62.0	3.00	ND	3.00	7.00
Field Test (ppb)	Free Chlorine	4000	MCL	710	320	600	370	780	640	810	450
Field Test (pH)	pH	--	--	7.36	7.12	6.99	7.18	6.97	6.99	7.01	6.98
Field Test (ms/cm)	Specific Conductivity	--	--	0.310	0.300	0.270	0.290	0.280	0.290	0.260	0.280
Field Test (degrees Celcius)	Temperature	--	--	24.4	45.3	25.6	41.4	25.0	43.8	25.6	41.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.170	0.320	0.540	0.0400	0.150	0.0200	0.00310
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55400	--	54500	--	54000	--	54000	--
	Total Organic Carbon	--	--	ND	--	ND	--	ND	--	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	--	ND	--	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	--	ND	--	ND	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	--	ND	--	ND	--	ND	--
	Petroleum Hydrocarbons, Total	--	--	ND	--	ND	--	ND	--	ND	--
Metals (ppb)	Copper	1300	MCL	14.2	--	10.4	--	7.50	--	10.7	--
	Lead	15	MCL	1.20	--	0.620	--	0.690	--	1.20	--
	Mercury	2	MCL	ND	--	ND	--	ND	--	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	--	ND	--	ND	--	ND	--
	2-Methylnaphthalene	--	--	ND	--	ND	--	ND	--	ND	--
	Acenaphthylene	--	--	ND	--	ND	--	ND	--	ND	--
	Anthracene	--	--	ND	--	ND	--	ND	--	ND	--
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	--	ND	--	ND	--

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-MAHO5457		Location ID: H2-MAHO5464		Location ID: H2-MAHO5475		Location ID: H2-MAHO5476	
				Location Type: Residence	Address: 5457 Mahogany Lane	Location Type: Residence	Address: 5464 Mahogany Lane	Location Type: Residence	Address: 5475 Mahogany Lane	Location Type: Residence	Address: 5476 Mahogany Lane
				Field Sample ID: H2-TW-0013597-24092-A	Field Sample ID: H2-TW-0013597-24092-A-H	Field Sample ID: H2-TW-0013600-24092-A	Field Sample ID: H2-TW-0013600-24092-A-H	Field Sample ID: H2-TW-0013603-24092-A	Field Sample ID: H2-TW-0013603-24092-A-H	Field Sample ID: H2-TW-0011886-24092-A	Field Sample ID: H2-TW-0011886-24092-A-H
				Sample Date: 2024-10-15	Sample Date: 2024-10-15						
				Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	--	ND	--	ND	--	ND	--
	Benzo(g,h,i)perylene	--	--	ND	--	ND	--	ND	--	ND	--
	Benzo(k)fluoranthene	--	--	ND	--	ND	--	ND	--	ND	--
	Chrysene	--	--	ND	--	ND	--	ND	--	ND	--
	Dibenz(a,h)anthracene	--	--	ND	--	ND	--	ND	--	ND	--
	Fluorene	--	--	ND	--	ND	--	ND	--	ND	--
	Indeno(1,2,3-c,d)pyrene	--	--	ND	--	ND	--	ND	--	ND	--
	Naphthalene	--	--	ND	--	ND	--	ND	--	ND	--
	Phenanthrene	--	--	ND	--	ND	--	ND	--	ND	--
	Pyrene	--	--	ND	--	ND	--	ND	--	ND	--
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	Benzene	5	MCL	ND	--	ND	--	ND	--	ND	--
	Cumene	--	--	ND	--	ND	--	ND	--	ND	--
	Ethylbenzene	700	MCL	ND	--	ND	--	ND	--	ND	--
	m,p-Xylene	--	--	ND	--	ND	--	ND	--	ND	--
	n-Butylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	n-Propylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	o-Xylene	--	--	ND	--	ND	--	ND	--	ND	--
	sec-Butylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	tert-Butylbenzene	--	--	ND	--	ND	--	ND	--	ND	--
	Toluene	1000	MCL	ND	--	ND	--	ND	--	ND	--

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	H2-MAHO5457		H2-MAHO5464		H2-MAHO5475		H2-MAHO5476																
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:
				H2-TW-0013597-24092-A	H2-TW-0013597-24092-A-H	H2-TW-0013600-24092-A	H2-TW-0013600-24092-A-H	H2-TW-0013603-24092-A	H2-TW-0013603-24092-A-H	H2-TW-0011886-24092-A	H2-TW-0011886-24092-A-H															
				2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15	2024-10-15															
				N (Normal)	N (Normal)																					
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	--	ND	--	ND	--	ND	--															
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	--	ND	--	ND	--	ND	--															
	Bromoform	--	--	0.700	--	ND	--	ND	--	ND	--															
	Chloroform	--	--	ND	--	ND	--	ND	--	ND	--															
	Dibromochloromethane	--	--	0.310	--	ND	--	ND	--	ND	--															
	Total Trihalomethanes		80	MCL	1.01	--	ND	--	ND	--	ND	--														

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-NAUP6227						H2-NAUP6230	
				H2-NAUP6224	Residence						Residence	
				6224 Naupaka Street	6227 Naupaka Street						6230 Naupaka Street	
				Field Sample ID:	H2-TW-0013504-24092-A	H2-TW-0013506-24092-A	H2-TW-0013506-24092-A-1	H2-TW-0013506-24092-A-2	H2-TW-0013506-24092-A-3	H2-TW-0013506-24092-A-4	H2-TW-0013506-24092-A-R1	H2-TW-0013507-24092-A
				Sample Date:	2024-11-27	2024-11-13	2024-12-16	2024-12-16	2024-12-16	2024-12-16	2024-12-16	2024-11-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	440	740	740	600	560	530	690	770	
Field Test (pH)	pH	--	--	6.93	7.02	7.05	7.02	7.08	7.11	6.92	7.03	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.290	0.250	0.250	0.250	0.250	0.250	0.260	
Field Test (degrees Celcius)	Temperature	--	--	26.5	24.7	26.1	25.0	25.2	24.6	24.9	23.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.16	7.71	0.350	0.00	0.00	0.00590	0.620	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56100	58900	55500	57400	58400	60400	59700	56500	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	8.50	19.7	22.5	19.5	21.1	17.3	22.6	14.2	
	Lead	15	MCL	0.270	0.220	0.150	0.140	0.170	ND	0.190	0.240	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-NAUP6227				H2-NAUP6230		
				H2-NAUP6224	H2-TW-0013506-24092-A	H2-TW-0013506-24092-A-1	H2-TW-0013506-24092-A-2	H2-TW-0013506-24092-A-3	H2-TW-0013506-24092-A-4	H2-TW-0013506-24092-A-R1	
				Location Type:	Residence				Residence		
				Address:	6224 Naupaka Street				6227 Naupaka Street		
				Field Sample ID:	H2-TW-0013504-24092-A	H2-TW-0013506-24092-A	H2-TW-0013506-24092-A-1	H2-TW-0013506-24092-A-2	H2-TW-0013506-24092-A-3	H2-TW-0013506-24092-A-4	H2-TW-0013506-24092-A-R1
				Sample Date:	2024-11-27	2024-11-13	2024-12-16	2024-12-16	2024-12-16	2024-12-16	2024-11-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.510	ND	ND	ND	0.410	ND	ND
	Bromoform	--	--	0.520	1.20	0.390	0.440	0.450	1.20	0.460	0.440

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-NAUP6227						H2-NAUP6230	
				H2-NAUP6224	Residence						Residence	
				Location Type:	6227 Naupaka Street						6230 Naupaka Street	
				Address:	6224 Naupaka Street						6230 Naupaka Street	
				Field Sample ID:	H2-TW-0013504-24092-A	H2-TW-0013506-24092-A	H2-TW-0013506-24092-A-1	H2-TW-0013506-24092-A-2	H2-TW-0013506-24092-A-3	H2-TW-0013506-24092-A-4	H2-TW-0013506-24092-A-R1	H2-TW-0013507-24092-A
				Sample Date:	2024-11-27	2024-11-13	2024-12-16	2024-12-16	2024-12-16	2024-12-16	2024-12-16	2024-11-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.340	1.10	0.290	0.330	0.370	0.980	0.360	0.370	0.370
	Total Trihalomethanes	80	MCL	0.860	2.81	0.680	0.770	0.820	2.59	0.820	0.810	0.810

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		Location ID:	H2-NAUP6254	H2-NAUP6259	H2-NIUS6608	H2-NIUS6612	H2-NIUS6670	H2-NUHO6762	H2-PAMA6311	H2-SAND5110	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	6254 Naupaka Street	6259 Naupaka Street	6608 Niu Street	6612 Niu Street	6670 Niu Street	6762 Nuholani Street	6311 Pamakani Lane	5110 Sandalwood Lane	
		Field Sample ID:	H2-TW-0011873-24092-A	H2-TW-0011879-24092-A	H2-TW-0013528-24092-A	H2-TW-0011866-24092-A	H2-TW-0013540-24092-A	H2-TW-0011871-24092-A	H2-TW-0013624-24092-A	H2-TW-0013650-24331-A	
		Sample Date:	2024-11-13	2024-11-13	2024-11-22	2024-12-27	2024-11-22	2024-11-22	2024-11-22	2024-12-06	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	650	700	780	520	280	1160	870	390
Field Test (pH)	pH	--	--	7.16	7.22	7.09	6.98	6.94	7.13	7.04	6.99
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.270	0.260	0.250	0.260	0.290	0.280	0.240
Field Test (degrees Celcius)	Temperature	--	--	23.8	23.2	26.7	22.4	27.3	24.9	25.6	23.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.94	0.00	0.00	0.0310	1.69	0.840	0.560	0.180
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	57300	57800	53400	57000	53500	56500	54500	57100
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	9.30	24.5	8.90	15.7	7.20	14.1	12.1	18.7
	Lead	15	MCL	0.330	0.360	0.240	0.280	0.200	0.320	0.870	0.980
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		Location ID:	H2-NAUP6254	H2-NAUP6259	H2-NIUS6608	H2-NIUS6612	H2-NIUS6670	H2-NUHO6762	H2-PAMA6311	H2-SAND5110
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	6254 Naupaka Street	6259 Naupaka Street	6608 Niu Street	6612 Niu Street	6670 Niu Street	6762 Nuholani Street	6311 Pamakani Lane	5110 Sandalwood Lane
		Field Sample ID:	H2-TW-0011873-24092-A	H2-TW-0011879-24092-A	H2-TW-0013528-24092-A	H2-TW-0011866-24092-A	H2-TW-0013540-24092-A	H2-TW-0011871-24092-A	H2-TW-0013624-24092-A	H2-TW-0013650-24331-A
		Sample Date:	2024-11-13	2024-11-13	2024-11-22	2024-12-27	2024-11-22	2024-11-22	2024-11-22	2024-12-06
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND						
	Chrysene	--	--	ND						
	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		Location ID:	H2-NAUP6254	H2-NAUP6259	H2-NIUS6608	H2-NIUS6612	H2-NIUS6670	H2-NUHO6762	H2-PAMA6311	H2-SAND5110
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	6254 Naupaka Street	6259 Naupaka Street	6608 Niu Street	6612 Niu Street	6670 Niu Street	6762 Nuholani Street	6311 Pamakani Lane	5110 Sandalwood Lane
		Field Sample ID:	H2-TW-0011873-24092-A	H2-TW-0011879-24092-A	H2-TW-0013528-24092-A	H2-TW-0011866-24092-A	H2-TW-0013540-24092-A	H2-TW-0011871-24092-A	H2-TW-0013624-24092-A	H2-TW-0013650-24331-A
		Sample Date:	2024-11-13	2024-11-13	2024-11-22	2024-12-27	2024-11-22	2024-11-22	2024-11-22	2024-12-06
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.410	0.340	ND	0.430	ND	ND	ND
	Bromoform	--	--	0.920	0.740	0.670	2.20	0.880	0.700	1.10
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	0.900	0.680	0.530	1.40	0.620	0.520	0.660
	Total Trihalomethanes	80	MCL	2.23	1.76	1.20	4.03	1.50	1.22	1.76

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		<b>Location ID:</b>	H2-SAND5151	H2-TAMA5312	H2-TAMA5314	
		<b>Location Type:</b>	Residence	Residence	Residence	
		<b>Address:</b>	5151 Sandalwood Lane	5312 Tamarind Lane	5314 Tamarind Lane	
		<b>Field Sample ID:</b>	H2-TW-0013658-24092-A	H2-TW-0011888-24092-A	H2-TW-0013661-24092-A	
		<b>Sample Date:</b>	2024-11-22	2024-11-22	2024-11-26	
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>			
Field Test (ppb)	Free Chlorine	4000	MCL	720	850	600
Field Test (pH)	pH	--	--	7.00	7.11	6.90
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.280	0.260
Field Test (degrees Celcius)	Temperature	--	--	27.1	26.6	26.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.870	0.00	0.420
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58100	54200	60900
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	10.9	11.6	8.80
	Lead	15	MCL	0.890	0.500	0.370
	Mercury	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		<b>Location ID:</b>	H2-SAND5151	H2-TAMA5312	H2-TAMA5314	
		<b>Location Type:</b>	Residence	Residence	Residence	
		<b>Address:</b>	5151 Sandalwood Lane	5312 Tamarind Lane	5314 Tamarind Lane	
		<b>Field Sample ID:</b>	H2-TW-0013658-24092-A	H2-TW-0011888-24092-A	H2-TW-0013661-24092-A	
		<b>Sample Date:</b>	2024-11-22	2024-11-22	2024-11-26	
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>			
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Residences in Zone H2**

		<b>Location ID:</b>	H2-SAND5151	H2-TAMA5312	H2-TAMA5314	
		<b>Location Type:</b>	Residence	Residence	Residence	
		<b>Address:</b>	5151 Sandalwood Lane	5312 Tamarind Lane	5314 Tamarind Lane	
		<b>Field Sample ID:</b>	H2-TW-0013658-24092-A	H2-TW-0011888-24092-A	H2-TW-0013661-24092-A	
		<b>Sample Date:</b>	2024-11-22	2024-11-22	2024-11-26	
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>			
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.470	0.710	0.490
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.280	0.460	0.380
	Total Trihalomethanes	80	MCL	0.750	1.17	0.870

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

		Location ID: H2-HYD0377A			H2-HYD1331A						
		Location Type: Hydrant			Hydrant						
		Address: Hydrant 377			Hydrant 1331						
		Field Sample ID: H2-DL-0017757-24275	H2-DL-0017757-24306	H2-DL-0017757-24306	H2-DL-0017757-24336	H2-DL-0017757-24336	H2-DL-0017758-24275	H2-DL-0017758-24306	H2-DL-0017758-24336		
		-A	-A	-3-A	-A	-3-A	-A	-A	-A		
		Sample Date: 2024-10-15	2024-11-13	2024-11-13	2024-12-27	2024-12-27	2024-10-15	2024-11-13	2024-12-27		
		Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	--	--	Absent	--	--	
	E. coli	--	--	Absent	--	--	--	Absent	--	--	
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	10.0	--	--	--	6.00	--	--	
Field Test (ppb)	Free Chlorine	4000	MCL	580	600	--	500	720	340	490	
Field Test (pH)	pH	--	--	7.20	7.25	--	7.22	7.09	7.08	7.00	
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.280	--	0.260	0.270	0.310	0.250	
Field Test (degrees Celcius)	Temperature	--	--	29.5	25.5	--	26.0	29.0	24.7	25.8	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.46	0.00	--	0.840	3.41	0.00	1.42	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	59200	61100	61000	59700	60300	54800	57100	58500
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	0.0110	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

		Location ID: H2-HYD0377A			H2-HYD1331A					
		Location Type: Hydrant			Hydrant					
		Address: Hydrant 377			Hydrant 1331					
		Field Sample ID: H2-DL-0017757-24275	H2-DL-0017757-24306	H2-DL-0017757-24306	H2-DL-0017757-24336	H2-DL-0017757-24336	H2-DL-0017758-24275	H2-DL-0017758-24306	H2-DL-0017758-24336	
		-A	-A	-3-A	-A	-3-A	-A	-A	-A	
		Sample Date: 2024-10-15	2024-11-13	2024-11-13	2024-12-27	2024-12-27	2024-10-15	2024-11-13	2024-12-27	
		Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	--	ND	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	--	ND	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.720	0.680	0.670	0.610	0.620	ND	ND
	Bromoform	--	--	1.90	1.50	1.40	2.00	2.00	ND	0.580

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	H2-HYD0377A Hydrant Hydrant 377					H2-HYD1331A Hydrant Hydrant 1331																				
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type																	
				H2-DL-0017757-24275 -A	2024-10-15	N (Normal)	H2-DL-0017757-24306 -A	2024-11-13	N (Normal)	H2-DL-0017757-24306 -3-A	2024-11-13	FD (Field Duplicate)	H2-DL-0017757-24336 -A	2024-12-27	N (Normal)	H2-DL-0017757-24336 -3-A	2024-12-27	FD (Field Duplicate)	H2-DL-0017758-24275 -A	2024-10-15	N (Normal)	H2-DL-0017758-24306 -A	2024-11-13	N (Normal)	H2-DL-0017758-24336 -A	2024-12-27	N (Normal)		
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	1.80	1.50	1.40	1.60	1.60	1.60	ND	ND	0.440																	
	Total Trihalomethanes	80	MCL	4.42	3.68	3.47	4.21	4.22	ND	ND	1.02																		

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

		Location ID:		H2-HYD1646A			
		Location Type:		Hydrant			
		Address:		Hydrant 1646			
		Field Sample ID:	H2-DL-0000688-24275	H2-DL-0000688-24306	H2-DL-0000688-24306	H2-DL-0000688-24336	
			-A	-A	-3-A	-A	
		Sample Date:	2024-10-15	2024-11-13	2024-11-13	2024-12-27	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Bacterial Test (in 100 mL)	Coliform	--	--	Absent	--	--	--
	E. coli	--	--	Absent	--	--	--
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	5.00	--	--	--
Field Test (ppb)	Free Chlorine	4000	MCL	760	600	--	590
Field Test (pH)	pH	--	--	7.30	7.00	--	7.05
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.270	--	0.260
Field Test (degrees Celcius)	Temperature	--	--	29.2	26.6	--	27.1
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.10	0.0420	--	0.530
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55100	60700	60700	57600
	Total Organic Carbon	--	--	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone H2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

		Location ID: H2-HYD1646A					
		Location Type: Hydrant					
		Address: Hydrant 1646					
		Field Sample ID: H2-DL-0000688-24275	H2-DL-0000688-24306	H2-DL-0000688-24306	H2-DL-0000688-24336		
		-A	-A	-3-A	-A		
		Sample Date: 2024-10-15	2024-11-13	2024-11-13	2024-12-27		
		Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	--
	Benzene	5	MCL	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND
	Bromoform	--	--	0.590	0.530	0.510	0.710

**Summary of Chemistry Results**  
**Zone H2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in October 2024 - December 2024 from Hydrants in Zone H2**

		Location ID: H2-HYD1646A					
		Location Type: Hydrant					
		Address: Hydrant 1646					
		Field Sample ID: H2-DL-0000688-24275	H2-DL-0000688-24306	H2-DL-0000688-24306	H2-DL-0000688-24336		
		-A	-A	-3-A	-A		
		Sample Date: 2024-10-15	2024-11-13	2024-11-13	2024-12-27		
		Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.350	0.310	0.320	0.370
	Total Trihalomethanes	80	MCL	0.940	0.840	0.830	1.08