

**Summary of Chemistry Results  
Zone C1  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone C1**

				Location ID: C1-BLDG1655 Location Type: Child Development Center Address: Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd							
				Field Sample ID:	C1-TW-0014751-25001-N-1	C1-TW-0014751-25001-N-2	C1-TW-0014751-25001-3-N-1	C1-TW-0014751-25032-N-1	C1-TW-0014751-25032-N-2	C1-TW-0014751-25060-N-1	C1-TW-0014751-25060-N-2
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-03-04	2025-03-04
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	490	720	--	590	550	600	470	
Field Test (pH)	pH	--	--	7.20	7.08	--	7.07	7.08	7.42	7.31	
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.260	--	0.270	0.260	0.240	0.230	
Field Test (degrees Celcius)	Temperature	--	--	24.4	26.2	--	25.5	23.7	23.7	20.9	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.02	0.990	--	0.0570	1.65	0.0270	0.00660	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	57600	57800	60800	51000	53000	53100	52000	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	17.0	16.5	16.9	16.2	15.6	17.5	15.9	
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone C1**

				Location ID: C1-BLDG1655 Location Type: Child Development Center Address: Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd							
				Field Sample ID:	C1-TW-0014751-25001-N-1	C1-TW-0014751-25001-N-2	C1-TW-0014751-25001-3-N-1	C1-TW-0014751-25032-N-1	C1-TW-0014751-25032-N-2	C1-TW-0014751-25060-N-1	C1-TW-0014751-25060-N-2
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-03-04	2025-03-04
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone C1**

				Location ID: C1-BLDG1655 Location Type: Child Development Center Address: Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd							
				Field Sample ID:	C1-TW-0014751-25001-N-1	C1-TW-0014751-25001-N-2	C1-TW-0014751-25001-3-N-1	C1-TW-0014751-25032-N-1	C1-TW-0014751-25032-N-2	C1-TW-0014751-25060-N-1	C1-TW-0014751-25060-N-2
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-03-04	2025-03-04
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone C1**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

		Location ID: C1-HYD1183			C1-HYD1765			C1-HYD1769			
		Location Type: Hydrant			Hydrant			Hydrant			
		Address: FH ID: 512			FH ID: FH 503			FHID: 563			
		Field Sample ID: C1-DL-0000531-25001	C1-DL-0000531-25032	C1-DL-0000531-25060	C1-DL-0000526-25001	C1-DL-0000526-25032	C1-DL-0000526-25060	C1-DL-0017789-25001	C1-DL-0017789-25032		
		-N	-N	-N	-N	-N	-N	-N	-N		
		Sample Date: 2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05		
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	220	40.0	30.0	480	260	430	300	260
Field Test (pH)	pH	--	--	8.76	9.03	9.10	7.25	7.30	7.21	7.11	7.35
Field Test (ms/cm)	Specific Conductivity	--	--	0.310	0.300	0.270	0.249	0.280	0.250	0.250	0.250
Field Test (degrees Celcius)	Temperature	--	--	27.0	27.3	27.4	24.3	24.8	24.8	27.2	25.0
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.230	0.140	0.380	0.690	0.0110	1.40	0.660
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	71900	60100	72700	52100	52300	53900	55100	56300
	Total Organic Carbon	--	--	310	440	300	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone C1**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

		Location ID: C1-HYD1183			C1-HYD1765			C1-HYD1769		
		Location Type: Hydrant			Hydrant			Hydrant		
		Address: FH ID: 512			FH ID: FH 503			FHID: 563		
		Field Sample ID: C1-DL-0000531-25001	C1-DL-0000531-25032	C1-DL-0000531-25060	C1-DL-0000526-25001	C1-DL-0000526-25032	C1-DL-0000526-25060	C1-DL-0017789-25001	C1-DL-0017789-25032	C1-DL-0017789-25060
		-N	-N	-N	-N	-N	-N	-N	-N	-N
		Sample Date: 2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05	2025-03-04
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	ND	--	--	ND
	1,3,5-Trimethylbenzene	--	--	ND						
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	ND	--	--	ND
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	3.70	3.70	2.70	ND	ND	0.350	0.420
	Bromoform	--	--	27.1	30.6	17.4	0.320	0.710	ND	1.40
	Chloroform	--	--	1.70	1.80	1.60	ND	ND	ND	ND
	Dibromochloromethane	--	--	9.40	9.30	5.50	0.280	0.460	0.250	0.990
	Total Trihalomethanes	80	MCL	41.9	45.4	27.2	0.600	1.17	0.250	2.74

**Summary of Chemistry Results**  
**Zone C1**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-HYD354				C1-HYD444				
				C1-HYD1769	C1-DL-0017789-25060	C1-DL-0017791-25001	C1-DL-0017791-25032	C1-DL-0017791-25060	C1-DL-0017788-25001	C1-DL-0017788-25032	C1-DL-0017788-25060	C1-DL-0017788-25060	
				Hydrant FHID: 563	-N	-3-N							
				Address:									
				Field Sample ID:									
				Sample Date:	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-03-04	2025-03-04
				Sample Type:	N (Normal)	FD (Field Duplicate)							
Field Test (ppb)	Free Chlorine	4000	MCL		410	680	690	450	460	530	540		--
Field Test (pH)	pH	--	--		7.31	7.08	7.17	7.31	7.35	7.22	7.26		--
Field Test (ms/cm)	Specific Conductivity	--	--		0.260	0.300	0.270	0.260	0.260	0.230	0.260		--
Field Test (degrees Celcius)	Temperature	--	--		26.7	26.4	26.4	26.1	25.3	26.5	24.2		--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.510	0.660	0.640	0.330	0.910	0.420	0.210		--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		56200	51300	51000	55200	52400	51200	52300		52600
	Total Organic Carbon	--	--		ND	ND	ND	ND	ND	210	ND		ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND		ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND		ND						
	Petroleum Hydrocarbons (as Oil)	--	--		ND		ND						
	Petroleum Hydrocarbons, Total	--	--		ND		ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND		ND						
	2-Methylnaphthalene	--	--		ND		ND						
	Acenaphthylene	--	--		ND		ND						
	Anthracene	--	--		ND		ND						
	Benzo(a)pyrene	0.2	MCL		ND		ND						
	Benzo(b)fluoranthene	--	--		ND		ND						
	Benzo(g,h,i)perylene	--	--		ND		ND						
	Benzo(k)fluoranthene	--	--		ND		ND						
	Chrysene	--	--		ND		ND						
	Dibenz(a,h)anthracene	--	--		ND		ND						
	Fluorene	--	--		ND		ND						
	Indeno(1,2,3-c,d)pyrene	--	--		ND		ND						

**Summary of Chemistry Results  
Zone C1  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

		Location ID:	C1-HYD1769	C1-HYD354				C1-HYD444			
		Location Type:	Hydrant	Hydrant				Hydrant			
		Address:	FHID: 563	FHID: 479				FHID: 413			
		Field Sample ID:	C1-DL-0017789-25060 -N	C1-DL-0017791-25001 -N	C1-DL-0017791-25032 -N	C1-DL-0017791-25060 -N	C1-DL-0017788-25001 -N	C1-DL-0017788-25032 -N	C1-DL-0017788-25060 -N	C1-DL-0017788-25060 -3-N	
		Sample Date:	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-01-27	2025-02-05	2025-03-04	2025-03-04	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND							
	Phenanthrene	--	--	ND							
	Pyrene	--	--	ND							
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND							
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	ND	--	--	
	1,3,5-Trimethylbenzene	--	--	ND							
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	ND	--	--	
	Benzene	5	MCL	ND							
	Cumene	--	--	ND							
	Ethylbenzene	700	MCL	ND							
	m,p-Xylene	--	--	ND							
	n-Butylbenzene	--	--	ND							
	n-Propylbenzene	--	--	ND							
	o-Xylene	--	--	ND							
	sec-Butylbenzene	--	--	ND							
	tert-Butylbenzene	--	--	ND							
	Toluene	1000	MCL	ND							
	Xylenes, Total	10000	MCL	ND							
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.440	ND	ND	ND	ND	ND	ND	
	Bromoform	--	--	1.20	ND	ND	ND	ND	0.620	ND	
	Chloroform	--	--	ND							
	Dibromochloromethane	--	--	1.00	ND	ND	ND	ND	0.490	ND	
	Total Trihalomethanes	80	MCL	2.64	ND	ND	ND	ND	1.11	ND	

**Summary of Chemistry Results  
Zone C1  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

		Location ID: C1-HYD817				
		Location Type: Hydrant				
		Address: FHID: 530A				
		Field Sample ID: C1-DL-0017790-25001-N	C1-DL-0017790-25032-N	C1-DL-0017790-25060-N		
		Sample Date: 2025-01-27	2025-02-05	2025-03-04		
		Sample Type: N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	550	460	460
Field Test (pH)	pH	--	--	7.23	7.32	7.29
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.240	0.260
Field Test (degrees Celcius)	Temperature	--	--	24.8	24.8	25.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.280	1.92	0.150
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51300	50300	54900
	Total Organic Carbon	--	--	ND	230	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND

**Summary of Chemistry Results  
Zone C1  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone C1**

		Location ID: C1-HYD817				
		Location Type: Hydrant				
		Address: FHID: 530A				
		Field Sample ID: C1-DL-0017790-25001	C1-DL-0017790-25032	C1-DL-0017790-25060		
		-N	-N	-N		
		Sample Date: 2025-01-27	2025-02-05	2025-03-04		
		Sample Type: N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.550	0.480	0.420
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.460	0.450	0.390
	Total Trihalomethanes	80	MCL	1.01	0.930	0.810

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-BLDG0584 Medical Building Building 584,CAREER INFORMATION CENTER, 2367 North Rd				C1-BLDG1407 Medical Building Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd			C1-BLDG1514 Medical Building Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd			
				Field Sample ID:	Sample Date:	Sample Type:	DOH Project Screening Level	Basis of Project Screening Level	Field Sample ID:	Sample Date:	Sample Type:	DOH Project Screening Level	Basis of Project Screening Level	Field Sample ID:
Field Test (ppb)	Free Chlorine	4000	MCL	30.0	--	30.0	40.0	530	600	470	550			
Field Test (pH)	pH	--	--	7.79	--	7.87	8.21	7.29	7.19	7.37	7.57			
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	--	0.250	0.240	0.260	0.250	0.240	0.270			
Field Test (degrees Celcius)	Temperature	--	--	23.4	--	24.6	23.1	22.5	22.0	22.0	25.2			
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	1.32	0.200	0.00	0.600	0.00	0.00			
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	64500	64700	57000	61000	57900	55300	53200	62300			
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
Metals (ppb)	Copper	1300	MCL	9.30	10.3	15.0	8.90	50.1	54.9	53.3	17.6			
	Lead	15	MCL	ND	ND	ND	ND	0.150	0.160	ND	0.310			
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND			
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND			
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND			

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C1-BLDG0584 Location Type: Medical Building Address: Building 584,CAREER INFORMATION CENTER, 2367 North Rd				Location ID: C1-BLDG1407 Location Type: Medical Building Address: Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd			Location ID: C1-BLDG1514 Location Type: Medical Building Address: Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd																	
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type																
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	C1-TW-0014693-25001-N	2025-01-07	N (Normal)	C1-TW-0014693-25001-3-N	2025-01-07	FD (Field Duplicate)	C1-TW-0014693-25032-N	2025-02-04	N (Normal)	C1-TW-0014693-25060-N	2025-03-04	N (Normal)	C1-TW-0014730-25001-N	2025-01-07	N (Normal)	C1-TW-0014730-25032-N	2025-02-04	N (Normal)	C1-TW-0014730-25060-N	2025-03-04	N (Normal)	C1-TW-0014738-25001-N	2025-01-07	N (Normal)	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-BLDG0584 Medical Building Building 584,CAREER INFORMATION CENTER, 2367 North Rd				C1-BLDG1407 Medical Building Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd			C1-BLDG1514 Medical Building Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	
				Field Sample ID:	Sample Date:	Sample Type:	DOH Project Screening Level	Basis of Project Screening Level	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:
Volatile Organic Compounds (ppb)	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.520	0.500	0.320	0.360	ND	ND	ND	ND
Bromoform		--	--	4.70	4.50	3.40	2.60	0.400	ND	0.820	0.720	0.720
Chloroform		--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dibromochloromethane		--	--	1.40	1.40	1.00	1.10	ND	ND	ND	ND	ND
Total Trihalomethanes		80	MCL	6.62	6.40	4.72	4.06	0.400	ND	0.820	0.720	0.720

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-BLDG1514 Medical Building Address: Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd		C1-BLDG1535 Medical Building Address: Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road									
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type						
Field Test (ppb)	Free Chlorine	4000	MCL	C1-TW-0014738-25032-N	2025-02-04	N (Normal)	C1-TW-0014739-25001-N	2025-01-07	N (Normal)	C1-TW-0014739-25032-N	2025-02-05	N (Normal)	C1-TW-0014739-25060-N	2025-03-04	N (Normal)
Field Test (pH)	pH	--	--	610	500	750	590	580	7.40	7.52	7.17	7.38	7.36		
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.240	0.250	0.240							
Field Test (degrees Celcius)	Temperature	--	--	25.1	24.9	24.1	24.8	23.6							
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.720	0.00	0.430	0.600	0.00							
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52800	55500	58400	51200	52400							
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND							
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND							
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND							
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND							
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND							
Metals (ppb)	Copper	1300	MCL	14.8	22.8	42.7	61.3	65.1							
	Lead	15	MCL	0.250	0.520	ND	ND	ND							
	Mercury	2	MCL	ND	ND	ND	ND	ND							
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND							
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND							
	Acenaphthylene	--	--	ND	ND	ND	ND	ND							
	Anthracene	--	--	ND	ND	ND	ND	ND							
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND							

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C1-BLDG1514		Location ID: C1-BLDG1535			
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type
				Medical Building Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd		Medical Building Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road			
				C1-TW-0014738-25032-N	2025-02-04	N (Normal)	C1-TW-0014739-25001-N	2025-01-07	N (Normal)
				C1-TW-0014738-25060-N	2025-03-04	N (Normal)	C1-TW-0014739-25032-N	2025-02-05	N (Normal)
							C1-TW-0014739-25060-N	2025-03-04	N (Normal)
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	
	Naphthalene	--	--	ND	ND	ND	ND	ND	
	Phenanthrene	--	--	ND	ND	ND	ND	ND	
	Pyrene	--	--	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone C1**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone C1**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-BLDG1514 Medical Building Address: Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd		C1-BLDG1535 Medical Building Address: Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road		
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND
	Bromoform	--	--	0.430	1.50	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.490	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.430	1.99	ND	ND	ND