

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-11TH0201	D2-11TH0210	D2-12TH0212A	D2-13TH0211B	D2-15TH0205	D2-16TH0203E	D2-16TH0212C	D2-18TH0108	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	201 11th Street	210 11th Street	212A 12th Street	211B 13th Street	205 15th Street	203E 16th Street	212C 16th Street	108 18th Street	
		Field Sample ID:	D2-TW-0008359-24092-N	D2-TW-0008367-24092-N	D2-TW-0008385-24092-N	D2-TW-0008402-24331-N	D2-TW-0007104-24092-N	D2-TW-0007828-24092-N	D2-TW-0008169-24092-N	D2-TW-0008192-24092-N	
		Sample Date:	2025-03-18	2025-03-20	2025-03-12	2025-01-30	2025-03-25	2025-03-28	2025-03-23	2025-02-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	590	440	570	1880	800	280	600	680
Field Test (pH)	pH	--	--	7.28	7.32	7.20	7.27	7.28	6.95	7.34	7.15
Field Test (ms/cm)	Specific Conductivity	--	--	0.290	0.250	0.260	0.260	0.250	0.260	0.250	0.280
Field Test (degrees Celcius)	Temperature	--	--	25.4	24.0	22.3	24.4	24.7	27.4	24.0	24.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.700	0.480	0.250	0.00	3.62	1.29	0.00	0.180
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54100	54800	54800	52800	53600	54700	53100	53100
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	19.7	20.1	22.4	11.6	6.40	9.30	10.0	33.0
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	0.140	ND
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
	Benzo(k)fluoranthene	--	--	ND	ND						
	Chrysene	--	--	ND	ND						

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		<b>Location ID:</b>	D2-11TH0201	D2-11TH0210	D2-12TH0212A	D2-13TH0211B	D2-15TH0205	D2-16TH0203E	D2-16TH0212C	D2-18TH0108
		<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		<b>Address:</b>	201 11th Street	210 11th Street	212A 12th Street	211B 13th Street	205 15th Street	203E 16th Street	212C 16th Street	108 18th Street
		<b>Field Sample ID:</b>	D2-TW-0008359-24092-N	D2-TW-0008367-24092-N	D2-TW-0008385-24092-N	D2-TW-0008402-24331-N	D2-TW-0007104-24092-N	D2-TW-0007828-24092-N	D2-TW-0008169-24092-N	D2-TW-0008192-24092-N
		<b>Sample Date:</b>	2025-03-18	2025-03-20	2025-03-12	2025-01-30	2025-03-25	2025-03-28	2025-03-23	2025-02-27
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND	ND	ND	ND	ND	0.320	ND
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.280	0.280

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-11TH0201	D2-11TH0210	D2-12TH0212A	D2-13TH0211B	D2-15TH0205	D2-16TH0203E	D2-16TH0212C	D2-18TH0108	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	201 11th Street	210 11th Street	212A 12th Street	211B 13th Street	205 15th Street	203E 16th Street	212C 16th Street	108 18th Street	
		Field Sample ID:	D2-TW-0008359-24092-N	D2-TW-0008367-24092-N	D2-TW-0008385-24092-N	D2-TW-0008402-24331-N	D2-TW-0007104-24092-N	D2-TW-0007828-24092-N	D2-TW-0008169-24092-N	D2-TW-0008192-24092-N	
		Sample Date:	2025-03-18	2025-03-20	2025-03-12	2025-01-30	2025-03-25	2025-03-28	2025-03-23	2025-02-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.600	0.280	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-18TH0108	D2-19TH0176	D2-19TH0201	D2-19TH0216	D2-19TH1707	D2-1ST0106	D2-1ST0202		
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence		
		Address:	108 18th Street	176 19th Street	201 19th Street	216 19th Street	1707 19th Way	106 1st Street	202 1st Street		
		Field Sample ID:	D2-TW-0008192-24092-3-N	D2-TW-0007445-24092-N	D2-TW-0007832-24092-N	D2-TW-0007845-24092-N	D2-TW-0007849-24092-N	D2-TW-0008075-24092-N	D2-TW-0007907-24092-N	D2-TW-0007907-24092-3-N	
		Sample Date:	2025-02-27	2025-03-17	2025-03-23	2025-03-23	2025-03-11	2025-03-28	2025-03-20	2025-03-20	
		Sample Type:	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	--	700	410	140	310	670	630	--
Field Test (pH)	pH	--	--	--	7.31	7.30	7.34	7.11	7.10	7.37	--
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.380	0.250	0.250	0.280	0.250	0.250	--
Field Test (degrees Celcius)	Temperature	--	--	--	24.7	24.1	24.8	23.3	23.8	26.6	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.590	0.00	1.93	0.00	1.02	0.930	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52900	53300	56000	56200	56500	54300	55800	54500
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	32.5	53.4	46.6	54.8	53.5	44.6	7.60	7.50
	Lead	15	MCL	ND	ND	0.300	0.440	ND	0.220	ND	ND
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
	Benzo(k)fluoranthene	--	--	ND	ND						
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-18TH0108	D2-19TH0176	D2-19TH0201	D2-19TH0216	D2-19TH1707	D2-1ST0106	D2-1ST0202	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	108 18th Street	176 19th Street	201 19th Street	216 19th Street	1707 19th Way	106 1st Street	202 1st Street	
		Field Sample ID:	D2-TW-0008192-24092-3-N	D2-TW-0007445-24092-N	D2-TW-0007832-24092-N	D2-TW-0007845-24092-N	D2-TW-0007849-24092-N	D2-TW-0008075-24092-N	D2-TW-0007907-24092-N	D2-TW-0007907-24092-3-N
		Sample Date:	2025-02-27	2025-03-17	2025-03-23	2025-03-23	2025-03-11	2025-03-28	2025-03-20	2025-03-20
		Sample Type:	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)					
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND	ND	ND	0.410	ND	ND	ND
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND	ND	ND	0.310	ND	ND	0.270

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-18TH0108	D2-19TH0176	D2-19TH0201	D2-19TH0216	D2-19TH1707	D2-1ST0106	D2-1ST0202	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		108 18th Street	176 19th Street	201 19th Street	216 19th Street	1707 19th Way	106 1st Street	202 1st Street	
					D2-TW-0008192-24092-3-N	D2-TW-0007445-24092-N	D2-TW-0007832-24092-N	D2-TW-0007845-24092-N	D2-TW-0007849-24092-N	D2-TW-0008075-24092-N	D2-TW-0007907-24092-N	D2-TW-0007907-24092-3-N
					2025-02-27	2025-03-17	2025-03-23	2025-03-23	2025-03-11	2025-03-28	2025-03-20	2025-03-20
					FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)					
					ND	ND	ND	0.720	ND	ND	0.270	0.260

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-20TH0113	D2-20TH0140	D2-20TH0147	D2-20TH0149	D2-20TH0166	D2-20TH0180		D2-21ST0111	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence	
		Address:	113 20th Street	140 20th Street	147 20th Street	149 20th Street	166 20th Street	180 20th Street		111 21st Street	
		Field Sample ID:	D2-TW-0006941-24092-N	D2-TW-0007962-24092-N	D2-TW-0007969-24092-N	D2-TW-0007971-24092-N	D2-TW-0007168-24092-N	D2-TW-0007175-24092-N	D2-TW-0007175-24092-3-N	D2-TW-0008007-24092-N	
		Sample Date:	2025-01-17	2025-01-10	2025-03-17	2025-03-20	2025-01-10	2025-03-21	2025-03-21	2025-03-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	720	670	310	440	860	910	--	450
Field Test (pH)	pH	--	--	7.23	7.35	7.34	7.33	7.15	7.32	--	7.33
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.260	0.290	0.250	0.240	0.250	--	0.250
Field Test (degrees Celcius)	Temperature	--	--	23.7	26.0	23.8	26.1	24.5	23.7	--	23.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.290	0.00	0.00	0.550	0.0530	0.00	--	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	50900	59500	54600	56500	56900	53200	54000	54600
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	26.8	47.4	39.4	50.8	51.5	25.1	27.7	28.7
	Lead	15	MCL	ND	0.150	ND	0.170	ND	0.150	0.130	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-20TH0113	D2-20TH0140	D2-20TH0147	D2-20TH0149	D2-20TH0166	D2-20TH0180		D2-21ST0111
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	113 20th Street	140 20th Street	147 20th Street	149 20th Street	166 20th Street	180 20th Street		111 21st Street
		Field Sample ID:	D2-TW-0006941-24092-N	D2-TW-0007962-24092-N	D2-TW-0007969-24092-N	D2-TW-0007971-24092-N	D2-TW-0007168-24092-N	D2-TW-0007175-24092-N	D2-TW-0007175-24092-3-N	D2-TW-0008007-24092-N
		Sample Date:	2025-01-17	2025-01-10	2025-03-17	2025-03-20	2025-01-10	2025-03-21	2025-03-21	2025-03-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-20TH0113	D2-20TH0140	D2-20TH0147	D2-20TH0149	D2-20TH0166	D2-20TH0180		D2-21ST0111
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	113 20th Street	140 20th Street	147 20th Street	149 20th Street	166 20th Street	180 20th Street		111 21st Street
		Field Sample ID:	D2-TW-0006941-24092-N	D2-TW-0007962-24092-N	D2-TW-0007969-24092-N	D2-TW-0007971-24092-N	D2-TW-0007168-24092-N	D2-TW-0007175-24092-N	D2-TW-0007175-24092-3-N	D2-TW-0008007-24092-N
		Sample Date:	2025-01-17	2025-01-10	2025-03-17	2025-03-20	2025-01-10	2025-03-21	2025-03-21	2025-03-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-21ST0120	D2-21ST0140	D2-2ND0112	D2-2ND0113	D2-3RD0117	D2-3RD0132	D2-4TH0116	D2-4TH0128	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	120 21st Street	140 21st Street	112 2nd Street	113 2nd Street	117 3rd Street	132 3rd Street	116 4th Street	128 4th Street	
		Field Sample ID:	D2-TW-0008374-24092-N	D2-TW-0008095-24092-N	D2-TW-0008099-24092-N	D2-TW-0008100-24092-N	D2-TW-0007570-24092-N	D2-TW-0007002-24092-N	D2-TW-0008217-24092-N	D2-TW-0008020-24092-N	
		Sample Date:	2025-03-18	2025-03-20	2025-03-21	2025-01-14	2025-03-01	2025-03-18	2025-03-23	2025-03-18	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	460	500	760	610	1540	620	440	590
Field Test (pH)	pH	--	--	7.27	7.32	7.30	7.17	7.24	7.19	7.09	7.27
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.240	0.260	0.250	0.260	0.280	0.300
Field Test (degrees Celcius)	Temperature	--	--	24.7	23.0	23.4	22.8	23.7	23.4	23.2	23.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.740	0.00	0.00	0.0820	0.250	0.00	0.00	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56900	52500	54000	51800	52100	56700	54200	53800
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	46.0	45.9	38.8	33.1	40.9	69.7	67.4	61.1
	Lead	15	MCL	0.240	0.140	0.130	ND	ND	0.240	0.960	0.270
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
	Benzo(k)fluoranthene	--	--	ND	ND						
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-21ST0120	D2-21ST0140	D2-2ND0112	D2-2ND0113	D2-3RD0117	D2-3RD0132	D2-4TH0116	D2-4TH0128
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	120 21st Street	140 21st Street	112 2nd Street	113 2nd Street	117 3rd Street	132 3rd Street	116 4th Street	128 4th Street
		Field Sample ID:	D2-TW-0008374-24092-N	D2-TW-0008095-24092-N	D2-TW-0008099-24092-N	D2-TW-0008100-24092-N	D2-TW-0007570-24092-N	D2-TW-0007002-24092-N	D2-TW-0008217-24092-N	D2-TW-0008020-24092-N
		Sample Date:	2025-03-18	2025-03-20	2025-03-21	2025-01-14	2025-03-01	2025-03-18	2025-03-23	2025-03-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND						
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND						

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

				Location ID:	D2-21ST0120	D2-21ST0140	D2-2ND0112	D2-2ND0113	D2-3RD0117	D2-3RD0132	D2-4TH0116	D2-4TH0128
				Location Type:	Residence							
				Address:	120 21st Street	140 21st Street	112 2nd Street	113 2nd Street	117 3rd Street	132 3rd Street	116 4th Street	128 4th Street
				Field Sample ID:	D2-TW-0008374-24092-N	D2-TW-0008095-24092-N	D2-TW-0008099-24092-N	D2-TW-0008100-24092-N	D2-TW-0007570-24092-N	D2-TW-0007002-24092-N	D2-TW-0008217-24092-N	D2-TW-0008020-24092-N
				Sample Date:	2025-03-18	2025-03-20	2025-03-21	2025-01-14	2025-03-01	2025-03-18	2025-03-23	2025-03-18
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-4TH0201B	D2-4TH0208A	D2-5TH0123		D2-5TH0201	D2-5TH0206	D2-6TH0206	D2-7TH0203	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	201B 4th Street	208A 4th Street	123 5th Street		201 5th Street	206 5th Street	206 6th Street	203 7th Street	
		Field Sample ID:	D2-TW-0008030-24092-N	D2-TW-0008035-24092-N	D2-TW-0007587-24092-N	D2-TW-0007587-24092-3-N	D2-TW-0007593-24092-N	D2-TW-0007594-24092-N	D2-TW-0007612-24092-N	D2-TW-0007453-24092-N	
		Sample Date:	2025-03-18	2025-03-18	2025-03-20	2025-03-20	2025-03-24	2025-03-24	2025-03-25	2025-03-24	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	660	690	100	--	800	390	690	610
Field Test (pH)	pH	--	--	7.23	7.28	7.31	--	7.33	7.31	7.23	7.13
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	0.250	--	0.250	0.250	0.250	0.250
Field Test (degrees Celcius)	Temperature	--	--	24.5	23.9	25.2	--	24.9	23.6	23.4	23.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0560	0.170	0.00	--	2.59	0.00	1.33	0.140
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55100	54700	56200	57000	50800	55200	54200	54300
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	200
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	3.10	3.20	63.5	61.8	4.20	5.90	9.80	19.3
	Lead	15	MCL	ND	0.130	0.240	0.200	ND	ND	0.140	0.240
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-4TH0201B	D2-4TH0208A	D2-5TH0123		D2-5TH0201	D2-5TH0206	D2-6TH0206	D2-7TH0203
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	201B 4th Street	208A 4th Street	123 5th Street		201 5th Street	206 5th Street	206 6th Street	203 7th Street
		Field Sample ID:	D2-TW-0008030-24092-N	D2-TW-0008035-24092-N	D2-TW-0007587-24092-N	D2-TW-0007587-24092-3-N	D2-TW-0007593-24092-N	D2-TW-0007594-24092-N	D2-TW-0007612-24092-N	D2-TW-0007453-24092-N
		Sample Date:	2025-03-18	2025-03-18	2025-03-20	2025-03-20	2025-03-24	2025-03-24	2025-03-25	2025-03-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.340	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.280	ND	ND	0.290	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-4TH0201B	D2-4TH0208A	D2-5TH0123		D2-5TH0201	D2-5TH0206	D2-6TH0206	D2-7TH0203
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		201B 4th Street	208A 4th Street	123 5th Street		201 5th Street	206 5th Street	206 6th Street	203 7th Street
					D2-TW-0008030-24092-N	D2-TW-0008035-24092-N	D2-TW-0007587-24092-N	D2-TW-0007587-24092-3-N	D2-TW-0007593-24092-N	D2-TW-0007594-24092-N	D2-TW-0007612-24092-N	D2-TW-0007453-24092-N
					2025-03-18	2025-03-18	2025-03-20	2025-03-20	2025-03-24	2025-03-24	2025-03-25	2025-03-24
					N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
					ND	ND	0.620	ND	ND	ND	0.290	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

				Location ID:	D2-8TH0203	D2-9TH0214	D2-AIMO0133		D2-AIMO0138	D2-APOL0458	D2-APOL0748	D2-APOL0828
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	203 8th Street	214 9th Street	133 Aimokulani Alley		138 Aimokulani Alley	458 Apollo Avenue	748 Apollo Avenue	828 Apollo Avenue
				Field Sample ID:	D2-TW-0007460-24092-N	D2-TW-0007470-24092-N	D2-TW-0008092-24092-N	D2-TW-0008092-24092-3-N	D2-TW-0008319-24092-N	D2-TW-0007581-24092-N	D2-TW-0007203-24092-N	D2-TW-0007211-24092-N
				Sample Date:	2025-03-25	2025-03-24	2025-02-27	2025-02-27	2025-03-20	2025-03-20	2025-03-23	2025-03-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	660	420	520	--	730	870	720	820	
Field Test (pH)	pH	--	--	7.14	7.17	7.13	--	7.68	7.49	7.23	7.32	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.250	0.240	--	0.250	0.300	0.300	0.270	
Field Test (degrees Celcius)	Temperature	--	--	23.7	25.8	24.7	--	24.5	24.2	23.8	22.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.120	0.860	0.430	--	0.00	1.31	0.530	0.0110	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55200	53900	54100	53800	53700	54900	55500	53800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	31.3	33.8	5.70	5.90	8.40	12.7	11.0	6.70	
	Lead	15	MCL	ND	0.160	0.250	0.290	0.260	0.220	0.160	0.350	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-8TH0203	D2-9TH0214	D2-AIMO0133		D2-AIMO0138	D2-APOL0458	D2-APOL0748	D2-APOL0828
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	203 8th Street	214 9th Street	133 Aimokulani Alley		138 Aimokulani Alley	458 Apollo Avenue	748 Apollo Avenue	828 Apollo Avenue
		Field Sample ID:	D2-TW-0007460-24092-N	D2-TW-0007470-24092-N	D2-TW-0008092-24092-N	D2-TW-0008092-24092-3-N	D2-TW-0008319-24092-N	D2-TW-0007581-24092-N	D2-TW-0007203-24092-N	D2-TW-0007211-24092-N
		Sample Date:	2025-03-25	2025-03-24	2025-02-27	2025-02-27	2025-03-20	2025-03-20	2025-03-23	2025-03-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.370	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	0.340	ND	0.270

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-8TH0203	D2-9TH0214	D2-AIMO0133		D2-AIMO0138	D2-APOL0458	D2-APOL0748	D2-APOL0828	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	203 8th Street	214 9th Street	133 Aimokulani Alley		138 Aimokulani Alley	458 Apollo Avenue	748 Apollo Avenue	828 Apollo Avenue	
		Field Sample ID:	D2-TW-0007460-24092-N	D2-TW-0007470-24092-N	D2-TW-0008092-24092-N	D2-TW-0008092-24092-3-N	D2-TW-0008319-24092-N	D2-TW-0007581-24092-N	D2-TW-0007203-24092-N	D2-TW-0007211-24092-N	
		Sample Date:	2025-03-25	2025-03-24	2025-02-27	2025-02-27	2025-03-20	2025-03-20	2025-03-23	2025-03-18	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.710	ND	0.270	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BEAR0501B	D2-BEAR0502	D2-BEAR0603	D2-BEAR1004	D2-BEED0306		D2-CHAL2404A	D2-CHAL2405A
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	501B Beard Avenue	502 Beard Avenue	603 Beard Avenue	1004 Beard Avenue	306 Beedle Street		2404A Challenger Loop	2405A Challenger Loop
				Field Sample ID:	D2-TW-0007650-24092-N	D2-TW-0007082-24092-N	D2-TW-0007224-24092-N	D2-TW-0007234-24092-N	D2-TW-0007659-24092-N	D2-TW-0007659-24092-3-N	D2-TW-0007475-24092-N	D2-TW-0007476-24092-N
				Sample Date:	2025-03-19	2025-03-20	2025-01-14	2025-03-19	2025-03-26	2025-03-26	2025-03-23	2025-01-16
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Field Test (ppb)	Free Chlorine	4000	MCL		580	790	740	790	220	--	700	620
Field Test (pH)	pH	--	--		7.27	7.12	7.16	7.26	7.33	--	7.15	7.29
Field Test (ms/cm)	Specific Conductivity	--	--		0.240	0.260	0.270	0.240	0.250	--	0.270	0.270
Field Test (degrees Celcius)	Temperature	--	--		23.1	24.4	23.6	23.5	25.2	--	23.2	21.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.0240	0.00840	0.00	0.0370	4.79	--	0.830	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		54700	54300	53100	53300	54200	57600	53700	50400
	Total Organic Carbon	--	--		ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--		ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL		3.60	4.00	28.3	24.5	41.4	42.3	33.6	28.8
	Lead	15	MCL		ND	ND	ND	0.170	ND	ND	ND	0.210
	Mercury	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
Benzo(k)fluoranthene	--	--		ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BEAR0501B	D2-BEAR0502	D2-BEAR0603	D2-BEAR1004	D2-BEED0306		D2-CHAL2404A	D2-CHAL2405A
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	501B Beard Avenue	502 Beard Avenue	603 Beard Avenue	1004 Beard Avenue	306 Beedle Street		2404A Challenger Loop	2405A Challenger Loop
				Field Sample ID:	D2-TW-0007650-24092-N	D2-TW-0007082-24092-N	D2-TW-0007224-24092-N	D2-TW-0007234-24092-N	D2-TW-0007659-24092-N	D2-TW-0007659-24092-3-N	D2-TW-0007475-24092-N	D2-TW-0007476-24092-N
				Sample Date:	2025-03-19	2025-03-20	2025-01-14	2025-03-19	2025-03-26	2025-03-26	2025-03-23	2025-01-16
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BEAR0501B	D2-BEAR0502	D2-BEAR0603	D2-BEAR1004	D2-BEED0306		D2-CHAL2404A	D2-CHAL2405A
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	501B Beard Avenue	502 Beard Avenue	603 Beard Avenue	1004 Beard Avenue	306 Beedle Street		2404A Challenger Loop	2405A Challenger Loop
				Field Sample ID:	D2-TW-0007650-24092-N	D2-TW-0007082-24092-N	D2-TW-0007224-24092-N	D2-TW-0007234-24092-N	D2-TW-0007659-24092-N	D2-TW-0007659-24092-3-N	D2-TW-0007475-24092-N	D2-TW-0007476-24092-N
				Sample Date:	2025-03-19	2025-03-20	2025-01-14	2025-03-19	2025-03-26	2025-03-26	2025-03-23	2025-01-16
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	0.260	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	0.260	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-CHAL2405B	D2-CHAL2415B	D2-CHAL2418D	D2-CHAL2421A	D2-CHAL2422C	D2-CHAL2424B	D2-CHAL2425A	D2-CHAL2428D	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2405B Challenger Loop	2415B Challenger Loop	2418D Challenger Loop	2421A Challenger Loop	2422C Challenger Loop	2424B Challenger Loop	2425A Challenger Loop	2428D Challenger Loop	
		Field Sample ID:	D2-TW-0008198-24092-N	D2-TW-0008206-24092-N	D2-TW-0008334-24092-N	D2-TW-0008076-24092-N	D2-TW-0007809-24092-N	D2-TW-0007978-24092-N	D2-TW-0008079-24092-N	D2-TW-0008340-24092-N	
		Sample Date:	2025-03-25	2025-03-17	2025-02-27	2025-03-20	2025-03-20	2025-03-18	2025-03-18	2025-03-24	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-CHAL2405B	D2-CHAL2415B	D2-CHAL2418D	D2-CHAL2421A	D2-CHAL2422C	D2-CHAL2424B	D2-CHAL2425A	D2-CHAL2428D
Field Test (ppb)	Free Chlorine	4000	MCL	730	520	680	770	720	680	870	530
Field Test (pH)	pH	--	--	7.23	7.38	7.11	7.12	7.13	7.14	7.26	7.20
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.260	0.240	0.260	0.270	0.260	0.240	0.250
Field Test (degrees Celcius)	Temperature	--	--	24.7	22.6	24.4	23.6	23.9	24.1	22.9	24.6
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.67	0.00	0.460	0.00	0.00	0.00200	0.00	0.200
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53400	56400	54700	56700	54100	54400	53100	53800
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	15.8	111	17.5	49.7	32.4	24.4	51.7	55.7
	Lead	15	MCL	ND	0.230	ND	0.170	0.180	0.240	ND	0.380
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		<b>Location ID:</b>	D2-CHAL2405B	D2-CHAL2415B	D2-CHAL2418D	D2-CHAL2421A	D2-CHAL2422C	D2-CHAL2424B	D2-CHAL2425A	D2-CHAL2428D
		<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		<b>Address:</b>	2405B Challenger Loop	2415B Challenger Loop	2418D Challenger Loop	2421A Challenger Loop	2422C Challenger Loop	2424B Challenger Loop	2425A Challenger Loop	2428D Challenger Loop
		<b>Field Sample ID:</b>	D2-TW-0008198-24092-N	D2-TW-0008206-24092-N	D2-TW-0008334-24092-N	D2-TW-0008076-24092-N	D2-TW-0007809-24092-N	D2-TW-0007978-24092-N	D2-TW-0008079-24092-N	D2-TW-0008340-24092-N
		<b>Sample Date:</b>	2025-03-25	2025-03-17	2025-02-27	2025-03-20	2025-03-20	2025-03-18	2025-03-18	2025-03-24
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>							
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND						
	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.340	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.590	ND	ND	ND	ND	0.560

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-CHAL2405B	D2-CHAL2415B	D2-CHAL2418D	D2-CHAL2421A	D2-CHAL2422C	D2-CHAL2424B	D2-CHAL2425A	D2-CHAL2428D
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2405B Challenger Loop	2415B Challenger Loop	2418D Challenger Loop	2421A Challenger Loop	2422C Challenger Loop	2424B Challenger Loop	2425A Challenger Loop	2428D Challenger Loop
		Field Sample ID:	D2-TW-0008198-24092-N	D2-TW-0008206-24092-N	D2-TW-0008334-24092-N	D2-TW-0008076-24092-N	D2-TW-0007809-24092-N	D2-TW-0007978-24092-N	D2-TW-0008079-24092-N	D2-TW-0008340-24092-N
		Sample Date:	2025-03-25	2025-03-17	2025-02-27	2025-03-20	2025-03-20	2025-03-18	2025-03-18	2025-03-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND	0.710	ND	ND	ND	ND	0.490
	Total Trihalomethanes	80	MCL	ND	1.64	ND	ND	ND	ND	1.05

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-CHAL2437B	D2-CORN1201	D2-CORN1209	D2-CORN1219	D2-FOXB1112	D2-FOXB1401	D2-FOXB1501	D2-FOXB1717	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2437B Challenger Loop	1201 Cornet Avenue	1209 Cornet Avenue	1219 Cornet Avenue	1112 Fox Boulevard	1401 Fox Boulevard	1501 Fox Boulevard	1717 Fox Boulevard	
		Field Sample ID:	D2-TW-0007988-24092-N	D2-TW-0007818-24092-N	D2-TW-0007822-24092-N	D2-TW-0008040-24092-N	D2-TW-0008347-24092-N	D2-TW-0007513-24092-N	D2-TW-0007858-24092-N	D2-TW-0007874-24092-N	
		Sample Date:	2025-03-23	2025-03-21	2025-03-20	2025-03-24	2025-03-18	2025-03-18	2025-03-25	2025-03-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-CHAL2437B	D2-CORN1201	D2-CORN1209	D2-CORN1219	D2-FOXB1112	D2-FOXB1401	D2-FOXB1501	D2-FOXB1717
Field Test (ppb)	Free Chlorine	4000	MCL	890	690	670	560	620	450	550	800
Field Test (pH)	pH	--	--	7.32	7.57	7.20	7.16	7.26	7.27	7.08	7.13
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.260	0.280	0.250	0.280	0.240	0.270	0.290
Field Test (degrees Celcius)	Temperature	--	--	23.2	25.5	23.9	23.2	22.3	24.4	26.1	25.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.290	1.04	1.03	0.00	0.000190	0.710	0.220
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56000	52400	55100	53300	53700	56100	54200	52200
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	24.3	25.7	32.4	22.0	18.2	34.2	60.6	19.8
	Lead	15	MCL	ND	ND	0.180	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-CHAL2437B	D2-CORN1201	D2-CORN1209	D2-CORN1219	D2-FOXB1112	D2-FOXB1401	D2-FOXB1501	D2-FOXB1717
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2437B Challenger Loop	1201 Cornet Avenue	1209 Cornet Avenue	1219 Cornet Avenue	1112 Fox Boulevard	1401 Fox Boulevard	1501 Fox Boulevard	1717 Fox Boulevard
		Field Sample ID:	D2-TW-0007988-24092-N	D2-TW-0007818-24092-N	D2-TW-0007822-24092-N	D2-TW-0008040-24092-N	D2-TW-0008347-24092-N	D2-TW-0007513-24092-N	D2-TW-0007858-24092-N	D2-TW-0007874-24092-N
		Sample Date:	2025-03-23	2025-03-21	2025-03-20	2025-03-24	2025-03-18	2025-03-18	2025-03-25	2025-03-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND						
	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	0.340	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-CHAL2437B	D2-CORN1201	D2-CORN1209	D2-CORN1219	D2-FOXB1112	D2-FOXB1401	D2-FOXB1501	D2-FOXB1717
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2437B Challenger Loop	1201 Cornet Avenue	1209 Cornet Avenue	1219 Cornet Avenue	1112 Fox Boulevard	1401 Fox Boulevard	1501 Fox Boulevard	1717 Fox Boulevard
		Field Sample ID:	D2-TW-0007988-24092-N	D2-TW-0007818-24092-N	D2-TW-0007822-24092-N	D2-TW-0008040-24092-N	D2-TW-0008347-24092-N	D2-TW-0007513-24092-N	D2-TW-0007858-24092-N	D2-TW-0007874-24092-N
		Sample Date:	2025-03-23	2025-03-21	2025-03-20	2025-03-24	2025-03-18	2025-03-18	2025-03-25	2025-03-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	0.360	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.700	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-FOXB1717	D2-FOXB1923	D2-FOXB1927		D2-FOXB1929		D2-FOXB2021	D2-GEM10305	
		Location Type:	Residence	Residence	Residence		Residence		Residence	Residence	
		Address:	1717 Fox Boulevard	1923 Fox Boulevard	1927 Fox Boulevard		1929 Fox Boulevard		2021 Fox Boulevard	305 Gemini Avenue	
		Field Sample ID:	D2-TW-0007874-24092-3-N	D2-TW-0008245-24092-N	D2-TW-0008001-24092-N	D2-TW-0008001-24092-3-N	D2-TW-0008003-24092-N	D2-TW-0008003-24092-3-N	D2-TW-0007046-24092-N	D2-TW-0007142-24092-N	
		Sample Date:	2025-03-20	2025-03-19	2025-03-18	2025-03-18	2025-03-27	2025-03-27	2025-03-20	2025-03-10	
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	--	760	480	--	740	--	470	800
Field Test (pH)	pH	--	--	--	7.27	7.31	--	7.24	--	7.16	7.16
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.240	0.260	--	0.240	--	0.260	0.440
Field Test (degrees Celcius)	Temperature	--	--	--	24.5	23.4	--	22.5	--	24.2	24.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.0690	0.380	--	0.00	--	0.00	0.280
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53300	54100	53500	52900	58200	53200	53800	54400
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	19.1	34.6	62.0	65.8	42.2	42.4	32.9	10.5
	Lead	15	MCL	ND	ND	0.330	0.310	ND	ND	ND	0.150
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-FOXB1717	D2-FOXB1923	D2-FOXB1927		D2-FOXB1929		D2-FOXB2021	D2-GEM10305
		Location Type:	Residence	Residence	Residence		Residence		Residence	Residence
		Address:	1717 Fox Boulevard	1923 Fox Boulevard	1927 Fox Boulevard		1929 Fox Boulevard		2021 Fox Boulevard	305 Gemini Avenue
		Field Sample ID:	D2-TW-0007874-24092-3-N	D2-TW-0008245-24092-N	D2-TW-0008001-24092-N	D2-TW-0008001-24092-3-N	D2-TW-0008003-24092-N	D2-TW-0008003-24092-3-N	D2-TW-0007046-24092-N	D2-TW-0007142-24092-N
		Sample Date:	2025-03-20	2025-03-19	2025-03-18	2025-03-18	2025-03-27	2025-03-27	2025-03-20	2025-03-10
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-FOXB1717	D2-FOXB1923	D2-FOXB1927		D2-FOXB1929		D2-FOXB2021	D2-GEMIO305
				Location Type:	Residence	Residence	Residence		Residence		Residence	Residence
				Address:	1717 Fox Boulevard	1923 Fox Boulevard	1927 Fox Boulevard		1929 Fox Boulevard		2021 Fox Boulevard	305 Gemini Avenue
				Field Sample ID:	D2-TW-0007874-24092-3-N	D2-TW-0008245-24092-N	D2-TW-0008001-24092-N	D2-TW-0008001-24092-3-N	D2-TW-0008003-24092-N	D2-TW-0008003-24092-3-N	D2-TW-0007046-24092-N	D2-TW-0007142-24092-N
				Sample Date:	2025-03-20	2025-03-19	2025-03-18	2025-03-18	2025-03-27	2025-03-27	2025-03-20	2025-03-10
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

				Location ID:	D2-GEMI0312	D2-HOAA0904	D2-HONU0112	D2-HOOL0704	D2-HOOP0912	D2-HUIL0347	D2-JULI0115	D2-JULI0305
				Location Type:	Residence							
				Address:	312 Gemini Avenue	904 Hoano Alley	112 Honu Alley	704 Hoolaulima Alley	912 Hoopinana Alley	347 Huilanui Alley	115 Julian Avenue	305 Julian Avenue
				Field Sample ID:	D2-TW-0007146-24092-N	D2-TW-0008130-24092-N	D2-TW-0008136-24092-N	D2-TW-0008146-24092-N	D2-TW-0008113-24092-N	D2-TW-0006983-24092-N	D2-TW-0007258-24092-N	D2-TW-0007266-24092-N
				Sample Date:	2025-03-19	2025-03-17	2025-01-16	2025-03-26	2025-03-18	2025-03-23	2025-03-12	2025-03-20
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	760	720	680	650	690	220	720	520	
Field Test (pH)	pH	--	--	7.28	7.17	7.31	7.22	7.17	7.25	7.20	7.14	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	0.260	0.240	0.260	0.250	0.250	0.280	
Field Test (degrees Celcius)	Temperature	--	--	23.8	24.0	25.2	23.4	25.3	25.1	23.3	25.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	0.0640	0.440	2.93	0.500	0.680	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56300	53500	51600	54000	53400	55600	54800	56100	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	5.20	5.30	6.30	26.8	12.1	5.90	39.5	126	
	Lead	15	MCL	ND	ND	0.130	0.230	0.170	0.360	0.260	0.130	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		<b>Location ID:</b>	D2-GEMI0312	D2-HOAA0904	D2-HONU0112	D2-HOOL0704	D2-HOOP0912	D2-HUIL0347	D2-JULI0115	D2-JULI0305
		<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		<b>Address:</b>	312 Gemini Avenue	904 Hoano Alley	112 Honu Alley	704 Hoolaulima Alley	912 Hoopinana Alley	347 Huilanui Alley	115 Julian Avenue	305 Julian Avenue
		<b>Field Sample ID:</b>	D2-TW-0007146-24092-N	D2-TW-0008130-24092-N	D2-TW-0008136-24092-N	D2-TW-0008146-24092-N	D2-TW-0008113-24092-N	D2-TW-0006983-24092-N	D2-TW-0007258-24092-N	D2-TW-0007266-24092-N
		<b>Sample Date:</b>	2025-03-19	2025-03-17	2025-01-16	2025-03-26	2025-03-18	2025-03-23	2025-03-12	2025-03-20
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND						
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND						

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

				Location ID:	D2-GEMI0312	D2-HOAA0904	D2-HONU0112	D2-HOOL0704	D2-HOOP0912	D2-HUIL0347	D2-JULI0115	D2-JULI0305
				Location Type:	Residence							
				Address:	312 Gemini Avenue	904 Hoano Alley	112 Honu Alley	704 Hoolaulima Alley	912 Hoopinana Alley	347 Huilanui Alley	115 Julian Avenue	305 Julian Avenue
				Field Sample ID:	D2-TW-0007146-24092-N	D2-TW-0008130-24092-N	D2-TW-0008136-24092-N	D2-TW-0008146-24092-N	D2-TW-0008113-24092-N	D2-TW-0006983-24092-N	D2-TW-0007258-24092-N	D2-TW-0007266-24092-N
				Sample Date:	2025-03-19	2025-03-17	2025-01-16	2025-03-26	2025-03-18	2025-03-23	2025-03-12	2025-03-20
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-JULI0309	D2-JULI0403	D2-JULI0409	D2-JULI0507	D2-JULI0508		D2-JULI0605	D2-JULI0607	
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	309 Julian Avenue	403 Julian Avenue	409 Julian Avenue	507 Julian Avenue	508 Julian Avenue		605 Julian Avenue	607 Julian Way	
		Field Sample ID:	D2-TW-0007268-24092-N	D2-TW-0007310-24092-N	D2-TW-0007517-24092-N	D2-TW-0007522-24092-N	D2-TW-0007523-24331-N-H-WQI	D2-TW-0007523-24331-N-WQI	D2-TW-0007358-24331-N	D2-TW-0007359-24092-N	
		Sample Date:	2025-03-19	2025-03-25	2025-03-25	2025-03-25	2025-02-03	2025-02-03	2025-01-22	2025-03-19	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	--	--	Absent	--	--	
	E. coli	--	--	--	--	--	--	Absent	--	--	
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	--	--	--	49.0	64.0	--	--	
Field Test (ppb)	Free Chlorine	4000	MCL	270	260	650	430	660	880	500	800
Field Test (pH)	pH	--	--	7.24	7.13	7.31	7.32	7.27	7.23	7.09	7.45
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.270	0.260	0.240	0.280	0.290	0.260	0.240
Field Test (degrees Celcius)	Temperature	--	--	24.1	25.5	24.5	23.3	34.7	25.1	23.0	22.5
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0520	1.22	0.0350	0.0440	0.780	1.72	0.410	0.430
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55400	54200	54000	54600	--	48100	49700	53700
	Total Organic Carbon	--	--	ND	ND	ND	ND	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	48.8	23.8	56.8	103	--	4.90	72.7	46.1
	Lead	15	MCL	0.130	ND	ND	0.180	--	ND	0.140	0.150
	Mercury	2	MCL	ND	ND	ND	ND	--	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	--	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-JULI0309	D2-JULI0403	D2-JULI0409	D2-JULI0507	D2-JULI0508		D2-JULI0605	D2-JULI0607	
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	309 Julian Avenue	403 Julian Avenue	409 Julian Avenue	507 Julian Avenue	508 Julian Avenue		605 Julian Avenue	607 Julian Way	
		Field Sample ID:	D2-TW-0007268-24092-N	D2-TW-0007310-24092-N	D2-TW-0007517-24092-N	D2-TW-0007522-24092-N	D2-TW-0007523-24331-N-H-WQI	D2-TW-0007523-24331-N-WQI	D2-TW-0007358-24331-N	D2-TW-0007359-24092-N	
		Sample Date:	2025-03-19	2025-03-25	2025-03-25	2025-03-25	2025-02-03	2025-02-03	2025-01-22	2025-03-19	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	--	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	--	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	--	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	--	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		<b>Location ID:</b>	D2-JULI0309	D2-JULI0403	D2-JULI0409	D2-JULI0507	D2-JULI0508		D2-JULI0605	D2-JULI0607	
		<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		<b>Address:</b>	309 Julian Avenue	403 Julian Avenue	409 Julian Avenue	507 Julian Avenue	508 Julian Avenue		605 Julian Avenue	607 Julian Way	
		<b>Field Sample ID:</b>	D2-TW-0007268-24092-N	D2-TW-0007310-24092-N	D2-TW-0007517-24092-N	D2-TW-0007522-24092-N	D2-TW-0007523-24331-N-H-WQI	D2-TW-0007523-24331-N-WQI	D2-TW-0007358-24331-N	D2-TW-0007359-24092-N	
		<b>Sample Date:</b>	2025-03-19	2025-03-25	2025-03-25	2025-03-25	2025-02-03	2025-02-03	2025-01-22	2025-03-19	
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>								
Trihalomethanes (ppb)	Bromoform	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	--	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-KAUW0631	D2-KAWE0731	D2-KAWE0735	D2-KOAA0508		D2-KULE0608	D2-KUMA0282	D2-KUMA0288	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence	
		Address:	631 Kawenaole Alley	731 Kawehiwehi Street	735 Kawehiwehi Street	508 Koaina Alley		608 Kulekia Alley	282 Kumama Alley	288 Kumama Alley	
		Field Sample ID:	D2-TW-0006929-24092-N	D2-TW-0007773-24331-N	D2-TW-0007777-24092-N	D2-TW-0007788-24092-N	D2-TW-0007788-24092-3-N	D2-TW-0007919-24092-N	D2-TW-0007921-24092-N	D2-TW-0006986-24092-N	
		Sample Date:	2025-01-10	2025-01-16	2025-03-20	2025-03-28	2025-03-28	2025-01-16	2025-03-20	2025-01-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	720	710	700	710	--	720	760	660
Field Test (pH)	pH	--	--	7.26	7.32	7.12	7.04	--	7.45	7.22	7.27
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.270	0.280	0.290	--	0.300	0.240	0.260
Field Test (degrees Celcius)	Temperature	--	--	23.6	24.2	24.4	23.3	--	23.2	23.3	23.0
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	1.17	0.310	--	0.00	0.00290	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56100	51300	55200	53600	53100	54300	52200	51900
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	8.70	15.2	5.90	7.00	8.20	16.3	3.80	8.10
	Lead	15	MCL	ND	0.340	ND	0.130	0.370	1.90	0.240	0.220
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		Location ID:	D2-KAUW0631	D2-KAWE0731	D2-KAWE0735	D2-KOAA0508		D2-KULE0608	D2-KUMA0282	D2-KUMA0288
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	631 Kawenaole Alley	731 Kawehiwehi Street	735 Kawehiwehi Street	508 Koaina Alley		608 Kulekia Alley	282 Kumama Alley	288 Kumama Alley
		Field Sample ID:	D2-TW-0006929-24092-N	D2-TW-0007773-24331-N	D2-TW-0007777-24092-N	D2-TW-0007788-24092-N	D2-TW-0007788-24092-3-N	D2-TW-0007919-24092-N	D2-TW-0007921-24092-N	D2-TW-0006986-24092-N
		Sample Date:	2025-01-10	2025-01-16	2025-03-20	2025-03-28	2025-03-28	2025-01-16	2025-03-20	2025-01-27
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-KAUW0631	D2-KAWE0731	D2-KAWE0735	D2-KOAA0508		D2-KULE0608	D2-KUMA0282	D2-KUMA0288
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		631 Kauwenaole Alley	731 Kawehiwehi Street	735 Kawehiwehi Street	508 Koaina Alley		608 Kulekia Alley	282 Kumama Alley	288 Kumama Alley
					D2-TW-0006929-24092-N	D2-TW-0007773-24331-N	D2-TW-0007777-24092-N	D2-TW-0007788-24092-N	D2-TW-0007788-24092-3-N	D2-TW-0007919-24092-N	D2-TW-0007921-24092-N	D2-TW-0006986-24092-N
					2025-01-10	2025-01-16	2025-03-20	2025-03-28	2025-03-28	2025-01-16	2025-03-20	2025-01-27
					N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
					ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-KUMA0295	D2-LEWA0246	D2-LEWA0252	D2-LEWA0261	D2-LEWA0262		D2-LEWA0267	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence		Residence	
					295 Kumama Alley	246 Lewa Hia Loop	252 Lewa Hia Loop	261 Lewa Hia Loop	262 Lewa Hia Loop		267 Lewa Hia Loop	
					D2-TW-0006989-24092-N	D2-TW-0007624-24092-N	D2-TW-0007626-24092-N	D2-TW-0007630-24092-N	D2-TW-0007631-24092-N	D2-TW-0007631-24092-3-N	D2-TW-0007636-24092-N	D2-TW-0007636-24092-3-N
					2025-03-18	2025-03-18	2025-03-18	2025-03-20	2025-03-21	2025-03-21	2025-03-25	2025-03-25
					N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
					990	690	220	770	830	--	850	--
Field Test (ppb)	Free Chlorine	4000	MCL									
Field Test (pH)	pH	--	--		7.52	7.32	7.40	7.02	7.34	--	7.17	--
Field Test (ms/cm)	Specific Conductivity	--	--		0.240	0.290	0.290	0.260	0.260	--	0.270	--
Field Test (degrees Celcius)	Temperature	--	--		24.7	21.9	22.9	25.9	23.5	--	23.5	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.000500	0.00	0.0150	0.280	0.00	--	0.000620	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		55300	56800	54200	53100	54000	52700	53900	52800
	Total Organic Carbon	--	--		ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--		ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL		12.7	5.50	14.5	5.30	6.60	5.10	6.10	5.80
	Lead	15	MCL		0.280	ND	0.310	0.140	0.170	0.150	0.290	0.200
	Mercury	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--		ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-KUMA0295	D2-LEWA0246	D2-LEWA0252	D2-LEWA0261	D2-LEWA0262		D2-LEWA0267	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
					295 Kumama Alley	246 Lewa Hia Loop	252 Lewa Hia Loop	261 Lewa Hia Loop	262 Lewa Hia Loop		267 Lewa Hia Loop	
					D2-TW-0006989-24092-N	D2-TW-0007624-24092-N	D2-TW-0007626-24092-N	D2-TW-0007630-24092-N	D2-TW-0007631-24092-N	D2-TW-0007631-24092-3-N	D2-TW-0007636-24092-N	D2-TW-0007636-24092-3-N
					2025-03-18	2025-03-18	2025-03-18	2025-03-20	2025-03-21	2025-03-21	2025-03-25	2025-03-25
					N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-KUMA0295	D2-LEWA0246	D2-LEWA0252	D2-LEWA0261	D2-LEWA0262		D2-LEWA0267	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		295 Kumama Alley	246 Lewa Hia Loop	252 Lewa Hia Loop	261 Lewa Hia Loop	262 Lewa Hia Loop		267 Lewa Hia Loop	
					D2-TW-0006989-24092-N	D2-TW-0007624-24092-N	D2-TW-0007626-24092-N	D2-TW-0007630-24092-N	D2-TW-0007631-24092-N	D2-TW-0007631-24092-3-N	D2-TW-0007636-24092-N	D2-TW-0007636-24092-3-N
					2025-03-18	2025-03-18	2025-03-18	2025-03-20	2025-03-21	2025-03-21	2025-03-25	2025-03-25
					N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
					ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-LEWA0278		D2-LEWA0338	D2-LEWA0366		D2-LEWA0372		D2-LEWA0375
				Location ID:	Location Type:	Address:	Location ID:	Location Type:	Address:	Location ID:	Location Type:
				D2-TW-0008227-24092-N	D2-TW-0008227-24092-3-N	D2-TW-0008239-24092-N	D2-TW-0008158-24092-N	D2-TW-0008158-24092-3-N	D2-TW-0008161-24092-N	D2-TW-0008161-24092-3-N	D2-TW-0007401-24092-N
				2025-03-26	2025-03-26	2025-03-20	2025-03-21	2025-03-21	2025-01-17	2025-01-17	2025-01-14
				N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	760	--	590	880	--	650	--	610
Field Test (pH)	pH	--	--	7.23	--	7.24	7.30	--	7.27	--	7.19
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	--	0.240	0.260	--	0.230	--	0.270
Field Test (degrees Celcius)	Temperature	--	--	22.9	--	24.5	23.2	--	25.0	--	23.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	0.00	0.00	--	0.170	--	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56800	54000	54100	53000	54700	50500	51500	52800
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	9.40	6.30	6.80	8.50	8.00	11.9	11.5	10.2
	Lead	15	MCL	0.210	0.360	0.330	0.140	ND	ND	ND	0.160
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-LEWA0278		D2-LEWA0338	D2-LEWA0366		D2-LEWA0372		D2-LEWA0375	
				Location ID:	Location Type:	Address:	Residence	Residence	Residence	Residence	Residence	Residence
				Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				D2-TW-0008227-24092-N	2025-03-26	N (Normal)	D2-TW-0008227-24092-3-N	2025-03-26	FD (Field Duplicate)	D2-TW-0008239-24092-N	2025-03-20	N (Normal)
				D2-TW-0008158-24092-N	2025-03-21	N (Normal)	D2-TW-0008158-24092-3-N	2025-03-21	FD (Field Duplicate)	D2-TW-0008161-24092-N	2025-01-17	N (Normal)
				D2-TW-0008161-24092-N	2025-01-17	N (Normal)	D2-TW-0008161-24092-3-N	2025-01-17	FD (Field Duplicate)	D2-TW-0007401-24092-N	2025-01-14	N (Normal)
				D2-TW-0007401-24092-N	2025-01-14	N (Normal)						
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-LEWA0278		D2-LEWA0338	D2-LEWA0366		D2-LEWA0372		D2-LEWA0375																																
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:																												
				D2-LEWA0278	Residence	278 Lewa Hia Loop	D2-TW-0008227-24092-N	2025-03-26	N (Normal)	D2-TW-0008227-24092-3-N	2025-03-26	FD (Field Duplicate)	D2-LEWA0338	Residence	338 Lewa Mawaho Loop	D2-TW-0008239-24092-N	2025-03-20	N (Normal)	D2-LEWA0366	Residence	366 Lewahana Loop	D2-TW-0008158-24092-N	2025-03-21	N (Normal)	D2-TW-0008158-24092-3-N	2025-03-21	FD (Field Duplicate)	D2-LEWA0372	Residence	372 Lewahana Loop	D2-TW-0008161-24092-N	2025-01-17	N (Normal)	D2-TW-0008161-24092-3-N	2025-01-17	FD (Field Duplicate)	D2-LEWA0375	Residence	375 Lewahana Loop	D2-TW-0007401-24092-N	2025-01-14	N (Normal)	
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-LEWA0384		D2-LEWA0386	D2-LEWA0409	D2-LEWA0411	D2-MERC0214	D2-MERC0222	D2-MERC0224																		
				Location ID:	Location Type:	Address:	Residence	Residence	Residence	Residence	Residence	Residence	Residence																
				Field Sample ID:	Sample Date:	Sample Type:																							
				D2-TW-0007271-24092-N	2025-03-27	N (Normal)	D2-TW-0007271-24092-3-N	2025-03-27	FD (Field Duplicate)	D2-TW-0007272-24092-N	2025-03-19	N (Normal)	D2-TW-0007286-24092-N	2025-03-24	N (Normal)	D2-TW-0007287-24092-N	2025-03-19	N (Normal)	D2-TW-0007295-24331-N	2025-01-16	N (Normal)	D2-TW-0007298-24092-N	2025-03-25	N (Normal)	D2-TW-0007299-24092-N	2025-03-18	N (Normal)		
				700	--		230	750	760	740	730	930																	
Field Test (ppb)	Free Chlorine	4000	MCL																										
Field Test (pH)	pH	--	--	7.25	--		7.19	7.20	7.37	7.30	7.23	7.02																	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	--		0.230	0.260	0.250	0.270	0.280	0.270																	
Field Test (degrees Celcius)	Temperature	--	--	24.6	--		27.1	25.6	23.0	24.9	23.6	22.8																	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--		0.180	0.690	0.00	0.00	0.190	0.0700																	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	57100		54300	53700	53400	55400	52000	55800	55100																	
	Total Organic Carbon	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Petroleum Hydrocarbons (as Oil)	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Petroleum Hydrocarbons, Total	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
Metals (ppb)	Copper	1300	MCL	10.6		6.50	10.5	17.3	14.7	7.90	7.10	9.00																	
	Lead	15	MCL	0.150		0.170	0.160	ND	0.210	0.180	ND	0.130																	
	Mercury	2	MCL	ND		ND	ND	ND	ND	ND	ND	ND																	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	2-Methylnaphthalene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Acenaphthylene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Anthracene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Benzo(a)pyrene	0.2	MCL	ND		ND	ND	ND	ND	ND	ND	ND																	
	Benzo(b)fluoranthene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Benzo(g,h,i)perylene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	
	Benzo(k)fluoranthene	--	--	ND		ND	ND	ND	ND	ND	ND	ND																	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D2-LEWA0384		D2-LEWA0386	D2-LEWA0409	D2-LEWA0411	D2-MERC0214	D2-MERC0222	D2-MERC0224
				Location Type: Residence	Address: 384 Lewahana Loop	Residence	Residence	Residence	Residence	Residence	Residence
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.540	0.560	0.450	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-LEWA0384		D2-LEWA0386	D2-LEWA0409	D2-LEWA0411	D2-MERC0214	D2-MERC0222	D2-MERC0224																																					
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:																								
				D2-LEWA0384	Residence	384 Lewahana Loop	D2-TW-0007271-24092-N	2025-03-27	N (Normal)	D2-TW-0007271-24092-3-N	2025-03-27	FD (Field Duplicate)	D2-LEWA0386	Residence	386 Lewahana Loop	D2-TW-0007272-24092-N	2025-03-19	N (Normal)	D2-LEWA0409	Residence	409 Lewa Mawaho Loop	D2-TW-0007286-24092-N	2025-03-24	N (Normal)	D2-LEWA0411	Residence	411 Lewa Mawaho Loop	D2-TW-0007287-24092-N	2025-03-19	N (Normal)	D2-MERC0214	Residence	214 Mercury Street	D2-TW-0007295-24331-N	2025-01-16	N (Normal)	D2-MERC0222	Residence	222 Mercury Street	D2-TW-0007298-24092-N	2025-03-25	N (Normal)	D2-MERC0224	Residence	224 Mercury Street	D2-TW-0007299-24092-N	2025-03-18	N (Normal)
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
	Dibromochloromethane	--	--	0.520	0.540	0.380	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	Total Trihalomethanes	80	MCL	1.06	1.10	0.830	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-PORT1304		D2-PORT1308		D2-PORT1404	D2-PORT1608	
				D2-MERC0232	Residence		Residence		Residence	Residence	
				232 Mercury Street	1304 Porter Avenue		1308 Porter Avenue		1404 Porter Avenue	1608 Porter Avenue	
				D2-TW-0007303-24092-N	D2-TW-0007726-24092-N	D2-TW-0007726-24092-3-N	D2-TW-0007728-24092-N	D2-TW-0007728-24092-3-N	D2-TW-0008420-24092-N	D2-TW-0008430-24092-N	D2-TW-0008430-24092-3-N
				2025-01-16	2025-01-22	2025-01-22	2025-01-17	2025-01-17	2025-01-17	2025-03-18	2025-03-18
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Field Test (ppb)	Free Chlorine	4000	MCL	790	530	--	640	--	790	550	--
Field Test (pH)	pH	--	--	7.09	7.30	--	7.27	--	7.26	7.30	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	--	0.230	--	0.230	0.280	--
Field Test (degrees Celcius)	Temperature	--	--	22.9	24.0	--	23.6	--	23.2	23.9	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0210	0.720	--	0.170	--	0.140	2.43	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55100	50200	52200	51900	49100	54400	51800	52900
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	6.00	17.9	17.4	18.3	22.8	51.9	9.60	9.80
	Lead	15	MCL	ND	ND	ND	ND	ND	0.150	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-PORT1304		D2-PORT1308		D2-PORT1404	D2-PORT1608	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				D2-MERC0232 Residence 232 Mercury Street	D2-TW-0007726-24092-N	D2-TW-0007726-24092-3-N	D2-TW-0007728-24092-N	D2-TW-0007728-24092-3-N	D2-TW-0008420-24092-N	D2-TW-0008430-24092-N	D2-TW-0008430-24092-3-N
					2025-01-16	2025-01-22	2025-01-17	2025-01-22	2025-01-17	2025-01-17	2025-03-18
					N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.250	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-PORT1304		D2-PORT1308		D2-PORT1404	D2-PORT1608	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	D2-MERC0232 Residence 232 Mercury Street	D2-TW-0007726-24092-N 2025-01-22 N (Normal)	D2-TW-0007726-24092-3-N 2025-01-22 FD (Field Duplicate)	D2-TW-0007728-24092-N 2025-01-17 N (Normal)	D2-TW-0007728-24092-3-N 2025-01-17 FD (Field Duplicate)	D2-TW-0008420-24092-N 2025-01-17 N (Normal)	D2-TW-0008430-24092-N 2025-03-18 N (Normal)	D2-TW-0008430-24092-3-N 2025-03-18 FD (Field Duplicate)
				ND	ND	ND	0.250	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-PORT1732		D2-PORT1812	D2-SIGN0203C	D2-SIGN0301B	D2-SIGN0302C	D2-SIGN0401A	
				Location ID:	Location Type:	Address:	Residence	Residence	Residence	Residence	Residence
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
				D2-TW-0007685-24092-N	D2-TW-0007685-24092-3-N	D2-TW-0007406-24092-N	D2-TW-0007940-24092-N	D2-TW-0007945-24092-N	D2-TW-0006968-24092-N	D2-TW-0006985-24092-N	D2-TW-0006985-24092-3-N
				2025-01-31	2025-01-31	2025-01-10	2025-03-12	2025-03-20	2025-03-18	2025-03-21	2025-03-21
				N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Field Test (ppb)	Free Chlorine	4000	MCL	540	--	1000	640	670	720	840	--
Field Test (pH)	pH	--	--	7.28	--	7.17	7.08	7.12	7.14	7.14	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	--	0.250	0.250	0.270	0.260	0.230	--
Field Test (degrees Celcius)	Temperature	--	--	24.2	--	24.8	24.3	24.9	25.1	25.2	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0900	--	0.00	0.00	0.220	0.0680	0.550	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	50900	52000	57500	54500	54800	53300	54500	53100
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	24.3	23.8	44.2	12.5	6.30	8.00	15.6	15.4
	Lead	15	MCL	ND	ND	ND	ND	0.170	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-PORT1732		D2-PORT1812	D2-SIGN0203C	D2-SIGN0301B	D2-SIGN0302C	D2-SIGN0401A	
				Location ID:	Location Type:	Address:	Residence	Residence	Residence	Residence	Residence
				D2-TW-0007685-24092-N	D2-TW-0007685-24092-3-N	D2-TW-0007406-24092-N	D2-TW-0007940-24092-N	D2-TW-0007945-24092-N	D2-TW-0006968-24092-N	D2-TW-0006985-24092-N	D2-TW-0006985-24092-3-N
				2025-01-31	2025-01-31	2025-01-10	2025-03-12	2025-03-20	2025-03-18	2025-03-21	2025-03-21
				N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-PORT1732		D2-PORT1812	D2-SIGN0203C	D2-SIGN0301B	D2-SIGN0302C	D2-SIGN0401A	
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:
				D2-TW-0007685-24092-N	D2-TW-0007685-24092-3-N	D2-TW-0007406-24092-N	D2-TW-0007940-24092-N	D2-TW-0007945-24092-N	D2-TW-0006968-24092-N	D2-TW-0006985-24092-N	D2-TW-0006985-24092-3-N
				2025-01-31	2025-01-31	2025-01-10	2025-03-12	2025-03-20	2025-03-18	2025-03-21	2025-03-21
				N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	0.300	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.300	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-SIGN0403A	D2-SIGN0502A	D2-SIGN0502H	D2-SIGN0504I	D2-SIGN1002	D2-TINK1732	D2-TINK1805	
				Location Type:	Residence							
				Address:	403A Signer Boulevard	502A Signer Boulevard	502H Signer Boulevard	504I Signer Boulevard	1002 Signer Boulevard	1732 Tinker Avenue	1805 Tinker Avenue	
				Field Sample ID:	D2-TW-0007646-24092-N	D2-TW-0008443-24092-N	D2-TW-0008448-24092-N	D2-TW-0008457-24092-N	D2-TW-0007926-24092-N	D2-TW-0007324-24092-N	D2-TW-0007335-24092-N	D2-TW-0007335-24092-3-N
				Sample Date:	2025-03-12	2025-03-18	2025-01-16	2025-03-21	2025-02-27	2025-01-10	2025-03-24	2025-03-24
				Sample Type:	N (Normal)	FD (Field Duplicate)						
Field Test (ppb)	Free Chlorine	4000	MCL		610	480	800	900	540	640	530	--
Field Test (pH)	pH	--	--		7.07	7.33	7.13	7.23	7.10	7.41	7.29	--
Field Test (ms/cm)	Specific Conductivity	--	--		0.260	0.240	0.260	0.250	0.290	0.240	0.250	--
Field Test (degrees Celcius)	Temperature	--	--		24.9	23.3	24.2	24.4	22.4	25.8	22.5	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.310	0.0150	0.00	0.100	0.170	0.370	0.00	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		55400	55900	53100	53400	52300	57900	52900	53300
	Total Organic Carbon	--	--		ND							
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND							
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND							
	Petroleum Hydrocarbons (as Oil)	--	--		ND							
	Petroleum Hydrocarbons, Total	--	--		ND							
Metals (ppb)	Copper	1300	MCL		31.5	81.3	22.0	27.6	10.7	96.8	34.7	34.8
	Lead	15	MCL		ND	ND	ND	0.170	ND	ND	ND	ND
	Mercury	2	MCL		ND							
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND							
	2-Methylnaphthalene	--	--		ND							
	Acenaphthylene	--	--		ND							
	Anthracene	--	--		ND							
	Benzo(a)pyrene	0.2	MCL		ND							
	Benzo(b)fluoranthene	--	--		ND							
	Benzo(g,h,i)perylene	--	--		ND							
Benzo(k)fluoranthene	--	--		ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-SIGN0403A	D2-SIGN0502A	D2-SIGN0502H	D2-SIGN0504I	D2-SIGN1002	D2-TINK1732	D2-TINK1805	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	403A Signer Boulevard	502A Signer Boulevard	502H Signer Boulevard	504I Signer Boulevard	1002 Signer Boulevard	1732 Tinker Avenue	1805 Tinker Avenue	
				Sample Date:	2025-03-12	2025-03-18	2025-01-16	2025-03-21	2025-02-27	2025-01-10	2025-03-24	2025-03-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)				
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-SIGN0403A	D2-SIGN0502A	D2-SIGN0502H	D2-SIGN0504I	D2-SIGN1002	D2-TINK1732	D2-TINK1805	
				Location Type:	Residence							
				Address:	403A Signer Boulevard	502A Signer Boulevard	502H Signer Boulevard	504I Signer Boulevard	1002 Signer Boulevard	1732 Tinker Avenue	1805 Tinker Avenue	
				Field Sample ID:	D2-TW-0007646-24092-N	D2-TW-0008443-24092-N	D2-TW-0008448-24092-N	D2-TW-0008457-24092-N	D2-TW-0007926-24092-N	D2-TW-0007324-24092-N	D2-TW-0007335-24092-N	D2-TW-0007335-24092-3-N
				Sample Date:	2025-03-12	2025-03-18	2025-01-16	2025-03-21	2025-02-27	2025-01-10	2025-03-24	2025-03-24
				Sample Type:	N (Normal)	FD (Field Duplicate)						
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-TINK1807	D2-TINK1810	D2-TINK1908		D2-WORT0105
				Location Type:	Residence	Residence	Residence		Residence
				Address:	1807 Tinker Avenue	1810 Tinker Avenue	1908 Tinker Avenue		105 Worthington Avenue
				Field Sample ID:	D2-TW-0007337-24092-N	D2-TW-0007339-24092-N	D2-TW-0007699-24092-N	D2-TW-0007699-24092-3-N	D2-TW-0007395-24092-N
				Sample Date:	2025-03-20	2025-03-18	2025-03-21	2025-03-21	2025-01-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL		400	390	870	--	630
Field Test (pH)	pH	--	--		7.13	7.31	7.37	--	7.36
Field Test (ms/cm)	Specific Conductivity	--	--		0.260	0.290	0.260	--	0.260
Field Test (degrees Celcius)	Temperature	--	--		24.2	24.6	29.0	--	21.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.0370	0.450	0.320	--	0.350
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		52400	54400	54200	53700	51000
	Total Organic Carbon	--	--		ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--		ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL		63.8	42.5	38.2	38.0	35.1
	Lead	15	MCL		ND	0.140	ND	ND	0.130
	Mercury	2	MCL		ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--		ND	ND	ND	ND	ND
	Acenaphthylene	--	--		ND	ND	ND	ND	ND
	Anthracene	--	--		ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--		ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--		ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--		ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

				Location ID:	D2-TINK1807	D2-TINK1810	D2-TINK1908		D2-WORT0105
				Location Type:	Residence	Residence	Residence		Residence
				Address:	1807 Tinker Avenue	1810 Tinker Avenue	1908 Tinker Avenue		105 Worthington Avenue
				Field Sample ID:	D2-TW-0007337-24092-N	D2-TW-0007339-24092-N	D2-TW-0007699-24092-N	D2-TW-0007699-24092-3-N	D2-TW-0007395-24092-N
				Sample Date:	2025-03-20	2025-03-18	2025-03-21	2025-03-21	2025-01-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D2**

		<b>Location ID:</b>	D2-TINK1807	D2-TINK1810	D2-TINK1908		D2-WORT0105	
		<b>Location Type:</b>	Residence	Residence	Residence		Residence	
		<b>Address:</b>	1807 Tinker Avenue	1810 Tinker Avenue	1908 Tinker Avenue		105 Worthington Avenue	
		<b>Field Sample ID:</b>	D2-TW-0007337-24092-N	D2-TW-0007339-24092-N	D2-TW-0007699-24092-N	D2-TW-0007699-24092-3-N	D2-TW-0007395-24092-N	
		<b>Sample Date:</b>	2025-03-20	2025-03-18	2025-03-21	2025-03-21	2025-01-22	
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>					
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				D2-BLDG641H								
				School								
				HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25001-N-1	D2-TW-0015498-25001-N-2	D2-TW-0015498-25001-N-3	D2-TW-0015498-25001-N-4	D2-TW-0015498-25001-N-5	D2-TW-0015498-25001-3-N-1	D2-TW-0015498-25032-N-1	D2-TW-0015498-25032-N-2
				Sample Date:	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-02-07	2025-02-07
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	150	510	200	470	880	--	610	680	
Field Test (pH)	pH	--	--	7.26	7.25	7.33	7.36	7.28	--	7.29	7.29	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.270	0.260	0.250	0.260	--	0.280	0.280	
Field Test (degrees Celcius)	Temperature	--	--	25.5	28.0	24.5	23.2	26.3	--	23.9	25.4	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.710	0.530	1.03	--	0.470	0.700	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56600	57500	56100	58000	58900	57000	53600	52100	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	162	29.0	45.2	197	17.6	160	130	20.1	
	Lead	15	MCL	0.210	ND	0.170	ND	ND	0.200	0.300	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				D2-BLDG641H								
				School								
				HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25001-N-1	D2-TW-0015498-25001-N-2	D2-TW-0015498-25001-N-3	D2-TW-0015498-25001-N-4	D2-TW-0015498-25001-N-5	D2-TW-0015498-25001-3-N-1	D2-TW-0015498-25032-N-1	D2-TW-0015498-25032-N-2
				Sample Date:	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-02-07	2025-02-07
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.310	ND	0.970	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				Location ID: D2-BLDG641H Location Type: School Address: HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25001-N-1	D2-TW-0015498-25001-N-2	D2-TW-0015498-25001-N-3	D2-TW-0015498-25001-N-4	D2-TW-0015498-25001-N-5	D2-TW-0015498-25001-3-N-1	D2-TW-0015498-25032-N-1	D2-TW-0015498-25032-N-2
				Sample Date:	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-01-03	2025-02-07	2025-02-07
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.450	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.310	ND	1.42	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				Location ID: D2-BLDG641H Location Type: School Address: HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25032-N-3	D2-TW-0015498-25032-N-4	D2-TW-0015498-25032-N-5	D2-TW-0015498-25032-3-N-4	D2-TW-0015498-25032-3-N-5	D2-TW-0015498-25060-N-2	D2-TW-0015498-25060-N-4	D2-TW-0015498-25060-3-N-4
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	570	1190	510	--	--	800	630	--	
Field Test (pH)	pH	--	--	7.30	7.22	7.24	--	--	7.13	7.15	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.300	0.260	--	--	0.260	0.250	--	
Field Test (degrees Celcius)	Temperature	--	--	24.1	27.3	27.3	--	--	26.5	24.0	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.640	1.80	2.53	--	--	0.990	0.0550	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53900	51900	52100	52100	52800	53300	55000	54000	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	89.8	121	221	121	223	13.6	167	168	
	Lead	15	MCL	0.270	ND	ND	ND	ND	0.130	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				Location ID: D2-BLDG641H Location Type: School Address: HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25032-N-3	D2-TW-0015498-25032-N-4	D2-TW-0015498-25032-N-5	D2-TW-0015498-25032-3-N-4	D2-TW-0015498-25032-3-N-5	D2-TW-0015498-25060-N-2	D2-TW-0015498-25060-N-4	D2-TW-0015498-25060-3-N-4
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.480	ND	0.340	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				Location ID: D2-BLDG641H Location Type: School Address: HICKAM ELEM - P1, Building 641H								
				Field Sample ID:	D2-TW-0015498-25032-N-3	D2-TW-0015498-25032-N-4	D2-TW-0015498-25032-N-5	D2-TW-0015498-25032-3-N-4	D2-TW-0015498-25032-3-N-5	D2-TW-0015498-25060-N-2	D2-TW-0015498-25060-N-4	D2-TW-0015498-25060-3-N-4
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.380	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.860	ND	0.340	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

		Location ID: D2-BLDG641H				
		Location Type: School				
		Address: HICKAM ELEM - P1, Building 641H				
		Field Sample ID:		D2-TW-0015498-25060-N-1	D2-TW-0015498-25060-N-3	D2-TW-0015498-25060-N-5
		Sample Date:		2025-03-11	2025-03-11	2025-03-11
		Sample Type:		N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	40.0	770	240
Field Test (pH)	pH	--	--	7.18	7.22	7.21
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.260
Field Test (degrees Celcius)	Temperature	--	--	26.1	24.5	26.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.590	0.800	0.260
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52900	54300	55000
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	155	29.5	221
	Lead	15	MCL	0.290	0.160	ND
	Mercury	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

		Location ID: D2-BLDG641H				
		Location Type: School				
		Address: HICKAM ELEM - P1, Building 641H				
		Field Sample ID:	D2-TW-0015498-25060-N-1	D2-TW-0015498-25060-N-3	D2-TW-0015498-25060-N-5	
		Sample Date:	2025-03-11	2025-03-11	2025-03-11	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D2**

				Location ID: D2-BLDG641H			
				Location Type: School			
				Address: HICKAM ELEM - P1, Building 641H			
				Field Sample ID:	D2-TW-0015498-25060-N-1	D2-TW-0015498-25060-N-3	D2-TW-0015498-25060-N-5
				Sample Date:	2025-03-11	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D2**

				Location ID: D2-BLDG623H Location Type: Child Development Center Address: Building 623H,HARBOR CHILD DEVELOPMENT CENTER							
				Field Sample ID:	D2-TW-0015492-25001-N-1	D2-TW-0015492-25001-N-2	D2-TW-0015492-25032-N-1	D2-TW-0015492-25032-N-2	D2-TW-0015492-25032-3-N-1	D2-TW-0015492-25060-N-1	D2-TW-0015492-25060-N-2
				Sample Date:	2025-01-06	2025-01-06	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	640	730	810	950	--	830	600	
Field Test (pH)	pH	--	--	7.07	7.20	7.30	7.27	--	7.27	7.27	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.250	0.280	0.270	--	0.290	0.290	
Field Test (degrees Celcius)	Temperature	--	--	25.2	24.5	23.5	22.7	--	24.4	23.7	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.0590	0.340	0.160	--	0.00	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	59000	58700	51700	52500	54000	53600	54300	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	24.0	10.4	14.9	10.1	14.7	15.8	9.80	
	Lead	15	MCL	ND	ND	ND	ND	ND	0.210	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D2**

				Location ID: D2-BLDG623H Location Type: Child Development Center Address: Building 623H,HARBOR CHILD DEVELOPMENT CENTER							
				Field Sample ID:	D2-TW-0015492-25001-N-1	D2-TW-0015492-25001-N-2	D2-TW-0015492-25032-N-1	D2-TW-0015492-25032-N-2	D2-TW-0015492-25032-3-N-1	D2-TW-0015492-25060-N-1	D2-TW-0015492-25060-N-2
				Sample Date:	2025-01-06	2025-01-06	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D2**

				Location ID: D2-BLDG623H Location Type: Child Development Center Address: Building 623H,HARBOR CHILD DEVELOPMENT CENTER							
				Field Sample ID:	D2-TW-0015492-25001-N-1	D2-TW-0015492-25001-N-2	D2-TW-0015492-25032-N-1	D2-TW-0015492-25032-N-2	D2-TW-0015492-25032-3-N-1	D2-TW-0015492-25060-N-1	D2-TW-0015492-25060-N-2
				Sample Date:	2025-01-06	2025-01-06	2025-02-07	2025-02-07	2025-02-07	2025-03-11	2025-03-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.270	ND	ND	ND	ND
	Bromoform	--	--	ND	0.550	ND	1.00	ND	ND	0.450	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.460	ND	0.790	ND	ND	0.360	ND
	Total Trihalomethanes	80	MCL	ND	1.01	ND	2.06	ND	ND	0.810	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		Location ID: D2-HYD0079			D2-HYD0498			D2-HYD1599			
		Location Type: Hydrant			Hydrant			Hydrant			
		Address: FH:519			FH:509			FH:429			
		Field Sample ID: D2-DL-0017714-25001	D2-DL-0017714-25032	D2-DL-0017714-25060	D2-DL-0017715-25001	D2-DL-0017715-25032	D2-DL-0017715-25060	D2-DL-0000574-25001	D2-DL-0000574-25032		
		-N	-N	-N	-N	-N	-N	-N	-N		
		Sample Date: 2025-01-09	2025-02-26	2025-03-04	2025-01-09	2025-02-25	2025-03-04	2025-01-09	2025-02-25		
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	670	740	680	690	860	560	500	340
Field Test (pH)	pH	--	--	7.24	7.25	7.26	7.05	7.25	7.25	7.31	7.38
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.270	0.260	0.260	0.230	0.250	0.230	0.270
Field Test (degrees Celcius)	Temperature	--	--	27.5	28.2	27.4	23.9	22.7	23.1	28.7	26.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.850	0.620	0.860	0.00	0.400	0.340	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58100	53200	52000	59000	54500	53900	58100	51400
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		Location ID: D2-HYD0079			D2-HYD0498			D2-HYD1599		
		Location Type: Hydrant			Hydrant			Hydrant		
		Address: FH:519			FH:509			FH:429		
		Field Sample ID: D2-DL-0017714-25001	D2-DL-0017714-25032	D2-DL-0017714-25060	D2-DL-0017715-25001	D2-DL-0017715-25032	D2-DL-0017715-25060	D2-DL-0000574-25001	D2-DL-0000574-25032	
		-N	-N	-N	-N	-N	-N	-N	-N	
		Sample Date: 2025-01-09	2025-02-26	2025-03-04	2025-01-09	2025-02-25	2025-03-04	2025-01-09	2025-02-25	
		Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	ND	--	ND	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	ND	--	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	0.330	
	Bromoform	--	--	ND	ND	ND	ND	ND	1.10	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	0.270	ND	ND	ND	0.890	
	Total Trihalomethanes	80	MCL	ND	0.270	ND	ND	ND	2.32	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-HYD1599			D2-HYD1610			D2-HYD236	
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date
				Location ID: D2-HYD1599			Location ID: D2-HYD1610			Location ID: D2-HYD236	
				Location Type: Hydrant			Location Type: Hydrant			Location Type: Hydrant	
				Address: FH:429			Address: FH:074			Address: FH:236 (Possibly HYD263, HYD-2154)	
				D2-DL-0000574-25032 -3-N	D2-DL-0000574-25060 -N	D2-DL-0000574-25060 -3-N	D2-DL-0000583-25001 -N	D2-DL-0000583-25032 -N	D2-DL-0000583-25060 -N	D2-DL-0017711-25001 -N	D2-DL-0017711-25032 -N
				2025-02-25	2025-03-04	2025-03-04	2025-01-09	2025-02-25	2025-03-17	2025-01-09	2025-02-25
				FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	--	460	--	590	350	560	660	510
Field Test (pH)	pH	--	--	--	7.29	--	7.35	7.29	7.27	7.32	7.27
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.260	--	0.270	0.230	0.290	0.270	0.230
Field Test (degrees Celcius)	Temperature	--	--	--	26.7	--	24.6	23.4	24.3	24.8	25.1
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.870	--	1.00	0.120	0.890	1.29	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52900	54100	53900	57900	52500	54900	58600	52100
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-HYD1599			D2-HYD1610			D2-HYD236	
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date
				Location ID: D2-HYD1599 Location Type: Hydrant Address: FH:429			Location ID: D2-HYD1610 Location Type: Hydrant Address: FH:074			Location ID: D2-HYD236 Location Type: Hydrant Address: FH:236 (Possibly HYD263, HYD-2154)	
				D2-DL-0000574-25032 -3-N	D2-DL-0000574-25060 -N	D2-DL-0000574-25060 -3-N	D2-DL-0000583-25001 -N	D2-DL-0000583-25032 -N	D2-DL-0000583-25060 -N	D2-DL-0017711-25001 -N	D2-DL-0017711-25032 -N
				2025-02-25	2025-03-04	2025-03-04	2025-01-09	2025-02-25	2025-03-17	2025-01-09	2025-02-25
				FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	--	--	ND	--	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	--	--	ND	--	--	ND	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.400	0.340	0.350	ND	ND	ND	ND	ND
	Bromoform	--	--	1.30	0.890	0.930	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND



**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HYD321				D2-HYD365			
				D2-HYD236	D2-DL-0017709-25060	D2-DL-0017709-25032	D2-DL-0017709-25060	D2-DL-0017717-25001	D2-DL-0017717-25032	D2-DL-0017717-25060	D2-DL-0017717-25060	
				Hydrant FH:236 (Possibly HYD263, HYD-2154)	-N	-3-N						
				Hydrant FH:321	2025-03-17	2025-01-13	2025-02-25	2025-03-17	2025-01-13	2025-02-25	2025-03-21	2025-03-21
				Hydrant FH:365	N (Normal)	FD (Field Duplicate)						
Field Test (ppb)	Free Chlorine	4000	MCL		710	370	40.0	50.0	570	190	1110	--
Field Test (pH)	pH	--	--		7.17	7.79	8.12	7.67	7.18	7.34	7.22	--
Field Test (ms/cm)	Specific Conductivity	--	--		0.250	0.280	0.240	0.270	0.260	0.230	0.300	--
Field Test (degrees Celcius)	Temperature	--	--		23.8	26.0	27.5	27.2	29.2	30.8	29.2	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL		0.00	0.350	0.150	0.580	1.13	0.110	0.370	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--		56000	61900	60500	63300	55200	52800	53000	52700
	Total Organic Carbon	--	--		ND	ND	200	200	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND							
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND							
	Petroleum Hydrocarbons (as Oil)	--	--		ND							
	Petroleum Hydrocarbons, Total	--	--		ND							
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--		ND							
	2-Methylnaphthalene	--	--		ND							
	Acenaphthylene	--	--		ND							
	Anthracene	--	--		ND							
	Benzo(a)pyrene	0.2	MCL		ND							
	Benzo(b)fluoranthene	--	--		ND							
	Benzo(g,h,i)perylene	--	--		ND							
	Benzo(k)fluoranthene	--	--		ND							
	Chrysene	--	--		ND							
	Dibenz(a,h)anthracene	--	--		ND							
	Fluorene	--	--		ND							

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		Location ID: D2-HYD236		Location ID: D2-HYD321				Location ID: D2-HYD365									
		Location Type: Hydrant		Location Type: Hydrant				Location Type: Hydrant									
		Address: FH:236 (Possibly HYD263, HYD-2154)		Address: FH:321				Address: FH:365									
		Field Sample ID: D2-DL-0017711-25060		Field Sample ID: D2-DL-0017709-25001		Field Sample ID: D2-DL-0017709-25032		Field Sample ID: D2-DL-0017709-25060		Field Sample ID: D2-DL-0017717-25001		Field Sample ID: D2-DL-0017717-25032		Field Sample ID: D2-DL-0017717-25060		Field Sample ID: D2-DL-0017717-25060	
		-N		-N		-N		-N		-N		-N		-N		-3-N	
		Sample Date: 2025-03-17		Sample Date: 2025-01-13		Sample Date: 2025-02-25		Sample Date: 2025-03-17		Sample Date: 2025-01-13		Sample Date: 2025-02-25		Sample Date: 2025-03-21		Sample Date: 2025-03-21	
		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level														
Synthetic Organic Compounds (ppb)	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND												
	Naphthalene	--	--	ND	ND												
	Phenanthrene	--	--	ND	ND												
	Pyrene	--	--	ND	ND												
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND												
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	ND	--	--	--	--	--	--	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND												
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	ND	--	--	--	--	--	--	--	--	--
	Benzene	5	MCL	ND	ND												
	Cumene	--	--	ND	ND												
	Ethylbenzene	700	MCL	ND	ND												
	m,p-Xylene	--	--	ND	ND												
	n-Butylbenzene	--	--	ND	ND												
	n-Propylbenzene	--	--	ND	ND												
	o-Xylene	--	--	ND	ND												
	sec-Butylbenzene	--	--	ND	ND												
	tert-Butylbenzene	--	--	ND	ND												
	Toluene	1000	MCL	ND	ND												
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.370	0.270	0.390	0.330	0.470	0.500	0.510	0.510	0.510	0.510	0.510	0.510	0.510
	Bromoform	--	--	ND	12.0	5.20	6.30	4.40	4.30	5.50	5.40	5.40	5.40	5.40	5.40	5.40	5.40
	Chloroform	--	--	ND	ND												

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HYD321				D2-HYD365			
				Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:
				D2-HYD236 Hydrant FH:236 (Possibly HYD263, HYD-2154)	D2-DL-0017711-25060 -N	D2-DL-0017709-25001 -N	D2-DL-0017709-25032 -N	D2-DL-0017709-25060 -N	D2-DL-0017717-25001 -N	D2-DL-0017717-25032 -N	D2-DL-0017717-25060 -N	D2-DL-0017717-25060 -3-N
					2025-03-17 N (Normal)	2025-01-13 N (Normal)	2025-02-25 N (Normal)	2025-03-17 N (Normal)	2025-01-13 N (Normal)	2025-02-25 N (Normal)	2025-03-21 N (Normal)	2025-03-21 FD (Field Duplicate)
Trihalomethanes (ppb)	Dibromochloromethane	--	--	ND	1.40	0.450	0.760	1.30	1.90	2.00	2.00	
	Total Trihalomethanes	80	MCL	ND	13.8	5.92	7.45	6.03	6.67	8.00	7.91	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		D2-HYD420				D2-HYD56					
		Hydrant				Hydrant					
		FH:420				FH:056					
		D2-DL-0017707-25001	D2-DL-0017707-25032	D2-DL-0017707-25060	D2-DL-0017707-25060	D2-DL-0017708-25001	D2-DL-0017708-25032	D2-DL-0017708-25032	D2-DL-0017708-25060		
		-N	-N	-N	-3-N	-N	-N	-3-N	-N		
		2025-01-14	2025-02-25	2025-03-21	2025-03-21	2025-01-13	2025-02-25	2025-02-25	2025-03-21		
		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	630	600	920	--	640	470	--	760
Field Test (pH)	pH	--	--	6.97	7.22	7.20	--	7.31	7.19	--	6.85
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.250	0.270	--	0.250	0.260	--	0.250
Field Test (degrees Celcius)	Temperature	--	--	26.8	24.1	25.9	--	26.1	24.6	--	26.7
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.30	0.430	1.58	--	4.03	1.06	--	0.850
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55700	52900	53700	53700	53800	53200	53500	54000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		D2-HYD420				D2-HYD56			
		Hydrant				Hydrant			
		FH:420				FH:056			
		D2-DL-0017707-25001	D2-DL-0017707-25032	D2-DL-0017707-25060	D2-DL-0017707-25060	D2-DL-0017708-25001	D2-DL-0017708-25032	D2-DL-0017708-25032	D2-DL-0017708-25060
		-N	-N	-N	-3-N	-N	-N	-3-N	-N
		2025-01-14	2025-02-25	2025-03-21	2025-03-21	2025-01-13	2025-02-25	2025-02-25	2025-03-21
		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	--	ND	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.370	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.260	ND	0.280	0.310	ND	ND
	Total Trihalomethanes	80	MCL	0.630	ND	0.280	0.310	ND	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HYD79				D2-HYD84			
				D2-HYD56	D2-DL-0017708-25060	D2-DL-0017712-25001	D2-DL-0017712-25032	D2-DL-0017712-25060	D2-DL-0017713-25001	D2-DL-0017713-25001	D2-DL-0017713-25032	D2-DL-0017713-25060
				Hydrant FH:056	-3-N	-N	-N	-N	-N	-3-N	-N	-N
				Address:								
				Field Sample ID:								
				Sample Date:	2025-03-21	2025-01-13	2025-02-25	2025-03-21	2025-01-14	2025-01-14	2025-02-25	2025-03-21
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	--	110	160	250	540	--	710	660	
Field Test (pH)	pH	--	--	--	7.89	7.84	7.42	7.10	--	7.23	7.35	
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.270	0.270	0.290	0.270	--	0.250	0.250	
Field Test (degrees Celcius)	Temperature	--	--	--	27.0	25.9	26.6	25.0	--	24.9	25.7	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.00	1.40	0.650	0.670	--	1.49	0.500	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54300	63400	59800	56600	51400	53600	51800	53000	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		Location ID: D2-HYD56		D2-HYD79				D2-HYD84			
		Location Type: Hydrant		Hydrant				Hydrant			
		Address: FH:056		FH:079				FH:084			
		Field Sample ID: D2-DL-0017708-25060		D2-DL-0017712-25001	D2-DL-0017712-25032	D2-DL-0017712-25060	D2-DL-0017713-25001	D2-DL-0017713-25001	D2-DL-0017713-25032	D2-DL-0017713-25060	
		-3-N		-N	-N	-N	-N	-3-N	-N	-N	
		Sample Date: 2025-03-21		2025-01-13	2025-02-25	2025-03-21	2025-01-14	2025-01-14	2025-02-25	2025-03-21	
		Sample Type: FD (Field Duplicate)		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	ND	ND	--	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	ND	ND	--	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.850	1.10	0.750	ND	ND	ND	
	Bromoform	--	--	ND	9.60	12.9	7.20	ND	ND	ND	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	3.00	4.30	2.80	ND	ND	ND	
	Total Trihalomethanes	80	MCL	ND	13.5	18.3	10.8	ND	ND	ND	

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		<b>Location ID:</b>	D2-HYD84	
		<b>Location Type:</b>	Hydrant	
		<b>Address:</b>	FH:084	
		<b>Field Sample ID:</b>	D2-DL-0017713-25060 -3-N	
		<b>Sample Date:</b>	2025-03-21	
		<b>Sample Type:</b>	FD (Field Duplicate)	
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53800
	Total Organic Carbon	--	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	--	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND
	2-Methylnaphthalene	--	--	ND
	Acenaphthylene	--	--	ND
	Anthracene	--	--	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Benzo(b)fluoranthene	--	--	ND
	Benzo(g,h,i)perylene	--	--	ND
	Benzo(k)fluoranthene	--	--	ND
	Chrysene	--	--	ND
	Dibenz(a,h)anthracene	--	--	ND
	Fluorene	--	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND
	Naphthalene	--	--	ND
Phenanthrene	--	--	ND	
Pyrene	--	--	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND
	1,3,5-Trimethylbenzene	--	--	ND

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D2**

		<b>Location ID:</b>	D2-HYD84
		<b>Location Type:</b>	Hydrant
		<b>Address:</b>	FH:084
		<b>Field Sample ID:</b>	D2-DL-0017713-25060 -3-N
		<b>Sample Date:</b>	2025-03-21
		<b>Sample Type:</b>	FD (Field Duplicate)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>
Volatile Organic Compounds (ppb)	Benzene	5	MCL
	Cumene	--	--
	Ethylbenzene	700	MCL
	m,p-Xylene	--	--
	n-Butylbenzene	--	--
	n-Propylbenzene	--	--
	o-Xylene	--	--
	sec-Butylbenzene	--	--
	tert-Butylbenzene	--	--
	Toluene	1000	MCL
	Xylenes, Total	10000	MCL
Trihalomethanes (ppb)	Bromodichloromethane	--	--
	Bromoform	--	--
	Chloroform	--	--
	Dibromochloromethane	--	--
	Total Trihalomethanes	80	MCL

**Summary of Chemistry Results**  
**Zone D2**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D2-BLDG554H Medical Building Building 554H,OCCUPATIONAL HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd			D2-BLDG559H Medical Building Building 559H,MEDICAL/DENTAL CLINIC - AIR FORCE, 755 Scott Circle											
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type						
Field Test (ppb)	Free Chlorine	4000	MCL	D2-TW-0015474-25001-N	2025-01-14	N (Normal)	D2-TW-0015474-25032-N	2025-02-25	N (Normal)	D2-TW-0015474-25060-N	2025-03-19	N (Normal)	650	710	610	10.0	150	530
Field Test (pH)	pH	--	--										7.18	7.21	7.18	7.05	7.18	7.22
Field Test (ms/cm)	Specific Conductivity	--	--										0.240	0.260	0.250	0.250	0.250	0.250
Field Test (degrees Celcius)	Temperature	--	--										22.3	23.2	23.5	22.0	21.8	21.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL										0.0210	0.140	0.530	0.390	0.480	0.0740
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--										54400	54500	56300	53300	54000	54700
	Total Organic Carbon	--	--										ND	ND	ND	200	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--										ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--										ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--										ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--										ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL										59.7	43.8	81.0	78.8	68.3	60.7
	Lead	15	MCL										0.190	0.180	0.310	0.170	ND	ND
	Mercury	2	MCL										ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--										ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--										ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--										ND	ND	ND	ND	ND	ND
	Anthracene	--	--										ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL										0.0180	ND	ND	ND	ND	ND

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D2-BLDG554H Location Type: Medical Building Address: Building 554H,OCCUPATIONAL HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd			Location ID: D2-BLDG559H Location Type: Medical Building Address: Building 559H,MEDICAL/DENTAL CLINIC - AIR FORCE, 755 Scott Circle		
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	D2-TW-0015474-25001-N	2025-01-14	N (Normal)	D2-TW-0015476-25001-N	2025-01-14	N (Normal)
	Benzo(g,h,i)perylene	--	--	D2-TW-0015474-25032-N	2025-02-25	N (Normal)	D2-TW-0015476-25032-N	2025-02-25	N (Normal)
	Benzo(k)fluoranthene	--	--	D2-TW-0015474-25060-N	2025-03-19	N (Normal)	D2-TW-0015476-25060-N	2025-03-19	N (Normal)
	Chrysene	--	--						
	Dibenz(a,h)anthracene	--	--						
	Fluorene	--	--						
	Indeno(1,2,3-c,d)pyrene	--	--						
	Naphthalene	--	--						
	Phenanthrene	--	--						
	Pyrene	--	--						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--						
	1,3,5-Trimethylbenzene	--	--						
	Benzene	5	MCL						
	Cumene	--	--						
	Ethylbenzene	700	MCL						
	m,p-Xylene	--	--						
	n-Butylbenzene	--	--						
	n-Propylbenzene	--	--						
o-Xylene	--	--							

**Summary of Chemistry Results**

**Zone D2**

**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

**Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D2**

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D2-BLDG554H Location Type: Medical Building Address: Building 554H, OCCUPATIONAL HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd			Location ID: D2-BLDG559H Location Type: Medical Building Address: Building 559H, MEDICAL/DENTAL CLINIC - AIR FORCE, 755 Scott Circle		
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	D2-TW-0015474-25001-N	2025-01-14	N (Normal)	D2-TW-0015476-25001-N	2025-01-14	N (Normal)
	tert-Butylbenzene	--	--	D2-TW-0015474-25032-N	2025-02-25	N (Normal)	D2-TW-0015476-25032-N	2025-02-25	N (Normal)
	Toluene	1000	MCL	D2-TW-0015474-25060-N	2025-03-19	N (Normal)	D2-TW-0015476-25060-N	2025-03-19	N (Normal)
	Xylenes, Total	10000	MCL						
Trihalomethanes (ppb)	Bromodichloromethane	--	--				0.470	1.30	0.340
	Bromoform	--	--	0.320		0.310	2.00	4.00	0.490
	Chloroform	--	--	ND	ND	ND	0.580	0.880	0.270
	Dibromochloromethane	--	--	ND	ND	ND	0.910	2.20	0.480
	Total Trihalomethanes	80	MCL	0.320	ND	0.310	3.96	8.38	1.58