

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-AUPA0071	D3-AUPA0131	D3-HALE1007		D3-HONO0133	D3-HONO0134		D3-HONO0142	
		Location Type:	Residence	Residence	Residence		Residence	Residence		Residence	
		Address:	71 Aupaka Street	131 Aupaka Street	1007 Halehaka Street		133 Honohono Street	134 Honohono Street		142 Honohono Street	
		Field Sample ID:	D3-TW-0009639-24092-N	D3-TW-0009654-24092-N	D3-TW-0009677-24092-N	D3-TW-0009677-24092-3-N	D3-TW-0009684-24092-N	D3-TW-0009685-24092-N	D3-TW-0009685-24092-3-N	D3-TW-0009692-24092-N	
		Sample Date:	2025-03-23	2025-03-11	2025-03-19	2025-03-19	2025-01-10	2025-03-01	2025-03-01	2025-03-26	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	320	690	810	--	660	1460	--	790
Field Test (pH)	pH	--	--	7.04	7.08	7.25	--	7.29	7.31	--	7.24
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.260	0.240	--	0.260	0.240	--	0.240
Field Test (degrees Celcius)	Temperature	--	--	26.9	23.8	25.6	--	24.9	23.9	--	23.5
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.530	0.260	0.150	--	0.650	0.610	--	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54300	52900	53000	54400	58800	58200	52300	54500
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	28.0	22.2	8.20	8.90	54.8	4.50	4.40	7.50
	Lead	15	MCL	ND	ND	ND	ND	0.430	ND	ND	0.140
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-AUPA0071	D3-AUPA0131	D3-HALE1007		D3-HONO0133	D3-HONO0134		D3-HONO0142
		Location Type:	Residence	Residence	Residence		Residence	Residence		Residence
		Address:	71 Aupaka Street	131 Aupaka Street	1007 Halehaka Street		133 Honohono Street	134 Honohono Street		142 Honohono Street
		Field Sample ID:	D3-TW-0009639-24092-N	D3-TW-0009654-24092-N	D3-TW-0009677-24092-N	D3-TW-0009677-24092-3-N	D3-TW-0009684-24092-N	D3-TW-0009685-24092-N	D3-TW-0009685-24092-3-N	D3-TW-0009692-24092-N
		Sample Date:	2025-03-23	2025-03-11	2025-03-19	2025-03-19	2025-01-10	2025-03-01	2025-03-01	2025-03-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.370	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.390	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-AUPA0071	D3-AUPA0131	D3-HALE1007		D3-HONO0133	D3-HONO0134		D3-HONO0142
				Location Type:	Residence	Residence	Residence		Residence	Residence		Residence
				Address:	71 Aupaka Street	131 Aupaka Street	1007 Halehaka Street		133 Honohono Street	134 Honohono Street		142 Honohono Street
				Field Sample ID:	D3-TW-0009639-24092-N	D3-TW-0009654-24092-N	D3-TW-0009677-24092-N	D3-TW-0009677-24092-3-N	D3-TW-0009684-24092-N	D3-TW-0009685-24092-N	D3-TW-0009685-24092-3-N	D3-TW-0009692-24092-N
				Sample Date:	2025-03-23	2025-03-11	2025-03-19	2025-03-19	2025-01-10	2025-03-01	2025-03-01	2025-03-26
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		0.760	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

				Location ID:	D3-HONO0142	D3-ILIM0137	D3-KIKA0706	D3-KIKA0716	D3-KOKO0121	D3-KOKO0123	D3-KOKO0125	D3-KOKO0141
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	142 Honohono Street	137 Ilima Street	706 Kikanai Loop	716 Kikanai Loop	121 Kokomalei Street	123 Kokomalei Street	125 Kokomalei Street	141 Kokomalei Street
				Field Sample ID:	D3-TW-0009692-24092-3-N	D3-TW-0009722-24092-N	D3-TW-0009727-24092-N	D3-TW-0009733-24331-N	D3-TW-0009779-24092-N	D3-TW-0009781-24092-N	D3-TW-0009783-24092-N	D3-TW-0009795-24092-N
				Sample Date:	2025-03-26	2025-03-19	2025-03-21	2025-02-06	2025-03-10	2025-03-19	2025-01-10	2025-01-16
				Sample Type:	FD (Field Duplicate)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	--	640	880	1170	550	760	830	590	
Field Test (pH)	pH	--	--	--	7.32	7.12	7.23	7.24	7.33	7.27	7.18	
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.250	0.260	0.280	0.240	0.250	0.230	0.230	
Field Test (degrees Celcius)	Temperature	--	--	--	24.4	24.4	24.3	22.8	24.3	25.5	24.4	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.00	2.19	0.510	0.00	0.00	0.490	0.250	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55900	54000	53100	54200	51900	53300	58300	57100	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	7.00	7.20	5.30	5.30	31.6	56.2	37.2	49.8	
	Lead	15	MCL	0.140	ND	ND	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-HONO0142	D3-ILIM0137	D3-KIKA0706	D3-KIKA0716	D3-KOKO0121	D3-KOKO0123	D3-KOKO0125	D3-KOKO0141
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	142 Honohono Street	137 Ilima Street	706 Kikanai Loop	716 Kikanai Loop	121 Kokomalei Street	123 Kokomalei Street	125 Kokomalei Street	141 Kokomalei Street
		Field Sample ID:	D3-TW-0009692-24092-3-N	D3-TW-0009722-24092-N	D3-TW-0009727-24092-N	D3-TW-0009733-24331-N	D3-TW-0009779-24092-N	D3-TW-0009781-24092-N	D3-TW-0009783-24092-N	D3-TW-0009795-24092-N
		Sample Date:	2025-03-26	2025-03-19	2025-03-21	2025-02-06	2025-03-10	2025-03-19	2025-01-10	2025-01-16
		Sample Type:	FD (Field Duplicate)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND	ND	ND	ND	ND	0.360	ND
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND	ND	0.250	ND	0.250	0.300	0.380

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-HONO0142	D3-ILIM0137	D3-KIKA0706	D3-KIKA0716	D3-KOKO0121	D3-KOKO0123	D3-KOKO0125	D3-KOKO0141	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	142 Honohono Street	137 Ilima Street	706 Kikanai Loop	716 Kikanai Loop	121 Kokomalei Street	123 Kokomalei Street	125 Kokomalei Street	141 Kokomalei Street	
		Field Sample ID:	D3-TW-0009692-24092-3-N	D3-TW-0009722-24092-N	D3-TW-0009727-24092-N	D3-TW-0009733-24331-N	D3-TW-0009779-24092-N	D3-TW-0009781-24092-N	D3-TW-0009783-24092-N	D3-TW-0009795-24092-N	
		Sample Date:	2025-03-26	2025-03-19	2025-03-21	2025-02-06	2025-03-10	2025-03-19	2025-01-10	2025-01-16	
		Sample Type:	FD (Field Duplicate)	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	0.250	ND	0.250	0.300	0.740	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-KOKO0175	D3-KOPI0121	D3-KOPI0133		D3-LEHU0304	D3-LEHU0308	D3-LILI0162	D3-MAKA1024	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	175 Kokomalei Street	121 Kopiko Street	133 Kopiko Street		304 Lehua Lane	308 Lehua Lane	162 Liliwai Street	1024 Makalika Loop	
		Field Sample ID:	D3-TW-0009809-24092-N	D3-TW-0009820-24092-N	D3-TW-0009826-24092-N	D3-TW-0009826-24092-3-N	D3-TW-0009832-24092-N	D3-TW-0011193-24092-N	D3-TW-0011222-24092-N	D3-TW-0011241-24092-N	
		Sample Date:	2025-01-23	2025-03-07	2025-01-10	2025-01-10	2025-03-18	2025-03-17	2025-03-13	2025-03-10	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	580	550	730	--	760	760	730	430
Field Test (pH)	pH	--	--	7.15	7.34	7.31	--	7.32	7.14	7.20	6.99
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.260	--	0.240	0.250	0.250	0.440
Field Test (degrees Celcius)	Temperature	--	--	20.7	24.4	21.3	--	23.5	23.9	22.5	25.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	--	0.0220	0.00	0.00	0.730
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53600	51700	56300	59600	53200	55700	54200	54000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	96.4	58.5	79.6	81.4	7.90	12.0	9.60	7.60
	Lead	15	MCL	0.130	ND	0.190	0.190	0.160	0.170	0.130	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-KOKO0175	D3-KOPI0121	D3-KOPI0133		D3-LEHU0304	D3-LEHU0308	D3-LILI0162	D3-MAKA1024
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	175 Kokomalei Street	121 Kopiko Street	133 Kopiko Street		304 Lehua Lane	308 Lehua Lane	162 Liliwai Street	1024 Makalika Loop
		Field Sample ID:	D3-TW-0009809-24092-N	D3-TW-0009820-24092-N	D3-TW-0009826-24092-N	D3-TW-0009826-24092-3-N	D3-TW-0009832-24092-N	D3-TW-0011193-24092-N	D3-TW-0011222-24092-N	D3-TW-0011241-24092-N
		Sample Date:	2025-01-23	2025-03-07	2025-01-10	2025-01-10	2025-03-18	2025-03-17	2025-03-13	2025-03-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.370	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.290	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-KOKO0175	D3-KOPI0121	D3-KOPI0133		D3-LEHU0304	D3-LEHU0308	D3-LILI0162	D3-MAKA1024	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	175 Kokomalei Street	121 Kopiko Street	133 Kopiko Street		304 Lehua Lane	308 Lehua Lane	162 Liliwai Street	1024 Makalika Loop	
		Field Sample ID:	D3-TW-0009809-24092-N	D3-TW-0009820-24092-N	D3-TW-0009826-24092-N	D3-TW-0009826-24092-3-N	D3-TW-0009832-24092-N	D3-TW-0011193-24092-N	D3-TW-0011222-24092-N	D3-TW-0011241-24092-N	
		Sample Date:	2025-01-23	2025-03-07	2025-01-10	2025-01-10	2025-03-18	2025-03-17	2025-03-13	2025-03-10	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	0.660	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-MELI0214	D3-MELI0242	D3-MELI0301	D3-MELI0341	D3-MELI0348		D3-NANU0881	D3-NANU0883	
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	214 Melia Street	242 Melia Street	301 Melia Street	341 Melia Street	348 Melia Street		881 Nanu Street	883 Nanu Street	
		Field Sample ID:	D3-TW-0011261-24092-N	D3-TW-0011283-24092-N	D3-TW-0011290-24092-N	D3-TW-0011302-24092-N	D3-TW-0011309-24092-N	D3-TW-0011309-24092-3-N	D3-TW-0011318-24092-N	D3-TW-0011320-24092-N	
		Sample Date:	2025-03-10	2025-03-10	2025-01-17	2025-03-18	2025-03-19	2025-03-19	2025-03-10	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	760	730	660	620	790	--	760	690
Field Test (pH)	pH	--	--	7.32	7.27	7.16	7.58	7.27	--	7.33	7.23
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.240	0.270	0.270	0.260	--	0.250	0.260
Field Test (degrees Celcius)	Temperature	--	--	25.2	24.1	25.2	22.9	25.0	--	25.5	22.7
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.0240	0.850	0.290	--	0.00	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52400	52900	52600	52800	55000	55300	52300	52700
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	13.1	4.70	5.60	5.00	6.60	5.60	6.40	5.30
	Lead	15	MCL	0.230	0.160	ND	0.280	ND	ND	0.160	0.160
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-MELI0214	D3-MELI0242	D3-MELI0301	D3-MELI0341	D3-MELI0348		D3-NANU0881	D3-NANU0883
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
					214 Melia Street	242 Melia Street	301 Melia Street	341 Melia Street	348 Melia Street		881 Nanu Street	883 Nanu Street
					D3-TW-0011261-24092-N	D3-TW-0011283-24092-N	D3-TW-0011290-24092-N	D3-TW-0011302-24092-N	D3-TW-0011309-24092-N	D3-TW-0011309-24092-3-N	D3-TW-0011318-24092-N	D3-TW-0011320-24092-N
					2025-03-10	2025-03-10	2025-01-17	2025-03-18	2025-03-19	2025-03-19	2025-03-10	2025-03-07
					N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	0.860	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.500	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-MELI0214	D3-MELI0242	D3-MELI0301	D3-MELI0341	D3-MELI0348		D3-NANU0881	D3-NANU0883
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	214 Melia Street	242 Melia Street	301 Melia Street	341 Melia Street	348 Melia Street		881 Nanu Street	883 Nanu Street
		Field Sample ID:	D3-TW-0011261-24092-N	D3-TW-0011283-24092-N	D3-TW-0011290-24092-N	D3-TW-0011302-24092-N	D3-TW-0011309-24092-N	D3-TW-0011309-24092-3-N	D3-TW-0011318-24092-N	D3-TW-0011320-24092-N
		Sample Date:	2025-03-10	2025-03-10	2025-01-17	2025-03-18	2025-03-19	2025-03-19	2025-03-10	2025-03-07
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	1.36	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-NANU0893		D3-NANU0935	D3-NEHE1008	D3-NEHE1012	D3-NEHE1018	D3-OHAN0101	D3-OHAN0131	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	893 Nanu Street		935 Nanu Street	1008 Nehe Street	1012 Nehe Street	1018 Nehe Street	101 Ohana Nui Circle	131 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0011327-24092-N	D3-TW-0011327-24092-3-N	D3-TW-0011350-24092-N	D3-TW-0011369-24092-N	D3-TW-0011370-24092-N	D3-TW-0011373-24092-N	D3-TW-0011382-24092-N	D3-TW-0010198-24092-N	
		Sample Date:	2025-03-19	2025-03-19	2025-03-07	2025-03-19	2025-03-13	2025-03-19	2025-03-10	2025-03-13	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	870	--	620	590	790	740	1040	780
Field Test (pH)	pH	--	--	7.40	--	7.21	7.23	7.25	7.21	7.29	7.36
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	--	0.300	0.260	0.250	0.250	0.250	0.300
Field Test (degrees Celcius)	Temperature	--	--	23.1	--	25.2	25.7	23.2	23.4	27.1	24.8
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00200	--	0.0210	0.280	0.00	0.00300	0.00	0.680
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53300	52800	52400	56300	55200	52600	53200	54000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	4.80	4.90	4.60	9.30	7.60	5.50	6.40	6.50
	Lead	15	MCL	0.140	0.140	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-NANU0893		D3-NANU0935	D3-NEHE1008	D3-NEHE1012	D3-NEHE1018	D3-OHAN0101	D3-OHAN0131
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	893 Nanu Street		935 Nanu Street	1008 Nehe Street	1012 Nehe Street	1018 Nehe Street	101 Ohana Nui Circle	131 Ohana Nui Circle
		Field Sample ID:	D3-TW-0011327-24092-N	D3-TW-0011327-24092-3-N	D3-TW-0011350-24092-N	D3-TW-0011369-24092-N	D3-TW-0011370-24092-N	D3-TW-0011373-24092-N	D3-TW-0011382-24092-N	D3-TW-0010198-24092-N
		Sample Date:	2025-03-19	2025-03-19	2025-03-07	2025-03-19	2025-03-13	2025-03-19	2025-03-10	2025-03-13
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)					
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-NANU0893	D3-NANU0935	D3-NEHE1008	D3-NEHE1012	D3-NEHE1018	D3-OHAN0101	D3-OHAN0131		
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence		
		Address:	893 Nanu Street		935 Nanu Street	1008 Nehe Street	1012 Nehe Street	1018 Nehe Street	101 Ohana Nui Circle	131 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0011327-24092-N	D3-TW-0011327-24092-3-N	D3-TW-0011350-24092-N	D3-TW-0011369-24092-N	D3-TW-0011370-24092-N	D3-TW-0011373-24092-N	D3-TW-0011382-24092-N	D3-TW-0010198-24092-N	
		Sample Date:	2025-03-19	2025-03-19	2025-03-07	2025-03-19	2025-03-13	2025-03-19	2025-03-10	2025-03-13	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0151	D3-OHAN0153	D3-OHAN0202	D3-OHAN0332	D3-OHAN0343	D3-OHAN0352		D3-OHAN0354	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence	
		Address:	151 Ohana Nui Circle	153 Ohana Nui Circle	202 Ohana Nui Circle	332 Ohana Nui Circle	343 Ohana Nui Circle	352 Ohana Nui Circle		354 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0010206-24092-N	D3-TW-0010208-24092-N	D3-TW-0010222-24092-N	D3-TW-0010243-24092-N	D3-TW-0010248-24092-N	D3-TW-0010251-24092-N	D3-TW-0010251-24092-3-N	D3-TW-0010253-24092-N	
		Sample Date:	2025-03-19	2025-03-11	2025-03-11	2025-03-23	2025-03-19	2025-03-11	2025-03-11	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	760	780	840	610	740	780	--	650
Field Test (pH)	pH	--	--	7.33	7.16	7.36	7.19	7.32	7.29	--	7.16
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.270	0.240	0.260	0.270	0.240	--	0.290
Field Test (degrees Celcius)	Temperature	--	--	23.7	24.7	25.6	24.3	24.9	22.7	--	23.9
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0980	0.240	0.470	0.180	0.00	0.0210	--	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55300	56300	53400	53100	54500	53900	54700	54600
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	8.00	7.30	5.40	6.90	8.90	7.20	7.30	7.90
	Lead	15	MCL	0.180	0.180	0.160	ND	0.210	0.140	0.140	0.140
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0151	D3-OHAN0153	D3-OHAN0202	D3-OHAN0332	D3-OHAN0343	D3-OHAN0352		D3-OHAN0354
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	151 Ohana Nui Circle	153 Ohana Nui Circle	202 Ohana Nui Circle	332 Ohana Nui Circle	343 Ohana Nui Circle	352 Ohana Nui Circle		354 Ohana Nui Circle
		Field Sample ID:	D3-TW-0010206-24092-N	D3-TW-0010208-24092-N	D3-TW-0010222-24092-N	D3-TW-0010243-24092-N	D3-TW-0010248-24092-N	D3-TW-0010251-24092-N	D3-TW-0010251-24092-3-N	D3-TW-0010253-24092-N
		Sample Date:	2025-03-19	2025-03-11	2025-03-11	2025-03-23	2025-03-19	2025-03-11	2025-03-11	2025-03-07
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0151	D3-OHAN0153	D3-OHAN0202	D3-OHAN0332	D3-OHAN0343	D3-OHAN0352		D3-OHAN0354
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		151 Ohana Nui Circle	153 Ohana Nui Circle	202 Ohana Nui Circle	332 Ohana Nui Circle	343 Ohana Nui Circle	352 Ohana Nui Circle		354 Ohana Nui Circle
					D3-TW-0010206-24092-N	D3-TW-0010208-24092-N	D3-TW-0010222-24092-N	D3-TW-0010243-24092-N	D3-TW-0010248-24092-N	D3-TW-0010251-24092-N	D3-TW-0010251-24092-3-N	D3-TW-0010253-24092-N
					2025-03-19	2025-03-11	2025-03-11	2025-03-23	2025-03-19	2025-03-11	2025-03-11	2025-03-07
					N (Normal)	FD (Field Duplicate)	N (Normal)					
					ND	ND						

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

				Location ID:	D3-OHAN0432	D3-OHAN0438	D3-OHAN0451	D3-OHAN0463	D3-OHAN0511	D3-OHAN0538	D3-OHAN0546	D3-OHAN0612
				Location Type:	Residence							
				Address:	432 Ohana Nui Circle	438 Ohana Nui Circle	451 Ohana Nui Circle	463 Ohana Nui Circle	511 Ohana Nui Circle	538 Ohana Nui Circle	546 Ohana Nui Circle	612 Ohana Nui Circle
				Field Sample ID:	D3-TW-0010271-24092-N	D3-TW-0010275-24092-N	D3-TW-0010276-24092-N	D3-TW-0010279-24092-N	D3-TW-0010286-24092-N	D3-TW-0010303-24092-N	D3-TW-0010308-24092-N	D3-TW-0009447-24092-N
				Sample Date:	2025-03-10	2025-03-07	2025-03-19	2025-03-11	2025-01-09	2025-03-21	2025-03-20	2025-03-19
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	700	540	680	720	770	1300	810	650	
Field Test (pH)	pH	--	--	7.25	7.30	7.34	7.30	7.12	7.13	7.26	7.30	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.250	0.280	0.250	0.260	0.240	0.250	
Field Test (degrees Celcius)	Temperature	--	--	25.2	24.8	26.1	24.7	25.9	25.4	26.0	25.2	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	0.950	0.190	0.700	1.92	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51800	55200	53700	51300	61000	53000	56900	53800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	210	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	10.4	5.60	6.10	6.60	7.40	6.60	5.90	6.00	
	Lead	15	MCL	ND	0.160	0.190	0.150	ND	0.180	0.140	0.140	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0432	D3-OHAN0438	D3-OHAN0451	D3-OHAN0463	D3-OHAN0511	D3-OHAN0538	D3-OHAN0546	D3-OHAN0612
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	432 Ohana Nui Circle	438 Ohana Nui Circle	451 Ohana Nui Circle	463 Ohana Nui Circle	511 Ohana Nui Circle	538 Ohana Nui Circle	546 Ohana Nui Circle	612 Ohana Nui Circle
		Field Sample ID:	D3-TW-0010271-24092-N	D3-TW-0010275-24092-N	D3-TW-0010276-24092-N	D3-TW-0010279-24092-N	D3-TW-0010286-24092-N	D3-TW-0010303-24092-N	D3-TW-0010308-24092-N	D3-TW-0009447-24092-N
		Sample Date:	2025-03-10	2025-03-07	2025-03-19	2025-03-11	2025-01-09	2025-03-21	2025-03-20	2025-03-19
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND						
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND						

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

				Location ID:	D3-OHAN0432	D3-OHAN0438	D3-OHAN0451	D3-OHAN0463	D3-OHAN0511	D3-OHAN0538	D3-OHAN0546	D3-OHAN0612
				Location Type:	Residence							
				Address:	432 Ohana Nui Circle	438 Ohana Nui Circle	451 Ohana Nui Circle	463 Ohana Nui Circle	511 Ohana Nui Circle	538 Ohana Nui Circle	546 Ohana Nui Circle	612 Ohana Nui Circle
				Field Sample ID:	D3-TW-0010271-24092-N	D3-TW-0010275-24092-N	D3-TW-0010276-24092-N	D3-TW-0010279-24092-N	D3-TW-0010286-24092-N	D3-TW-0010303-24092-N	D3-TW-0010308-24092-N	D3-TW-0009447-24092-N
				Sample Date:	2025-03-10	2025-03-07	2025-03-19	2025-03-11	2025-01-09	2025-03-21	2025-03-20	2025-03-19
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0612	D3-OHAN0715	D3-OHAN0723	D3-OHAN0733		D3-OHAN0747	D3-OHAN0754	D3-OHAN0755	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence	
		Address:	612 Ohana Nui Circle	715 Ohana Nui Circle	723 Ohana Nui Circle	733 Ohana Nui Circle		747 Ohana Nui Circle	754 Ohana Nui Circle	755 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0009447-24092-3-N	D3-TW-0009458-24092-N	D3-TW-0009461-24092-N	D3-TW-0009465-24092-N	D3-TW-0009465-24092-3-N	D3-TW-0009471-24092-N	D3-TW-0009475-24092-N	D3-TW-0009476-24092-N	
		Sample Date:	2025-03-19	2025-03-19	2025-03-23	2025-01-17	2025-01-17	2025-01-17	2025-03-18	2025-03-19	
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	--	750	750	730	--	800	550	690
Field Test (pH)	pH	--	--	--	7.33	7.11	6.99	--	7.12	7.23	7.20
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.250	0.270	0.270	--	0.280	0.270	0.260
Field Test (degrees Celcius)	Temperature	--	--	--	25.4	25.7	26.5	--	23.5	24.9	24.7
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.00	0.690	1.10	--	0.0320	2.95	0.450
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54500	57100	55000	49700	52400	52100	56900	55000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	5.40	6.90	4.80	5.50	5.50	4.20	5.30	15.1
	Lead	15	MCL	0.130	0.310	ND	ND	ND	ND	0.300	0.240
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0612	D3-OHAN0715	D3-OHAN0723	D3-OHAN0733		D3-OHAN0747	D3-OHAN0754	D3-OHAN0755
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	612 Ohana Nui Circle	715 Ohana Nui Circle	723 Ohana Nui Circle	733 Ohana Nui Circle		747 Ohana Nui Circle	754 Ohana Nui Circle	755 Ohana Nui Circle
		Field Sample ID:	D3-TW-0009447-24092-3-N	D3-TW-0009458-24092-N	D3-TW-0009461-24092-N	D3-TW-0009465-24092-N	D3-TW-0009465-24092-3-N	D3-TW-0009471-24092-N	D3-TW-0009475-24092-N	D3-TW-0009476-24092-N
		Sample Date:	2025-03-19	2025-03-19	2025-03-23	2025-01-17	2025-01-17	2025-01-17	2025-03-18	2025-03-19
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.260	0.250	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0612	D3-OHAN0715	D3-OHAN0723	D3-OHAN0733		D3-OHAN0747	D3-OHAN0754	D3-OHAN0755
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	612 Ohana Nui Circle	715 Ohana Nui Circle	723 Ohana Nui Circle	733 Ohana Nui Circle		747 Ohana Nui Circle	754 Ohana Nui Circle	755 Ohana Nui Circle
				Field Sample ID:	D3-TW-0009447-24092-3-N	D3-TW-0009458-24092-N	D3-TW-0009461-24092-N	D3-TW-0009465-24092-N	D3-TW-0009465-24092-3-N	D3-TW-0009471-24092-N	D3-TW-0009475-24092-N	D3-TW-0009476-24092-N
				Sample Date:	2025-03-19	2025-03-19	2025-03-23	2025-01-17	2025-01-17	2025-01-17	2025-03-18	2025-03-19
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	0.260	0.250	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D3-OHAN0761		D3-OHAN0767	D3-OHAN0771	D3-OHAN0775	D3-OHAN0783	D3-OHAN0794	
				Residence	Residence	Residence	Residence	Residence	Residence	Residence	
				761 Ohana Nui Circle		767 Ohana Nui Circle	771 Ohana Nui Circle	775 Ohana Nui Circle	783 Ohana Nui Circle	794 Ohana Nui Circle	
				D3-TW-0009480-24092-N	D3-TW-0009480-24092-3-N	D3-TW-0009486-24092-N	D3-TW-0009488-24092-N	D3-TW-0009490-24092-N	D3-TW-0009493-24092-N	D3-TW-0009499-24092-N	D3-TW-0009499-24092-3-N
				2025-01-28	2025-01-28	2025-01-28	2025-03-11	2025-03-18	2025-03-17	2025-03-26	2025-03-26
				N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Field Test (ppb)	Free Chlorine	4000	MCL	670	--	700	700	730	640	560	--
Field Test (pH)	pH	--	--	7.16	--	7.33	7.18	7.28	7.28	7.05	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	--	0.240	0.250	0.260	0.280	0.280	--
Field Test (degrees Celcius)	Temperature	--	--	23.4	--	23.0	21.9	24.5	26.7	25.7	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.610	--	0.130	0.410	0.220	1.10	0.950	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53000	51300	52500	54500	57100	54200	55600	56000
	Total Organic Carbon	--	--	ND	ND	ND	ND	230	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	10.8	11.1	5.40	5.40	4.90	4.30	9.60	6.10
	Lead	15	MCL	ND	ND	ND	ND	0.200	ND	0.220	0.320
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0761		D3-OHAN0767	D3-OHAN0771	D3-OHAN0775	D3-OHAN0783	D3-OHAN0794	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
		Address:	761 Ohana Nui Circle		767 Ohana Nui Circle	771 Ohana Nui Circle	775 Ohana Nui Circle	783 Ohana Nui Circle	794 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0009480-24092-N	D3-TW-0009480-24092-3-N	D3-TW-0009486-24092-N	D3-TW-0009488-24092-N	D3-TW-0009490-24092-N	D3-TW-0009493-24092-N	D3-TW-0009499-24092-N	D3-TW-0009499-24092-3-N
		Sample Date:	2025-01-28	2025-01-28	2025-01-28	2025-03-11	2025-03-18	2025-03-17	2025-03-26	2025-03-26
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D3-OHAN0761		D3-OHAN0767	D3-OHAN0771	D3-OHAN0775	D3-OHAN0783	D3-OHAN0794			
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND		

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0803	D3-OHAN0824	D3-OHAN0857	D3-OHAN0858		D3-OHAN0862	D3-OHAN0871	D3-OHAN0877	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence	
		Address:	803 Ohana Nui Circle	824 Ohana Nui Circle	857 Ohana Nui Circle	858 Ohana Nui Circle		862 Ohana Nui Circle	871 Ohana Nui Circle	877 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0009505-24092-N	D3-TW-0009519-24092-N	D3-TW-0009538-24092-N	D3-TW-0009539-24092-N	D3-TW-0009539-24092-3-N	D3-TW-0009541-24092-N	D3-TW-0009548-24092-N	D3-TW-0009551-24092-N	
		Sample Date:	2025-03-18	2025-02-14	2025-03-19	2025-01-17	2025-01-17	2025-01-21	2025-03-12	2025-03-18	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	800	860	840	750	--	800	770	700
Field Test (pH)	pH	--	--	7.12	7.25	7.13	7.09	--	7.21	7.06	7.29
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.260	0.260	0.280	--	0.310	0.260	0.270
Field Test (degrees Celcius)	Temperature	--	--	21.9	24.6	23.9	23.1	--	22.0	24.5	25.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0320	0.00	0.900	0.0730	--	0.0320	0.500	0.180
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53900	50300	54000	50700	51800	52400	54500	57300
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	7.00	5.10	5.70	4.80	4.80	5.60	4.60	4.80
	Lead	15	MCL	0.150	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	0.0510	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0803	D3-OHAN0824	D3-OHAN0857	D3-OHAN0858		D3-OHAN0862	D3-OHAN0871	D3-OHAN0877
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	803 Ohana Nui Circle	824 Ohana Nui Circle	857 Ohana Nui Circle	858 Ohana Nui Circle		862 Ohana Nui Circle	871 Ohana Nui Circle	877 Ohana Nui Circle
		Field Sample ID:	D3-TW-0009505-24092-N	D3-TW-0009519-24092-N	D3-TW-0009538-24092-N	D3-TW-0009539-24092-N	D3-TW-0009539-24092-3-N	D3-TW-0009541-24092-N	D3-TW-0009548-24092-N	D3-TW-0009551-24092-N
		Sample Date:	2025-03-18	2025-02-14	2025-03-19	2025-01-17	2025-01-17	2025-01-21	2025-03-12	2025-03-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.310	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.320	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0803	D3-OHAN0824	D3-OHAN0857	D3-OHAN0858		D3-OHAN0862	D3-OHAN0871	D3-OHAN0877
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	803 Ohana Nui Circle	824 Ohana Nui Circle	857 Ohana Nui Circle	858 Ohana Nui Circle		862 Ohana Nui Circle	871 Ohana Nui Circle	877 Ohana Nui Circle
				Field Sample ID:	D3-TW-0009505-24092-N	D3-TW-0009519-24092-N	D3-TW-0009538-24092-N	D3-TW-0009539-24092-N	D3-TW-0009539-24092-3-N	D3-TW-0009541-24092-N	D3-TW-0009548-24092-N	D3-TW-0009551-24092-N
				Sample Date:	2025-03-18	2025-02-14	2025-03-19	2025-01-17	2025-01-17	2025-01-21	2025-03-12	2025-03-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		0.630	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0915		D3-OHAN0921		D3-OHAN0941	D3-OHAN0944	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				D3-OHAN0913 Residence 913 Ohana Nui Circle	D3-OHAN0915 Residence 915 Ohana Nui Circle		D3-OHAN0921 Residence 921 Ohana Nui Circle		D3-OHAN0941 Residence 941 Ohana Nui Circle	D3-OHAN0944 Residence 944 Ohana Nui Circle	
				D3-TW-0009627-24092-N	D3-TW-0009628-24092-N	D3-TW-0009628-24092-3-N	D3-TW-0009630-24092-N	D3-TW-0009630-24092-3-N	D3-TW-0010003-24092-N	D3-TW-0010006-24092-N	D3-TW-0010006-24092-3-N
				2025-03-11	2025-03-18	2025-03-18	2025-01-28	2025-01-28	2025-03-20	2025-03-28	2025-03-28
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Field Test (ppb)	Free Chlorine	4000	MCL	730	700	--	710	--	790	770	--
Field Test (pH)	pH	--	--	7.15	7.27	--	7.32	--	7.27	7.22	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.240	--	0.240	--	0.240	0.240	--
Field Test (degrees Celcius)	Temperature	--	--	24.5	23.9	--	23.4	--	27.4	24.3	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.840	0.0140	--	0.180	--	0.630	0.0530	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53000	52800	56400	51200	51200	52800	54400	54400
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	6.60	4.60	4.30	3.80	3.50	7.80	6.50	6.30
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0915		D3-OHAN0921		D3-OHAN0941	D3-OHAN0944	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location Type:	Address:	Field Sample ID:
				D3-OHAN0913 Residence 913 Ohana Nui Circle	D3-OHAN0915 Residence 915 Ohana Nui Circle		D3-OHAN0921 Residence 921 Ohana Nui Circle		D3-OHAN0941 Residence 941 Ohana Nui Circle	D3-OHAN0944 Residence 944 Ohana Nui Circle	
				D3-TW-0009627-24092-N	D3-TW-0009628-24092-N	D3-TW-0009628-24092-3-N	D3-TW-0009630-24092-N	D3-TW-0009630-24092-3-N	D3-TW-0010003-24092-N	D3-TW-0010006-24092-N	D3-TW-0010006-24092-3-N
				2025-03-11	2025-03-18	2025-03-18	2025-01-28	2025-01-28	2025-03-20	2025-03-28	2025-03-28
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN0915		D3-OHAN0921		D3-OHAN0941	D3-OHAN0944		
				Location Type:	Residence		Residence		Residence	Residence		
				Address:	915 Ohana Nui Circle		921 Ohana Nui Circle		941 Ohana Nui Circle	944 Ohana Nui Circle		
				Field Sample ID:	D3-TW-0009628-24092-N	D3-TW-0009628-24092-N	D3-TW-0009628-24092-3-N	D3-TW-0009630-24092-N	D3-TW-0009630-24092-3-N	D3-TW-0010003-24092-N	D3-TW-0010006-24092-N	D3-TW-0010006-24092-3-N
				Sample Date:	2025-03-11	2025-03-18	2025-03-18	2025-01-28	2025-01-28	2025-03-20	2025-03-28	2025-03-28
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	D3-OHAN0913 Residence 913 Ohana Nui Circle	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0945	D3-OHAN1006	D3-OHAN1025	D3-OHAN1027	D3-OHAN1041		D3-OHAN1044	D3-OHAN1063	
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	945 Ohana Nui Circle	1006 Ohana Nui Circle	1025 Ohana Nui Circle	1027 Ohana Nui Circle	1041 Ohana Nui Circle		1044 Ohana Nui Circle	1063 Ohana Nui Circle	
		Field Sample ID:	D3-TW-0010007-24092-N	D3-TW-0010044-24092-N	D3-TW-0010049-24092-N	D3-TW-0010050-24092-N	D3-TW-0010055-24092-N	D3-TW-0010055-24092-3-N	D3-TW-0010058-24092-N	D3-TW-0009561-24092-N	
		Sample Date:	2025-03-11	2025-03-17	2025-03-10	2025-03-10	2025-03-11	2025-03-11	2025-03-18	2025-03-10	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	880	670	740	780	680	--	800	410
Field Test (pH)	pH	--	--	7.33	7.17	7.22	7.26	7.10	--	7.29	7.10
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.250	0.250	0.250	0.230	--	0.270	0.440
Field Test (degrees Celcius)	Temperature	--	--	26.8	25.1	24.2	25.9	23.2	--	23.6	25.0
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0460	0.0110	1.25	0.820	0.320	--	0.650	0.730
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54500	54400	52800	52700	53200	54800	54400	53800
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	5.40	7.00	5.70	5.80	5.10	4.90	5.30	4.80
	Lead	15	MCL	0.200	0.290	ND	0.330	0.130	0.130	0.240	0.180
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0945	D3-OHAN1006	D3-OHAN1025	D3-OHAN1027	D3-OHAN1041		D3-OHAN1044	D3-OHAN1063
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	945 Ohana Nui Circle	1006 Ohana Nui Circle	1025 Ohana Nui Circle	1027 Ohana Nui Circle	1041 Ohana Nui Circle		1044 Ohana Nui Circle	1063 Ohana Nui Circle
		Field Sample ID:	D3-TW-0010007-24092-N	D3-TW-0010044-24092-N	D3-TW-0010049-24092-N	D3-TW-0010050-24092-N	D3-TW-0010055-24092-N	D3-TW-0010055-24092-3-N	D3-TW-0010058-24092-N	D3-TW-0009561-24092-N
		Sample Date:	2025-03-11	2025-03-17	2025-03-10	2025-03-10	2025-03-11	2025-03-11	2025-03-18	2025-03-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN0945	D3-OHAN1006	D3-OHAN1025	D3-OHAN1027	D3-OHAN1041		D3-OHAN1044	D3-OHAN1063
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	945 Ohana Nui Circle	1006 Ohana Nui Circle	1025 Ohana Nui Circle	1027 Ohana Nui Circle	1041 Ohana Nui Circle		1044 Ohana Nui Circle	1063 Ohana Nui Circle
		Field Sample ID:	D3-TW-0010007-24092-N	D3-TW-0010044-24092-N	D3-TW-0010049-24092-N	D3-TW-0010050-24092-N	D3-TW-0010055-24092-N	D3-TW-0010055-24092-3-N	D3-TW-0010058-24092-N	D3-TW-0009561-24092-N
		Sample Date:	2025-03-11	2025-03-17	2025-03-10	2025-03-10	2025-03-11	2025-03-11	2025-03-18	2025-03-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN1068	D3-OKIK0302	D3-OKIK0304	D3-OKIK0341	D3-PAKA0401	D3-PAKA0418	D3-PILO0163	D3-PILO0171	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	1068 Ohana Nui Circle	302 Okika Street	304 Okika Street	341 Okika Street	401 Pakalana Street	418 Pakalana Street	163 Pilokea Court	171 Pilokea Court	
		Field Sample ID:	D3-TW-0009566-24092-N	D3-TW-0009568-24092-N	D3-TW-0009570-24092-N	D3-TW-0009587-24092-N	D3-TW-0010320-24092-N	D3-TW-0010335-24092-N	D3-TW-0010339-24092-N	D3-TW-0010344-24092-N	
		Sample Date:	2025-03-11	2025-03-12	2025-01-10	2025-01-10	2025-03-13	2025-01-10	2025-03-01	2025-01-10	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	750	660	740	740	650	890	900	770
Field Test (pH)	pH	--	--	7.29	7.28	7.33	7.32	7.38	7.14	7.35	7.38
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.240	0.260	0.260	0.300	0.250	0.250	0.240
Field Test (degrees Celcius)	Temperature	--	--	24.1	23.8	24.8	24.4	23.6	23.7	23.6	23.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.330	0.00190	0.00	0.00	1.52	0.00110	0.00	0.270
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52100	56400	56700	56900	55500	57300	51800	57500
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	9.20	5.80	7.00	4.80	13.5	11.0	29.9	34.7
	Lead	15	MCL	0.190	ND	0.180	ND	0.180	ND	ND	ND
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
	Benzo(k)fluoranthene	--	--	ND	ND						
Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-OHAN1068	D3-OKIK0302	D3-OKIK0304	D3-OKIK0341	D3-PAKA0401	D3-PAKA0418	D3-PILO0163	D3-PILO0171
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1068 Ohana Nui Circle	302 Okika Street	304 Okika Street	341 Okika Street	401 Pakalana Street	418 Pakalana Street	163 Pilokea Court	171 Pilokea Court
		Field Sample ID:	D3-TW-0009566-24092-N	D3-TW-0009568-24092-N	D3-TW-0009570-24092-N	D3-TW-0009587-24092-N	D3-TW-0010320-24092-N	D3-TW-0010335-24092-N	D3-TW-0010339-24092-N	D3-TW-0010344-24092-N
		Sample Date:	2025-03-11	2025-03-12	2025-01-10	2025-01-10	2025-03-13	2025-01-10	2025-03-01	2025-01-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	0.440	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.900	ND	0.440
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND	ND	ND	ND	1.10	ND	0.420

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

				Location ID:	D3-OHAN1068	D3-OKIK0302	D3-OKIK0304	D3-OKIK0341	D3-PAKA0401	D3-PAKA0418	D3-PILO0163	D3-PILO0171
				Location Type:	Residence							
				Address:	1068 Ohana Nui Circle	302 Okika Street	304 Okika Street	341 Okika Street	401 Pakalana Street	418 Pakalana Street	163 Pilokea Court	171 Pilokea Court
				Field Sample ID:	D3-TW-0009566-24092-N	D3-TW-0009568-24092-N	D3-TW-0009570-24092-N	D3-TW-0009587-24092-N	D3-TW-0010320-24092-N	D3-TW-0010335-24092-N	D3-TW-0010339-24092-N	D3-TW-0010344-24092-N
				Sample Date:	2025-03-11	2025-03-12	2025-01-10	2025-01-10	2025-03-13	2025-01-10	2025-03-01	2025-01-10
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	2.44	ND	0.860	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-PILO0187	D3-PUAK0278	D3-PUAK1038	D3-PUAP0202	D3-PUAP0209	D3-PUUL0114	D3-WELA0254	D3-WELA0271	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	187 Pilokea Court	278 Puakauhi Court	1038 Puakala Street	202 Puapilo Court	209 Puapilo Court	114 Puuloa Circle	254 Wela Loop	271 Wela Loop	
		Field Sample ID:	D3-TW-0010353-24092-N	D3-TW-0010362-24092-N	D3-TW-0010389-24092-N	D3-TW-0010390-24092-N	D3-TW-0010596-24092-N	D3-TW-0010618-24092-N	D3-TW-0010627-24092-N	D3-TW-0010640-24092-N	
		Sample Date:	2025-03-11	2025-03-19	2025-01-16	2025-03-13	2025-03-11	2025-03-21	2025-03-17	2025-03-18	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	770	730	540	640	700	740	420	730
Field Test (pH)	pH	--	--	7.05	7.20	7.21	7.35	7.36	7.00	7.30	7.09
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.250	0.270	0.290	0.240	0.270	0.280	0.260
Field Test (degrees Celcius)	Temperature	--	--	23.6	23.4	22.6	23.8	24.3	27.5	23.4	23.6
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.140	0.00	0.110	0.220	0.220	0.470	0.380	0.00220
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53200	54500	52800	53300	55000	52500	53300	55100
	Total Organic Carbon	--	--	ND	ND						
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND						
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND						
	Petroleum Hydrocarbons, Total	--	--	ND	ND						
Metals (ppb)	Copper	1300	MCL	58.6	34.7	7.70	40.6	22.5	31.2	8.70	10.4
	Lead	15	MCL	ND	ND	ND	0.150	ND	ND	ND	0.210
	Mercury	2	MCL	ND	ND						
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND						
	2-Methylnaphthalene	--	--	ND	ND						
	Acenaphthylene	--	--	ND	ND						
	Anthracene	--	--	ND	ND						
	Benzo(a)pyrene	0.2	MCL	ND	ND						
	Benzo(b)fluoranthene	--	--	ND	ND						
	Benzo(g,h,i)perylene	--	--	ND	ND						
	Benzo(k)fluoranthene	--	--	ND	ND						
	Chrysene	--	--	ND	ND						

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

		Location ID:	D3-PILO0187	D3-PUAK0278	D3-PUAK1038	D3-PUAP0202	D3-PUAP0209	D3-PUUL0114	D3-WELA0254	D3-WELA0271
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	187 Pilokea Court	278 Puakauhi Court	1038 Puakala Street	202 Puapilo Court	209 Puapilo Court	114 Puuloa Circle	254 Wela Loop	271 Wela Loop
		Field Sample ID:	D3-TW-0010353-24092-N	D3-TW-0010362-24092-N	D3-TW-0010389-24092-N	D3-TW-0010390-24092-N	D3-TW-0010596-24092-N	D3-TW-0010618-24092-N	D3-TW-0010627-24092-N	D3-TW-0010640-24092-N
		Sample Date:	2025-03-11	2025-03-19	2025-01-16	2025-03-13	2025-03-11	2025-03-21	2025-03-17	2025-03-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND						
	Fluorene	--	--	ND						
	Indeno(1,2,3-c,d)pyrene	--	--	ND						
	Naphthalene	--	--	ND						
	Phenanthrene	--	--	ND						
	Pyrene	--	--	ND						
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND						
	1,3,5-Trimethylbenzene	--	--	ND						
	Benzene	5	MCL	ND						
	Cumene	--	--	ND						
	Ethylbenzene	700	MCL	ND						
	m,p-Xylene	--	--	ND						
	n-Butylbenzene	--	--	ND						
	n-Propylbenzene	--	--	ND						
	o-Xylene	--	--	ND						
	sec-Butylbenzene	--	--	ND						
	tert-Butylbenzene	--	--	ND						
	Toluene	1000	MCL	ND						
	Xylenes, Total	10000	MCL	ND						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND						
	Bromoform	--	--	ND						
	Chloroform	--	--	ND						
	Dibromochloromethane	--	--	ND						

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

				Location ID:	D3-PILO0187	D3-PUAK0278	D3-PUAK1038	D3-PUAP0202	D3-PUAP0209	D3-PUUL0114	D3-WELA0254	D3-WELA0271
				Location Type:	Residence							
				Address:	187 Pilokea Court	278 Puakauhi Court	1038 Puakala Street	202 Puapilo Court	209 Puapilo Court	114 Puuloa Circle	254 Wela Loop	271 Wela Loop
				Field Sample ID:	D3-TW-0010353-24092-N	D3-TW-0010362-24092-N	D3-TW-0010389-24092-N	D3-TW-0010390-24092-N	D3-TW-0010596-24092-N	D3-TW-0010618-24092-N	D3-TW-0010627-24092-N	D3-TW-0010640-24092-N
				Sample Date:	2025-03-11	2025-03-19	2025-01-16	2025-03-13	2025-03-11	2025-03-21	2025-03-17	2025-03-18
				Sample Type:	N (Normal)							
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D3-WELA0281		Location ID: D3-WELA0287	
				Location Type:	Address:	Location Type:	Address:
				Residence	281 Wela Loop	Residence	287 Wela Loop
				Field Sample ID: D3-TW-0010644-24092-N		Field Sample ID: D3-TW-0010650-24092-N	Field Sample ID: D3-TW-0010650-24092-3-N
				Sample Date: 2025-03-10		Sample Date: 2025-03-18	Sample Date: 2025-03-18
				Sample Type: N (Normal)		Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)
Field Test (ppb)	Free Chlorine	4000	MCL	610	740	--	
Field Test (pH)	pH	--	--	7.22	7.12	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.430	0.250	--	
Field Test (degrees Celcius)	Temperature	--	--	27.4	23.4	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.450	0.0470	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53400	54200	54300	
	Total Organic Carbon	--	--	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	11.0	7.10	7.00	
	Lead	15	MCL	0.150	0.140	0.140	
	Mercury	2	MCL	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-WELA0287	
				Location Type:	Residence	Residence
				Address:	287 Wela Loop	
				Field Sample ID:	D3-TW-0010644-24092-N	D3-TW-0010650-24092-N
				Sample Date:	2025-03-10	2025-03-18
				Sample Type:	N (Normal)	N (Normal)
						D3-TW-0010650-24092-3-N
						FD (Field Duplicate)
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	ND	ND	ND
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-WELA0287	
				D3-WELA0281	D3-TW-0010650-24092-N	D3-TW-0010650-24092-3-N
				Residence	Residence	
				281 Wela Loop	287 Wela Loop	
				D3-TW-0010644-24092-N	D3-TW-0010650-24092-N	D3-TW-0010650-24092-3-N
				Sample Date: 2025-03-10	2025-03-18	2025-03-18
				Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0001								
				School								
				Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25001-N-1	D3-TW-0017506-25001-N-2	D3-TW-0017506-25001-N-3	D3-TW-0017506-25001-N-4	D3-TW-0017506-25001-N-5	D3-TW-0017506-25032-N-1	D3-TW-0017506-25032-N-2	D3-TW-0017506-25032-N-3
				Sample Date:	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-02-14	2025-02-14	2025-02-14
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	500	300	620	680	1010	500	860	890	
Field Test (pH)	pH	--	--	7.34	7.32	7.38	7.08	7.24	7.32	7.37	7.43	
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.280	0.280	0.250	0.250	0.260	0.260	0.260	
Field Test (degrees Celcius)	Temperature	--	--	22.3	22.1	23.6	25.9	27.0	23.1	22.8	24.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	0.730	0.00	0.00	0.00	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	57300	58000	59300	58300	58800	52300	52500	51800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	63.9	59.0	43.8	24.6	12.6	61.5	96.4	67.1	
	Lead	15	MCL	ND	0.140	0.180	0.130	ND	ND	0.130	0.260	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0001 Location Type: School Address: Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25001-N-1	D3-TW-0017506-25001-N-2	D3-TW-0017506-25001-N-3	D3-TW-0017506-25001-N-4	D3-TW-0017506-25001-N-5	D3-TW-0017506-25032-N-1	D3-TW-0017506-25032-N-2	D3-TW-0017506-25032-N-3
				Sample Date:	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-02-14	2025-02-14	2025-02-14
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0001								
				School								
				Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25001-N-1	D3-TW-0017506-25001-N-2	D3-TW-0017506-25001-N-3	D3-TW-0017506-25001-N-4	D3-TW-0017506-25001-N-5	D3-TW-0017506-25032-N-1	D3-TW-0017506-25032-N-2	D3-TW-0017506-25032-N-3
				Sample Date:	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-01-09	2025-02-14	2025-02-14	2025-02-14
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	0.250	ND	0.270	
	Bromoform	--	--	ND	0.430	ND	ND	0.510	0.600	0.590	0.710	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.270	0.380	0.290	0.300	0.420	0.520	0.490	0.580	
	Total Trihalomethanes	80	MCL	0.270	0.810	0.290	0.300	0.930	1.37	1.08	1.56	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0001								
				School								
				Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25032-N-4	D3-TW-0017506-25032-N-5	D3-TW-0017506-25060-N-1	D3-TW-0017506-25060-N-2	D3-TW-0017506-25060-N-3	D3-TW-0017506-25060-N-4	D3-TW-0017506-25060-N-5	D3-TW-0017506-25060-3-N-4
				Sample Date:	2025-02-14	2025-02-14	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	FD (Field Duplicate)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	800	1150	300	310	350	610	630	--	
Field Test (pH)	pH	--	--	7.51	7.40	7.16	7.34	7.42	7.29	7.26	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	0.290	0.290	0.300	0.310	0.310	--	
Field Test (degrees Celcius)	Temperature	--	--	23.8	23.4	22.6	22.5	23.2	26.0	26.4	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52600	51400	52200	54000	51400	52700	53600	54200	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	37.4	9.20	58.5	70.5	45.2	30.4	15.2	19.3	
	Lead	15	MCL	0.200	ND	0.250	ND	ND	0.130	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0001								
				School								
				Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25032-N-4	D3-TW-0017506-25032-N-5	D3-TW-0017506-25060-N-1	D3-TW-0017506-25060-N-2	D3-TW-0017506-25060-N-3	D3-TW-0017506-25060-N-4	D3-TW-0017506-25060-N-5	D3-TW-0017506-25060-3-N-4
				Sample Date:	2025-02-14	2025-02-14	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	FD (Field Duplicate)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0001								
				School								
				Assets School, 1 Ohana Nui Way, Building 1								
				Field Sample ID:	D3-TW-0017506-25032-N-4	D3-TW-0017506-25032-N-5	D3-TW-0017506-25060-N-1	D3-TW-0017506-25060-N-2	D3-TW-0017506-25060-N-3	D3-TW-0017506-25060-N-4	D3-TW-0017506-25060-N-5	D3-TW-0017506-25060-3-N-4
				Sample Date:	2025-02-14	2025-02-14	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	FD (Field Duplicate)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.280	0.250	ND						
	Bromoform	--	--	1.20	0.690	0.440	0.580	0.680	0.560	0.480	0.630	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.780	0.560	0.380	0.450	0.550	0.490	0.420	0.530	
	Total Trihalomethanes	80	MCL	2.26	1.50	0.820	1.03	1.23	1.05	0.900	1.16	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0520 Location Type: School Address: Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25001-N-1	D3-TW-0017507-25001-N-2	D3-TW-0017507-25001-N-3	D3-TW-0017507-25001-N-4	D3-TW-0017507-25001-N-5	D3-TW-0017507-25032-N-1	D3-TW-0017507-25032-N-3	D3-TW-0017507-25032-N-4
				Sample Date:	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-02-07	2025-02-07	2025-02-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	950	610	120	110	40.0	400	460	340	
Field Test (pH)	pH	--	--	7.22	7.25	7.06	7.18	7.12	7.33	7.30	7.34	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.240	0.250	0.250	0.280	0.250	0.250	0.250	
Field Test (degrees Celcius)	Temperature	--	--	24.8	24.7	23.7	24.4	23.7	24.7	22.0	23.0	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0590	0.0890	0.0250	0.0560	0.00	0.00	0.190	0.350	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58000	58800	52900	57300	59600	52200	50900	52200	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	60.2	54.1	51.2	136	201	110	40.0	174	
	Lead	15	MCL	ND	ND	0.220	ND	0.170	0.170	0.190	0.160	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0520								
				School								
				Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25001-N-1	D3-TW-0017507-25001-N-2	D3-TW-0017507-25001-N-3	D3-TW-0017507-25001-N-4	D3-TW-0017507-25001-N-5	D3-TW-0017507-25032-N-1	D3-TW-0017507-25032-N-3	D3-TW-0017507-25032-N-4
				Sample Date:	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-02-07	2025-02-07	2025-02-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0520								
				School								
				Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25001-N-1	D3-TW-0017507-25001-N-2	D3-TW-0017507-25001-N-3	D3-TW-0017507-25001-N-4	D3-TW-0017507-25001-N-5	D3-TW-0017507-25032-N-1	D3-TW-0017507-25032-N-3	D3-TW-0017507-25032-N-4
				Sample Date:	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-02-07	2025-02-07	2025-02-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.320	ND	1.20	1.20	0.950	0.450	0.370	0.450	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.300	0.310	0.650	0.540	0.530	0.400	0.330	0.400	
	Total Trihalomethanes	80	MCL	0.620	0.310	1.85	1.74	1.48	0.850	0.700	0.850	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0520 Location Type: School Address: Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25032-N-2	D3-TW-0017507-25032-N-5	D3-TW-0017507-25032-3-N-3	D3-TW-0017507-25060-N-1	D3-TW-0017507-25060-N-3	D3-TW-0017507-25060-N-4	D3-TW-0017507-25060-3-N-1	D3-TW-0017507-25060-3-N-3
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-03-06	2025-03-06	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	210	90.0	--	420	540	60.0	--	--	--
Field Test (pH)	pH	--	--	7.32	7.32	--	7.25	7.34	7.27	--	--	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	--	0.270	0.270	0.270	--	--	--
Field Test (degrees Celcius)	Temperature	--	--	23.6	22.0	--	26.5	24.4	25.0	--	--	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	--	0.140	0.00660	0.160	--	--	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52400	53800	53100	52800	54600	53900	55500	53000	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	63.5	161	38.3	76.5	30.9	195	76.7	28.9	
	Lead	15	MCL	0.150	0.190	0.200	0.290	0.160	0.140	0.280	0.160	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0520 Location Type: School Address: Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25032-N-2	D3-TW-0017507-25032-N-5	D3-TW-0017507-25032-3-N-3	D3-TW-0017507-25060-N-1	D3-TW-0017507-25060-N-3	D3-TW-0017507-25060-N-4	D3-TW-0017507-25060-3-N-1	D3-TW-0017507-25060-3-N-3
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-03-06	2025-03-06	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0520								
				School								
				Chester Nimitz Elementary, 520 Main St, Building 520								
				Field Sample ID:	D3-TW-0017507-25032-N-2	D3-TW-0017507-25032-N-5	D3-TW-0017507-25032-3-N-3	D3-TW-0017507-25060-N-1	D3-TW-0017507-25060-N-3	D3-TW-0017507-25060-N-4	D3-TW-0017507-25060-3-N-1	D3-TW-0017507-25060-3-N-3
				Sample Date:	2025-02-07	2025-02-07	2025-02-07	2025-03-06	2025-03-06	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.300	0.350	0.400	0.460	0.360	0.530	0.670	0.340	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.270	0.290	0.320	0.380	0.320	0.460	0.520	0.310	
	Total Trihalomethanes	80	MCL	0.570	0.640	0.720	0.840	0.680	0.990	1.19	0.650	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID:		D3-BLDG0520		D3-BLDG0830					
		Location Type:		School		School					
		Address:		Chester Nimitz Elementary, 520 Main St, Building 520		Holy Family Catholic Academy, 830 Main St, Building 830					
		Field Sample ID:		D3-TW-0017507-25060-N-2	D3-TW-0017507-25060-N-5	D3-TW-0017509-25001-N-1	D3-TW-0017509-25001-N-2	D3-TW-0017509-25001-N-3	D3-TW-0017509-25001-N-4	D3-TW-0017509-25001-N-5	D3-TW-0017509-25032-N-2
		Sample Date:		2025-03-06	2025-03-06	2025-01-08	2025-01-08	2025-01-08	2025-01-08	2025-01-08	2025-02-05
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	320	130	660	650	210	670	580	340
Field Test (pH)	pH	--	--	7.28	7.30	7.05	7.11	7.46	7.29	7.31	7.25
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.270	0.260	0.250	0.230	0.230	0.230	0.240
Field Test (degrees Celcius)	Temperature	--	--	25.2	23.8	24.3	24.1	26.8	25.6	25.1	23.5
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0220	0.150	0.110	0.00	0.00670	0.0110	0.210	0.160
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52400	52000	58900	60600	58800	59800	56800	52000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	68.4	247	8.70	8.10	41.8	39.9	34.4	8.80
	Lead	15	MCL	0.150	0.190	ND	ND	ND	ND	0.150	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D3-BLDG0520		D3-BLDG0830						
				Location ID:	Location Type:	School						
				Chester Nimitz Elementary, 520 Main St, Building 520		Holy Family Catholic Academy, 830 Main St, Building 830						
				Field Sample ID:	Sample Date:	Sample Type:	D3-TW-0017509-25001-N-1	D3-TW-0017509-25001-N-2	D3-TW-0017509-25001-N-3	D3-TW-0017509-25001-N-4	D3-TW-0017509-25001-N-5	D3-TW-0017509-25032-N-2
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	D3-TW-0017507-25060-N-2	2025-03-06	N (Normal)	2025-01-08	2025-01-08	2025-01-08	2025-01-08	2025-01-08	2025-02-05
	Chrysene	--	--	D3-TW-0017507-25060-N-5	2025-03-06	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
	Dibenz(a,h)anthracene	--	--									
	Fluorene	--	--									
	Indeno(1,2,3-c,d)pyrene	--	--									
	Naphthalene	--	--									
	Phenanthrene	--	--									
	Pyrene	--	--									
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--									
	1,3,5-Trimethylbenzene	--	--									
	Benzene	5	MCL									
	Cumene	--	--									
	Ethylbenzene	700	MCL									
	m,p-Xylene	--	--									
	n-Butylbenzene	--	--									
	n-Propylbenzene	--	--									
	o-Xylene	--	--									
	sec-Butylbenzene	--	--									
	tert-Butylbenzene	--	--									
	Toluene	1000	MCL									
	Xylenes, Total	10000	MCL									

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID: D3-BLDG0520		Location ID: D3-BLDG0830							
		Location Type: School		Location Type: School							
		Address: Chester Nimitz Elementary, 520 Main St, Building 520		Address: Holy Family Catholic Academy, 830 Main St, Building 830							
		Field Sample ID: D3-TW-0017507-25060-N-2	Field Sample ID: D3-TW-0017507-25060-N-5	Field Sample ID: D3-TW-0017509-25001-N-1	Field Sample ID: D3-TW-0017509-25001-N-2	Field Sample ID: D3-TW-0017509-25001-N-3	Field Sample ID: D3-TW-0017509-25001-N-4	Field Sample ID: D3-TW-0017509-25001-N-5	Field Sample ID: D3-TW-0017509-25032-N-2		
		Sample Date: 2025-03-06	Sample Date: 2025-03-06	Sample Date: 2025-01-08	Sample Date: 2025-01-08	Sample Date: 2025-01-08	Sample Date: 2025-01-08	Sample Date: 2025-01-08	Sample Date: 2025-01-08		
		Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	
	Bromoform	--	--	0.660	0.630	ND	0.360	ND	ND	0.470	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.510	0.460	ND	0.280	ND	ND	0.350	
	Total Trihalomethanes	80	MCL	1.17	1.09	ND	0.640	ND	ND	0.820	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0830								
				Location Type: School								
				Address: Holy Family Catholic Academy, 830 Main St, Building 830								
				Field Sample ID:	D3-TW-0017509-25032-N-1	D3-TW-0017509-25032-N-3	D3-TW-0017509-25032-N-4	D3-TW-0017509-25032-N-5	D3-TW-0017509-25032-3-N-1	D3-TW-0017509-25060-N-1	D3-TW-0017509-25060-N-3	D3-TW-0017509-25060-N-4
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	700	340	680	450	--	200	300	1020	
Field Test (pH)	pH	--	--	7.30	7.25	7.36	7.36	--	7.42	7.40	7.24	
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.240	0.250	0.250	--	0.250	0.250	0.260	
Field Test (degrees Celcius)	Temperature	--	--	22.8	23.5	24.1	24.4	--	24.2	25.6	27.8	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.330	0.160	0.260	0.250	--	0.00	0.00	0.490	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53600	52700	51400	51800	52600	51800	53800	53200	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	9.30	38.0	33.9	27.6	10.2	8.20	40.2	27.5	
	Lead	15	MCL	ND	0.280	ND	0.430	ND	ND	0.190	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0830								
				Location Type: School								
				Address: Holy Family Catholic Academy, 830 Main St, Building 830								
				Field Sample ID:	D3-TW-0017509-25032-N-1	D3-TW-0017509-25032-N-3	D3-TW-0017509-25032-N-4	D3-TW-0017509-25032-N-5	D3-TW-0017509-25032-3-N-1	D3-TW-0017509-25060-N-1	D3-TW-0017509-25060-N-3	D3-TW-0017509-25060-N-4
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG0830 Location Type: School Address: Holy Family Catholic Academy, 830 Main St, Building 830								
				Field Sample ID:	D3-TW-0017509-25032-N-1	D3-TW-0017509-25032-N-3	D3-TW-0017509-25032-N-4	D3-TW-0017509-25032-N-5	D3-TW-0017509-25032-3-N-1	D3-TW-0017509-25060-N-1	D3-TW-0017509-25060-N-3	D3-TW-0017509-25060-N-4
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-06	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	0.330	0.290	0.350
	Bromoform	--	--	0.740	0.570	0.570	0.610	0.650	1.70	1.20	1.50	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.570	0.390	0.460	0.470	0.470	0.910	0.730	0.920	
	Total Trihalomethanes	80	MCL	1.31	0.960	1.03	1.08	1.12	2.94	2.22	2.77	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID: D3-BLDG0830			D3-BLDG1309H						
		Location Type: School			School						
		Address: Holy Family Catholic Academy, 830 Main St, Building 830			MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H						
		Field Sample ID:	D3-TW-0017509-25060-N-2	D3-TW-0017509-25060-N-5	D3-TW-0017509-25060-3-N-5	D3-TW-0015133-25001-N-1	D3-TW-0015133-25001-N-2	D3-TW-0015133-25001-N-3	D3-TW-0015133-25001-N-4	D3-TW-0015133-25001-N-5	
		Sample Date:	2025-03-06	2025-03-06	2025-03-06	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)					
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D3-BLDG0830			D3-BLDG1309H				
Field Test (ppb)	Free Chlorine	4000	MCL	430	1680	--	300	180	30.0	440	660
Field Test (pH)	pH	--	--	7.44	7.18	--	7.33	7.15	7.10	7.42	7.14
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	--	0.250	0.260	0.260	0.250	0.280
Field Test (degrees Celcius)	Temperature	--	--	26.5	25.8	--	28.8	28.1	25.2	29.7	24.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.260	--	0.180	0.330	0.0680	0.340	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54100	55600	53600	56800	59300	56600	61000	55000
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	10.2	25.2	25.6	11.1	21.3	32.2	43.5	53.3
	Lead	15	MCL	ND	ND	ND	0.150	ND	0.130	0.180	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID: D3-BLDG0830			Location ID: D3-BLDG1309H					
		Location Type: School			Location Type: School					
		Address: Holy Family Catholic Academy, 830 Main St, Building 830			Address: MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H					
		Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
		D3-TW-0017509-25060-N-2	D3-TW-0017509-25060-N-5	D3-TW-0017509-25060-3-N-5	D3-TW-0015133-25001-N-1	D3-TW-0015133-25001-N-2	D3-TW-0015133-25001-N-3	D3-TW-0015133-25001-N-4	D3-TW-0015133-25001-N-5	
		Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
		2025-03-06	2025-03-06	2025-03-06	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02
		Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG0830			D3-BLDG1309H					
				School			School					
				Holy Family Catholic Academy, 830 Main St, Building 830			MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H					
				Field Sample ID:	D3-TW-0017509-25060-N-2	D3-TW-0017509-25060-N-5	D3-TW-0017509-25060-3-N-5	D3-TW-0015133-25001-N-1	D3-TW-0015133-25001-N-2	D3-TW-0015133-25001-N-3	D3-TW-0015133-25001-N-4	D3-TW-0015133-25001-N-5
				Sample Date:	2025-03-06	2025-03-06	2025-03-06	2025-01-02	2025-01-02	2025-01-02	2025-01-02	2025-01-02
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.390	0.430	0.440	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	1.80	1.70	1.90	0.660	0.420	0.390	2.70	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	1.10	1.10	1.20	ND	0.280	ND	0.540	ND	ND
	Total Trihalomethanes	80	MCL	3.29	3.23	3.54	0.660	0.700	0.390	3.24	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG1309H								
				School								
				MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H								
				Field Sample ID:	D3-TW-0015133-25032-N-1	D3-TW-0015133-25032-N-2	D3-TW-0015133-25032-N-3	D3-TW-0015133-25032-N-4	D3-TW-0015133-25032-N-5	D3-TW-0015133-25060-N-1	D3-TW-0015133-25060-N-2	D3-TW-0015133-25060-N-3
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	660	560	390	580	650	650	620	480	
Field Test (pH)	pH	--	--	7.35	7.23	7.14	7.37	7.31	7.06	7.15	7.33	
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.270	0.280	0.250	0.250	0.250	0.240	0.260	
Field Test (degrees Celcius)	Temperature	--	--	24.0	24.2	26.5	25.6	23.1	29.0	25.8	23.4	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.580	0.840	0.670	1.19	0.510	0.500	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54200	50600	53100	52900	51500	52400	54600	52100	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	11.4	49.6	32.8	50.3	31.4	11.5	32.0	34.0	
	Lead	15	MCL	0.160	0.160	0.130	0.600	0.140	0.170	ND	0.130	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				D3-BLDG1309H								
				School								
				MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H								
				Field Sample ID:	D3-TW-0015133-25032-N-1	D3-TW-0015133-25032-N-2	D3-TW-0015133-25032-N-3	D3-TW-0015133-25032-N-4	D3-TW-0015133-25032-N-5	D3-TW-0015133-25060-N-1	D3-TW-0015133-25060-N-2	D3-TW-0015133-25060-N-3
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

				Location ID: D3-BLDG1309H Location Type: School Address: MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H								
				Field Sample ID:	D3-TW-0015133-25032-N-1	D3-TW-0015133-25032-N-2	D3-TW-0015133-25032-N-3	D3-TW-0015133-25032-N-4	D3-TW-0015133-25032-N-5	D3-TW-0015133-25060-N-1	D3-TW-0015133-25060-N-2	D3-TW-0015133-25060-N-3
				Sample Date:	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.440	ND						
	Bromoform	--	--	ND	1.70	ND	0.610	ND	ND	0.330	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	1.20	ND	0.520	ND	ND	0.310	ND	ND
	Total Trihalomethanes	80	MCL	ND	3.34	ND	1.13	ND	ND	0.640	ND	ND

**Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID:	D3-BLDG1309H			
		Location Type:	School			
		Address:	MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H			
		Field Sample ID:	D3-TW-0015133-25060-N-4	D3-TW-0015133-25060-N-5	D3-TW-0015133-25060-3-N-4	
		Sample Date:	2025-03-07	2025-03-07	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	520	590	--
Field Test (pH)	pH	--	--	7.33	7.30	--
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	--
Field Test (degrees Celcius)	Temperature	--	--	25.5	23.5	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.140	0.350	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52500	51300	50600
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	20.4	26.0	20.4
	Lead	15	MCL	0.160	ND	0.150
	Mercury	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND

**Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID:	D3-BLDG1309H			
		Location Type:	School			
		Address:	MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H			
		Field Sample ID:	D3-TW-0015133-25060-N-4	D3-TW-0015133-25060-N-5	D3-TW-0015133-25060-3-N-4	
		Sample Date:	2025-03-07	2025-03-07	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Synthetic Organic Compounds (ppb)	Benzo(k)fluoranthene	--	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Schools in Zone D3

		Location ID:	D3-BLDG1309H			
		Location Type:	School			
		Address:	MOKULELE ELEM BLDG A, 250 Aupaka St, Building 1309H			
		Field Sample ID:	D3-TW-0015133-25060-N-4	D3-TW-0015133-25060-N-5	D3-TW-0015133-25060-3-N-4	
		Sample Date:	2025-03-07	2025-03-07	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.310	ND	ND
	Bromoform	--	--	1.00	ND	0.330
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.840	ND	0.290
	Total Trihalomethanes	80	MCL	2.15	ND	0.620

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

				Location ID: D3-BLDG0515 Location Type: Child Development Center Address: Building 515, Pearl Harbor Church of Christ (515 Main St)								
				Field Sample ID:	D3-TW-0017510-25001-N-1	D3-TW-0017510-25001-N-2	D3-TW-0017510-25001-3-N-1	D3-TW-0017510-25032-N-1	D3-TW-0017510-25032-N-2	D3-TW-0017510-25032-3-N-1	D3-TW-0017510-25060-N-1	D3-TW-0017510-25060-3-N-1
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-02-04	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	620	640	--	580	570	--	440	--	
Field Test (pH)	pH	--	--	7.30	7.31	--	7.32	7.28	--	7.10	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	--	0.250	0.240	--	0.240	--	
Field Test (degrees Celcius)	Temperature	--	--	27.2	28.3	--	24.9	25.0	--	27.3	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.230	0.190	--	0.600	0.900	--	0.400	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58200	60300	59800	51800	54200	52800	55000	52300	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	12.3	7.90	12.2	11.8	8.70	12.1	17.0	16.7	
	Lead	15	MCL	0.150	0.170	0.130	ND	0.130	ND	0.200	0.180	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

				Location ID: D3-BLDG0515 Location Type: Child Development Center Address: Building 515, Pearl Harbor Church of Christ (515 Main St)								
				Field Sample ID:	D3-TW-0017510-25001-N-1	D3-TW-0017510-25001-N-2	D3-TW-0017510-25001-3-N-1	D3-TW-0017510-25032-N-1	D3-TW-0017510-25032-N-2	D3-TW-0017510-25032-3-N-1	D3-TW-0017510-25060-N-1	D3-TW-0017510-25060-3-N-1
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-02-04	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

				Location ID: D3-BLDG0515 Location Type: Child Development Center Address: Building 515, Pearl Harbor Church of Christ (515 Main St)								
				Field Sample ID:	D3-TW-0017510-25001-N-1	D3-TW-0017510-25001-N-2	D3-TW-0017510-25001-3-N-1	D3-TW-0017510-25032-N-1	D3-TW-0017510-25032-N-2	D3-TW-0017510-25032-3-N-1	D3-TW-0017510-25060-N-1	D3-TW-0017510-25060-3-N-1
				Sample Date:	2025-01-07	2025-01-07	2025-01-07	2025-02-04	2025-02-04	2025-02-04	2025-03-06	2025-03-06
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	0.300	0.310
	Bromoform	--	--	0.490	0.580	0.360	ND	0.620	0.420	0.930	1.00	1.00
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.460	0.560	0.350	ND	0.530	0.320	0.780	0.800	0.800
	Total Trihalomethanes	80	MCL	0.950	1.14	0.710	ND	1.15	0.740	2.01	2.11	2.11

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-BLDG1330H							
				Location Type:	Child Development Center							
				Address:	Building 1330H, YOUTH CENTER, 234 Melick Ave							
				Field Sample ID:	D3-TW-0017510-25060-N-2	D3-TW-0015139-25001-N-1	D3-TW-0015139-25001-N-2	D3-TW-0015139-25032-N-1	D3-TW-0015139-25032-N-2	D3-TW-0015139-25060-N-1	D3-TW-0015139-25060-N-2	D3-TW-0015139-25060-3-N-2
				Sample Date:	2025-03-06	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Field Test (ppb)	Free Chlorine	4000	MCL	570	530	590	540	470	370	150	--	
Field Test (pH)	pH	--	--	7.12	7.56	7.47	7.46	7.27	7.38	7.33	--	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.270	0.270	0.240	0.240	0.250	0.250	--	
Field Test (degrees Celcius)	Temperature	--	--	27.8	26.9	25.4	25.0	25.7	26.9	27.2	--	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.420	1.14	0.670	0.310	0.320	0.0510	0.180	--	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52400	57700	56800	52600	52400	54200	54800	52900	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	9.00	101	86.7	86.1	92.2	88.5	60.7	61.6	
	Lead	15	MCL	0.180	0.170	0.130	0.160	ND	0.180	0.180	0.170	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location Type:							
				D3-BLDG0515	D3-BLDG1330H							
				Child Development Center	Child Development Center							
				Address:	Address:							
				Building 515, Pearl Harbor Church of Christ (515 Main St)	Building 1330H, YOUTH CENTER, 234 Melick Ave							
				Field Sample ID:	D3-TW-0017510-25060-N-2	D3-TW-0015139-25001-N-1	D3-TW-0015139-25001-N-2	D3-TW-0015139-25032-N-1	D3-TW-0015139-25032-N-2	D3-TW-0015139-25060-N-1	D3-TW-0015139-25060-N-2	D3-TW-0015139-25060-3-N-2
				Sample Date:	2025-03-06	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location Type:							
				D3-BLDG0515	D3-BLDG1330H							
				Child Development Center	Child Development Center							
				Address:	Address:							
				Building 515, Pearl Harbor Church of Christ (515 Main St)	Building 1330H, YOUTH CENTER, 234 Melick Ave							
				Field Sample ID:	D3-TW-0017510-25060-N-2	D3-TW-0015139-25001-N-1	D3-TW-0015139-25001-N-2	D3-TW-0015139-25032-N-1	D3-TW-0015139-25032-N-2	D3-TW-0015139-25060-N-1	D3-TW-0015139-25060-N-2	D3-TW-0015139-25060-3-N-2
				Sample Date:	2025-03-06	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.290	ND	ND	0.400	ND	ND	ND	ND	ND
	Bromoform	--	--	0.940	0.700	0.850	1.80	0.350	0.660	0.840	0.810	0.810
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.780	0.460	0.590	1.30	0.340	0.420	0.530	0.530	0.530
	Total Trihalomethanes	80	MCL	2.01	1.16	1.44	3.50	0.690	1.08	1.37	1.34	1.34

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1335H		D3-BLDG1335H							D3-BLDG1586H	
		Location Type: Child Development Center		Child Development Center							Child Development Center	
		Address: Building 1335H, School Age Center - CDC (70 Alula Way)		Building 1335H, School Age Center - CDC (70 Alula Way)							Building 1586H, CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)	
		Field Sample ID:	D3-TW-0015141-25001-N-1	D3-TW-0015141-25001-N-2	D3-TW-0015141-25032-N-1	D3-TW-0015141-25032-N-2	D3-TW-0015141-25032-3-N-1	D3-TW-0015141-25060-N-1	D3-TW-0015141-25060-N-2	D3-TW-0015143-25001-N-2		
		Sample Date:	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-01-02		
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	240	630	540	710	--	330	610	770	
Field Test (pH)	pH	--	--	7.23	7.30	7.33	7.37	--	7.10	7.12	7.12	
Field Test (ms/cm)	Specific Conductivity	--	--	0.290	0.260	0.270	0.270	--	0.250	0.250	0.280	
Field Test (degrees Celcius)	Temperature	--	--	25.8	24.8	24.2	23.4	--	24.7	24.4	24.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.130	0.00	0.00	0.00	--	0.00	0.280	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56700	56800	53300	54400	56800	52600	53700	58300	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	98.2	30.7	87.4	30.5	88.2	95.7	30.2	49.1	
	Lead	15	MCL	0.410	ND	0.340	ND	0.350	0.330	0.170	0.280	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1335H		D3-BLDG1335H							D3-BLDG1586H	
		Location Type: Child Development Center		Child Development Center							Child Development Center	
		Address: Building 1335H, School Age Center - CDC (70 Alula Way)		Building 1335H, School Age Center - CDC (70 Alula Way)							Building 1586H, CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)	
		Field Sample ID:	D3-TW-0015141-25001-N-1	D3-TW-0015141-25001-N-2	D3-TW-0015141-25032-N-1	D3-TW-0015141-25032-N-2	D3-TW-0015141-25032-3-N-1	D3-TW-0015141-25060-N-1	D3-TW-0015141-25060-N-2	D3-TW-0015143-25001-N-2		
		Sample Date:	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-01-02		
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1335H		D3-BLDG1335H							D3-BLDG1586H	
		Location Type: Child Development Center		Child Development Center							Child Development Center	
		Address: Building 1335H, School Age Center - CDC (70 Alula Way)		Building 1335H, School Age Center - CDC (70 Alula Way)							Building 1586H, CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)	
		Field Sample ID:	D3-TW-0015141-25001-N-1	D3-TW-0015141-25001-N-2	D3-TW-0015141-25032-N-1	D3-TW-0015141-25032-N-2	D3-TW-0015141-25032-3-N-1	D3-TW-0015141-25060-N-1	D3-TW-0015141-25060-N-2	D3-TW-0015141-25060-N-2	D3-TW-0015143-25001-N-2	
		Sample Date:	2025-01-13	2025-01-13	2025-02-05	2025-02-05	2025-02-05	2025-03-07	2025-03-07	2025-03-07	2025-01-02	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.580	0.280	0.360	0.380	0.410	ND	ND	ND	
	Bromoform	--	--	2.20	1.00	0.980	1.60	1.70	0.660	0.900	ND	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	1.60	0.840	0.790	1.10	1.20	0.490	0.580	ND	
	Total Trihalomethanes	80	MCL	4.38	2.12	2.13	3.08	3.31	1.15	1.48	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1586H		D3-BLDG1586H Child Development Center						D3-BLDG1654H Child Development Center	
		Location Type:		Building 1586H,CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)						Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)	
		Address:									
		Field Sample ID:		D3-TW-0015143-25001-N-1	D3-TW-0015143-25032-N-1	D3-TW-0015143-25032-N-2	D3-TW-0015143-25060-N-1	D3-TW-0015143-25060-N-2	D3-TW-0015143-25060-3-N-2	D3-TW-0015153-25001-N-1	D3-TW-0015153-25001-N-2
		Sample Date:		2025-01-02	2025-02-03	2025-02-03	2025-03-07	2025-03-07	2025-03-07	2025-01-02	2025-01-02
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	640	810	1070	740	670	--	900	630
Field Test (pH)	pH	--	--	7.16	7.25	7.18	7.06	7.13	--	7.29	7.08
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.290	0.280	0.250	0.240	--	0.240	0.280
Field Test (degrees Celcius)	Temperature	--	--	24.9	25.7	22.5	26.1	24.2	--	26.1	26.1
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.000120	0.00560	0.350	0.380	0.450	--	0.260	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56900	42800	45000	52800	54100	53000	59100	57800
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	15.2	13.0	70.4	8.20	44.9	41.9	29.8	71.3
	Lead	15	MCL	ND	ND	0.490	ND	0.310	0.300	ND	0.230
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1586H		D3-BLDG1586H Child Development Center						D3-BLDG1654H Child Development Center	
		Location Type:		Building 1586H,CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)						Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)	
		Address:									
		Field Sample ID:		D3-TW-0015143-25001-N-1	D3-TW-0015143-25032-N-1	D3-TW-0015143-25032-N-2	D3-TW-0015143-25060-N-1	D3-TW-0015143-25060-N-2	D3-TW-0015143-25060-3-N-2	D3-TW-0015153-25001-N-1	D3-TW-0015153-25001-N-2
		Sample Date:		2025-01-02	2025-02-03	2025-02-03	2025-03-07	2025-03-07	2025-03-07	2025-01-02	2025-01-02
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID:		D3-BLDG1586H						D3-BLDG1654H	
		Location Type:		Child Development Center						Child Development Center	
		Address:		Building 1586H,CHILD DEVELOPMENT CENTER-HICKAM MAIN CDC (80 Liliwai St)						Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)	
		Field Sample ID:		D3-TW-0015143-25001-N-1	D3-TW-0015143-25032-N-1	D3-TW-0015143-25032-N-2	D3-TW-0015143-25060-N-1	D3-TW-0015143-25060-N-2	D3-TW-0015143-25060-3-N-2	D3-TW-0015153-25001-N-1	D3-TW-0015153-25001-N-2
		Sample Date:		2025-01-02	2025-02-03	2025-02-03	2025-03-07	2025-03-07	2025-03-07	2025-01-02	2025-01-02
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.430	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.290	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	0.720	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1654H Location Type: Child Development Center Address: Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)				D3-BLDG1859H Child Development Center Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)					
		Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Field Test (ppb)	Free Chlorine	4000	MCL	690	660	350	440	1050	770	--	820
Field Test (pH)	pH	--	--	7.18	7.14	7.16	7.10	7.16	7.15	--	7.32
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.270	0.300	0.290	0.260	0.250	--	0.230
Field Test (degrees Celcius)	Temperature	--	--	23.3	23.8	25.2	24.1	26.9	25.7	--	25.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.150	0.580	0.00	0.00	0.830	0.340	--	0.340
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51000	50500	53200	52700	58800	57800	57400	52500
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	24.3	68.2	82.0	169	16.2	117	116	9.70
	Lead	15	MCL	ND	0.170	ND	0.520	ND	0.180	0.170	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

				Location ID: D3-BLDG1654H Location Type: Child Development Center Address: Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)				Location ID: D3-BLDG1859H Location Type: Child Development Center Address: Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)			
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID: D3-BLDG1654H Location Type: Child Development Center Address: Building 1654H,CHILD DEVELOPMENT CENTER-HICKAM WEST CDC (170 Kuntz Ave)				Location ID: D3-BLDG1859H Location Type: Child Development Center Address: Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)					
		Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:		
		Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:		
		Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.450	ND	ND	0.320
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	0.370	ND	0.250	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.820	ND	0.250	0.320

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID:	D3-BLDG1859H			
		Location Type:	Child Development Center			
		Address:	Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)			
		Field Sample ID:	D3-TW-0015186-25032-N-2	D3-TW-0015186-25060-N-1	D3-TW-0015186-25060-N-2	
		Sample Date:	2025-02-05	2025-03-17	2025-03-17	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	480	640	620
Field Test (pH)	pH	--	--	7.35	7.19	7.21
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.260	0.260
Field Test (degrees Celcius)	Temperature	--	--	25.4	25.3	24.6
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.220	0.140	0.100
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55300	54600	54000
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	145	60.6	42.8
	Lead	15	MCL	0.270	0.180	0.190
	Mercury	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID:	D3-BLDG1859H			
		Location Type:	Child Development Center			
		Address:	Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)			
		Field Sample ID:	D3-TW-0015186-25032-N-2	D3-TW-0015186-25060-N-1	D3-TW-0015186-25060-N-2	
		Sample Date:	2025-02-05	2025-03-17	2025-03-17	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Synthetic Organic Compounds (ppb)	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
	Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND
1,3,5-Trimethylbenzene		--	--	ND	ND	ND
Benzene		5	MCL	ND	ND	ND
Cumene		--	--	ND	ND	ND
Ethylbenzene		700	MCL	ND	ND	ND
m,p-Xylene		--	--	ND	ND	ND
n-Butylbenzene		--	--	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone D3

		Location ID:	D3-BLDG1859H			
		Location Type:	Child Development Center			
		Address:	Building 1859H, MAKAI RECREATION CENTER (Previously a NR before February 2023)			
		Field Sample ID:	D3-TW-0015186-25032-N-2	D3-TW-0015186-25060-N-1	D3-TW-0015186-25060-N-2	
		Sample Date:	2025-02-05	2025-03-17	2025-03-17	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.480	0.320	0.340
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.330	0.320	0.260
	Total Trihalomethanes	80	MCL	0.810	0.640	0.600

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		D3-HYD0188				D3-HYD0213			D3-HYD0219		
		Hydrant				Hydrant			Hydrant		
		FH 188				FH 213			FH 219		
		D3-DL-0017729-25001	D3-DL-0017729-25032	D3-DL-0017729-25032	D3-DL-0017729-25060	D3-DL-0017735-25001	D3-DL-0017735-25032	D3-DL-0017735-25060	D3-DL-0017733-25001		
		-N	-N	-3-N	-N	-N	-N	-N	-N		
		2025-01-09	2025-02-05	2025-02-05	2025-03-21	2025-01-09	2025-02-24	2025-03-17	2025-01-09		
		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	730	590	--	340	880	700	710	690
Field Test (pH)	pH	--	--	7.28	7.09	--	7.34	7.26	7.01	7.19	7.27
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	--	0.260	0.250	0.250	0.260	0.270
Field Test (degrees Celcius)	Temperature	--	--	25.6	27.9	--	26.0	25.7	26.7	25.2	25.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	2.03	--	0.780	0.00	1.00	0.670	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	62100	50000	49700	53300	59700	53400	55300	59300
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		D3-HYD0188				D3-HYD0213			D3-HYD0219
		Hydrant				Hydrant			Hydrant
		FH 188				FH 213			FH 219
		D3-DL-0017729-25001	D3-DL-0017729-25032	D3-DL-0017729-25032	D3-DL-0017729-25060	D3-DL-0017735-25001	D3-DL-0017735-25032	D3-DL-0017735-25060	D3-DL-0017733-25001
		-N	-N	-3-N	-N	-N	-N	-N	-N
		2025-01-09	2025-02-05	2025-02-05	2025-03-21	2025-01-09	2025-02-24	2025-03-17	2025-01-09
		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	--	ND	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.340	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.250	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.590	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		Location ID: D3-HYD0219			D3-HYD0222			D3-HYD0411			
		Location Type: Hydrant			Hydrant			Hydrant			
		Address: FH 219			FH 222			FH 411			
		Field Sample ID: D3-DL-0017733-25001-3-N	D3-DL-0017733-25032-N	D3-DL-0017733-25060-N	D3-DL-0017730-25001-N	D3-DL-0017730-25032-N	D3-DL-0017730-25060-N	D3-DL-0017731-25001-N	D3-DL-0017731-25001-3-N		
		Sample Date: 2025-01-09	2025-02-24	2025-03-17	2025-01-09	2025-02-24	2025-03-17	2025-01-09	2025-01-09		
		Sample Type: FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	--	560	640	850	730	710	700	--
Field Test (pH)	pH	--	--	--	7.01	7.23	7.24	7.13	7.22	7.19	--
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.250	0.230	0.250	0.250	0.230	0.260	--
Field Test (degrees Celcius)	Temperature	--	--	--	29.6	24.5	26.2	27.6	26.1	23.1	--
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	1.01	0.00	0.00	0.550	0.0550	0.00	--
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	59600	52100	53600	59100	52900	55300	55100	57200
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		Location ID: D3-HYD0219			Location ID: D3-HYD0222			Location ID: D3-HYD0411		
		Location Type: Hydrant			Location Type: Hydrant			Location Type: Hydrant		
		Address: FH 219			Address: FH 222			Address: FH 411		
		Field Sample ID: D3-DL-0017733-25001-3-N	Field Sample ID: D3-DL-0017733-25032-N	Field Sample ID: D3-DL-0017733-25060-N	Field Sample ID: D3-DL-0017730-25001-N	Field Sample ID: D3-DL-0017730-25032-N	Field Sample ID: D3-DL-0017730-25060-N	Field Sample ID: D3-DL-0017731-25001-N	Field Sample ID: D3-DL-0017731-25001-3-N	
		Sample Date: 2025-01-09	Sample Date: 2025-02-24	Sample Date: 2025-03-17	Sample Date: 2025-01-09	Sample Date: 2025-02-24	Sample Date: 2025-03-17	Sample Date: 2025-01-09	Sample Date: 2025-01-09	
		Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	ND	--	ND	
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	ND	--	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	
	Cumene	--	--	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		Location ID: D3-HYD0411		Location ID: D3-HYD0520				Location ID: D3-HYD0592			
		Location Type: Hydrant		Location Type: Hydrant				Location Type: Hydrant			
		Address: FH 411		Address: FH 520				Address: FH 592			
		Field Sample ID: D3-DL-0017731-25032	Field Sample ID: D3-DL-0017731-25060	Field Sample ID: D3-DL-0017734-25001	Field Sample ID: D3-DL-0017734-25032	Field Sample ID: D3-DL-0017734-25060	Field Sample ID: D3-DL-0017734-25060	Field Sample ID: D3-DL-0017732-25001	Field Sample ID: D3-DL-0017732-25032		
		-N	-N	-N	-N	-N	-3-N	-N	-N		
		Sample Date: 2025-02-24	Sample Date: 2025-03-21	Sample Date: 2025-01-09	Sample Date: 2025-02-24	Sample Date: 2025-03-21	Sample Date: 2025-03-21	Sample Date: 2025-01-09	Sample Date: 2025-02-24		
		Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	750	880	700	330	850	--	750	560
Field Test (pH)	pH	--	--	7.01	7.27	7.15	7.26	7.16	--	7.26	7.25
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.230	0.260	0.240	0.230	--	0.260	0.240
Field Test (degrees Celcius)	Temperature	--	--	28.4	24.5	23.0	22.3	25.3	--	25.2	24.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.63	0.00	0.130	0.0420	0.620	--	0.130	0.150
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53600	54300	56200	51800	53800	54300	58000	54300
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		Location ID: D3-HYD0411		Location ID: D3-HYD0520				Location ID: D3-HYD0592	
		Hydrant		Hydrant				Hydrant	
		FH 411		FH 520				FH 592	
		D3-DL-0017731-25032	D3-DL-0017731-25060	D3-DL-0017734-25001	D3-DL-0017734-25032	D3-DL-0017734-25060	D3-DL-0017734-25060	D3-DL-0017732-25001	D3-DL-0017732-25032
		-N	-N	-N	-N	-N	-3-N	-N	-N
		2025-02-24	2025-03-21	2025-01-09	2025-02-24	2025-03-21	2025-03-21	2025-01-09	2025-02-24
		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	--	--	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	--	--	--	ND	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.250
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.250

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D3-HYD0592		Location ID: D3-HYD2080												
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID								
				D3-DL-0017732-25060 -N	2025-03-21	N (Normal)	D3-DL-0000547-25001 -N	2025-01-09	N (Normal)	D3-DL-0000547-25032 -N	2025-02-24	N (Normal)	D3-DL-0000547-25060 -N	2025-03-21	N (Normal)	D3-DL-0000547-25060 -3-N	2025-03-21	FD (Field Duplicate)
				590	100	30.0	40.0	--										
Field Test (ppb)	Free Chlorine	4000	MCL															
Field Test (pH)	pH	--	--	7.30	7.14	7.36	7.38	--										
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.260	0.240	0.260	--										
Field Test (degrees Celcius)	Temperature	--	--	24.8	29.3	28.6	29.2	--										
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.720	0.280	1.28	--										
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52400	57300	51900	55300	55300										
	Total Organic Carbon	--	--	ND	ND	ND	220	ND										
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND										
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND										
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND										
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND										
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND										
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND										
	Acenaphthylene	--	--	ND	ND	ND	ND	ND										
	Anthracene	--	--	ND	ND	ND	ND	ND										
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND										
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND										
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND										
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND										
	Chrysene	--	--	ND	ND	ND	ND	ND										
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND										
	Fluorene	--	--	ND	ND	ND	ND	ND										
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND										

Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone D3

		Location ID: D3-HYD0592		Location ID: D3-HYD2080				
		Location Type: Hydrant		Location Type: Hydrant				
		Address: FH 592		Address: FH ID: 473				
		Field Sample ID: D3-DL-0017732-25060		Field Sample ID: D3-DL-0000547-25001	Field Sample ID: D3-DL-0000547-25032	Field Sample ID: D3-DL-0000547-25060	Field Sample ID: D3-DL-0000547-25060	
		-N		-N	-N	-N	-3-N	
		Sample Date: 2025-03-21		Sample Date: 2025-01-09	Sample Date: 2025-02-24	Sample Date: 2025-03-21	Sample Date: 2025-03-21	
		Sample Type: N (Normal)		Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level					
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.640	0.940	0.990	0.960
	Bromoform	--	--	ND	6.30	9.70	8.60	8.60
	Chloroform	--	--	ND	ND	0.300	0.360	0.350
	Dibromochloromethane	--	--	ND	2.10	2.90	2.90	2.90
	Total Trihalomethanes	80	MCL	ND	9.04	13.8	12.9	12.8

**Summary of Chemistry Results
Zone D3
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D3

		Location ID: D3-BLDG1864H				
		Location Type: Medical Building				
		Address: BLDG 1864H - Veterinary Clinic, 1864 Kuntz Ave				
		Field Sample ID:	D3-TW-0014166-25001-N	D3-TW-0014166-25032-N	D3-TW-0014166-25060-N	
		Sample Date:	2025-01-02	2025-02-05	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	180	400	240
Field Test (pH)	pH	--	--	7.16	7.16	7.25
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	0.250
Field Test (degrees Celcius)	Temperature	--	--	25.4	27.6	23.2
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.420	0.700	0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	57300	51500	52100
	Total Organic Carbon	--	--	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	75.6	133	53.1
	Lead	15	MCL	0.130	0.130	ND
	Mercury	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND
	Anthracene	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D3

		Location ID:	D3-BLDG1864H			
		Location Type:	Medical Building			
		Address:	BLDG 1864H - Veterinary Clinic, 1864 Kuntz Ave			
		Field Sample ID:	D3-TW-0014166-25001-N	D3-TW-0014166-25032-N	D3-TW-0014166-25060-N	
		Sample Date:	2025-01-02	2025-02-05	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND
	Chrysene	--	--	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND
	Fluorene	--	--	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND
	Pyrene	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Cumene	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND

Summary of Chemistry Results

Zone D3

Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Other Buildings in Zone D3

		Location ID:	D3-BLDG1864H			
		Location Type:	Medical Building			
		Address:	BLDG 1864H - Veterinary Clinic, 1864 Kuntz Ave			
		Field Sample ID:	D3-TW-0014166-25001-N	D3-TW-0014166-25032-N	D3-TW-0014166-25060-N	
		Sample Date:	2025-01-02	2025-02-05	2025-03-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	Toluene	1000	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.820	ND	ND
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.460	ND	0.260
	Total Trihalomethanes	80	MCL	1.28	ND	0.260