

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-ANDE2866	F2-ANDE2896	F2-ANDE3042		F2-ANDE3045	F2-ARIZ3052	F2-CATL5227	F2-CATL5233
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	2866 Anderson Avenue	2896 Anderson Avenue	3042 Anderson Avenue		3045 Anderson Avenue	3052 Arizona Road	5227 Catlin Lane	5233 Catlin Lane
				Field Sample ID:	F2-TW-0010755-24092-N	F2-TW-0009591-24092-N	F2-TW-0010760-24092-N	F2-TW-0010760-24092-3-N	F2-TW-0010761-24092-N	F2-TW-0011042-24092-N	F2-TW-0011093-24092-N	F2-TW-0011098-24092-N
				Sample Date:	2025-01-16	2025-02-11	2025-03-24	2025-03-24	2025-01-27	2025-02-11	2025-01-16	2025-01-20
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	850	680	770	--	740	790	630	800	
Field Test (pH)	pH	--	--	7.13	7.31	7.29	--	7.21	7.34	7.22	7.18	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	0.230	--	0.250	0.270	0.240	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	22.7	25.0	25.6	--	24.1	24.3	30.0	24.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0200	0.00	0.00120	--	0.0950	0.00	0.840	0.270	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52800	51800	54400	52800	52600	53700	52100	52600	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	7.10	7.00	3.80	3.90	2.30	3.60	12.6	11.4	
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	0.190	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-ANDE2866	F2-ANDE2896	F2-ANDE3042		F2-ANDE3045	F2-ARIZ3052	F2-CATL5227	F2-CATL5233
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	2866 Anderson Avenue	2896 Anderson Avenue	3042 Anderson Avenue		3045 Anderson Avenue	3052 Arizona Road	5227 Catlin Lane	5233 Catlin Lane
				Field Sample ID:	F2-TW-0010755-24092-N	F2-TW-0009591-24092-N	F2-TW-0010760-24092-N	F2-TW-0010760-24092-3-N	F2-TW-0010761-24092-N	F2-TW-0011042-24092-N	F2-TW-0011093-24092-N	F2-TW-0011098-24092-N
				Sample Date:	2025-01-16	2025-02-11	2025-03-24	2025-03-24	2025-01-27	2025-02-11	2025-01-16	2025-01-20
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.420	0.410	0.330	0.340	0.430	0.480	0.380	0.360	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-ANDE2866	F2-ANDE2896	F2-ANDE3042		F2-ANDE3045	F2-ARIZ3052	F2-CATL5227	F2-CATL5233
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	2866 Anderson Avenue	2896 Anderson Avenue	3042 Anderson Avenue		3045 Anderson Avenue	3052 Arizona Road	5227 Catlin Lane	5233 Catlin Lane
		Field Sample ID:	F2-TW-0010755-24092-N	F2-TW-0009591-24092-N	F2-TW-0010760-24092-N	F2-TW-0010760-24092-3-N	F2-TW-0010761-24092-N	F2-TW-0011042-24092-N	F2-TW-0011093-24092-N	F2-TW-0011098-24092-N
		Sample Date:	2025-01-16	2025-02-11	2025-03-24	2025-03-24	2025-01-27	2025-02-11	2025-01-16	2025-01-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.470	0.380	0.380	0.340	0.370	0.390	0.320
	Total Trihalomethanes	80	MCL	0.890	0.790	0.710	0.680	0.800	0.870	0.680

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-CATL5286		F2-CATL5302	F2-CURT3003	F2-CURT3017	F2-DALY3043	F2-DALY3045	F2-DALY3049
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	5286 Catlin Lane		5302 Catlin Lane	3003 Curtis Drive	3017 Curtis Drive	3043 Daly Drive	3045 Daly Drive	3049 Daly Drive
				Field Sample ID:	F2-TW-0011108-24092-N	F2-TW-0011108-24092-3-N	F2-TW-0011115-24092-N	F2-TW-0011133-24092-N	F2-TW-0011140-24092-N	F2-TW-0011143-24092-N	F2-TW-0011144-24092-N	F2-TW-0011146-24092-N
				Sample Date:	2025-03-24	2025-03-24	2025-01-27	2025-02-19	2025-02-19	2025-02-10	2025-01-27	2025-01-27
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	420	--		990	500	630	690	670	560
Field Test (pH)	pH	--	--	7.26	--		7.29	7.28	7.20	7.25	7.34	7.27
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	--		0.260	0.720	0.270	0.240	0.260	0.260
Field Test (degrees Celcuis)	Temperature	--	--	26.8	--		23.4	24.8	22.5	26.1	23.9	25.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--		0.00	0.150	0.400	0.00	0.190	0.480
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54600	54400		50000	51900	54100	52000	51400	51700
	Total Organic Carbon	--	--	ND	ND		ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND		ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	8.00	7.50		6.30	17.7	19.1	20.1	18.2	35.9
	Lead	15	MCL	0.160	0.140		0.260	ND	ND	ND	ND	0.180
	Mercury	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-CATL5286		F2-CATL5302	F2-CURT3003	F2-CURT3017	F2-DALY3043	F2-DALY3045	F2-DALY3049
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5286 Catlin Lane		5302 Catlin Lane	3003 Curtis Drive	3017 Curtis Drive	3043 Daly Drive	3045 Daly Drive	3049 Daly Drive
		Field Sample ID:	F2-TW-0011108-24092-N	F2-TW-0011108-24092-3-N	F2-TW-0011115-24092-N	F2-TW-0011133-24092-N	F2-TW-0011140-24092-N	F2-TW-0011143-24092-N	F2-TW-0011144-24092-N	F2-TW-0011146-24092-N
		Sample Date:	2025-03-24	2025-03-24	2025-01-27	2025-02-19	2025-02-19	2025-02-10	2025-01-27	2025-01-27
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	0.330	0.980
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.260	0.430

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-CATL5286		F2-CATL5302	F2-CURT3003	F2-CURT3017	F2-DALY3043	F2-DALY3045	F2-DALY3049
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5286 Catlin Lane		5302 Catlin Lane	3003 Curtis Drive	3017 Curtis Drive	3043 Daly Drive	3045 Daly Drive	3049 Daly Drive
		Field Sample ID:	F2-TW-0011108-24092-N	F2-TW-0011108-24092-3-N	F2-TW-0011115-24092-N	F2-TW-0011133-24092-N	F2-TW-0011140-24092-N	F2-TW-0011143-24092-N	F2-TW-0011144-24092-N	F2-TW-0011146-24092-N
		Sample Date:	2025-03-24	2025-03-24	2025-01-27	2025-02-19	2025-02-19	2025-02-10	2025-01-27	2025-01-27
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.590	1.41

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-DEWE3237	F2-DICK0579	F2-DICK0583	F2-DORI2264D	F2-DORI2266A	F2-DORI2272C	F2-DORI2273A	F2-DORI2273B
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3237 Dewert Lane	579 Dickson Lane	583 Dickson Lane	2264D Doris Miller Loop	2266A Doris Miller Loop	2272C Doris Miller Loop	2273A Doris Miller Loop	2273B Doris Miller Loop
				Field Sample ID:	F2-TW-0011174-24092-N	F2-TW-0011180-24092-N	F2-TW-0011182-24092-N	F2-TW-0011187-24092-N	F2-TW-0011192-24092-N	F2-TW-0011418-24092-N	F2-TW-0011420-24092-N	F2-TW-0011421-24092-N
				Sample Date:	2025-02-17	2025-01-27	2025-03-12	2025-01-29	2025-01-28	2025-02-17	2025-02-19	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	640	770	730	680	280	430	440	300	
Field Test (pH)	pH	--	--	7.15	7.16	7.23	7.18	7.36	7.09	7.18	7.28	
Field Test (ms/cm)	Specific Conductivity	--	--	0.300	0.300	0.260	0.250	0.250	0.300	0.270	0.300	
Field Test (degrees Celcuis)	Temperature	--	--	24.8	23.1	23.4	23.8	25.1	24.4	26.0	25.7	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.0670	0.0400	0.470	0.170	0.0480	0.740	0.0470	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52600	53500	55400	51600	51100	51000	51400	51200	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	18.8	6.30	51.2	36.5	39.9	32.2	31.5	25.7	
	Lead	15	MCL	0.200	0.300	0.270	ND	ND	0.260	ND	0.160	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-DEWE3237	F2-DICK0579	F2-DICK0583	F2-DORI2264D	F2-DORI2266A	F2-DORI2272C	F2-DORI2273A	F2-DORI2273B
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3237 Dewert Lane	579 Dickson Lane	583 Dickson Lane	2264D Doris Miller Loop	2266A Doris Miller Loop	2272C Doris Miller Loop	2273A Doris Miller Loop	2273B Doris Miller Loop
				Field Sample ID:	F2-TW-0011174-24092-N	F2-TW-0011180-24092-N	F2-TW-0011182-24092-N	F2-TW-0011187-24092-N	F2-TW-0011192-24092-N	F2-TW-0011418-24092-N	F2-TW-0011420-24092-N	F2-TW-0011421-24092-N
				Sample Date:	2025-02-17	2025-01-27	2025-03-12	2025-01-29	2025-01-28	2025-02-17	2025-02-19	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	0.460	ND	ND	0.500

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-DEWE3237	F2-DICK0579	F2-DICK0583	F2-DORI2264D	F2-DORI2266A	F2-DORI2272C	F2-DORI2273A	F2-DORI2273B
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3237 Dewert Lane	579 Dickson Lane	583 Dickson Lane	2264D Doris Miller Loop	2266A Doris Miller Loop	2272C Doris Miller Loop	2273A Doris Miller Loop	2273B Doris Miller Loop
				Field Sample ID:	F2-TW-0011174-24092-N	F2-TW-0011180-24092-N	F2-TW-0011182-24092-N	F2-TW-0011187-24092-N	F2-TW-0011192-24092-N	F2-TW-0011418-24092-N	F2-TW-0011420-24092-N	F2-TW-0011421-24092-N
				Sample Date:	2025-02-17	2025-01-27	2025-03-12	2025-01-29	2025-01-28	2025-02-17	2025-02-19	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.360	0.310	0.420	
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.820	0.310	0.920	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-DORI2273D	F2-DORI2274A	F2-DORI2275C		F2-DORI2277A	F2-DRIS2995	F2-ENGE4115	F2-FINC4123
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	2273D Doris Miller Loop	2274A Doris Miller Loop	2275C Doris Miller Loop		2277A Doris Miller Loop	2995 Driskell Drive	4115 Enger Street	4123 Fincher Street
				Field Sample ID:	F2-TW-0011423-24092-N	F2-TW-0011424-24092-N	F2-TW-0011430-24092-N	F2-TW-0011430-24092-3-N	F2-TW-0011436-24092-N	F2-TW-0011446-24092-N	F2-TW-0011467-24092-N	F2-TW-0011472-24092-N
				Sample Date:	2025-01-28	2025-02-11	2025-01-29	2025-01-29	2025-03-20	2025-02-19	2025-01-28	2025-02-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	350	1130	780	--		560	630	620	350
Field Test (pH)	pH	--	--	7.18	7.25	7.08	--		7.26	7.23	7.12	7.18
Field Test (ms/cm)	Specific Conductivity	--	--	0.280	0.230	0.280	--		0.260	0.250	0.280	0.260
Field Test (degrees Celcuis)	Temperature	--	--	21.2	22.5	24.8	--		24.8	25.2	25.1	24.6
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	2.75	--		0.0450	0.800	1.03	0.0990
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	50900	51800	51400	51900		55100	51800	52000	52700
	Total Organic Carbon	--	--	ND	ND	ND	ND		ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND		ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	72.0	36.4	19.1	16.0		45.2	13.8	4.60	33.1
	Lead	15	MCL	0.190	ND	ND	ND		1.30	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND		ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND		ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND		ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND		ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-DORI2273D	F2-DORI2274A	F2-DORI2275C		F2-DORI2277A	F2-DRIS2995	F2-ENGE4115	F2-FINC4123
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	2273D Doris Miller Loop	2274A Doris Miller Loop	2275C Doris Miller Loop		2277A Doris Miller Loop	2995 Driskell Drive	4115 Enger Street	4123 Fincher Street
				Field Sample ID:	F2-TW-0011423-24092-N	F2-TW-0011424-24092-N	F2-TW-0011430-24092-N	F2-TW-0011430-24092-3-N	F2-TW-0011436-24092-N	F2-TW-0011446-24092-N	F2-TW-0011467-24092-N	F2-TW-0011472-24092-N
				Sample Date:	2025-01-28	2025-02-11	2025-01-29	2025-01-29	2025-03-20	2025-02-19	2025-01-28	2025-02-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	0.550
	Bromoform	--	--	0.340	0.350	0.320	ND	ND	ND	0.450	2.10	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-DORI2273D	F2-DORI2274A	F2-DORI2275C		F2-DORI2277A	F2-DRIS2995	F2-ENGE4115	F2-FINC4123
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	2273D Doris Miller Loop	2274A Doris Miller Loop	2275C Doris Miller Loop		2277A Doris Miller Loop	2995 Driskell Drive	4115 Enger Street	4123 Fincher Street
		Field Sample ID:	F2-TW-0011423-24092-N	F2-TW-0011424-24092-N	F2-TW-0011430-24092-N	F2-TW-0011430-24092-3-N	F2-TW-0011436-24092-N	F2-TW-0011446-24092-N	F2-TW-0011467-24092-N	F2-TW-0011472-24092-N
		Sample Date:	2025-01-28	2025-02-11	2025-01-29	2025-01-29	2025-03-20	2025-02-19	2025-01-28	2025-02-21
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.270	0.310	ND	ND	ND	0.430	1.70
	Total Trihalomethanes	80	MCL	0.610	0.660	0.320	ND	ND	0.880	4.35

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-FINC4147	F2-GILL3212	F2-GILL3220	F2-GILL3234	F2-GILL3235	F2-GORD2647	F2-GORD2654	F2-GORD2690
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	4147 Fincher Street	3212 Gillespie Lane	3220 Gillespie Lane	3234 Gillespie Lane	3235 Gillespie Lane	2647 Gordon Street	2654 Gordon Street	2690 Gordon Street
				Field Sample ID:	F2-TW-0011480-24092-N	F2-TW-0011515-24092-N	F2-TW-0011520-24092-N	F2-TW-0011532-24092-N	F2-TW-0011533-24092-N	F2-TW-0011558-24092-N	F2-TW-0011563-24092-N	F2-TW-0011577-24092-N
				Sample Date:	2025-02-11	2025-01-28	2025-02-12	2025-01-28	2025-01-29	2025-03-17	2025-03-23	2025-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	690	710	1390	710	970	700	840	550	
Field Test (pH)	pH	--	--	7.17	7.20	7.03	7.27	7.23	7.27	7.12	7.23	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.280	0.240	0.240	0.260	0.230	0.270	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	23.5	24.3	23.2	23.0	24.1	23.2	23.5	22.9	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.820	0.280	0.170	0.130	3.75	0.620	0.0340	0.0570	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52500	52900	52400	53800	61100	54400	55100	51100	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	7.00	10.4	19.9	6.70	7.30	2.20	4.50	5.10	
	Lead	15	MCL	0.140	ND	0.450	ND	0.270	0.130	ND	0.190	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-FINC4147	F2-GILL3212	F2-GILL3220	F2-GILL3234	F2-GILL3235	F2-GORD2647	F2-GORD2654	F2-GORD2690
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	4147 Fincher Street	3212 Gillespie Lane	3220 Gillespie Lane	3234 Gillespie Lane	3235 Gillespie Lane	2647 Gordon Street	2654 Gordon Street	2690 Gordon Street
		Field Sample ID:	F2-TW-0011480-24092-N	F2-TW-0011515-24092-N	F2-TW-0011520-24092-N	F2-TW-0011532-24092-N	F2-TW-0011533-24092-N	F2-TW-0011558-24092-N	F2-TW-0011563-24092-N	F2-TW-0011577-24092-N
		Sample Date:	2025-02-11	2025-01-28	2025-02-12	2025-01-28	2025-01-29	2025-03-17	2025-03-23	2025-01-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.290	ND	ND	ND	ND	0.300	0.280
	Bromoform	--	--	0.740	0.510	ND	ND	0.580	0.650	0.880
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.620	0.380	ND	ND	0.570	0.680	0.760

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-FINC4147	F2-GILL3212	F2-GILL3220	F2-GILL3234	F2-GILL3235	F2-GORD2647	F2-GORD2654	F2-GORD2690
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	4147 Fincher Street	3212 Gillespie Lane	3220 Gillespie Lane	3234 Gillespie Lane	3235 Gillespie Lane	2647 Gordon Street	2654 Gordon Street	2690 Gordon Street
				Field Sample ID:	F2-TW-0011480-24092-N	F2-TW-0011515-24092-N	F2-TW-0011520-24092-N	F2-TW-0011532-24092-N	F2-TW-0011533-24092-N	F2-TW-0011558-24092-N	F2-TW-0011563-24092-N	F2-TW-0011577-24092-N
				Sample Date:	2025-02-11	2025-01-28	2025-02-12	2025-01-28	2025-01-29	2025-03-17	2025-03-23	2025-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	1.65	0.890	ND	ND	ND	1.15	1.63	1.92	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-GORD2724	F2-GORD2725	F2-GORD2735	F2-GORD2792	F2-GORD2860	F2-HAIL3114	F2-HAIL3124	F2-HAIL3130
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	2724 Gordon Street	2725 Gordon Street	2735 Gordon Street	2792 Gordon Street	2860 Gordon Street	3114 Hailey Court	3124 Hailey Court	3130 Hailey Court
				Field Sample ID:	F2-TW-0011588-24092-N	F2-TW-0011589-24092-N	F2-TW-0011593-24092-N	F2-TW-0011604-24092-N	F2-TW-0011621-24331-N	F2-TW-0011641-24092-N	F2-TW-0011646-24092-N	F2-TW-0011649-24092-N
				Sample Date:	2025-01-24	2025-03-24	2025-03-17	2025-01-20	2025-03-25	2025-01-27	2025-01-27	2025-01-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	410	650	660	570	850	700	420	780	
Field Test (pH)	pH	--	--	7.23	6.89	7.28	7.00	7.17	7.23	7.14	7.27	
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.250	0.230	0.250	0.270	0.240	0.300	0.240	
Field Test (degrees Celcuis)	Temperature	--	--	25.4	26.9	24.1	25.2	25.2	22.7	28.0	23.0	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.140	0.970	0.0490	1.34	0.290	0.0250	1.03	0.240	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	50000	54200	53600	52700	55300	51400	50700	53800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	7.60	2.40	3.60	10.8	3.90	15.6	13.0	15.2	
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	0.0110	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-GORD2724	F2-GORD2725	F2-GORD2735	F2-GORD2792	F2-GORD2860	F2-HAIL3114	F2-HAIL3124	F2-HAIL3130
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2724 Gordon Street	2725 Gordon Street	2735 Gordon Street	2792 Gordon Street	2860 Gordon Street	3114 Hailey Court	3124 Hailey Court	3130 Hailey Court
		Field Sample ID:	F2-TW-0011588-24092-N	F2-TW-0011589-24092-N	F2-TW-0011593-24092-N	F2-TW-0011604-24092-N	F2-TW-0011621-24331-N	F2-TW-0011641-24092-N	F2-TW-0011646-24092-N	F2-TW-0011649-24092-N
		Sample Date:	2025-01-24	2025-03-24	2025-03-17	2025-01-20	2025-03-25	2025-01-27	2025-01-27	2025-01-29
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.350	ND	0.360	0.310	0.420	0.300	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.330	0.300	0.280	0.330	0.430	0.260	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-GORD2724	F2-GORD2725	F2-GORD2735	F2-GORD2792	F2-GORD2860	F2-HAIL3114	F2-HAIL3124	F2-HAIL3130
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	2724 Gordon Street	2725 Gordon Street	2735 Gordon Street	2792 Gordon Street	2860 Gordon Street	3114 Hailey Court	3124 Hailey Court	3130 Hailey Court
				Field Sample ID:	F2-TW-0011588-24092-N	F2-TW-0011589-24092-N	F2-TW-0011593-24092-N	F2-TW-0011604-24092-N	F2-TW-0011621-24331-N	F2-TW-0011641-24092-N	F2-TW-0011646-24092-N	F2-TW-0011649-24092-N
				Sample Date:	2025-01-24	2025-03-24	2025-03-17	2025-01-20	2025-03-25	2025-01-27	2025-01-27	2025-01-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte											
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL		0.680	0.300	0.640	0.640	0.850	0.560	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-HAMM5301		F2-HAMP4130	F2-JALU3298	F2-KILM5440	F2-KIRK1956	F2-KIRK1983	F2-KOAI1656
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	5301 Hammond Lane		4130 Hampton Street	3298 Jaluit Lane	5440 Kilmer Lane	1956 Kirkpatrick Loop	1983 Kirkpatrick Loop	1656 Koaia Court
				Field Sample ID:	F2-TW-0011664-24092-N	F2-TW-0011664-24092-3-N	F2-TW-0011678-24092-N	F2-TW-0011706-24331-N	F2-TW-0011767-24092-N	F2-TW-0011779-24092-N	F2-TW-0011785-24092-N	F2-TW-0009838-24092-N
				Sample Date:	2025-01-24	2025-01-24	2025-01-29	2025-02-25	2025-02-19	2025-01-29	2025-01-29	2025-02-12
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	420	--		660	640	460	650	620	740
Field Test (pH)	pH	--	--	7.24	--		7.25	7.32	7.02	7.09	7.19	7.19
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	--		0.260	0.270	0.280	0.250	0.250	0.240
Field Test (degrees Celcuis)	Temperature	--	--	22.2	--		23.2	24.6	27.4	24.8	24.0	24.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.260	--		0.00	0.00	1.26	1.04	0.730	0.300
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	50100	49500		52200	53300	52900	52400	50900	52400
	Total Organic Carbon	--	--	ND	ND		ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND		ND	ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	38.4	43.5		2.40	50.4	47.1	4.70	4.20	67.1
	Lead	15	MCL	ND	ND		ND	0.210	0.260	0.160	0.250	ND
	Mercury	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-HAMM5301		F2-HAMP4130	F2-JALU3298	F2-KILM5440	F2-KIRK1956	F2-KIRK1983	F2-KOAI1656
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5301 Hammond Lane		4130 Hampton Street	3298 Jaluit Lane	5440 Kilmer Lane	1956 Kirkpatrick Loop	1983 Kirkpatrick Loop	1656 Koaia Court
		Field Sample ID:	F2-TW-0011664-24092-N	F2-TW-0011664-24092-3-N	F2-TW-0011678-24092-N	F2-TW-0011706-24331-N	F2-TW-0011767-24092-N	F2-TW-0011779-24092-N	F2-TW-0011785-24092-N	F2-TW-0009838-24092-N
		Sample Date:	2025-01-24	2025-01-24	2025-01-29	2025-02-25	2025-02-19	2025-01-29	2025-01-29	2025-02-12
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.360	ND	0.330	0.340	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.340	0.260	0.290	0.300	0.320

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-HAMM5301		F2-HAMP4130	F2-JALU3298	F2-KILM5440	F2-KIRK1956	F2-KIRK1983	F2-KOAI1656	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5301 Hammond Lane		4130 Hampton Street	3298 Jaluit Lane	5440 Kilmer Lane	1956 Kirkpatrick Loop	1983 Kirkpatrick Loop	1656 Koaia Court	
		Field Sample ID:	F2-TW-0011664-24092-N	F2-TW-0011664-24092-3-N	F2-TW-0011678-24092-N	F2-TW-0011706-24331-N	F2-TW-0011767-24092-N	F2-TW-0011779-24092-N	F2-TW-0011785-24092-N	F2-TW-0009838-24092-N	
		Sample Date:	2025-01-24	2025-01-24	2025-01-29	2025-02-25	2025-02-19	2025-01-29	2025-01-29	2025-02-12	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	0.700	0.260	0.620	0.640	0.720	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-KOEL5306	F2-KOUH1843	F2-KOUH1871	F2-LIPP2006	F2-LIPP2083	F2-LIPP2087	F2-LOUN4115	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5306 Koelsch Lane	1843 Kou Haole Loop	1871 Kou Haole Loop	2006 Lippia Loop	2083 Lippia Loop	2087 Lippia Loop	4115 Lounsbury Street	
		Field Sample ID:	F2-TW-0009852-24092-N	F2-TW-0009856-24092-N	F2-TW-0009861-24092-N	F2-TW-0009872-24092-N	F2-TW-0009878-24092-N	F2-TW-0009882-24092-N	F2-TW-0009889-24092-N-1-H-WQI	F2-TW-0009889-24092-N-1-WQI
		Sample Date:	2025-03-12	2025-01-29	2025-02-12	2025-03-20	2025-02-06	2025-02-06	2025-03-14	2025-03-14
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Bacterial Test (in 100 mL)	Coliform	--	--	--	--	--	--	--	--	Absent
	E. coli	--	--	--	--	--	--	--	--	Absent
Bacterial Test (MPN/mL)	Heterotrophic Plate Count	--	--	--	--	--	--	--	4.00	2.00
Field Test (ppb)	Free Chlorine	4000	MCL	60.0	540	510	950	520	680	720
Field Test (pH)	pH	--	--	7.31	7.13	7.12	7.27	7.32	7.21	7.18
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	0.240	0.260	0.290	0.260	0.270
Field Test (degrees Celcuis)	Temperature	--	--	21.6	25.6	23.1	23.7	26.3	24.6	40.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.570	1.31	0.500	0.170	0.690	0.470	3.41
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55400	52700	52600	54700	51900	53700	--
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	--
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	--
Metals (ppb)	Copper	1300	MCL	42.9	52.1	95.1	38.4	41.1	65.7	--
	Lead	15	MCL	0.140	ND	0.210	ND	ND	0.210	--
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	--
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	--
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	--
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	--
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	--

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-KOEL5306	F2-KOUH1843	F2-KOUH1871	F2-LIPP2006	F2-LIPP2083	F2-LIPP2087	F2-LOUN4115	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
				Address:	5306 Koelsch Lane	1843 Kou Haole Loop	1871 Kou Haole Loop	2006 Lippia Loop	2083 Lippia Loop	2087 Lippia Loop	4115 Lounsbury Street	
				Field Sample ID:	F2-TW-0009852-24092-N	F2-TW-0009856-24092-N	F2-TW-0009861-24092-N	F2-TW-0009872-24092-N	F2-TW-0009878-24092-N	F2-TW-0009882-24092-N	F2-TW-0009889-24092-N-1-H-WQI	F2-TW-0009889-24092-N-1-WQI
				Sample Date:	2025-03-12	2025-01-29	2025-02-12	2025-03-20	2025-02-06	2025-02-06	2025-03-14	2025-03-14
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-KOEL5306	F2-KOUH1843	F2-KOUH1871	F2-LIPP2006	F2-LIPP2083	F2-LIPP2087	F2-LOUN4115		
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence		
		Address:	5306 Koelsch Lane	1843 Kou Haole Loop	1871 Kou Haole Loop	2006 Lippia Loop	2083 Lippia Loop	2087 Lippia Loop	4115 Lounsbury Street		
		Field Sample ID:	F2-TW-0009852-24092-N	F2-TW-0009856-24092-N	F2-TW-0009861-24092-N	F2-TW-0009872-24092-N	F2-TW-0009878-24092-N	F2-TW-0009882-24092-N	F2-TW-0009889-24092-N-1-H-WQI	F2-TW-0009889-24092-N-1-WQI	
		Sample Date:	2025-03-12	2025-01-29	2025-02-12	2025-03-20	2025-02-06	2025-02-06	2025-03-14	2025-03-14	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Bromoform	--	--	ND	0.330	ND	0.350	0.320	0.320	--	0.370
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	--	ND
	Dibromochloromethane	--	--	ND	0.260	ND	0.360	0.310	0.300	--	0.390
	Total Trihalomethanes	80	MCL	ND	0.590	ND	0.710	0.630	0.620	--	0.760

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MALO3263	F2-MCCU1022	F2-MCCU1026	F2-MCCU1037	F2-MCCU1052	F2-MEYE0644	F2-MOOR3021	F2-MOOR3031
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3263 Maloelap Street	1022 McCurry Place	1026 McCurry Place	1037 McCurry Place	1052 McCurry Place	644 Meyerkord Loop	3021 Moore Drive	3031 Moore Drive
				Field Sample ID:	F2-TW-0009900-24092-N	F2-TW-0009909-24092-N	F2-TW-0009913-24092-N	F2-TW-0009924-24092-N	F2-TW-0009925-24092-N	F2-TW-0009967-24092-N	F2-TW-0009982-24092-N	F2-TW-0009987-24092-N
				Sample Date:	2025-03-17	2025-01-16	2025-02-21	2025-01-29	2025-02-12	2025-03-12	2025-02-11	2025-02-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	850	600	550	290	650	670	680	630	
Field Test (pH)	pH	--	--	7.25	7.27	7.12	7.24	7.09	7.26	6.99	7.10	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.280	0.250	0.250	0.240	0.260	0.270	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	24.6	26.8	26.7	26.7	23.4	23.9	28.8	25.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.820	0.780	0.950	0.0770	0.230	1.59	0.780	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54900	52300	51700	54100	51700	53300	50900	52500	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	9.90	4.50	1.40	2.80	3.60	70.2	20.2	20.6	
	Lead	15	MCL	0.170	ND	ND	0.240	0.840	0.310	2.00	0.210	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-MALO3263	F2-MCCU1022	F2-MCCU1026	F2-MCCU1037	F2-MCCU1052	F2-MEYE0644	F2-MOOR3021	F2-MOOR3031
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	3263 Maloelap Street	1022 McCurry Place	1026 McCurry Place	1037 McCurry Place	1052 McCurry Place	644 Meyerkord Loop	3021 Moore Drive	3031 Moore Drive
		Field Sample ID:	F2-TW-0009900-24092-N	F2-TW-0009909-24092-N	F2-TW-0009913-24092-N	F2-TW-0009924-24092-N	F2-TW-0009925-24092-N	F2-TW-0009967-24092-N	F2-TW-0009982-24092-N	F2-TW-0009987-24092-N
		Sample Date:	2025-03-17	2025-01-16	2025-02-21	2025-01-29	2025-02-12	2025-03-12	2025-02-11	2025-02-06
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.390	0.290	0.300	0.360	ND	ND
	Bromoform	--	--	0.330	1.20	0.970	1.20	1.10	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.290	1.10	0.800	0.900	0.840	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MALO3263	F2-MCCU1022	F2-MCCU1026	F2-MCCU1037	F2-MCCU1052	F2-MEYE0644	F2-MOOR3021	F2-MOOR3031
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3263 Maloelap Street	1022 McCurry Place	1026 McCurry Place	1037 McCurry Place	1052 McCurry Place	644 Meyerkord Loop	3021 Moore Drive	3031 Moore Drive
				Field Sample ID:	F2-TW-0009900-24092-N	F2-TW-0009909-24092-N	F2-TW-0009913-24092-N	F2-TW-0009924-24092-N	F2-TW-0009925-24092-N	F2-TW-0009967-24092-N	F2-TW-0009982-24092-N	F2-TW-0009987-24092-N
				Sample Date:	2025-03-17	2025-01-16	2025-02-21	2025-01-29	2025-02-12	2025-03-12	2025-02-11	2025-02-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	0.620	2.69	2.06	2.40	2.30	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MOOR3035	F2-MURR0666	F2-MURR0672	F2-MURR0680	F2-MURR0688	F2-MURR0793	F2-MURR0830	F2-MURR0845
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3035 Moore Drive	666 Murray Drive	672 Murray Drive	680 Murray Drive	688 Murray Drive	793 Murray Drive	830 Murray Drive	845 Murray Drive
				Field Sample ID:	F2-TW-0009989-24092-N	F2-TW-0010074-24092-N	F2-TW-0010076-24092-N	F2-TW-0010078-24092-N	F2-TW-0010080-24331-N	F2-TW-0010111-24092-N	F2-TW-0010121-24092-N	F2-TW-0010127-24092-N
				Sample Date:	2025-02-17	2025-01-27	2025-02-11	2025-02-19	2025-03-18	2025-03-12	2025-01-27	2025-01-27
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	680	560	620	610	650	700	780	790	
Field Test (pH)	pH	--	--	7.25	7.27	7.33	7.34	7.30	7.25	7.28	7.21	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	0.260	0.250	0.270	0.250	0.270	0.300	
Field Test (degrees Celcuis)	Temperature	--	--	25.0	21.6	23.8	26.6	23.2	25.4	26.7	24.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.120	0.00	0.00	0.540	0.00330	0.810	0.00	0.320	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52000	50300	52100	52300	54100	55600	52300	51800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	60.0	1.90	2.80	4.30	3.40	3.20	3.00	3.90	
	Lead	15	MCL	ND	0.140	ND	0.130	ND	ND	ND	0.170	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-MOOR3035	F2-MURR0666	F2-MURR0672	F2-MURR0680	F2-MURR0688	F2-MURR0793	F2-MURR0830	F2-MURR0845
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	3035 Moore Drive	666 Murray Drive	672 Murray Drive	680 Murray Drive	688 Murray Drive	793 Murray Drive	830 Murray Drive	845 Murray Drive
		Field Sample ID:	F2-TW-0009989-24092-N	F2-TW-0010074-24092-N	F2-TW-0010076-24092-N	F2-TW-0010078-24092-N	F2-TW-0010080-24331-N	F2-TW-0010111-24092-N	F2-TW-0010121-24092-N	F2-TW-0010127-24092-N
		Sample Date:	2025-02-17	2025-01-27	2025-02-11	2025-02-19	2025-03-18	2025-03-12	2025-01-27	2025-01-27
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.300	ND	ND	ND
	Bromoform	--	--	1.90	0.370	ND	0.500	ND	0.560	0.490
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.380	0.330	ND	0.620	0.320	ND	0.410

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-MOOR3035	F2-MURR0666	F2-MURR0672	F2-MURR0680	F2-MURR0688	F2-MURR0793	F2-MURR0830	F2-MURR0845	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	3035 Moore Drive	666 Murray Drive	672 Murray Drive	680 Murray Drive	688 Murray Drive	793 Murray Drive	830 Murray Drive	845 Murray Drive	
		Field Sample ID:	F2-TW-0009989-24092-N	F2-TW-0010074-24092-N	F2-TW-0010076-24092-N	F2-TW-0010078-24092-N	F2-TW-0010080-24331-N	F2-TW-0010111-24092-N	F2-TW-0010121-24092-N	F2-TW-0010127-24092-N	
		Sample Date:	2025-02-17	2025-01-27	2025-02-11	2025-02-19	2025-03-18	2025-03-12	2025-01-27	2025-01-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	2.28	0.700	ND	1.42	0.320	0.500	1.01	0.900

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MURR0854	F2-MURR0855		F2-MURR0863	F2-MURR0872	F2-MURR0880	F2-MURR0888	F2-MURR0937
				Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence
				Address:	854 Murray Drive	855 Murray Drive		863 Murray Drive	872 Murray Drive	880 Murray Drive	888 Murray Drive	937 Murray Drive
				Field Sample ID:	F2-TW-0010133-24092-N	F2-TW-0010134-24092-N	F2-TW-0010134-24092-3-N	F2-TW-0010140-24092-N	F2-TW-0010146-24092-N	F2-TW-0010150-24092-N	F2-TW-0010156-24092-N	F2-TW-0010169-24092-N
				Sample Date:	2025-02-19	2025-01-23	2025-01-23	2025-03-12	2025-01-27	2025-02-19	2025-02-17	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	570	450	--		630	640	570	640	650
Field Test (pH)	pH	--	--	7.14	7.30	--		7.30	7.31	7.52	7.23	7.50
Field Test (ms/cm)	Specific Conductivity	--	--	0.750	0.250	--		0.250	0.240	0.700	0.290	0.250
Field Test (degrees Celcuis)	Temperature	--	--	24.8	24.0	--		23.4	24.0	24.9	23.9	25.6
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0200	0.00	--		0.350	0.150	0.760	0.00380	0.0220
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	53800	53500	50300		55100	51500	51800	53100	52500
	Total Organic Carbon	--	--	ND	ND	ND		ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND		ND	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	5.70	3.00	2.80		4.30	3.40	18.5	2.30	3.30
	Lead	15	MCL	ND	ND	ND		0.270	0.210	ND	ND	0.130
	Mercury	2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND		ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-MURR0854	F2-MURR0855		F2-MURR0863	F2-MURR0872	F2-MURR0880	F2-MURR0888	F2-MURR0937
		Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence
		Address:	854 Murray Drive	855 Murray Drive		863 Murray Drive	872 Murray Drive	880 Murray Drive	888 Murray Drive	937 Murray Drive
		Field Sample ID:	F2-TW-0010133-24092-N	F2-TW-0010134-24092-N	F2-TW-0010134-24092-3-N	F2-TW-0010140-24092-N	F2-TW-0010146-24092-N	F2-TW-0010150-24092-N	F2-TW-0010156-24092-N	F2-TW-0010169-24092-N
		Sample Date:	2025-02-19	2025-01-23	2025-01-23	2025-03-12	2025-01-27	2025-02-19	2025-02-17	2025-02-17
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	0.290	0.490
	Bromoform	--	--	0.380	0.700	0.620	0.580	0.660	0.480	0.710
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.450	0.580	0.520	ND	0.530	0.470	0.670

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MURR0854	F2-MURR0855		F2-MURR0863	F2-MURR0872	F2-MURR0880	F2-MURR0888	F2-MURR0937
				Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence
				Address:	854 Murray Drive	855 Murray Drive		863 Murray Drive	872 Murray Drive	880 Murray Drive	888 Murray Drive	937 Murray Drive
				Field Sample ID:	F2-TW-0010133-24092-N	F2-TW-0010134-24092-N	F2-TW-0010134-24092-3-N	F2-TW-0010140-24092-N	F2-TW-0010146-24092-N	F2-TW-0010150-24092-N	F2-TW-0010156-24092-N	F2-TW-0010169-24092-N
				Sample Date:	2025-02-19	2025-01-23	2025-01-23	2025-03-12	2025-01-27	2025-02-19	2025-02-17	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte											
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	0.830	1.28	1.14	0.580	1.19	0.950	1.67	3.19	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MURR0942	F2-MURR0958	F2-MURR0966	F2-MURR0972	F2-NOON4021	F2-NOON4044	F2-NOON4052	F2-NYEC1676
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	942 Murray Drive	958 Murray Drive	966 Murray Drive	972 Murray Drive	4021 Noonan Street	4044 Noonan Street	4052 Noonan Street	1676 Nye Circle
				Field Sample ID:	F2-TW-0010173-24092-N	F2-TW-0010184-24092-N	F2-TW-0010186-24092-N	F2-TW-0010187-24092-N	F2-TW-0010398-24092-N	F2-TW-0010408-24092-N	F2-TW-0010411-24092-N	F2-TW-0010433-24092-N
				Sample Date:	2025-01-27	2025-03-12	2025-02-17	2025-02-12	2025-01-29	2025-02-21	2025-02-21	2025-01-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	660	580	850	540	590	680	480	650	
Field Test (pH)	pH	--	--	7.25	7.37	7.31	7.12	7.32	7.15	7.16	7.33	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.260	0.250	0.240	0.240	0.250	0.260	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	26.2	25.7	24.7	27.1	24.9	25.0	25.2	24.8	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.290	0.530	0.380	0.610	0.170	0.460	0.550	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	49500	55800	52400	51500	53700	53900	53400	51900	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	3.00	54.7	1.40	3.40	3.10	2.20	1.60	88.5	
	Lead	15	MCL	ND	0.390	ND	0.160	0.180	ND	ND	0.270	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-MURR0942	F2-MURR0958	F2-MURR0966	F2-MURR0972	F2-NOON4021	F2-NOON4044	F2-NOON4052	F2-NYEC1676
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	942 Murray Drive	958 Murray Drive	966 Murray Drive	972 Murray Drive	4021 Noonan Street	4044 Noonan Street	4052 Noonan Street	1676 Nye Circle
		Field Sample ID:	F2-TW-0010173-24092-N	F2-TW-0010184-24092-N	F2-TW-0010186-24092-N	F2-TW-0010187-24092-N	F2-TW-0010398-24092-N	F2-TW-0010408-24092-N	F2-TW-0010411-24092-N	F2-TW-0010433-24092-N
		Sample Date:	2025-01-27	2025-03-12	2025-02-17	2025-02-12	2025-01-29	2025-02-21	2025-02-21	2025-01-29
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	0.270	0.470	ND	ND	ND
	Bromoform	--	--	0.590	ND	0.660	1.40	0.350	0.510	0.300
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.520	ND	0.630	1.10	0.260	0.420	0.250

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-MURR0942	F2-MURR0958	F2-MURR0966	F2-MURR0972	F2-NOON4021	F2-NOON4044	F2-NOON4052	F2-NYEC1676
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	942 Murray Drive	958 Murray Drive	966 Murray Drive	972 Murray Drive	4021 Noonan Street	4044 Noonan Street	4052 Noonan Street	1676 Nye Circle
				Field Sample ID:	F2-TW-0010173-24092-N	F2-TW-0010184-24092-N	F2-TW-0010186-24092-N	F2-TW-0010187-24092-N	F2-TW-0010398-24092-N	F2-TW-0010408-24092-N	F2-TW-0010411-24092-N	F2-TW-0010433-24092-N
				Sample Date:	2025-01-27	2025-03-12	2025-02-17	2025-02-12	2025-01-29	2025-02-21	2025-02-21	2025-01-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	1.11	ND	1.56	2.97	0.610	0.930	0.990	0.550	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-NYEC1720	F2-NYEP1938				F2-NYEP1947	F2-OCAL1974	F2-PETE3212	F2-PETE3222
				Location Type:	Residence	Residential Child Care				Residence	Residence	Residence	Residence
				Address:	1720 Nye Circle	1938 Nye Place (CDH)				1947 Nye Place	1974 O'Callahan Street	3212 Peterson Court	3222 Peterson Court
				Field Sample ID:	F2-TW-0010434-24092-N	F2-TW-0010449-25001-N	F2-TW-0010449-25032-N	F2-TW-0010449-25060-N	F2-TW-0010452-24092-N	F2-TW-0010527-24092-N	F2-TW-0010542-24092-N	F2-TW-0010547-24092-N	
				Sample Date:	2025-01-29	2025-01-08	2025-02-06	2025-03-03	2025-03-12	2025-03-12	2025-01-29	2025-02-19	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Field Test (ppb)	Free Chlorine	4000	MCL	570	1000	590	550	630	640	640	500		
Field Test (pH)	pH	--	--	7.24	7.26	7.27	7.31	7.32	7.30	7.29	7.29		
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.250	0.250	0.270	0.260	0.260	0.250	0.730		
Field Test (degrees Celcuis)	Temperature	--	--	25.3	29.1	24.8	25.3	24.0	23.4	23.8	24.3		
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.280	0.0100	0.390	0.440	0.600	0.230	0.450	1.22		
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54400	58900	51800	52000	55600	54600	53900	50900		
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
Metals (ppb)	Copper	1300	MCL	30.2	34.4	32.1	46.8	65.8	7.80	20.9	2.30		
	Lead	15	MCL	ND	0.160	ND	0.170	0.290	0.390	ND	ND		
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-NYEC1720	F2-NYEP1938				F2-NYEP1947	F2-OCAL1974	F2-PETE3212	F2-PETE3222
				Location Type:	Residence	Residential Child Care				Residence	Residence	Residence	Residence
				Address:	1720 Nye Circle	1938 Nye Place (CDH)				1947 Nye Place	1974 O'Callahan Street	3212 Peterson Court	3222 Peterson Court
				Field Sample ID:	F2-TW-0010434-24092-N	F2-TW-0010449-25001-N	F2-TW-0010449-25032-N	F2-TW-0010449-25060-N		F2-TW-0010452-24092-N	F2-TW-0010527-24092-N	F2-TW-0010542-24092-N	F2-TW-0010547-24092-N
				Sample Date:	2025-01-29	2025-01-08	2025-02-06	2025-03-03		2025-03-12	2025-03-12	2025-01-29	2025-02-19
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Synthetic Organic Compounds (ppb)	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.530	0.340	ND	0.320	0.480	0.460	0.310		

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-NYEC1720	F2-NYEP1938				F2-NYEP1947	F2-OCAL1974	F2-PETE3212	F2-PETE3222
		Location Type:	Residence	Residential Child Care				Residence	Residence	Residence	Residence
		Address:	1720 Nye Circle	1938 Nye Place (CDH)				1947 Nye Place	1974 O'Callahan Street	3212 Peterson Court	3222 Peterson Court
		Field Sample ID:	F2-TW-0010434-24092-N	F2-TW-0010449-25001-N	F2-TW-0010449-25032-N	F2-TW-0010449-25060-N	F2-TW-0010452-24092-N	F2-TW-0010527-24092-N	F2-TW-0010542-24092-N	F2-TW-0010547-24092-N	
		Sample Date:	2025-01-29	2025-01-08	2025-02-06	2025-03-03	2025-03-12	2025-03-12	2025-01-29	2025-02-19	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	0.370	0.300	0.250	ND	ND	0.360	0.300
	Total Trihalomethanes	80	MCL	ND	0.900	0.640	0.250	0.320	0.480	0.820	0.610

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-PETE3256	F2-PETE3258	F2-PLUM1652		F2-PLUM1678	F2-POOL0617	F2-POOL0649	F2-POOL0653
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	3256 Peterson Court	3258 Peterson Court	1652 Plumbago Court		1678 Plumbago Court	617 Pool Street	649 Pool Street	653 Pool Street
				Field Sample ID:	F2-TW-0010798-24092-N	F2-TW-0010799-24092-N	F2-TW-0010804-24092-N	F2-TW-0010804-24092-3-N	F2-TW-0010816-24092-N	F2-TW-0010820-24092-N	F2-TW-0010826-24092-N	F2-TW-0010827-24092-N
				Sample Date:	2025-03-12	2025-01-29	2025-02-21	2025-02-21	2025-02-06	2025-02-11	2025-02-19	2025-03-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	650	710	610	--	1050	870	610	1160	
Field Test (pH)	pH	--	--	7.29	7.05	7.30	--	7.21	7.18	7.20	7.28	
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	0.260	0.250	--	0.280	0.260	0.270	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	25.5	25.7	25.2	--	27.8	23.3	24.9	26.2	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.530	1.02	0.390	--	1.76	0.150	0.430	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55100	53800	51500	50500	51300	52100	51400	53700	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	19.6	16.4	61.7	61.6	40.3	3.20	3.90	9.90	
	Lead	15	MCL	ND	ND	0.170	0.160	0.180	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-PETE3256	F2-PETE3258	F2-PLUM1652		F2-PLUM1678	F2-POOL0617	F2-POOL0649	F2-POOL0653
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	3256 Peterson Court	3258 Peterson Court	1652 Plumbago Court		1678 Plumbago Court	617 Pool Street	649 Pool Street	653 Pool Street
				Field Sample ID:	F2-TW-0010798-24092-N	F2-TW-0010799-24092-N	F2-TW-0010804-24092-N	F2-TW-0010804-24092-3-N	F2-TW-0010816-24092-N	F2-TW-0010820-24092-N	F2-TW-0010826-24092-N	F2-TW-0010827-24092-N
				Sample Date:	2025-03-12	2025-01-29	2025-02-21	2025-02-21	2025-02-06	2025-02-11	2025-02-19	2025-03-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.550	0.410	0.310	0.300	0.310	0.390	ND	0.460	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.340	0.300	0.290	0.310	0.380	0.340	0.450	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-PETE3256	F2-PETE3258	F2-PLUM1652		F2-PLUM1678	F2-POOL0617	F2-POOL0649	F2-POOL0653	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	3256 Peterson Court	3258 Peterson Court	1652 Plumbago Court		1678 Plumbago Court	617 Pool Street	649 Pool Street	653 Pool Street	
		Field Sample ID:	F2-TW-0010798-24092-N	F2-TW-0010799-24092-N	F2-TW-0010804-24092-N	F2-TW-0010804-24092-3-N	F2-TW-0010816-24092-N	F2-TW-0010820-24092-N	F2-TW-0010826-24092-N	F2-TW-0010827-24092-N	
		Sample Date:	2025-03-12	2025-01-29	2025-02-21	2025-02-21	2025-02-06	2025-02-11	2025-02-19	2025-03-01	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	0.550	0.750	0.610	0.590	0.620	0.770	0.340	0.910

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-POOL0730	F2-RAMA0821	F2-SAND0741	F2-SCHM2744	F2-SCHM2756	F2-SCHM2780		F2-SCHM2788
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	730 Pool Street	821 Ramage Street	741 Sanders Circle	2744 Schmitt Parkway	2756 Schmitt Parkway	2780 Schmitt Parkway		2788 Schmitt Parkway
				Field Sample ID:	F2-TW-0010838-24092-N	F2-TW-0010852-24092-N	F2-TW-0010873-24092-N	F2-TW-0010875-24092-N	F2-TW-0010878-24092-N	F2-TW-0010888-24092-N	F2-TW-0010888-24092-3-N	F2-TW-0010891-24092-N
				Sample Date:	2025-01-29	2025-02-21	2025-03-17	2025-02-21	2025-03-12	2025-02-11	2025-02-11	2025-02-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	890	590	210	140	640	570	--		630
Field Test (pH)	pH	--	--	7.31	7.27	7.14	7.07	7.35	7.11	--		7.26
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.260	0.260	0.250	0.260	--		0.260
Field Test (degrees Celcuis)	Temperature	--	--	26.0	24.5	23.9	23.7	25.2	25.5	--		22.4
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.400	0.00	0.180	0.530	1.13	--		0.00
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51400	52800	55800	54200	55900	52500	50900		50400
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND		ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND		ND
Metals (ppb)	Copper	1300	MCL	2.40	5.10	9.40	11.4	9.50	3.40	3.50		3.00
	Lead	15	MCL	ND	ND	0.490	ND	0.270	0.220	0.230		0.210
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND		ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-POOL0730	F2-RAMA0821	F2-SAND0741	F2-SCHM2744	F2-SCHM2756	F2-SCHM2780		F2-SCHM2788
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	730 Pool Street	821 Ramage Street	741 Sanders Circle	2744 Schmitt Parkway	2756 Schmitt Parkway	2780 Schmitt Parkway		2788 Schmitt Parkway
		Field Sample ID:	F2-TW-0010838-24092-N	F2-TW-0010852-24092-N	F2-TW-0010873-24092-N	F2-TW-0010875-24092-N	F2-TW-0010878-24092-N	F2-TW-0010888-24092-N	F2-TW-0010888-24092-3-N	F2-TW-0010891-24092-N
		Sample Date:	2025-01-29	2025-02-21	2025-03-17	2025-02-21	2025-03-12	2025-02-11	2025-02-11	2025-02-06
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	0.750	ND	ND	ND	ND
	Bromoform	--	--	0.410	0.430	3.40	0.460	0.390	0.410	0.440
	Chloroform	--	--	ND	ND	0.470	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.380	0.440	1.90	0.490	ND	0.370	0.370

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-POOL0730	F2-RAMA0821	F2-SAND0741	F2-SCHM2744	F2-SCHM2756	F2-SCHM2780		F2-SCHM2788	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence	
		Address:	730 Pool Street	821 Ramage Street	741 Sanders Circle	2744 Schmitt Parkway	2756 Schmitt Parkway	2780 Schmitt Parkway		2788 Schmitt Parkway	
		Field Sample ID:	F2-TW-0010838-24092-N	F2-TW-0010852-24092-N	F2-TW-0010873-24092-N	F2-TW-0010875-24092-N	F2-TW-0010878-24092-N	F2-TW-0010888-24092-N	F2-TW-0010888-24092-3-N	F2-TW-0010891-24092-N	
		Sample Date:	2025-01-29	2025-02-21	2025-03-17	2025-02-21	2025-03-12	2025-02-11	2025-02-11	2025-02-06	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	0.790	0.870	6.52	0.950	0.390	0.780	0.770	0.810

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-SHIE3263	F2-SHIE5230	F2-SHIE5296	F2-SHIE5314	F2-SHIE5320	F2-SHIE5328	F2-SHIE5334	F2-SIBL0713
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3263 Shields Lane	5230 Shields Street	5296 Shields Street	5314 Shields Street	5320 Shields Street	5328 Shields Street	5334 Shields Street	713 Sibley Street
				Field Sample ID:	F2-TW-0010893-24092-N	F2-TW-0010907-24092-N	F2-TW-0010922-24092-N	F2-TW-0010925-24092-N	F2-TW-0010927-24331-N	F2-TW-0010929-24092-N	F2-TW-0010931-24092-N	F2-TW-0010938-24092-N
				Sample Date:	2025-03-17	2025-02-17	2025-03-12	2025-02-17	2025-01-28	2025-02-17	2025-02-17	2025-03-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	760	830	620	840	500	980	640	570	
Field Test (pH)	pH	--	--	7.26	7.23	7.27	7.25	7.07	7.30	7.20	7.27	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.260	0.250	0.250	0.250	0.250	0.300	
Field Test (degrees Celcuis)	Temperature	--	--	24.2	24.6	24.1	24.7	22.8	25.5	23.7	28.4	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.0530	0.00880	0.300	0.00	0.00	0.240	0.0370	1.73	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	54400	52700	55300	52000	51200	51400	50400	54600	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	55.5	18.4	67.8	13.9	9.30	12.0	9.00	3.00	
	Lead	15	MCL	0.190	0.170	0.200	ND	0.210	ND	0.150	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-SHIE3263	F2-SHIE5230	F2-SHIE5296	F2-SHIE5314	F2-SHIE5320	F2-SHIE5328	F2-SHIE5334	F2-SIBL0713
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	3263 Shields Lane	5230 Shields Street	5296 Shields Street	5314 Shields Street	5320 Shields Street	5328 Shields Street	5334 Shields Street	713 Sibley Street
		Field Sample ID:	F2-TW-0010893-24092-N	F2-TW-0010907-24092-N	F2-TW-0010922-24092-N	F2-TW-0010925-24092-N	F2-TW-0010927-24331-N	F2-TW-0010929-24092-N	F2-TW-0010931-24092-N	F2-TW-0010938-24092-N
		Sample Date:	2025-03-17	2025-02-17	2025-03-12	2025-02-17	2025-01-28	2025-02-17	2025-02-17	2025-03-13
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.410	ND	0.310	0.650	0.710
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.290	ND	0.250	0.280	0.510	0.600

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-SHIE3263	F2-SHIE5230	F2-SHIE5296	F2-SHIE5314	F2-SHIE5320	F2-SHIE5328	F2-SHIE5334	F2-SIBL0713
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3263 Shields Lane	5230 Shields Street	5296 Shields Street	5314 Shields Street	5320 Shields Street	5328 Shields Street	5334 Shields Street	713 Sibley Street
				Field Sample ID:	F2-TW-0010893-24092-N	F2-TW-0010907-24092-N	F2-TW-0010922-24092-N	F2-TW-0010925-24092-N	F2-TW-0010927-24331-N	F2-TW-0010929-24092-N	F2-TW-0010931-24092-N	F2-TW-0010938-24092-N
				Sample Date:	2025-03-17	2025-02-17	2025-03-12	2025-02-17	2025-01-28	2025-02-17	2025-02-17	2025-03-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	0.290	0.410	0.250	0.590	1.16	0.250	1.31	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-SIBL0713	F2-SIBL0720	F2-SIBL0733	F2-SIBL0736	F2-SIBL0744	F2-SIBL0760	F2-SNYD3166	F2-SNYD3204
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	713 Sibley Street	720 Sibley Street	733 Sibley Street	736 Sibley Street	744 Sibley Street	760 Sibley Street	3166 Snyder Court	3204 Snyder Court
				Field Sample ID:	F2-TW-0010938-24092-3-N	F2-TW-0010943-24092-N	F2-TW-0010952-24092-N	F2-TW-0010955-24092-N	F2-TW-0010961-24331-N	F2-TW-0010563-24092-N	F2-TW-0010584-24092-N	F2-TW-0010973-24092-N
				Sample Date:	2025-03-13	2025-02-11	2025-02-23	2025-02-21	2025-01-23	2025-02-17	2025-02-11	2025-02-11
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	--	770	760	610	600	660	700	700	
Field Test (pH)	pH	--	--	--	7.32	7.33	7.11	7.25	7.30	7.06	7.27	
Field Test (ms/cm)	Specific Conductivity	--	--	--	0.260	0.290	0.250	0.270	0.250	0.260	0.230	
Field Test (degrees Celcuis)	Temperature	--	--	--	25.1	23.1	23.9	25.8	26.2	28.0	24.9	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	--	0.00	0.00	0.470	0.580	0.00	0.00	0.150	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	56400	51500	54900	54500	52300	51400	51000	51800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	23.2	3.50	2.80	3.10	3.50	6.50	27.6	23.0	
	Lead	15	MCL	0.150	0.340	0.270	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-SIBL0713	F2-SIBL0720	F2-SIBL0733	F2-SIBL0736	F2-SIBL0744	F2-SIBL0760	F2-SNYD3166	F2-SNYD3204
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	713 Sibley Street	720 Sibley Street	733 Sibley Street	736 Sibley Street	744 Sibley Street	760 Sibley Street	3166 Snyder Court	3204 Snyder Court
		Field Sample ID:	F2-TW-0010938-24092-3-N	F2-TW-0010943-24092-N	F2-TW-0010952-24092-N	F2-TW-0010955-24092-N	F2-TW-0010961-24331-N	F2-TW-0010563-24092-N	F2-TW-0010584-24092-N	F2-TW-0010973-24092-N
		Sample Date:	2025-03-13	2025-02-11	2025-02-23	2025-02-21	2025-01-23	2025-02-17	2025-02-11	2025-02-11
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.620	0.550	0.450	0.490	0.310	0.330	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.530	0.490	0.510	0.470	0.300	0.440	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-SIBL0713	F2-SIBL0720	F2-SIBL0733	F2-SIBL0736	F2-SIBL0744	F2-SIBL0760	F2-SNYD3166	F2-SNYD3204	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	713 Sibley Street	720 Sibley Street	733 Sibley Street	736 Sibley Street	744 Sibley Street	760 Sibley Street	3166 Snyder Court	3204 Snyder Court	
		Field Sample ID:	F2-TW-0010938-24092-3-N	F2-TW-0010943-24092-N	F2-TW-0010952-24092-N	F2-TW-0010955-24092-N	F2-TW-0010961-24331-N	F2-TW-0010563-24092-N	F2-TW-0010584-24092-N	F2-TW-0010973-24092-N	
		Sample Date:	2025-03-13	2025-02-11	2025-02-23	2025-02-21	2025-01-23	2025-02-17	2025-02-11	2025-02-11	
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	1.15	1.04	0.960	0.960	0.610	0.770	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-STOW2571	F2-STOW2585	F2-STOW2680	F2-STOW2731	F2-STOW2741	F2-STOW2760	F2-STOW2784	F2-STOW2785
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	2571 Stowell Circle	2585 Stowell Circle	2680 Stowell Circle	2731 Stowell Circle	2741 Stowell Circle	2760 Stowell Circle	2784 Stowell Circle	2785 Stowell Circle
				Field Sample ID:	F2-TW-0010979-24092-N	F2-TW-0010986-24092-N	F2-TW-0009261-24092-N	F2-TW-0009276-24092-N	F2-TW-0009281-24092-N	F2-TW-0009283-24092-N	F2-TW-0009292-24092-N	F2-TW-0009293-24092-N
				Sample Date:	2025-02-06	2025-02-06	2025-02-06	2025-02-06	2025-02-17	2025-02-21	2025-03-12	2025-02-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	840	580	1220	630	660	550	860	590	
Field Test (pH)	pH	--	--	7.08	7.29	7.26	7.28	7.28	7.11	7.32	7.00	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.250	0.280	0.250	0.250	0.250	0.240	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	24.1	25.1	23.1	25.8	23.2	24.6	22.1	25.9	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.890	0.380	0.210	0.520	0.00540	0.530	0.00	0.370	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51200	54600	51300	52700	53400	53900	54400	52900	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	3.80	3.00	3.70	3.90	2.90	1.90	5.10	4.40	
	Lead	15	MCL	0.280	ND	0.140	0.180	0.400	ND	0.230	0.410	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-STOW2571	F2-STOW2585	F2-STOW2680	F2-STOW2731	F2-STOW2741	F2-STOW2760	F2-STOW2784	F2-STOW2785
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2571 Stowell Circle	2585 Stowell Circle	2680 Stowell Circle	2731 Stowell Circle	2741 Stowell Circle	2760 Stowell Circle	2784 Stowell Circle	2785 Stowell Circle
		Field Sample ID:	F2-TW-0010979-24092-N	F2-TW-0010986-24092-N	F2-TW-0009261-24092-N	F2-TW-0009276-24092-N	F2-TW-0009281-24092-N	F2-TW-0009283-24092-N	F2-TW-0009292-24092-N	F2-TW-0009293-24092-N
		Sample Date:	2025-02-06	2025-02-06	2025-02-06	2025-02-06	2025-02-17	2025-02-21	2025-03-12	2025-02-21
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.280	0.280	0.250	0.320	0.470	0.290	0.320
	Bromoform	--	--	0.990	1.10	0.850	1.00	1.30	0.820	0.930
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.790	0.830	0.680	0.860	1.20	0.690	0.810

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-STOW2571	F2-STOW2585	F2-STOW2680	F2-STOW2731	F2-STOW2741	F2-STOW2760	F2-STOW2784	F2-STOW2785
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	2571 Stowell Circle	2585 Stowell Circle	2680 Stowell Circle	2731 Stowell Circle	2741 Stowell Circle	2760 Stowell Circle	2784 Stowell Circle	2785 Stowell Circle
				Field Sample ID:	F2-TW-0010979-24092-N	F2-TW-0010986-24092-N	F2-TW-0009261-24092-N	F2-TW-0009276-24092-N	F2-TW-0009281-24092-N	F2-TW-0009283-24092-N	F2-TW-0009292-24092-N	F2-TW-0009293-24092-N
				Sample Date:	2025-02-06	2025-02-06	2025-02-06	2025-02-06	2025-02-17	2025-02-21	2025-03-12	2025-02-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte											
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	2.06	2.21	1.78	2.18	2.97	1.80	1.93	2.06	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-VAES3022		F2-VAES3068	F2-VAES3070	F2-VAES3074
		Location Type:	Residence		Residence	Residence	Residence
		Address:	3022 Vaessen Court		3068 Vaessen Court	3070 Vaessen Court	3074 Vaessen Court
		Field Sample ID:	F2-TW-0009325-24092-N	F2-TW-0009325-24092-3-N	F2-TW-0009348-24092-N	F2-TW-0009349-24092-N	F2-TW-0009351-24092-N
		Sample Date:	2025-02-11	2025-02-11	2025-02-17	2025-02-17	2025-03-12
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Field Test (ppb)	Free Chlorine	4000	MCL	570	--	740	830
Field Test (pH)	pH	--	--	7.14	--	7.16	7.17
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	--	0.250	0.250
Field Test (degrees Celcuis)	Temperature	--	--	25.3	--	24.4	24.3
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	0.240	0.160
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	51400	51300	51800	52200
	Total Organic Carbon	--	--	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND
Metals (ppb)	Copper	1300	MCL	15.6	15.4	20.1	13.3
	Lead	15	MCL	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND
	2-Methylnaphthalene	--	--	ND	ND	ND	ND
	Acenaphthylene	--	--	ND	ND	ND	ND
	Anthracene	--	--	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

		Location ID:	F2-VAES3022		F2-VAES3068	F2-VAES3070	F2-VAES3074
		Location Type:	Residence		Residence	Residence	Residence
		Address:	3022 Vaessen Court		3068 Vaessen Court	3070 Vaessen Court	3074 Vaessen Court
		Field Sample ID:	F2-TW-0009325-24092-N	F2-TW-0009325-24092-3-N	F2-TW-0009348-24092-N	F2-TW-0009349-24092-N	F2-TW-0009351-24092-N
		Sample Date:	2025-02-11	2025-02-11	2025-02-17	2025-02-17	2025-03-12
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Synthetic Organic Compounds (ppb)	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	0.340
	Chloroform	--	--	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.280	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Residences in Zone F2

				Location ID:	F2-VAES3022		F2-VAES3068	F2-VAES3070	F2-VAES3074
				Location Type:	Residence		Residence	Residence	Residence
				Address:	3022 Vaessen Court		3068 Vaessen Court	3070 Vaessen Court	3074 Vaessen Court
				Field Sample ID:	F2-TW-0009325-24092-N	F2-TW-0009325-24092-3-N	F2-TW-0009348-24092-N	F2-TW-0009349-24092-N	F2-TW-0009351-24092-N
				Sample Date:	2025-02-11	2025-02-11	2025-02-17	2025-02-17	2025-03-12
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level				
Method Group	Analyte								
Trihalomethanes (ppb)	Total Trihalomethanes	80	MCL	ND	ND	ND	0.280	0.340	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone F2

				Location ID:	F2-BLDG1928							F2-BLDG4655
				Location Type:	Child Development Center							Child Development Center
				Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)							Building 4655,CATLIN SCHOOL AGE CENTER
				Field Sample ID:	F2-TW-0014145-25001-N-1	F2-TW-0014145-25001-N-2	F2-TW-0014145-25032-N-1	F2-TW-0014145-25032-N-2	F2-TW-0014145-25032-3-N-1	F2-TW-0014145-25060-N-1	F2-TW-0014145-25060-N-2	F2-TW-0014156-25001-N-1
				Sample Date:	2025-01-08	2025-01-08	2025-02-06	2025-02-06	2025-02-06	2025-03-03	2025-03-03	2025-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	690	690	600	610	--	830	500	470	
Field Test (pH)	pH	--	--	7.17	7.16	7.12	7.20	--	7.28	7.26	7.35	
Field Test (ms/cm)	Specific Conductivity	--	--	0.250	0.260	0.250	0.250	--	0.250	0.260	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	24.3	25.1	23.3	23.8	--	23.1	24.4	24.0	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.530	0.330	--	0.120	0.150	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	59100	60000	50700	51900	51100	52400	55000	62200	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	22.8	29.0	29.4	22.9	29.3	29.0	49.9	82.1	
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone F2

				Location ID:	F2-BLDG1928							F2-BLDG4655
				Location Type:	Child Development Center							Child Development Center
				Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)							Building 4655,CATLIN SCHOOL AGE CENTER
				Field Sample ID:	F2-TW-0014145-25001-N-1	F2-TW-0014145-25001-N-2	F2-TW-0014145-25032-N-1	F2-TW-0014145-25032-N-2	F2-TW-0014145-25032-3-N-1	F2-TW-0014145-25060-N-1	F2-TW-0014145-25060-N-2	F2-TW-0014156-25001-N-1
				Sample Date:	2025-01-08	2025-01-08	2025-02-06	2025-02-06	2025-02-06	2025-03-03	2025-03-03	2025-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development Centers in Zone F2

				Location ID:	F2-BLDG1928							F2-BLDG4655
				Location Type:	Child Development Center							Child Development Center
				Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)							Building 4655,CATLIN SCHOOL AGE CENTER
				Field Sample ID:	F2-TW-0014145-25001-N-1	F2-TW-0014145-25001-N-2	F2-TW-0014145-25032-N-1	F2-TW-0014145-25032-N-2	F2-TW-0014145-25032-3-N-1	F2-TW-0014145-25060-N-1	F2-TW-0014145-25060-N-2	F2-TW-0014156-25001-N-1
				Sample Date:	2025-01-08	2025-01-08	2025-02-06	2025-02-06	2025-02-06	2025-03-03	2025-03-03	2025-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.310	0.350	0.310	0.360	0.390	0.430	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.300	0.270	0.280	0.360	0.340	0.390	
	Total Trihalomethanes	80	MCL	ND	ND	0.610	0.620	0.590	0.720	0.730	0.820	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development
Centers in Zone F2

				Location ID:	F2-BLDG4655				
				Location Type:	Child Development Center				
				Address:	Building 4655,CATLIN SCHOOL AGE CENTER				
				Field Sample ID:	F2-TW-0014156-25001-N-2	F2-TW-0014156-25032-N-1	F2-TW-0014156-25032-N-2	F2-TW-0014156-25060-N-1	F2-TW-0014156-25060-N-2
				Sample Date:	2025-01-08	2025-02-06	2025-02-06	2025-03-03	2025-03-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Field Test (ppb)	Free Chlorine	4000	MCL	640	820	950	120	550	
Field Test (pH)	pH	--	--	7.32	7.33	7.31	7.17	7.20	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.280	0.280	0.250	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	24.0	21.3	21.9	23.7	25.4	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	0.00	0.0480	0.270	1.68	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	60500	53000	53100	53700	52800	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	
Metals (ppb)	Copper	1300	MCL	36.7	141	48.4	127	43.7	
	Lead	15	MCL	ND	ND	ND	0.290	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development
Centers in Zone F2

				Location ID:	F2-BLDG4655				
				Location Type:	Child Development Center				
				Address:	Building 4655,CATLIN SCHOOL AGE CENTER				
				Field Sample ID:	F2-TW-0014156-25001-N-2	F2-TW-0014156-25032-N-1	F2-TW-0014156-25032-N-2	F2-TW-0014156-25060-N-1	F2-TW-0014156-25060-N-2
				Sample Date:	2025-01-08	2025-02-06	2025-02-06	2025-03-03	2025-03-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Synthetic Organic Compounds (ppb)	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	ND	ND	ND	ND	ND
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND
	Fluorene	--	--	ND	ND	ND	ND	ND	ND
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Child Development
Centers in Zone F2

				Location ID:	F2-BLDG4655				
				Location Type:	Child Development Center				
				Address:	Building 4655,CATLIN SCHOOL AGE CENTER				
				Field Sample ID:	F2-TW-0014156-25001-N-2	F2-TW-0014156-25032-N-1	F2-TW-0014156-25032-N-2	F2-TW-0014156-25060-N-1	F2-TW-0014156-25060-N-2
				Sample Date:	2025-01-08	2025-02-06	2025-02-06	2025-03-03	2025-03-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Volatile Organic Compounds (ppb)	Toluene	1000	MCL	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.510	0.320	
	Bromoform	--	--	ND	0.310	1.10	3.90	1.90	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.260	0.310	0.650	1.70	1.00	
	Total Trihalomethanes	80	MCL	0.260	0.620	1.75	6.11	3.22	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0002				F2-HYD0003			
				Location Type:	Hydrant				Hydrant			
				Address:	FH 2				FH 3			
				Field Sample ID:	F2-DL-0017744-25001 -N	F2-DL-0017744-25001 -3-N	F2-DL-0017744-25032 -N	F2-DL-0017744-25060 -N	F2-DL-0017772-25001 -N	F2-DL-0017772-25032 -N	F2-DL-0017772-25032 -3-N	F2-DL-0017772-25060 -N
				Sample Date:	2025-01-08	2025-01-08	2025-02-19	2025-03-03	2025-01-08	2025-02-19	2025-02-19	2025-03-03
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	670	--	580	560	630	1140	--	390	
Field Test (pH)	pH	--	--	7.30	--	7.30	6.95	7.36	7.55	--	7.14	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	--	0.270	0.250	0.230	0.280	--	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	23.1	--	24.1	26.3	25.4	26.3	--	28.1	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.00	--	0.960	1.35	0.0360	0.390	--	1.25	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	58400	59700	50800	51800	59400	52400	52800	55400	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0002				F2-HYD0003			
				Location Type:	Hydrant				Hydrant			
				Address:	FH 2				FH 3			
				Field Sample ID:	F2-DL-0017744-25001 -N	F2-DL-0017744-25001 -3-N	F2-DL-0017744-25032 -N	F2-DL-0017744-25060 -N	F2-DL-0017772-25001 -N	F2-DL-0017772-25032 -N	F2-DL-0017772-25032 -3-N	F2-DL-0017772-25060 -N
				Sample Date:	2025-01-08	2025-01-08	2025-02-19	2025-03-03	2025-01-08	2025-02-19	2025-02-19	2025-03-03
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	ND	--	--	ND	--	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	ND	--	--	ND	--	--	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	0.270	0.300	0.290	
	Bromoform	--	--	ND	ND	0.380	0.310	0.800	0.590	0.850	0.790	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	ND	ND	0.270	0.550	0.640	0.660	0.690	
	Total Trihalomethanes	80	MCL	ND	ND	0.380	0.580	1.35	1.50	1.81	1.77	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0011			F2-HYD0012			F2-HYD0014	
				Location Type:	Hydrant			Hydrant			Hydrant	
				Address:	FH 11			FH 12 (Correct LOCID is F2-HYD1338)			FH 14	
				Field Sample ID:	F2-DL-0017745-25001 -N	F2-DL-0017745-25032 -N	F2-DL-0017745-25060 -N	F2-DL-0017776-25001 -N	F2-DL-0017776-25032 -N	F2-DL-0017776-25060 -N	F2-DL-0017746-25001 -N	F2-DL-0017746-25032 -N
				Sample Date:	2025-01-16	2025-02-17	2025-03-17	2025-01-16	2025-02-17	2025-03-20	2025-01-16	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	440	730	740	620	800	920	500	830	
Field Test (pH)	pH	--	--	8.30	7.28	7.39	7.18	7.27	7.25	7.17	7.11	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.260	0.260	0.230	0.290	0.260	0.230	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	26.9	25.7	26.5	26.2	24.2	26.1	26.5	24.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.260	0.280	1.40	0.470	0.00	1.40	0.360	0.690	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	65400	54400	57500	54700	53600	55300	53000	52300	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0011			F2-HYD0012			F2-HYD0014	
				Location Type:	Hydrant			Hydrant			Hydrant	
				Address:	FH 11			FH 12 (Correct LOCID is F2-HYD1338)			FH 14	
				Field Sample ID:	F2-DL-0017745-25001 -N	F2-DL-0017745-25032 -N	F2-DL-0017745-25060 -N	F2-DL-0017776-25001 -N	F2-DL-0017776-25032 -N	F2-DL-0017776-25060 -N	F2-DL-0017746-25001 -N	F2-DL-0017746-25032 -N
				Sample Date:	2025-01-16	2025-02-17	2025-03-17	2025-01-16	2025-02-17	2025-03-20	2025-01-16	2025-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	ND	--	--	--	ND	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	ND	--	--	--	ND	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.620	0.250	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	14.3	2.10	2.00	0.460	ND	0.400	0.540	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

		Location ID:	F2-HYD0011			F2-HYD0012			F2-HYD0014		
		Location Type:	Hydrant			Hydrant			Hydrant		
		Address:	FH 11			FH 12 (Correct LOCID is F2-HYD1338)			FH 14		
		Field Sample ID:	F2-DL-0017745-25001-N	F2-DL-0017745-25032-N	F2-DL-0017745-25060-N	F2-DL-0017776-25001-N	F2-DL-0017776-25032-N	F2-DL-0017776-25060-N	F2-DL-0017746-25001-N	F2-DL-0017746-25032-N	
		Sample Date:	2025-01-16	2025-02-17	2025-03-17	2025-01-16	2025-02-17	2025-03-20	2025-01-16	2025-02-17	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Trihalomethanes (ppb)	Dibromochloromethane	--	--	2.20	0.750	0.650	0.360	0.290	0.370	0.430	0.270
	Total Trihalomethanes	80	MCL	17.1	3.10	2.65	0.820	0.290	0.770	0.970	0.270

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0014		F2-HYD0026				F2-HYD0030	
				Location Type:	Hydrant		Hydrant				Hydrant	
				Address:	FH 14		FH 26				FH 30	
				Field Sample ID:	F2-DL-0017746-25060 -N	F2-DL-0017746-25060 -3-N	F2-DL-0017771-25001 -N	F2-DL-0017771-25001 -3-N	F2-DL-0017771-25032 -N	F2-DL-0017771-25060 -N	F2-DL-0017747-25001 -N	F2-DL-0017747-25032 -N
				Sample Date:	2025-03-20	2025-03-20	2025-01-16	2025-01-16	2025-02-19	2025-03-20	2025-01-16	2025-02-19
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	140	--	350	--	850	540	1340	600	
Field Test (pH)	pH	--	--	7.39	--	7.12	--	7.28	7.29	7.24	7.41	
Field Test (ms/cm)	Specific Conductivity	--	--	0.270	--	0.260	--	0.250	0.280	0.250	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	28.5	--	24.0	--	23.5	28.2	23.5	25.8	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.430	--	0.130	--	0.00	0.830	0.190	0.140	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55400	55500	52300	54300	52200	56100	51200	52900	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0014		F2-HYD0026				F2-HYD0030	
				Location Type:	Hydrant		Hydrant				Hydrant	
				Address:	FH 14		FH 26				FH 30	
				Field Sample ID:	F2-DL-0017746-25060 -N	F2-DL-0017746-25060 -3-N	F2-DL-0017771-25001 -N	F2-DL-0017771-25001 -3-N	F2-DL-0017771-25032 -N	F2-DL-0017771-25060 -N	F2-DL-0017747-25001 -N	F2-DL-0017747-25032 -N
				Sample Date:	2025-03-20	2025-03-20	2025-01-16	2025-01-16	2025-02-19	2025-03-20	2025-01-16	2025-02-19
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	--	ND	ND	--	--	ND	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	--	ND	ND	--	--	ND	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.620	0.610	0.320	0.320	0.490	0.460	0.360	0.830	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.560	0.490	0.280	0.270	0.400	0.470	0.320	0.510	
	Total Trihalomethanes	80	MCL	1.18	1.10	0.600	0.590	0.890	0.930	0.680	1.34	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0030	F2-HYD0031				F2-HYD0039		
				Location Type:	Hydrant	Hydrant				Hydrant		
				Address:	FH 30	FH 31				FH 39		
				Field Sample ID:	F2-DL-0017747-25060 -N	F2-DL-0017748-25001 -N	F2-DL-0017748-25032 -N	F2-DL-0017748-25060 -N	F2-DL-0017748-25060 -3-N	F2-DL-0017749-25001 -N	F2-DL-0017749-25032 -N	F2-DL-0017749-25060 -N
				Sample Date:	2025-03-24	2025-01-16	2025-02-19	2025-03-20	2025-03-20	2025-01-16	2025-02-19	2025-03-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	760	410	810	450	--	560	580	830	
Field Test (pH)	pH	--	--	7.37	7.40	7.51	7.44	--	7.32	7.29	7.35	
Field Test (ms/cm)	Specific Conductivity	--	--	0.230	0.270	0.260	0.250	--	0.260	0.250	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	26.7	26.8	28.7	28.1	--	26.8	26.2	24.5	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.130	1.73	0.0170	0.0780	--	0.900	0.310	0.00	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55400	57300	54000	61600	59300	53000	51600	57500	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	0.0140	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0030	F2-HYD0031				F2-HYD0039		
				Location Type:	Hydrant	Hydrant				Hydrant		
				Address:	FH 30	FH 31				FH 39		
				Field Sample ID:	F2-DL-0017747-25060 -N	F2-DL-0017748-25001 -N	F2-DL-0017748-25032 -N	F2-DL-0017748-25060 -N	F2-DL-0017748-25060 -3-N	F2-DL-0017749-25001 -N	F2-DL-0017749-25032 -N	F2-DL-0017749-25060 -N
				Sample Date:	2025-03-24	2025-01-16	2025-02-19	2025-03-20	2025-03-20	2025-01-16	2025-02-19	2025-03-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	--	ND	--	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	--	ND	--	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.620	0.830	1.00	0.970	0.300	ND	ND	ND
	Bromoform	--	--	0.350	2.80	3.70	3.90	4.00	1.00	0.510	0.390	
	Chloroform	--	--	ND	ND	ND	0.250	0.250	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.290	2.00	2.30	2.80	2.80	0.780	0.390	0.430	
	Total Trihalomethanes	80	MCL	0.640	5.42	6.83	7.95	8.02	2.08	0.900	0.820	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD003A			F2-HYD0047			F2-HYD0213	
				Location Type:	Hydrant			Hydrant			Hydrant	
				Address:	FH 3A			FH 47			FH 213 (Possibly F2-HYD0020)	
				Field Sample ID:	F2-DL-0017773-25001 -N	F2-DL-0017773-25032 -N	F2-DL-0017773-25060 -N	F2-DL-0017750-25001 -N	F2-DL-0017750-25032 -N	F2-DL-0017750-25060 -N	F2-DL-0017774-25001 -N	F2-DL-0017774-25032 -N
				Sample Date:	2025-01-16	2025-02-19	2025-03-24	2025-01-20	2025-02-19	2025-03-20	2025-01-20	2025-02-19
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	430	760	710	550	660	740	470	670	
Field Test (pH)	pH	--	--	7.18	7.32	7.26	7.25	7.38	7.21	7.16	7.26	
Field Test (ms/cm)	Specific Conductivity	--	--	0.260	0.650	0.230	0.250	0.250	0.240	0.250	0.250	
Field Test (degrees Celcuis)	Temperature	--	--	26.3	27.5	27.6	25.5	30.0	27.2	26.0	29.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	1.24	1.79	0.140	0.920	0.170	0.160	0.850	0.160	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	52700	51800	55100	51800	52400	55000	55400	52300	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

		Location ID:	F2-HYD003A			F2-HYD0047			F2-HYD0213	
		Location Type:	Hydrant			Hydrant			Hydrant	
		Address:	FH 3A			FH 47			FH 213 (Possibly F2-HYD0020)	
		Field Sample ID:	F2-DL-0017773-25001 -N	F2-DL-0017773-25032 -N	F2-DL-0017773-25060 -N	F2-DL-0017750-25001 -N	F2-DL-0017750-25032 -N	F2-DL-0017750-25060 -N	F2-DL-0017774-25001 -N	F2-DL-0017774-25032 -N
		Sample Date:	2025-01-16	2025-02-19	2025-03-24	2025-01-20	2025-02-19	2025-03-20	2025-01-20	2025-02-19
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	ND	--	--	ND	--	--	ND
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	ND	--	--	ND	--	--	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.440	0.360	0.430	0.490	0.410
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

		Location ID:	F2-HYD003A			F2-HYD0047			F2-HYD0213		
		Location Type:	Hydrant			Hydrant			Hydrant		
		Address:	FH 3A			FH 47			FH 213 (Possibly F2-HYD0020)		
		Field Sample ID:	F2-DL-0017773-25001-N	F2-DL-0017773-25032-N	F2-DL-0017773-25060-N	F2-DL-0017750-25001-N	F2-DL-0017750-25032-N	F2-DL-0017750-25060-N	F2-DL-0017774-25001-N	F2-DL-0017774-25032-N	
		Sample Date:	2025-01-16	2025-02-19	2025-03-24	2025-01-20	2025-02-19	2025-03-20	2025-01-20	2025-02-19	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Dibromochloromethane	--	--	0.310	0.350	0.430	0.330	0.360	0.420	0.400	0.500
	Total Trihalomethanes	80	MCL	0.310	0.350	0.870	0.690	0.790	0.910	0.810	1.11

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

				Location ID:	F2-HYD0213	F2-HYD0520				F2-HYD071A		
				Location Type:	Hydrant	Hydrant				Hydrant		
				Address:	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)				FH 71A		
				Field Sample ID:	F2-DL-0017774-25060 -N	F2-DL-0017775-25001 -N	F2-DL-0017775-25032 -N	F2-DL-0017775-25032 -3-N	F2-DL-0017775-25060 -N	F2-DL-0017751-25001 -N	F2-DL-0017751-25032 -N	F2-DL-0017751-25060 -N
				Sample Date:	2025-03-20	2025-01-20	2025-02-25	2025-02-25	2025-03-03	2025-01-20	2025-02-25	2025-03-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	740	750	700	--	730	630	640	750	
Field Test (pH)	pH	--	--	7.22	7.24	7.32	--	7.11	7.40	7.18	7.13	
Field Test (ms/cm)	Specific Conductivity	--	--	0.240	0.260	0.260	--	0.250	0.270	0.260	0.260	
Field Test (degrees Celcuis)	Temperature	--	--	27.0	25.3	26.8	--	24.6	25.2	28.2	24.3	
Field Test (nephelometric turbidity unit)	Turbidity	5	MCL	0.460	0.400	0.730	--	0.350	0.780	1.08	0.810	
General Chemistry (ppb)	Alkalinity, Total (as CaCO3)	--	--	55300	51500	51500	52800	53600	54100	52900	53500	
	Total Organic Carbon	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Acenaphthylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(b)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(g,h,i)perylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(k)fluoranthene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chrysene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibenz(a,h)anthracene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Fluorene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

		Location ID:	F2-HYD0213	F2-HYD0520					F2-HYD071A		
		Location Type:	Hydrant	Hydrant					Hydrant		
		Address:	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)					FH 71A		
		Field Sample ID:	F2-DL-0017774-25060 -N	F2-DL-0017775-25001 -N	F2-DL-0017775-25032 -N	F2-DL-0017775-25032 -3-N	F2-DL-0017775-25060 -N	F2-DL-0017751-25001 -N	F2-DL-0017751-25032 -N	F2-DL-0017751-25060 -N	
		Sample Date:	2025-03-20	2025-01-20	2025-02-25	2025-02-25	2025-03-03	2025-01-20	2025-02-25	2025-03-03	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Indeno(1,2,3-c,d)pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Pyrene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,2,4-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dibromoethane (EDB)	--	--	--	ND	--	--	--	ND	--	--
	1,3,5-Trimethylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-(2-Methoxy ethoxy)ethanol	--	--	--	ND	--	--	--	ND	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cumene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	n-Propylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	sec-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	tert-Butylbenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.540	ND	0.330	0.350	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone F2
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb), with the exception of Field and Bacterial Test results
Parts per Million (ppm)
Parts per Thousand (ppth)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
MPN/mL = Most probable number per milliliter

Drinking Water Samples Collected in January 2025 - March 2025 from Hydrants in Zone F2

		Location ID:	F2-HYD0213	F2-HYD0520					F2-HYD071A		
		Location Type:	Hydrant	Hydrant					Hydrant		
		Address:	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)					FH 71A		
		Field Sample ID:	F2-DL-0017774-25060-N	F2-DL-0017775-25001-N	F2-DL-0017775-25032-N	F2-DL-0017775-25032-3-N	F2-DL-0017775-25060-N	F2-DL-0017751-25001-N	F2-DL-0017751-25032-N	F2-DL-0017751-25060-N	
		Sample Date:	2025-03-20	2025-01-20	2025-02-25	2025-02-25	2025-03-03	2025-01-20	2025-02-25	2025-03-03	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Trihalomethanes (ppb)	Dibromochloromethane	--	--	0.510	ND	0.290	0.300	ND	ND	ND	
	Total Trihalomethanes	80	MCL	1.05	ND	0.620	0.650	ND	ND	ND	