

**Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-101S6397		Location ID: A3-101S6404		Location ID: A3-101S6412A		Location ID: A3-101S6427A		Location ID: A3-102S6464A
				Location Type: Residence	Address: 6397 101st Street	Location Type: Residence	Address: 6404 101st Street	Location Type: Residence	Address: 6412A 101st Street	Location Type: Residence	Address: 6427A 101st Street	Location Type: Residence
				Field Sample ID: A3-TW-0012521-22035-N	Field Sample ID: A3-TW-0012449-22035-3-N	Field Sample ID: A3-TW-0012449-22035-N	Field Sample ID: A3-TW-0017261-22035-N	Field Sample ID: A3-TW-0017261-22035-N-72	Field Sample ID: A3-TW-0017276-22035-3-N	Field Sample ID: A3-TW-0017276-22035-N	Field Sample ID: A3-TW-0016090-22035-N	
				Sample Date: 2022-02-05	Sample Date: 2022-02-05	Sample Date: 2022-02-05	Sample Date: 2022-02-05	Sample Date: 2022-02-07	Sample Date: 2022-02-05	Sample Date: 2022-02-05	Sample Date: 2022-02-07	
				Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (72 Hour Stagnation)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)	
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	0.0600	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: A3-102S6475			A3-103S6490			A3-103S6502B			
		Location Type: Residence			Residence			Residence			
		Address: 6475 102nd Street			6490 103rd Street			6502B 103rd Street			
		Field Sample ID:	A3-TW-0012526-22035-N	A3-TW-0012526-22035-N-72	A3-TW-0016100-22056-N	A3-TW-0016100-22056-N-2	A3-TW-0016100-22056-N-R1	A3-TW-0016110-22035-N	A3-TW-0016110-22035-N-72	A3-TW-0016119-22035-N	
		Sample Date:	2022-02-05	2022-02-07	2022-03-04	2022-03-05	2022-03-05	2022-02-05	2022-02-07	2022-02-05	
		Sample Type:	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	1940	ND	--	--	--	1530	ND	1950
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1940	ND	--	--	--	1530	ND	1950
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	--	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	--	--	--	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	0.220	0.130	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.740	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.10	2.10	2.30	2.10	2.00	2.10	2.40
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.70	1.50	1.80	2.00	1.60	1.70	1.60
	Copper	1300	MCL	65.8	65.0	100	122	96.9	54.0	90.0	120
	Lead	15	MCL	0.470	0.680	1.50	1.80	1.10	0.480	0.450	2.20
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	1.90	ND	ND	ND	ND	2.10	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	--	--	--	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	--	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	--	--	--	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	--	--	--	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	--	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	--	--	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	--	--	--	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	--	--	--	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	--	--	--	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-102S6475					Location ID: A3-103S6490		Location ID: A3-103S6502B
				Location Type: Residence					Location Type: Residence		Location Type: Residence
				Address: 6475 102nd Street					Address: 6490 103rd Street		Address: 6502B 103rd Street
				Field Sample ID: A3-TW-0012526-22035-N	Field Sample ID: A3-TW-0012526-22035-N-72	Field Sample ID: A3-TW-0016100-22056-N	Field Sample ID: A3-TW-0016100-22056-N-2	Field Sample ID: A3-TW-0016100-22056-N-R1	Field Sample ID: A3-TW-0016110-22035-N	Field Sample ID: A3-TW-0016110-22035-N-72	Field Sample ID: A3-TW-0016119-22035-N
				Sample Date: 2022-02-05	Sample Date: 2022-02-07	Sample Date: 2022-03-04	Sample Date: 2022-03-05	Sample Date: 2022-03-05	Sample Date: 2022-02-05	Sample Date: 2022-02-07	Sample Date: 2022-02-05
				Sample Type: N (Normal)	Sample Type: N (72 Hour Stagnation)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (72 Hour Stagnation)	Sample Type: N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	--	--	--	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	--	--	--	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	--	--	--	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	--	--	--	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	--	--	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	--	--	--	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	--	--	--	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	--	--	--	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	--	--	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	--	--	--	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	--	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	--	--	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	--	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	--	--	--	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	--	--	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	--	--	--	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	--	--	--	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	--	--	--	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	--	--	--	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	--	--	--	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		A3-103S6522		A3-103S6526B		A3-103S6534A		A3-104S6543A		A3-104S6558A		A3-104S6585A		
		Location Type:		Residence		Residence		Residence		Residence		Residence		Residence		
		Address:		6522 103rd Street		6526B 103rd Street		6534A 103rd Street		6543A 104th Street		6558A 104th Street		6585A 104th Street		
		Field Sample ID:		A3-TW-0012451-22035-N		A3-TW-0016388-22035-N		A3-TW-0016395-22035-3-N		A3-TW-0016395-22035-N		A3-TW-0016401-22035-N		A3-TW-0017344-22035-N		
		Sample Date:		2022-02-05		2022-02-05		2022-02-05		2022-02-05		2022-02-05		2022-02-05		
		Sample Type:		N (Normal)		N (Normal)		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level													
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1850	ND	ND	ND	ND	1820	2400 §	1630				
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	103	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	103	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.10	2.10	2.00	1.90	2.10	2.00	2.10	2.00	2.10	2.00	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.40	1.50	1.60	1.50	1.40	1.60	1.70	1.70	1.70	1.70	1.70	1.70	
	Copper	1300	MCL	43.2	42.1	16.2	15.6	27.4	33.1	142	62.0	62.0	62.0	62.0	62.0	
	Lead	15	MCL	0.470	0.550	0.260	0.250	0.350	0.580	1.30	1.00	1.00	1.00	1.00	1.00	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.80	1.80
Thallium	2	MCL	0.0780	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	1.90	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:		Location ID:	Location ID:	Location ID:	
				A3-103S6522	A3-103S6526B	A3-103S6534A		A3-104S6543A	A3-104S6558A	A3-104S6585A	
				Residence	Residence	Residence		Residence	Residence	Residence	
				6522 103rd Street	6526B 103rd Street	6534A 103rd Street		6543A 104th Street	6558A 104th Street	6585A 104th Street	
				A3-TW-0012451-22035-N	A3-TW-0016388-22035-N	A3-TW-0016395-22035-3-N	A3-TW-0016395-22035-N	A3-TW-0016401-22035-N	A3-TW-0017344-22035-N	A3-TW-0017397-22035-N	A3-TW-0017397-22035-N-72
				2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-07
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-105S6606	A3-105S6620	A3-105S6636A		A3-106S6645	A3-106S6660A	A3-106S6665	A3-106S6674	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	6606 105th Street	6620 105th Street	6636A 105th Street		6645 106th Street	6660A 106th Street	6665 106th Street	6674 106th Street	
		Field Sample ID:	A3-TW-0012532-22035-N	A3-TW-0012533-22035-N	A3-TW-0017469-22035-3-N	A3-TW-0017469-22035-N	A3-TW-0012535-22035-N	A3-TW-0016134-22035-N	A3-TW-0016695-22035-N	A3-TW-0012454-22035-N	
		Sample Date:	2022-02-07	2022-02-09	2022-02-05	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1750	ND	4980 §	1940	2010 §	ND	1890	2170 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	130
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	130
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.00	2.20	2.10	2.10	2.30	2.30	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.40	1.60	1.50	1.30	1.10	1.30	1.30
	Copper	1300	MCL	11.7	30.7	41.7	42.0	48.3	52.5	28.6	16.9
	Lead	15	MCL	0.190	0.430	0.650	0.600	0.320	0.470	0.330	0.280
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.140
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-105S6606	A3-105S6620	A3-105S6636A		A3-106S6645	A3-106S6660A	A3-106S6665	A3-106S6674
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	6606 105th Street	6620 105th Street	6636A 105th Street		6645 106th Street	6660A 106th Street	6665 106th Street	6674 106th Street
		Field Sample ID:	A3-TW-0012532-22035-N	A3-TW-0012533-22035-N	A3-TW-0017469-22035-3-N	A3-TW-0017469-22035-N	A3-TW-0012535-22035-N	A3-TW-0016134-22035-N	A3-TW-0016695-22035-N	A3-TW-0012454-22035-N
		Sample Date:	2022-02-07	2022-02-09	2022-02-05	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-106S6682B		A3-107S6714A	A3-107S6714B	A3-107S6715B	A3-108S6737B	A3-108S6738B	A3-108S6749
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	6682B 106th Street		6714A 107th Street	6714B 107th Street	6715B 107th Street	6737B 108th Street	6738B 108th Street	6749 108th Street
		Field Sample ID:	A3-TW-0016916-22035-3-N	A3-TW-0016916-22035-N	A3-TW-0012455-22035-N	A3-TW-0016163-22035-N	A3-TW-0016165-22035-N	A3-TW-0012457-22035-N	A3-TW-0016185-22035-N	A3-TW-0012459-22035-N
		Sample Date:	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2540 §	1890	ND	ND	1890	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	72.4	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	72.4	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.70	2.00	2.70	2.20	2.20	2.10	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.30	1.30	1.10	1.30	1.20	1.80
	Copper	1300	MCL	25.5	29.4	60.0	37.5	9.90	34.6	31.0
	Lead	15	MCL	0.360	0.410	0.930	0.460	0.180	0.350	0.210
	Mercury	2	MCL	ND	ND	ND	0.200	ND	0.150	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	0.950	1.60
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-106S6682B		Location ID: A3-107S6714A		Location ID: A3-107S6714B		Location ID: A3-107S6715B		Location ID: A3-108S6737B		Location ID: A3-108S6738B		Location ID: A3-108S6749		
				Residence		Residence		Residence		Residence		Residence		Residence		Residence		
				6682B 106th Street		6714A 107th Street		6714B 107th Street		6715B 107th Street		6737B 108th Street		6738B 108th Street		6749 108th Street		
				A3-TW-0016916-22035-3-N	A3-TW-0016916-22035-N	A3-TW-0012455-22035-N	A3-TW-0016163-22035-N	A3-TW-0016165-22035-N	A3-TW-0016165-22035-N	A3-TW-0012457-22035-N	A3-TW-0016185-22035-N	A3-TW-0012459-22035-N						
				2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07						
				FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)						
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level															
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-110S6814A		A3-111S6840A	A3-111S6844A	A3-112S6855A	A3-ALBA5461	A3-ALBA5465	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	6814A 110th Street		6840A 111th Street	6844A 111th Street	6855A 112th Street	5461 Albatross Avenue	5465 Albatross Avenue	
				Field Sample ID:	A3-TW-0012541-22035-N	A3-TW-0017425-22035-3-N	A3-TW-0017425-22035-N	A3-TW-0017441-22035-N	A3-TW-0016225-22035-N	A3-TW-0016233-22035-N	A3-TW-0016944-22035-N	A3-TW-0012577-22035-N
				Sample Date:	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-09	2022-02-09
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	1640	1610	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	95.0	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	95.0	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	0.330	2.00	2.00	2.00	2.10	2.20	2.30	2.30	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.60	1.80	1.80	1.30	1.10	ND	1.50	1.50	
	Copper	1300	MCL	9.90	19.0	19.0	15.5	27.6	36.7	24.2	23.3	
	Lead	15	MCL	0.150	0.350	0.400	ND	0.350	0.280	0.280	0.400	
	Mercury	2	MCL	ND	ND	ND	ND	0.170	0.250	ND	ND	
	Selenium	50	MCL	ND	2.10	1.90	0.950	ND	ND	ND	ND	
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-110S6814A		A3-111S6840A	A3-111S6844A	A3-112S6855A	A3-ALBA5461	A3-ALBA5465	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	6814A 110th Street		6840A 111th Street	6844A 111th Street	6855A 112th Street	5461 Albatross Avenue	5465 Albatross Avenue	
				Field Sample ID:	A3-TW-0012541-22035-N	A3-TW-0017425-22035-3-N	A3-TW-0017425-22035-N	A3-TW-0017441-22035-N	A3-TW-0016225-22035-N	A3-TW-0016233-22035-N	A3-TW-0016944-22035-N	A3-TW-0012577-22035-N
				Sample Date:	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-09	2022-02-09
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-ALBA5486	A3-BITT5514	A3-BITT5534	A3-BITT5552	A3-BLDG0621	A3-CORM5553		
				Location Type:	Residence	Residence	Residence	Residence	Non-Residence	School		
				Address:	5486 Albatross Avenue	5514 Bittern Avenue	5534 Bittern Avenue	5552 Bittern Avenue	Building 621, FITNESS CENTER	5553 Cormorant Ave, Iroquois Point Elementary		
				Field Sample ID:	A3-TW-0012578-22035-N	A3-TW-0012579-22035-N	A3-TW-0012580-22035-N	A3-TW-0012581-22035-N	A3-TW-0014396-22035-N	A3-TW-0012582-22035-3-N-3	A3-TW-0012582-22035-N-1	A3-TW-0012582-22035-N-2
				Sample Date:	2022-02-09	2022-02-09	2022-02-09	2022-02-09	2022-02-05	2022-02-04	2022-02-04	2022-02-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	4090 §	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	55.4	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	55.4	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.20	2.30	2.10	2.10	1.90	2.00	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.40	1.50	1.50	1.60	1.30	1.20	1.50	
	Copper	1300	MCL	22.9	10.0	36.5	19.1	35.1	46.9	10.0	182	
	Lead	15	MCL	0.180	ND	0.390	0.230	0.260	0.130	0.150	3.80	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-BIT5514	A3-BIT5534	A3-BIT5552	A3-BLDG0621	A3-CORM5553			
				Location Type:	Residence	Residence	Residence	Residence	Non-Residence	School		
				Address:	5486 Albatross Avenue	5514 Bittern Avenue	5534 Bittern Avenue	5552 Bittern Avenue	Building 621, FITNESS CENTER 5553 Cormorant Ave, Iroquois Point Elementary			
				Field Sample ID:	A3-TW-0012578-22035-N	A3-TW-0012579-22035-N	A3-TW-0012580-22035-N	A3-TW-0012581-22035-N	A3-TW-0014396-22035-N	A3-TW-0012582-22035-3-N-3	A3-TW-0012582-22035-N-1	A3-TW-0012582-22035-N-2
				Sample Date:	2022-02-09	2022-02-09	2022-02-09	2022-02-09	2022-02-05	2022-02-04	2022-02-04	2022-02-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-CORM5553			A3-CORM5564	A3-CORM5587B	A3-DOVE5630A	A3-DOVE5652	A3-DOVE5669A
				Location Type: School			Residence	Residence	Residence	Residence	Residence
				Address: 5553 Cormorant Ave, Iroquois Point Elementary			5564 Cormorant Avenue	5587B Cormorant Avenue	5630A Dovekie Avenue	5652 Dovekie Avenue	5669A Dovekie Avenue
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				A3-TW-0012582-22035-N-3	A3-TW-0012582-22035-N-4	A3-TW-0012582-22035-N-5	A3-TW-0016203-22035-N	A3-TW-0016216-22035-N	A3-TW-0016291-22035-N	A3-TW-0012586-22035-N	A3-TW-0012587-22035-N
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				2022-02-04	2022-02-04	2022-02-04	2022-02-09	2022-02-09	2022-02-08	2022-02-09	2022-02-09
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1650	2310 §	1780	ND	ND	1740	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.10	2.00	2.10	2.00	2.00	2.20	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.30	1.40	1.30	1.30	1.40	1.30	1.50	1.50
	Copper	1300	MCL	66.3	111	77.3	75.2	23.7	44.0	19.0	31.7
	Lead	15	MCL	0.160	0.330	0.450	0.330	0.190	0.210	0.250	0.250
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-CORM5553			A3-CORM5564	A3-CORM5587B	A3-DOVE5630A	A3-DOVE5652	A3-DOVE5669A	
				Location Type: School			Residence	Residence	Residence	Residence	Residence	
				Address: 5553 Cormorant Ave, Iroquois Point Elementary			5564 Cormorant Avenue	5587B Cormorant Avenue	5630A Dovekie Avenue	5652 Dovekie Avenue	5669A Dovekie Avenue	
				Field Sample ID:	A3-TW-0012582-22035-N-3	A3-TW-0012582-22035-N-4	A3-TW-0012582-22035-N-5	A3-TW-0016203-22035-N	A3-TW-0016216-22035-N	A3-TW-0016291-22035-N	A3-TW-0012586-22035-N	A3-TW-0012587-22035-N
				Sample Date:	2022-02-04	2022-02-04	2022-02-04	2022-02-09	2022-02-09	2022-02-08	2022-02-09	2022-02-09
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-DOVE5673	A3-DOVE5682	A3-EDGE5327		A3-EDGE5330A	A3-EDGE5363	A3-EDGE5371	A3-EDGE5390
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	5673 Dovekie Avenue	5682 Dovekie Avenue	5327 Edgewater Drive		5330A Edgewater Drive	5363 Edgewater Drive	5371 Edgewater Drive	5390 Edgewater Drive
				Field Sample ID:	A3-TW-0012588-22035-N	A3-TW-0016450-22035-N	A3-TW-0016313-22035-3-N	A3-TW-0016313-22035-N	A3-TW-0016314-22035-N	A3-TW-0012592-22035-N	A3-TW-0012593-22035-N	A3-TW-0012517-22035-N
				Sample Date:	2022-02-08	2022-02-09	2022-02-08	2022-02-08	2022-02-09	2022-02-09	2022-02-09	2022-02-09
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP		4740 §	ND	ND	1570	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		53.4	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP		53.4	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL		2.10	2.20	2.10	2.10	2.00	2.20	2.10	2.30
	Beryllium	4	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL		1.40	1.60	1.40	1.50	1.40	1.80	1.40	1.50
	Copper	1300	MCL		36.1	46.7	49.8	52.8	9.10	47.1	25.4	21.9
	Lead	15	MCL		0.370	0.830	0.420	0.460	0.150	0.300	0.210	0.320
	Mercury	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL		ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL		ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL		ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-DOVE5673	A3-DOVE5682	A3-EDGE5327		A3-EDGE5330A	A3-EDGE5363	A3-EDGE5371	A3-EDGE5390
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	5673 Dovekie Avenue	5682 Dovekie Avenue	5327 Edgewater Drive		5330A Edgewater Drive	5363 Edgewater Drive	5371 Edgewater Drive	5390 Edgewater Drive
				Field Sample ID:	A3-TW-0012588-22035-N	A3-TW-0016450-22035-N	A3-TW-0016313-22035-3-N	A3-TW-0016313-22035-N	A3-TW-0016314-22035-N	A3-TW-0012592-22035-N	A3-TW-0012593-22035-N	A3-TW-0012517-22035-N
				Sample Date:	2022-02-08	2022-02-09	2022-02-08	2022-02-08	2022-02-09	2022-02-09	2022-02-09	2022-02-09
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		A3-EDGE5397		A3-EDGE5402		A3-EEHA4852C		A3-EEHA4857C		A3-EEHI4999C							
		Location Type:		Residence		Residence		Residence		Residence		Residence							
		Address:		5397 Edgewater Drive		5402 Edgewater Drive		4852C East Eha Way		4857C East Eha Way		4999C East Ehiku Way							
		Field Sample ID:		A3-TW-0012518-22035-N		A3-TW-0012594-22035-3-N		A3-TW-0012594-22035-N		A3-TW-0016463-22035-N		A3-TW-0016463-22035-N-72		A3-TW-0017351-22035-N		A3-TW-0017369-22035-3-N		A3-TW-0017369-22035-N	
		Sample Date:		2022-02-09		2022-02-09		2022-02-09		2022-02-05		2022-02-07		2022-02-04		2022-02-04		2022-02-04	
		Sample Type:		N (Normal)		FD (Field Duplicate)		N (Normal)		N (Normal)		N (72 Hour Stagnation)		N (Normal)		FD (Field Duplicate)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level																
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	2320 §	1840	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	2.30	2.20	2.30	2.30	2.00	2.00	2.00	2.30	2.30	2.30	2.30	2.30	2.30	2.30	2.30
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.20	1.50	1.40	1.70	1.70	ND	1.60	1.40	1.40	1.60	1.40	1.40	1.60	1.40	1.60	1.60
	Copper	1300	MCL	24.9	21.7	19.9	56.8	56.8	50.1	40.4	15.7	15.7	16.5	15.7	16.5	16.5	16.5	16.5	16.5
	Lead	15	MCL	0.490	0.300	0.270	0.340	0.340	0.260	0.230	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	0.0870	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-EDGE5402		A3-EEHA4852C		A3-EEHA4857C	A3-EEHI4999C	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				A3-EDGE5397 Residence 5397 Edgewater Drive A3-TW-0012518-22035-N 2022-02-09 N (Normal)	Residence 5402 Edgewater Drive A3-TW-0012594-22035-3-N 2022-02-09 FD (Field Duplicate)	Residence 5402 Edgewater Drive A3-TW-0012594-22035-N 2022-02-09 N (Normal)	Residence 4852C East Eha Way A3-TW-0016463-22035-N 2022-02-05 N (Normal)	Residence 4852C East Eha Way A3-TW-0016463-22035-N-72 2022-02-07 N (72 Hour Stagnation)	Residence 4857C East Eha Way A3-TW-0017351-22035-N 2022-02-04 N (Normal)	Residence 4999C East Ehiku Way A3-TW-0017369-22035-3-N 2022-02-04 FD (Field Duplicate)	Residence 4999C East Ehiku Way A3-TW-0017369-22035-N 2022-02-04 N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-EEKA4755D		A3-EEKA4757A		A3-EEKO4821D	A3-EELU4786C		A3-EELU4791B	A3-ELIM4873D
		Location Type:	Residence		Residence		Residence	Residence		Residence	Residence
		Address:	4755D East Ekahi Way		4757A East Ekahi Way		4821D East Ekolu Way	4786C East Elua Way		4791B East Elua Way	4873D Elima Way
		Field Sample ID:	A3-TW-0012464-22035-N	A3-TW-0017283-22035-N	A3-TW-0017283-22035-N-72	A3-TW-0016970-22035-N	A3-TW-0016985-22035-N	A3-TW-0016985-22035-N-72	A3-TW-0016139-22035-N	A3-TW-0012468-22035-N	
		Sample Date:	2022-02-04	2022-02-05	2022-02-07	2022-02-04	2022-02-05	2022-02-07	2022-02-05	2022-02-04	
		Sample Type:	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2180 §	ND	1660	1970	ND	2110 §	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	28.5	2.30	2.10	2.00	2.20	2.30	2.10	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.60	1.20	1.50	1.70	ND	1.60	1.70
	Copper	1300	MCL	15.9	132	70.2	12.5	34.8	29.3	26.3	68.5
	Lead	15	MCL	0.140	0.400	0.220	ND	0.290	0.220	0.200	0.280
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.120	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-EEKA4757A		A3-EEKO4821D	A3-EELU4786C		A3-EELU4791B	A3-ELIM4873D	
				Location Type:	Residence		Residence	Residence		Residence	Residence	
				Address:	4757A East Ekahi Way		4821D East Ekolu Way	4786C East Elua Way		4791B East Elua Way	4873D Elima Way	
				Field Sample ID:	A3-TW-0012464-22035-N	A3-TW-0017283-22035-N	A3-TW-0017283-22035-N-72	A3-TW-0016970-22035-N	A3-TW-0016985-22035-N	A3-TW-0016985-22035-N-72	A3-TW-0016139-22035-N	A3-TW-0012468-22035-N
				Sample Date:	2022-02-04	2022-02-05	2022-02-07	2022-02-04	2022-02-05	2022-02-07	2022-02-05	2022-02-04
				Sample Type:	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	0.270	ND	ND	0.540	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	0.270	ND	ND	0.540	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-ELIM4876B		A3-EONO4934A	A3-EONO4938C	A3-ERNE5713	A3-ERNE5728A	A3-ERNE5744	A3-ERNE5761B	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	4876B Elima Way		4934A Eono Way	4938C Eono Way	5713 Erne Avenue	5728A Erne Avenue	5744 Erne Avenue	5761B Erne Avenue	
		Field Sample ID:	A3-TW-0017325-22035-N	A3-TW-0017325-22035-N-72	A3-TW-0017342-22035-N	A3-TW-0016698-22035-N	A3-TW-0012472-22035-N	A3-TW-0016516-22035-N	A3-TW-0012546-22035-N	A3-TW-0017005-22035-N	
		Sample Date:	2022-02-05	2022-02-07	2022-02-04	2022-02-04	2022-02-08	2022-02-08	2022-02-09	2022-02-08	
		Sample Type:	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2900 §	ND	2210 §	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	55.8	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	55.8	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.10	2.00	1.80	2.00	2.10	2.00	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.60	1.30	1.20	1.30	1.60	1.50	1.60
	Copper	1300	MCL	115	140	15.5	14.6	33.1	79.7	45.9	25.2
	Lead	15	MCL	0.290	0.400	0.170	ND	0.380	0.620	0.370	0.540
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	1.80	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-ELIM4876B		A3-EONO4934A	A3-EONO4938C	A3-ERNE5713	A3-ERNE5728A	A3-ERNE5744	A3-ERNE5761B
				Location Type: Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address: 4876B Elima Way		4934A Eono Way	4938C Eono Way	5713 Erne Avenue	5728A Erne Avenue	5744 Erne Avenue	5761B Erne Avenue
				Field Sample ID: A3-TW-0017325-22035-N	A3-TW-0017325-22035-N-72	A3-TW-0017342-22035-N	A3-TW-0016698-22035-N	A3-TW-0012472-22035-N	A3-TW-0016516-22035-N	A3-TW-0012546-22035-N	A3-TW-0017005-22035-N
				Sample Date: 2022-02-05	2022-02-07	2022-02-04	2022-02-04	2022-02-08	2022-02-08	2022-02-09	2022-02-08
				Sample Type: N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		A3-ERNE5770B	A3-ERNE5777A	A3-ERNE5787A	A3-EWAL4985D	A3-EWAL4986B		A3-FULM5812A	
		Location Type:		Residence	Residence	Residence	Residence	Residence		Residence	
		Address:		5770B Erne Avenue	5777A Erne Avenue	5787A Erne Avenue	4985D Ewalu Way	4986B Ewalu Way		5812A Fulmar Avenue	
		Field Sample ID:		A3-TW-0017011-22035-N	A3-TW-0017013-22035-N	A3-TW-0017021-22035-N	A3-TW-0016348-22035-N	A3-TW-0016350-22035-N	A3-TW-0016350-22035-N-72	A3-TW-0016357-22035-3-N	A3-TW-0016357-22035-N
		Sample Date:		2022-02-09	2022-02-08	2022-02-08	2022-02-04	2022-02-05	2022-02-07	2022-02-08	2022-02-08
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1690	ND	ND	1570	ND	1630	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	0.0770	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.10	2.20	2.10	2.20	2.30	2.10	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.50	1.60	1.50	1.30	1.70	1.40	1.30
	Copper	1300	MCL	28.4	23.8	25.7	16.0	76.7	190	11.5	11.5
	Lead	15	MCL	0.400	0.280	0.320	0.150	0.440	1.60	0.130	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	ND	0.0980	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-ERNE5770B	A3-ERNE5777A	A3-ERNE5787A	A3-EWAL4985D	A3-EWAL4986B		A3-FULM5812A	
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	
				Address:	5770B Erne Avenue	5777A Erne Avenue	5787A Erne Avenue	4985D Ewalu Way	4986B Ewalu Way		5812A Fulmar Avenue	
				Field Sample ID:	A3-TW-0017011-22035-N	A3-TW-0017013-22035-N	A3-TW-0017021-22035-N	A3-TW-0016348-22035-N	A3-TW-0016350-22035-N	A3-TW-0016350-22035-N-72	A3-TW-0016357-22035-3-N	A3-TW-0016357-22035-N
				Sample Date:	2022-02-09	2022-02-08	2022-02-08	2022-02-04	2022-02-05	2022-02-07	2022-02-08	2022-02-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	FD (Field Duplicate)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-FULM5822A	A3-FULM5835	A3-FULM5849A	A3-FULM5861	A3-GANN5887	A3-GANN5913A	A3-GANN5928B	A3-GANN5931	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5822A Fulmar Avenue	5835 Fulmar Avenue	5849A Fulmar Avenue	5861 Fulmar Avenue	5887 Gannet Avenue	5913A Gannet Avenue	5928B Gannet Avenue	5931 Gannet Avenue	
		Field Sample ID:	A3-TW-0016364-22035-N	A3-TW-0016374-22035-N	A3-TW-0017297-22035-N	A3-TW-0012482-22035-N	A3-TW-0017041-22035-N	A3-TW-0016536-22035-N	A3-TW-0016547-22035-N	A3-TW-0012485-22035-N	
		Sample Date:	2022-02-08	2022-02-08	2022-02-08	2022-02-08	2022-02-07	2022-02-07	2022-02-07	2022-02-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1630	ND	ND	ND	ND	2590 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.10	2.20	2.20	2.00	2.10	2.00	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.50	1.60	1.50	1.70	1.70	1.20	1.30
	Copper	1300	MCL	29.8	49.2	69.0	28.4	44.0	23.0	48.3	49.0
	Lead	15	MCL	0.550	0.200	0.250	0.240	0.510	0.280	0.180	0.280
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.150
	Selenium	50	MCL	ND	ND	ND	ND	ND	1.70	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-FULM5822A	A3-FULM5835	A3-FULM5849A	A3-FULM5861	A3-GANN5887	A3-GANN5913A	A3-GANN5928B	A3-GANN5931
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5822A Fulmar Avenue	5835 Fulmar Avenue	5849A Fulmar Avenue	5861 Fulmar Avenue	5887 Gannet Avenue	5913A Gannet Avenue	5928B Gannet Avenue	5931 Gannet Avenue
		Field Sample ID:	A3-TW-0016364-22035-N	A3-TW-0016374-22035-N	A3-TW-0017297-22035-N	A3-TW-0012482-22035-N	A3-TW-0017041-22035-N	A3-TW-0016536-22035-N	A3-TW-0016547-22035-N	A3-TW-0012485-22035-N
		Sample Date:	2022-02-08	2022-02-08	2022-02-08	2022-02-08	2022-02-07	2022-02-07	2022-02-07	2022-02-07
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-GANN5960	A3-GANN5989A	A3-GANN5996	A3-GANN6003B	A3-GANN6004		A3-HERO6053A	A3-HERO6071B	
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	5960 Gannet Avenue	5989A Gannet Avenue	5996 Gannet Avenue	6003B Gannet Avenue	6004 Gannet Avenue		6053A Heron Avenue	6071B Heron Avenue	
		Field Sample ID:	A3-TW-0012486-22035-N	A3-TW-0017079-22035-N	A3-TW-0012488-22035-N	A3-TW-0017085-22035-N	A3-TW-0012490-22035-3-N	A3-TW-0012490-22035-N	A3-TW-0017096-22035-N	A3-TW-0016242-22035-N	
		Sample Date:	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1750	ND	1660	ND	ND	ND	1760	2700 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.20	2.10	2.20	2.10	1.90	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.20	1.30	1.40	1.30	1.40	0.500	ND
	Copper	1300	MCL	34.3	48.5	32.7	22.9	34.9	15.8	30.4	20.4
	Lead	15	MCL	0.320	0.490	0.200	ND	0.280	ND	0.160	0.370
	Mercury	2	MCL	0.180	0.210	ND	ND	0.160	0.150	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	1.10	1.00	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.110	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-GANN5960	A3-GANN5989A	A3-GANN5996	A3-GANN6003B	A3-GANN6004		A3-HERO6053A	A3-HERO6071B
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	5960 Gannet Avenue	5989A Gannet Avenue	5996 Gannet Avenue	6003B Gannet Avenue	6004 Gannet Avenue		6053A Heron Avenue	6071B Heron Avenue
		Field Sample ID:	A3-TW-0012486-22035-N	A3-TW-0017079-22035-N	A3-TW-0012488-22035-N	A3-TW-0017085-22035-N	A3-TW-0012490-22035-3-N	A3-TW-0012490-22035-N	A3-TW-0017096-22035-N	A3-TW-0016242-22035-N
		Sample Date:	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	A3-HERO6089B	A3-HERO6097A	A3-HERO6105A		A3-HERO6121B	A3-HERO6137B	A3-HERO6156A	A3-HERO6169B	
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
				Address:	6089B Heron Avenue	6097A Heron Avenue	6105A Heron Avenue		6121B Heron Avenue	6137B Heron Avenue	6156A Heron Avenue	6169B Heron Avenue	
				Field Sample ID:	A3-TW-0016253-22035-N	A3-TW-0017136-22035-N	A3-TW-0017141-22035-3-N	A3-TW-0017141-22035-N	A3-TW-0017148-22035-N	A3-TW-0016572-22035-N	A3-TW-0016581-22035-N	A3-TW-0016595-22035-3-N	
				Sample Date:	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	2150 §	1530	1750	ND	ND	2050 §	ND		
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.00	1.90	1.90	1.90	1.90	1.90	2.10	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	0.120	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	ND	0.560	ND	1.70	1.60	1.30	1.20		
	Copper	1300	MCL	84.8	17.4	20.0	19.8	100	54.0	20.9	39.1		
	Lead	15	MCL	1.40	0.170	0.250	0.210	0.400	0.370	0.250	ND		
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	0.170	ND		
	Selenium	50	MCL	ND	ND	ND	ND	1.80	1.60	ND	ND		
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-HERO6089B	A3-HERO6097A	A3-HERO6105A		A3-HERO6121B	A3-HERO6137B	A3-HERO6156A	A3-HERO6169B
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	6089B Heron Avenue	6097A Heron Avenue	6105A Heron Avenue		6121B Heron Avenue	6137B Heron Avenue	6156A Heron Avenue	6169B Heron Avenue
		Field Sample ID:	A3-TW-0016253-22035-N	A3-TW-0017136-22035-N	A3-TW-0017141-22035-3-N	A3-TW-0017141-22035-N	A3-TW-0017148-22035-N	A3-TW-0016572-22035-N	A3-TW-0016581-22035-N	A3-TW-0016595-22035-3-N
		Sample Date:	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-07
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-HYD1426		A3-HYD1743	A3-HYD2499		A3-HYD663	A3-HYD664
				Location Type:	Hydrant		Hydrant	Hydrant		Hydrant	Hydrant
				Address:	FH ID: SA-LFH 2		A3-SA-JFH-44	FH752		SA-JFH-52	SA-JFH-4
				Field Sample ID:	20220108-A3-ZT01	20220109-A3-YT-02	220118-A3-YT01	220118-A3-ZT04	220118-A3-ZT05	220118-A3-ZT07	220118-A3-YT04
				Sample Date:	2022-01-08	2022-01-09	2022-01-18	2022-01-18	2022-01-18	2022-01-18	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	--	ND	ND	842	798	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	48.0	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	48.0	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	--	ND	0.302	0.739	0.734	0.632	0.293
	Barium	2000	MCL	2.00	--	2.22	2.07	73.6	72.7	1.93	1.98
	Beryllium	4	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	--	1.35	1.50	1.02	0.997	1.43	1.45
	Copper	1300	MCL	39.4	--	6.14	2.05	0.892	0.857	2.77	1.36
	Lead	15	MCL	ND	--	0.278	0.239	0.226	0.219	0.229	0.432
	Mercury	2	MCL	0.340	--	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	--	0.105	1.41	4.11	3.94	3.39	1.35
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	--	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	ND	--	--	--	--	--	--
	1,2-Dichlorobenzene	600	MCL	--	ND	--	--	--	--	--	--
	1,3-Dichlorobenzene	--	--	--	ND	--	--	--	--	--	--
	1,4-Dichlorobenzene	75	MCL	--	ND	--	--	--	--	--	--
	1-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND
	2,4-Dinitrotoluene	--	--	--	ND	--	--	--	--	--	--
	2,6-Dinitrotoluene	--	--	--	ND	--	--	--	--	--	--
2-Chloronaphthalene	--	--	--	ND	--	--	--	--	--	--	
2-Ethylhexyl adipate	--	--	--	--	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-HYD1426		A3-HYD1743	A3-HYD2499		A3-HYD663	A3-HYD664
				Location Type:	Hydrant		Hydrant	Hydrant		Hydrant	Hydrant
				Address:	FH ID: SA-LFH 2		A3-SA-JFH-44	FH752		SA-JFH-52	SA-JFH-4
				Field Sample ID:	20220108-A3-ZT01	20220109-A3-YT-02	220118-A3-YT01	220118-A3-ZT04	220118-A3-ZT05	220118-A3-ZT07	220118-A3-YT04
				Sample Date:	2022-01-08	2022-01-09	2022-01-18	2022-01-18	2022-01-18	2022-01-18	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	2-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND
	2-Methylphenol (o-Cresol)	--	--	--	0.0620	--	--	--	--	--	--
	2-Nitroaniline	--	--	--	ND	--	--	--	--	--	--
	3,3'-Dichlorobenzidine	--	--	--	ND	--	--	--	--	--	--
	3-Nitroaniline	--	--	--	ND	--	--	--	--	--	--
	4-Bromophenyl phenyl ether	--	--	--	ND	--	--	--	--	--	--
	4-Chloroaniline	--	--	--	ND	--	--	--	--	--	--
	4-Chlorophenyl phenyl ether	--	--	--	ND	--	--	--	--	--	--
	4-Nitroaniline	--	--	--	ND	--	--	--	--	--	--
	Acenaphthene	--	--	--	ND	--	--	--	--	--	--
	Acenaphthylene	--	--	--	ND	--	--	--	--	--	--
	Alachlor	--	--	--	--	ND	ND	ND	ND	ND	ND
	Anthracene	--	--	--	ND	--	--	--	--	--	--
	Atrazine	--	--	--	--	ND	ND	ND	ND	ND	ND
	Benzo(a)anthracene	--	--	--	ND	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	--	ND	--	--	--	--	--	--
	Benzo(g,h,i)perylene	--	--	--	ND	--	--	--	--	--	--
	Benzo(k)fluoranthene	--	--	--	ND	--	--	--	--	--	--
	Benzyl butyl phthalate	--	--	--	ND	--	--	--	--	--	--
	Bis(2-chloroethoxy)methane	--	--	--	ND	--	--	--	--	--	--
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	--	ND	--	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbazole	--	--	--	ND	--	--	--	--	--	--
	Chlordane	--	--	--	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-HYD1426		A3-HYD1743	A3-HYD2499		A3-HYD663	A3-HYD664
				Location Type:	Hydrant		Hydrant	Hydrant		Hydrant	Hydrant
				Address:	FH ID: SA-LFH 2		A3-SA-JFH-44	FH752		SA-JFH-52	SA-JFH-4
				Field Sample ID:	20220108-A3-ZT01	20220109-A3-YT-02	220118-A3-YT01	220118-A3-ZT04	220118-A3-ZT05	220118-A3-ZT07	220118-A3-YT04
				Sample Date:	2022-01-08	2022-01-09	2022-01-18	2022-01-18	2022-01-18	2022-01-18	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Chrysene	--	--	--	ND	--	--	--	--	--	--
	Dibenz(a,h)anthracene	--	--	--	ND	--	--	--	--	--	--
	Dibenzofuran	--	--	--	ND	--	--	--	--	--	--
	Diethyl phthalate	--	--	--	ND	--	--	--	--	--	--
	Dimethyl phthalate	--	--	--	ND	--	--	--	--	--	--
	di-n-Butyl phthalate	--	--	--	0.450	--	--	--	--	--	--
	di-n-Octyl phthalate	--	--	--	ND	--	--	--	--	--	--
	Endrin	--	--	--	--	ND	ND	ND	ND	ND	ND
	Fluoranthene	--	--	--	ND	--	--	--	--	--	--
	Fluorene	--	--	--	ND	--	--	--	--	--	--
	gamma-BHC (Lindane)	--	--	--	--	ND	ND	ND	ND	ND	ND
	Heptachlor	--	--	--	--	ND	ND	ND	ND	ND	ND
	Heptachlor epoxide	--	--	--	--	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobutadiene	--	--	--	ND	--	--	--	--	--	--
	Hexachlorocyclopentadiene	--	--	--	--	ND	ND	ND	ND	ND	ND
	Hexachloroethane	--	--	--	ND	--	--	--	--	--	--
	Indeno(1,2,3-c,d)pyrene	--	--	--	ND	--	--	--	--	--	--
	Isophorone	--	--	--	ND	--	--	--	--	--	--
	Methoxychlor	--	--	--	--	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Nitrobenzene	--	--	--	ND	--	--	--	--	--	--
	N-Nitrosodi-n-propylamine	--	--	--	ND	--	--	--	--	--	--
	N-Nitrosodiphenylamine	--	--	--	ND	--	--	--	--	--	--
	PCB, Total	--	--	--	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-HERO6169B	A3-HYD1426		A3-HYD1743	A3-HYD2499		A3-HYD663	A3-HYD664
		Location Type:	Residence	Hydrant		Hydrant	Hydrant		Hydrant	Hydrant
		Address:	6169B Heron Avenue	FH ID: SA-LFH 2		A3-SA-JFH-44	FH752		SA-JFH-52	SA-JFH-4
		Field Sample ID:	A3-TW-0016595-22035-N	20220108-A3-ZT01	20220109-A3-YT-02	220118-A3-YT01	220118-A3-ZT04	220118-A3-ZT05	220118-A3-ZT07	220118-A3-YT04
		Sample Date:	2022-02-07	2022-01-08	2022-01-09	2022-01-18	2022-01-18	2022-01-18	2022-01-18	2022-01-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	PCB-1016 (Aroclor 1016)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	--	--	ND	ND	ND	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	--	--	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	ND	ND	ND	ND	ND
	Phenanthrene	--	--	--	ND	--	--	--	--	--
	Pyrene	--	--	--	ND	--	--	--	--	--
	Simazine	--	--	--	--	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	--	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	--	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	--	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	--	ND	ND	ND	ND	ND

**Summary of Chemistry Results
 Zone A3 Post Residential and Non-Residential Flushing Data
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-HYD1426		A3-HYD1743	A3-HYD2499		A3-HYD663	A3-HYD664
				Location Type:	Hydrant		Hydrant	Hydrant		Hydrant	Hydrant
				Address:	FH ID: SA-LFH 2		A3-SA-JFH-44	FH752		SA-JFH-52	SA-JFH-4
				Field Sample ID:	20220108-A3-ZT01	20220109-A3-YT-02	220118-A3-YT01	220118-A3-ZT04	220118-A3-ZT05	220118-A3-ZT07	220118-A3-YT04
				Sample Date:	2022-01-08	2022-01-09	2022-01-18	2022-01-18	2022-01-18	2022-01-18	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	m,p-Xylene	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	--	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-HYD809	A3-HYD908	A3-HYD920	A3-IBIS6184B	A3-IBIS6200A		A3-IBIS6204	A3-IBIS6216A	
		Location Type:	Hydrant	Hydrant	Hydrant	Residence	Residence		Residence	Residence	
		Address:	SA-JFH-28	SA-JFH-72	SA-JFH-7	6184B Ibis Avenue	6200A Ibis Avenue		6204 Ibis Avenue	6216A Ibis Avenue	
		Field Sample ID:	220118-A3-YT02	220118-A3-ZT06	220118-A3-YT03	A3-TW-0016887-22035-N	A3-TW-0017107-22035-N	A3-TW-0017107-22035-N-72	A3-TW-0012549-22035-N	A3-TW-0017116-22035-N	
		Sample Date:	2022-01-18	2022-01-18	2022-01-18	2022-02-05	2022-02-05	2022-02-07	2022-02-05	2022-02-05	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	2150 §	1920	1820	1690
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.328	0.134	0.169	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.89	2.29	1.92	1.90	2.00	2.00	2.10	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.42	1.49	1.43	1.40	1.60	1.70	1.60	1.60
	Copper	1300	MCL	0.905	50.1	1.63	18.0	48.8	69.0	26.7	15.0
	Lead	15	MCL	0.120	7.57	0.137	0.250	0.450	0.530	0.240	0.330
	Mercury	2	MCL	ND	ND	ND	ND	ND	0.0580	ND	ND
	Selenium	50	MCL	1.45	ND	0.594	ND	ND	2.10	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.100	0.110	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	ND	ND	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	ND	ND	ND	--	--	--	--	--
	Atrazine	--	--	ND	ND	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	ND	ND	ND	--	--	--	--	--
Endrin	--	--	ND	ND	ND	--	--	--	--	--	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-HYD809	A3-HYD908	A3-HYD920	A3-IBIS6184B	A3-IBIS6200A		A3-IBIS6204	A3-IBIS6216A
		Location Type:	Hydrant	Hydrant	Hydrant	Residence	Residence		Residence	Residence
		Address:	SA-JFH-28	SA-JFH-72	SA-JFH-7	6184B Ibis Avenue	6200A Ibis Avenue		6204 Ibis Avenue	6216A Ibis Avenue
		Field Sample ID:	220118-A3-YT02	220118-A3-ZT06	220118-A3-YT03	A3-TW-0016887-22035-N	A3-TW-0017107-22035-N	A3-TW-0017107-22035-N-72	A3-TW-0012549-22035-N	A3-TW-0017116-22035-N
		Sample Date:	2022-01-18	2022-01-18	2022-01-18	2022-02-05	2022-02-05	2022-02-07	2022-02-05	2022-02-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	ND	ND	ND	--	--	--	--
	Heptachlor	--	--	ND	ND	ND	--	--	--	--
	Heptachlor epoxide	--	--	ND	ND	ND	--	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	--	--	--	--
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	--	--	--	--
	Methoxychlor	--	--	ND	ND	ND	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	PCB, Total	--	--	ND	ND	ND	--	--	--	--
	PCB-1016 (Aroclor 1016)	--	--	ND	ND	ND	--	--	--	--
	PCB-1221 (Aroclor 1221)	--	--	ND	ND	ND	--	--	--	--
	PCB-1232 (Aroclor 1232)	--	--	ND	ND	ND	--	--	--	--
	PCB-1242 (Aroclor 1242)	--	--	ND	ND	ND	--	--	--	--
	PCB-1248 (Aroclor 1248)	--	--	ND	ND	ND	--	--	--	--
	PCB-1254 (Aroclor 1254)	--	--	ND	ND	ND	--	--	--	--
	PCB-1260 (Aroclor 1260)	--	--	ND	ND	ND	--	--	--	--
	Pentachlorophenol	1	MCL	ND	ND	ND	--	--	--	--
	Simazine	--	--	ND	ND	ND	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:		Location ID:	Location ID:
				A3-HYD809	A3-HYD908	A3-HYD920	A3-IBIS6184B	A3-IBIS6200A		A3-IBIS6204	A3-IBIS6216A
				Hydrant	Hydrant	Hydrant	Residence	Residence		Residence	Residence
				SA-JFH-28	SA-JFH-72	SA-JFH-7	6184B Ibis Avenue	6200A Ibis Avenue		6204 Ibis Avenue	6216A Ibis Avenue
				220118-A3-YT02	220118-A3-ZT06	220118-A3-YT03	A3-TW-0016887-22035-N	A3-TW-0017107-22035-N	A3-TW-0017107-22035-N-72	A3-TW-0012549-22035-N	A3-TW-0017116-22035-N
				2022-01-18	2022-01-18	2022-01-18	2022-02-05	2022-02-05	2022-02-07	2022-02-05	2022-02-05
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-IBIS6232A	A3-IBIS6258B	A3-IBIS6266B		A3-IBIS6284A	A3-IBIS6302A	A3-IBIS6308B	A3-IBIS6316A	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence	
		Address:	6232A Ibis Avenue	6258B Ibis Avenue	6266B Ibis Avenue		6284A Ibis Avenue	6302A Ibis Avenue	6308B Ibis Avenue	6316A Ibis Avenue	
		Field Sample ID:	A3-TW-0017126-22035-N	A3-TW-0017173-22035-N	A3-TW-0017178-22035-3-N	A3-TW-0017178-22035-N	A3-TW-0017188-22035-N	A3-TW-0017198-22035-N	A3-TW-0016144-22035-N	A3-TW-0016147-22035-N	
		Sample Date:	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-09	2022-02-09	2022-02-07	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1820	1620	1600	1620	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	53.7	54.4	ND	ND	61.1	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	53.7	54.4	ND	ND	61.1	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.00	1.90	2.00	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.30	1.20	1.20	1.60	1.50	1.40	1.20
	Copper	1300	MCL	20.8	37.6	10.2	10.4	45.0	28.4	14.0	22.9
	Lead	15	MCL	0.170	0.300	ND	ND	0.260	0.230	ND	0.190
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	1.70	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-IBIS6232A	A3-IBIS6258B	A3-IBIS6266B		A3-IBIS6284A	A3-IBIS6302A	A3-IBIS6308B	A3-IBIS6316A
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	6232A Ibis Avenue	6258B Ibis Avenue	6266B Ibis Avenue		6284A Ibis Avenue	6302A Ibis Avenue	6308B Ibis Avenue	6316A Ibis Avenue
		Field Sample ID:	A3-TW-0017126-22035-N	A3-TW-0017173-22035-N	A3-TW-0017178-22035-3-N	A3-TW-0017178-22035-N	A3-TW-0017188-22035-N	A3-TW-0017198-22035-N	A3-TW-0016144-22035-N	A3-TW-0016147-22035-N
		Sample Date:	2022-02-05	2022-02-07	2022-02-07	2022-02-07	2022-02-07	2022-02-09	2022-02-09	2022-02-07
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IBIS6330A	A3-IBIS6352A	A3-IROQ5009B	A3-IROQ5012A	A3-IROQ5019	A3-IROQ5036A		A3-IROQ5041
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
					6330A Ibis Avenue	6352A Ibis Avenue	5009B Iroquois Avenue	5012A Iroquois Avenue	5019 Iroquois Point	5036A Iroquois Avenue		5041B Iroquois Avenue
					A3-TW-0017236-22035-N	A3-TW-0016701-22035-N	A3-TW-0016625-22035-N	A3-TW-0012562-22035-N	A3-TW-0012563-22035-N	A3-TW-0017059-22035-N	A3-TW-0017059-22035-N-72	A3-TW-0012565-22035-N
					2022-02-09	2022-02-09	2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-07	2022-02-04
					N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	1960	1860	2150 §	ND	1790	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	59.6	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	59.6	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	1.90	1.80	2.10	2.00	2.10	2.10	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.60	1.50	1.50	1.60	1.40	1.70	1.60	1.60	
	Copper	1300	MCL	45.0	24.1	201	14.3	19.0	58.3	92.0	97.3	
	Lead	15	MCL	0.220	0.170	0.960	0.280	0.280	0.660	0.930	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	1.80	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IBIS6330A	A3-IBIS6352A	A3-IROQ5009B	A3-IROQ5012A	A3-IROQ5019	A3-IROQ5036A		A3-IROQ5041
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residence	Residence
					6330A Ibis Avenue	6352A Ibis Avenue	5009B Iroquois Avenue	5012A Iroquois Avenue	5019 Iroquois Point	5036A Iroquois Avenue		5041B Iroquois Avenue
					A3-TW-0017236-22035-N	A3-TW-0016701-22035-N	A3-TW-0016625-22035-N	A3-TW-0012562-22035-N	A3-TW-0012563-22035-N	A3-TW-0017059-22035-N	A3-TW-0017059-22035-N-72	A3-TW-0012565-22035-N
					2022-02-09	2022-02-09	2022-02-05	2022-02-05	2022-02-05	2022-02-05	2022-02-07	2022-02-04
					N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IBIS6330A	A3-IBIS6352A	A3-IROQ5009B	A3-IROQ5012A	A3-IROQ5019	A3-IROQ5036A		A3-IROQ5041
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL		ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IROQ5066B		A3-IROQ5078	A3-IROQ5095B	A3-IROQ5111				
				Location Type:	Residence		Residence	Residence	School				
				Address:	5066B Iroquois Avenue		5078 Iroquois Avenue	5095B Iroquois Avenue	5111 Iroquois Ave, Iroquois Point Pre-School				
				Field Sample ID:	A3-TW-0017065-22035-N	A3-TW-0017214-22035-N	A3-TW-0017214-22035-N-72	A3-TW-0012567-22035-N	A3-TW-0017230-22035-N	220131A3CT02	220131A3CT03	220131A3DT04	
				Sample Date:	2022-02-05	2022-02-05	2022-02-07	2022-02-05	2022-02-05	2022-01-31	2022-01-31	2022-01-31	
				Sample Type:	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1640	ND	ND	1760	ND	ND	ND	ND	1800	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.00	2.00	1.90	2.00	1.90	2.10	2.10	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	0.0660	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.40	1.60	1.60	1.40	1.40	1.10	1.40	1.30	1.30	
	Copper	1300	MCL	34.4	69.3	74.0	28.9	21.4	92.5	80.9	73.2	73.2	
	Lead	15	MCL	0.280	0.550	0.710	0.310	0.490	0.370	0.370	0.290	0.290	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	1.70	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	0.100	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IROQ5066B		A3-IROQ5078	A3-IROQ5095B	A3-IROQ5111			
				Location Type:	Residence		Residence	Residence	School			
				Address:	5066B Iroquois Avenue		5078 Iroquois Avenue	5095B Iroquois Avenue	5111 Iroquois Ave, Iroquois Point Pre-School			
				Field Sample ID:	A3-TW-0017065-22035-N	A3-TW-0017214-22035-N	A3-TW-0017214-22035-N-72	A3-TW-0012567-22035-N	A3-TW-0017230-22035-N	220131A3CT02	220131A3CT03	220131A3DT04
				Sample Date:	2022-02-05	2022-02-05	2022-02-07	2022-02-05	2022-02-05	2022-01-31	2022-01-31	2022-01-31
				Sample Type:	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: A3-IROQ5111				A3-IROQ5125	A3-IROQ5135		A3-IROQ5162	
				Location Type: School				Residence	Residence		Residence	
				Address: 5111 Iroquois Ave, Iroquois Point Pre-School				5125 Iroquois Avenue	5135 Iroquois Avenue		5162 Iroquois Avenue	
				Field Sample ID:	220131A3DT05	220131A3DT06	220131A3JT02	A3-TW-0012569-22056-N-1	A3-TW-0012570-22035-N	A3-TW-0012571-22035-3-N	A3-TW-0012571-22035-N	A3-TW-0012572-22035-3-N
				Sample Date:	2022-01-31	2022-01-31	2022-01-31	2022-02-25	2022-02-07	2022-02-09	2022-02-09	2022-02-08
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	11600 §	2390 §	1600	ND	ND	ND	400	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	--	ND	52.5	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	--	ND	52.5	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.10	2.00	--	1.90	1.90	2.00	2.10	2.10
	Beryllium	4	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.30	1.50	1.30	--	1.80	1.50	1.60	1.40	1.40
	Copper	1300	MCL	86.5	75.1	79.8	--	30.0	21.6	23.6	32.1	32.1
	Lead	15	MCL	0.430	0.260	8.40	--	1.30	0.220	0.220	0.320	0.320
	Mercury	2	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
Thallium	2	MCL	ND	ND	ND	--	ND	ND	0.0940	0.0960	0.0960	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	--	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: A3-IROQ5111				A3-IROQ5125	A3-IROQ5135		A3-IROQ5162	
		Location Type: School				Residence	Residence		Residence	
		Address: 5111 Iroquois Ave, Iroquois Point Pre-School				5125 Iroquois Avenue	5135 Iroquois Avenue		5162 Iroquois Avenue	
		Field Sample ID:	220131A3DT05	220131A3DT06	220131A3JT02	A3-TW-0012569-22056-N-1	A3-TW-0012570-22035-N	A3-TW-0012571-22035-3-N	A3-TW-0012571-22035-N	A3-TW-0012572-22035-3-N
		Sample Date:	2022-01-31	2022-01-31	2022-01-31	2022-02-25	2022-02-07	2022-02-09	2022-02-09	2022-02-08
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	--	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	--	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	--	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	--	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	--	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	--	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	--	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	--	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IROQ5162	A3-IROQ5188	A3-IROQ5201B	A3-IROQ5222A	A3-IROQ5234	A3-IROQ5256A	A3-IROQ5272	A3-IROQ5282	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	5162 Iroquois Avenue	5188 Iroquois Avenue	5201B Iroquois Avenue	5222A Iroquois Avenue	5234 Iroquois Avenue	5256A Iroquois Avenue	5272 Iroquois Avenue	5282 Iroquois Avenue	
				Field Sample ID:	A3-TW-0012572-22035-N	A3-TW-0012573-22035-N	A3-TW-0016702-22035-N	A3-TW-0016709-22035-N	A3-TW-0012576-22035-N	A3-TW-0017154-22035-N	A3-TW-0017159-22035-N	A3-TW-0012499-22035-N	
				Sample Date:	2022-02-08	2022-02-09	2022-02-07	2022-02-08	2022-02-09	2022-02-09	2022-02-08	2022-02-08	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2040 §	ND	ND	ND	1730	ND	ND	ND	1910	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	179	ND	54.3	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	179	ND	54.3	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.10	2.20	2.10	2.10	2.10	2.10	2.20	2.20	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.30	1.60	1.20	1.40	1.50	1.50	1.50	1.20	1.40	
	Copper	1300	MCL	32.2	27.7	56.2	30.6	44.9	27.2	44.7	44.7	28.6	
	Lead	15	MCL	0.270	0.280	0.590	0.330	0.290	0.240	0.240	0.240	0.130	
	Mercury	2	MCL	ND	ND	0.140	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	0.0920	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	A3-IROQ5162	A3-IROQ5188	A3-IROQ5201B	A3-IROQ5222A	A3-IROQ5234	A3-IROQ5256A	A3-IROQ5272	A3-IROQ5282
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5162 Iroquois Avenue	5188 Iroquois Avenue	5201B Iroquois Avenue	5222A Iroquois Avenue	5234 Iroquois Avenue	5256A Iroquois Avenue	5272 Iroquois Avenue	5282 Iroquois Avenue
		Field Sample ID:	A3-TW-0012572-22035-N	A3-TW-0012573-22035-N	A3-TW-0016702-22035-N	A3-TW-0016709-22035-N	A3-TW-0012576-22035-N	A3-TW-0017154-22035-N	A3-TW-0017159-22035-N	A3-TW-0012499-22035-N
		Sample Date:	2022-02-08	2022-02-09	2022-02-07	2022-02-08	2022-02-09	2022-02-09	2022-02-08	2022-02-08
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IROQ5306A		A3-IROQ5320	A3-KELA4974D		A3-KELA4976B	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				A3-IROQ5297 Residence 5297 Iroquois Avenue	A3-IROQ5306A Residence 5306A Iroquois Avenue	A3-IROQ5320 Residence 5320 Iroquois Avenue	A3-IROQ5320 Residence 5320 Iroquois Avenue	A3-KELA4974D Residence 4974D Kela Place	A3-KELA4974D Residence 4974D Kela Place	A3-KELA4976B Residence 4976B Kela Place	A3-KELA4976B Residence 4976B Kela Place
				A3-TW-0012500-22035-N 2022-02-08 N (Normal)	A3-TW-0016491-22035-3-N 2022-02-09 FD (Field Duplicate)	A3-TW-0016491-22035-N 2022-02-09 N (Normal)	A3-TW-0016890-22035-N 2022-02-08 N (Normal)	A3-TW-0012504-22035-3-N 2022-02-04 FD (Field Duplicate)	A3-TW-0012504-22035-N 2022-02-04 N (Normal)	A3-TW-0016849-22035-N 2022-02-05 N (Normal)	A3-TW-0016849-22035-N-72 2022-02-07 N (72 Hour Stagnation)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	1860	2120 §	ND	2010 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.20	2.10	2.40	2.10	2.10	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.30	1.40	1.50	1.50	1.30	1.30	1.40	1.60
	Copper	1300	MCL	48.8	11.8	12.2	55.6	14.2	13.9	60.7	77.0
	Lead	15	MCL	0.220	ND	ND	0.410	0.150	0.150	0.260	0.440
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	0.110	ND	ND	ND	0.100	0.0990	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-IROQ5306A		A3-IROQ5320	A3-KELA4974D		A3-KELA4976B		
				Location Type:	Residence		Residence	Residence		Residence		
				Address:	5306A Iroquois Avenue		5320 Iroquois Avenue	4974D Kela Place		4976B Kela Place		
				Field Sample ID:	A3-TW-0012500-22035-N	A3-TW-0016491-22035-3-N	A3-TW-0016491-22035-N	A3-TW-0016890-22035-N	A3-TW-0012504-22035-3-N	A3-TW-0012504-22035-N	A3-TW-0016849-22035-N	A3-TW-0016849-22035-N-72
				Sample Date:	2022-02-08	2022-02-09	2022-02-09	2022-02-08	2022-02-04	2022-02-04	2022-02-05	2022-02-07
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (72 Hour Stagnation)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-MARI6033		A3-MARI6041A	A3-MARI6048	A3-MOKU4908A	A3-MOKU4918C	A3-MOKU4919A	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	6033 Marina Drive		6041A Marina Drive	6048 Marina Drive	4908A Mokupea Place	4918C Mokupea Place	4919A Mokupea Place	
				Field Sample ID:	A3-TW-0016854-22035-N	A3-TW-0016857-22035-3-N	A3-TW-0016857-22035-N	A3-TW-0016860-22035-N	A3-TW-0012506-22035-N	A3-TW-0016868-22035-N	A3-TW-0012508-22035-N	A3-TW-0012509-22035-N
				Sample Date:	2022-02-08	2022-02-09	2022-02-09	2022-02-08	2022-02-09	2022-02-04	2022-02-04	2022-02-05
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2930 §	ND	ND	ND	ND	7410 §	2100 §	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.10	2.00	2.00	2.20	2.00	1.90	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.30	1.50	1.50	1.60	1.60	1.80	1.40	1.50	
	Copper	1300	MCL	27.6	36.4	34.8	36.0	43.8	19.4	40.8	14.4	
	Lead	15	MCL	0.160	0.370	0.350	0.290	0.580	0.170	0.200	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	0.0990	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-MARI6033		A3-MARI6041A	A3-MARI6048	A3-MOKU4908A	A3-MOKU4918C	A3-MOKU4919A	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	6033 Marina Drive		6041A Marina Drive	6048 Marina Drive	4908A Mokupea Place	4918C Mokupea Place	4919A Mokupea Place	
				Field Sample ID:	A3-TW-0016854-22035-N	A3-TW-0016857-22035-3-N	A3-TW-0016857-22035-N	A3-TW-0016860-22035-N	A3-TW-0012506-22035-N	A3-TW-0016868-22035-N	A3-TW-0012508-22035-N	A3-TW-0012509-22035-N
				Sample Date:	2022-02-08	2022-02-09	2022-02-09	2022-02-08	2022-02-09	2022-02-04	2022-02-04	2022-02-05
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-MOKU4920B	A3-WEHA4839C	A3-WEHI4952C		A3-WEHI4956A	A3-WEKO4807D		A3-WELU4775A	
				Location Type:	Residence	Residence	Residence		Residence	Residence		Residence	
				Address:	4920B Mokupea Place	4839C West Eha Way	4952C West Ehiku Way		4956A West Ehiku Way	4807D West Ekolu Way		4775A West Elua Way	
				Field Sample ID:	A3-TW-0016726-22035-N	A3-TW-0016745-22035-N	A3-TW-0016753-22035-N	A3-TW-0016753-22035-N-72	A3-TW-0016765-22035-N	A3-TW-0016812-22035-3-N	A3-TW-0016812-22035-N	A3-TW-0016833-22035-N	
				Sample Date:	2022-02-04	2022-02-04	2022-02-05	2022-02-07	2022-02-04	2022-02-04	2022-02-04	2022-02-05	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1600	1790	1890	2270 §	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.30	2.10	2.10	2.10	2.00	2.00	2.10	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.40	1.30	1.30	1.80	1.70	1.70	1.70	1.50	1.50	
	Copper	1300	MCL	22.0	38.8	34.2	39.0	20.4	25.0	49.7	53.6	53.6	
	Lead	15	MCL	0.130	0.290	0.340	0.550	0.210	0.170	0.300	0.300	0.300	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone A3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone A3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	A3-MOKU4920B	A3-WEHA4839C	A3-WEHI4952C		A3-WEHI4956A	A3-WEKO4807D		A3-WELU4775A
				Location Type:	Residence	Residence	Residence		Residence	Residence		Residence
				Address:	4920B Mokupea Place	4839C West Eha Way	4952C West Ehiku Way		4956A West Ehiku Way	4807D West Ekolu Way		4775A West Elua Way
				Field Sample ID:	A3-TW-0016726-22035-N	A3-TW-0016745-22035-N	A3-TW-0016753-22035-N	A3-TW-0016753-22035-N-72	A3-TW-0016765-22035-N	A3-TW-0016812-22035-3-N	A3-TW-0016812-22035-N	A3-TW-0016833-22035-N
				Sample Date:	2022-02-04	2022-02-04	2022-02-05	2022-02-07	2022-02-04	2022-02-04	2022-02-04	2022-02-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	