

**Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: B1-KAEE2855E		Location ID: B1-KAEE2855F		Location ID: B1-KOKI2862A		Location ID: B1-KUPA2872A	Location ID: B1-KUPA2872F
				Location Type: Residence	Address: 2855E Kaee Loop	Location Type: Residence	Address: 2855F Kaee Loop	Location Type: Residence	Address: 2862A Kokio Loop	Location Type: Residence	Address: 2872A Kupalii Loop
				Field Sample ID: B1-TW-0017591-22048-N	Field Sample ID: B1-TW-0017591-22048-N-72	Field Sample ID: B1-TW-0017592-22048-N	Field Sample ID: B1-TW-0017592-22048-N-72	Field Sample ID: 220127B1CT01	Field Sample ID: 220127B1CT02	Field Sample ID: 220127B1CT03	Field Sample ID: 220127B1CT04
				Sample Date: 2022-02-17	Sample Date: 2022-02-20	Sample Date: 2022-02-18	Sample Date: 2022-02-21	Sample Date: 2022-01-27	Sample Date: 2022-01-27	Sample Date: 2022-01-27	Sample Date: 2022-01-27
				Sample Type: N (Normal)	Sample Type: N (72 Hour Stagnation)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)	Sample Type: N (Normal)	Sample Type: N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	--	--	--	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	--	--	--	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	--	--	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	--	--	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	--	--	ND	ND	ND	ND
	Benzene	5	MCL	ND	--	--	--	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	--	--	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	--	--	--	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	--	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	--	--	--	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	--	--	--	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	--	--	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	--	--	--	ND	ND	ND	ND
	Styrene	100	MCL	ND	--	--	--	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	--	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	--	--	--	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	--	--	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	--	--	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	--	--	--	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	--	--	--	ND	ND	ND	ND

Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: B1-MAKU2885B		B1-MAKU2899D	B1-MCGR0371	B1-MCGR0500	B1-MCGR0553	B1-MCGR0593	B1-MCGR0628
				Location Type: Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address: 2885B Makuu Loop		2899D Makuu Loop	371 McGrew Loop	500 McGrew Loop	553 McGrew Loop	593 McGrew Point	628 McGrew Loop
				Field Sample ID: 220127B1DT01	220127B1DT02	220127B1BT05	220127B1BT07	220127B1DT03	220127B1DT04	220127B1DT06	220127B1DT05
				Sample Date: 2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27
				Sample Type: N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	1580	2600 §	ND	ND	ND	1990
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.00	2.20	1.80	1.80	1.80	1.80	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.30	1.40	1.50	1.60	1.40	1.50	1.60	1.40
	Copper	1300	MCL	61.1	22.6	28.9	22.1	9.00	3.50	5.30	17.5
	Lead	15	MCL	ND	ND	0.230	1.50	0.260	ND	1.50	0.200
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: B1-MAKU2885B		B1-MAKU2899D	B1-MCGR0371	B1-MCGR0500	B1-MCGR0553	B1-MCGR0593	B1-MCGR0628
				Location Type: Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address: 2885B Makuu Loop		2899D Makuu Loop	371 McGrew Loop	500 McGrew Loop	553 McGrew Loop	593 McGrew Point	628 McGrew Loop
				Field Sample ID: 220127B1DT01	220127B1DT02	220127B1BT05	220127B1BT07	220127B1DT03	220127B1DT04	220127B1DT06	220127B1DT05
				Sample Date: 2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27
				Sample Type: N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	B1-MCGR0730		B1-MCGR0799	B1-MCGR0838	B1-MCGR0873	B1-OLIA2919A		
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	730 McGrew Loop		799 McGrew Loop	838 McGrew Loop	873 McGrew Loop	2919A Oliana Loop		
				Field Sample ID:	220127B1AT07	220127B1AT04	220127B1AT05	220127B1CT05	220127B1AT08	220127B1AT09	220127B1FT04	220129B1AT05
				Sample Date:	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-29
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	1600	1710	1840	ND	ND	1740	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	1.80	1.70	1.80	1.90	1.80	1.80	2.30	2.40	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.50	1.30	1.40	1.50	1.50	1.40	1.70	1.30	
	Copper	1300	MCL	17.2	6.10	7.30	7.40	30.2	6.60	17.0	18.0	
	Lead	15	MCL	ND	0.140	0.340	0.330	0.220	ND	0.270	0.290	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	B1-MCGR0730		B1-MCGR0799	B1-MCGR0838	B1-MCGR0873	B1-OLIA2919A		
				Location Type:	Residence		Residence	Residence	Residence	Residence		
				Address:	730 McGrew Loop		799 McGrew Loop	838 McGrew Loop	873 McGrew Loop	2919A Oliana Loop		
				Field Sample ID:	220127B1AT07	220127B1AT04	220127B1AT05	220127B1CT05	220127B1AT08	220127B1AT09	220127B1FT04	220129B1AT05
				Sample Date:	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-27	2022-01-29
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	B1-OLIA2927
Location Type:	Residence
Address:	2927 Oliana Loop
Field Sample ID:	220127B1BT06
Sample Date:	2022-01-27
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.30
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.50
	Copper	1300	MCL	8.60
	Lead	15	MCL	0.230
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
Thallium	2	MCL	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND

Summary of Chemistry Results
Zone B1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	B1-OLIA2927
Location Type:	Residence
Address:	2927 Oliana Loop
Field Sample ID:	220127B1BT06
Sample Date:	2022-01-27
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene (Total)	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
	Xylenes, Total	10000	MCL	ND