

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG1655					C1-BLDG2186		C1-HYD1183
				Location Type:	Child Development Center					Non-Residence		Hydrant
				Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd					Building 2186,NEX MINI-MART HOLOMOKU, 1477 North Rd		FH ID: 512
				Field Sample ID:	220128C1AT09	220127C1KT01	220127C1LT01	C1-TW-0014751-22057-N	C1-TW-0014751-22057-N-R1	220131C1AT01	220131C1AT02	20220105-C1-ZT03
				Sample Date:	2022-01-28	2022-01-27	2022-01-27	2022-02-26	2022-02-26	2022-01-31	2022-01-31	2022-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Synthetic Organic Compounds (ppb)	Pyrene	--	--	--	--	--	--	--	--	--	--	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	--	ND	ND	ND	ND
	1,1,2,2-Tetrachloroethane	--	--	--	--	--	--	--	--	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	1,1-Dichloroethane	--	--	--	--	--	--	--	--	--	--	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	--	ND	ND	ND	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	--	ND	ND	ND	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	--	ND	ND	ND	--
	2-Butanone (MEK)	--	--	--	--	--	--	--	--	--	--	ND
	2-Hexanone	--	--	--	--	--	--	--	--	--	--	ND
	4-Methyl-2-pentanone (MIBK)	--	--	--	--	--	--	--	--	--	--	ND
	Acetone	--	--	--	--	--	--	--	--	--	--	ND
	Benzene	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
Bromomethane	--	--	--	--	--	--	--	--	--	--	ND	
Carbon disulfide	--	--	--	--	--	--	--	--	--	--	ND	
Carbon Tetrachloride	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND	
Chlorobenzene	100	MCL	ND	ND	ND	--	--	ND	ND	ND	ND	
Chloroethane	--	--	--	--	--	--	--	--	--	--	ND	

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG1655					C1-BLDG2186		C1-HYD1183
				Location Type:	Child Development Center					Non-Residence		Hydrant
				Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd					Building 2186,NEX MINI-MART HOLOMOKU, 1477 North Rd		FH ID: 512
				Field Sample ID:	220128C1AT09	220127C1KT01	220127C1LT01	C1-TW-0014751-22057-N	C1-TW-0014751-22057-N-R1	220131C1AT01	220131C1AT02	20220105-C1-ZT03
				Sample Date:	2022-01-28	2022-01-27	2022-01-27	2022-02-26	2022-02-26	2022-01-31	2022-01-31	2022-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Volatile Organic Compounds (ppb)	Chloromethane	--	--	--	--	--	--	--	--	--	--	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	cis-1,3-Dichloropropene	--	--	--	--	--	--	--	--	--	--	ND
	Ethylbenzene	700	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	--	--	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	--	--	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	trans-1,3-Dichloropropene	--	--	--	--	--	--	--	--	--	--	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	--	--	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	--	--	--	--	--	ND
	Bromoform	--	--	--	--	--	--	--	--	--	--	4.10
	Chloroform	--	--	--	--	--	--	--	--	--	--	ND
	Dibromochloromethane	--	--	--	--	--	--	--	--	--	--	ND
	Total Trihalomethanes	80	MCL	--	--	--	--	--	--	--	--	4.10

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH ID: 512	FH ID: FH 503	FHID: 563	FHID: 479	FHID: 413	FHID: 530A
				Field Sample ID:	220203C1ZT03	20220106-C1-ZT06	220117-C1-XT06	220117-C1-XT02	220117-C1-XT03	220117-C1-XT01
				Sample Date:	2022-02-03	2022-01-06	2022-01-17	2022-01-17	2022-01-17	2022-01-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	311	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	ND	94.0	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	ND	ND	180	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	--	ND	ND	180	94.0	ND	ND
Metals (ppb)	Antimony	6	MCL	--	ND	ND	ND	ND	ND	0.115
	Arsenic	10	MCL	--	ND	0.175	0.249	0.287	0.143	
	Barium	2000	MCL	--	3.96	1.93	2.15	3.16	10.2	
	Beryllium	4	MCL	--	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	--	ND	ND	ND	ND	ND	
	Chromium	100	MCL	--	1.51	1.30	1.09	1.39	1.13	
	Copper	1300	MCL	--	2.58	2.62	16.3	0.877	0.427	
	Lead	15	MCL	--	0.906	0.362	1.19	ND	0.381	
	Mercury	2	MCL	--	ND	ND	ND	ND	ND	
	Selenium	50	MCL	--	ND	0.891	1.06	1.25	0.363	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	--	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	--	--	--	--	--	
	1,2-Dichlorobenzene	600	MCL	ND	--	--	--	--	--	
	1,3-Dichlorobenzene	--	--	ND	--	--	--	--	--	
	1,4-Dichlorobenzene	75	MCL	ND	--	--	--	--	--	
	1-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	
	2,4,5-Trichlorophenol	--	--	ND	--	--	--	--	--	
	2,4,6-Trichlorophenol	--	--	ND	--	--	--	--	--	
2,4-Dichlorophenol	--	--	ND	--	--	--	--	--		
2,4-Dimethylphenol	--	--	ND	--	--	--	--	--		

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH ID: 512	FH ID: FH 503	FHID: 563	FHID: 479	FHID: 413	FHID: 530A	
		Field Sample ID:	220203C1ZT03	20220106-C1-ZT06	220117-C1-XT06	220117-C1-XT02	220117-C1-XT03	220117-C1-XT01	
		Sample Date:	2022-02-03	2022-01-06	2022-01-17	2022-01-17	2022-01-17	2022-01-17	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817
Synthetic Organic Compounds (ppb)	2,4-Dinitrophenol	--	--	ND	--	--	--	--	--
	2,4-Dinitrotoluene	--	--	ND	--	--	--	--	--
	2,6-Dinitrotoluene	--	--	ND	--	--	--	--	--
	2-Chloronaphthalene	--	--	ND	--	--	--	--	--
	2-Chlorophenol	--	--	ND	--	--	--	--	--
	2-Ethylhexyl adipate	--	--	--	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	ND	ND	0.00915	ND	ND
	2-Methylphenol (o-Cresol)	--	--	ND	--	--	--	--	--
	2-Nitroaniline	--	--	ND	--	--	--	--	--
	3,3'-Dichlorobenzidine	--	--	ND	--	--	--	--	--
	3-Nitroaniline	--	--	ND	--	--	--	--	--
	4,6-Dinitro-2-methylphenol	--	--	ND	--	--	--	--	--
	4-Bromophenyl phenyl ether	--	--	ND	--	--	--	--	--
	4-Chloro-3-methylphenol	--	--	ND	--	--	--	--	--
	4-Chloroaniline	--	--	ND	--	--	--	--	--
	4-Chlorophenyl phenyl ether	--	--	ND	--	--	--	--	--
	4-Nitroaniline	--	--	ND	--	--	--	--	--
	4-Nitrophenol	--	--	ND	--	--	--	--	--
	Acenaphthene	--	--	ND	--	--	--	--	--
	Acenaphthylene	--	--	ND	--	--	--	--	--
	Alachlor	--	--	--	ND	ND	ND	ND	ND
	Anthracene	--	--	ND	--	--	--	--	--
Atrazine	--	--	--	ND	ND	ND	ND	ND	
Benzo(a)anthracene	--	--	ND	--	--	--	--	--	
Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH ID: 512	FH ID: FH 503	FHID: 563	FHID: 479	FHID: 413	FHID: 530A
				Field Sample ID:	220203C1ZT03	20220106-C1-ZT06	220117-C1-XT06	220117-C1-XT02	220117-C1-XT03	220117-C1-XT01
				Sample Date:	2022-02-03	2022-01-06	2022-01-17	2022-01-17	2022-01-17	2022-01-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Benzo(b)fluoranthene	--	--	ND	--	--	--	--	--	--
	Benzo(g,h,i)perylene	--	--	ND	--	--	--	--	--	--
	Benzo(k)fluoranthene	--	--	ND	--	--	--	--	--	--
	Benzyl butyl phthalate	--	--	ND	--	--	--	--	--	--
	Bis(2-chloroethoxy)methane	--	--	ND	--	--	--	--	--	--
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	ND	--	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbazole	--	--	ND	--	--	--	--	--	--
	Chlordane	--	--	--	ND	ND	ND	ND	ND	ND
	Chrysene	--	--	ND	--	--	--	--	--	--
	Cresols, m- & p-	--	--	ND	--	--	--	--	--	--
	Dibenz(a,h)anthracene	--	--	ND	--	--	--	--	--	--
	Dibenzofuran	--	--	ND	--	--	--	--	--	--
	Diethyl phthalate	--	--	ND	--	--	--	--	--	--
	Dimethyl phthalate	--	--	ND	--	--	--	--	--	--
	di-n-Butyl phthalate	--	--	ND	--	--	--	--	--	--
	di-n-Octyl phthalate	--	--	ND	--	--	--	--	--	--
	Endrin	--	--	--	ND	ND	ND	ND	ND	ND
	Fluoranthene	--	--	ND	--	--	--	--	--	--
	Fluorene	--	--	ND	--	--	--	--	--	--
	gamma-BHC (Lindane)	--	--	--	ND	ND	ND	ND	ND	ND
Heptachlor	--	--	--	ND	ND	ND	ND	ND	ND	
Heptachlor epoxide	--	--	--	ND	ND	ND	ND	ND	ND	
Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	
Hexachlorobutadiene	--	--	ND	--	--	--	--	--	--	

Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:
				C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817
				Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				FH ID: 512	FH ID: FH 503	FHID: 563	FHID: 479	FHID: 413	FHID: 530A
				220203C1ZT03	20220106-C1-ZT06	220117-C1-XT06	220117-C1-XT02	220117-C1-XT03	220117-C1-XT01
				2022-02-03	2022-01-06	2022-01-17	2022-01-17	2022-01-17	2022-01-17
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND
	Hexachloroethane	--	--	ND	--	--	--	--	--
	Indeno(1,2,3-c,d)pyrene	--	--	ND	--	--	--	--	--
	Isophorone	--	--	ND	--	--	--	--	--
	Methoxychlor	--	--	--	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND
	Nitrobenzene	--	--	ND	--	--	--	--	--
	N-Nitrosodi-n-propylamine	--	--	ND	--	--	--	--	--
	N-Nitrosodiphenylamine	--	--	ND	--	--	--	--	--
	PCB, Total	--	--	--	ND	ND	ND	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	--	ND	ND	ND	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	--	ND	ND	ND	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	--	ND	ND	ND	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	--	ND	ND	ND	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	--	ND	ND	ND	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	--	ND	ND	ND	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	--	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	ND	ND	ND	ND	ND	ND
	Phenanthrene	--	--	ND	--	--	--	--	--
	Phenol	--	--	ND	--	--	--	--	--
	Pyrene	--	--	ND	--	--	--	--	--
	Simazine	--	--	--	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	ND	ND	ND	ND	ND
	1,1-Dichloroethane	7	MCL	--	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone C1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-HYD1183	C1-HYD1765	C1-HYD1769	C1-HYD354	C1-HYD444	C1-HYD817
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH ID: 512	FH ID: FH 503	FHID: 563	FHID: 479	FHID: 413	FHID: 530A
				Field Sample ID:	220203C1ZT03	20220106-C1-ZT06	220117-C1-XT06	220117-C1-XT02	220117-C1-XT03	220117-C1-XT01
				Sample Date:	2022-02-03	2022-01-06	2022-01-17	2022-01-17	2022-01-17	2022-01-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	--	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	--	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	--	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	--	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	--	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	ND	ND	ND