

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-ABEN3327		D1-BENO3330		D1-BLDG1314	D1-BORL3322	D1-BOTH0401	D1-BOTH0409	D1-CCRU3346
		Location Type:		Residence		Residence		Non-Residence	Residence	Residence	Residence	Residence
		Address:		3327A Benoit Place		3330 Benoit Place		Building 1314, CLUB PEARL, 915 N Rd	3322 Orlando Place	401 Bothne Court	409 Bothne Court	3346 Cruse Place
		Field Sample ID:		220109-D1-BT04		220110-D1-BT01	220110-D1-BT03	220110-D1-ET12	220110-D1-GT01	220109-D1-GT07	220109-D1-AT03	220110-D1-CT01
		Sample Date:		2022-01-09		2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09	2022-01-10
		Sample Type:		N (Normal)		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	1.90	1.90	1.90	2.00	1.90	1.80	1.80	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.90	2.00	1.90	2.30	2.00	2.20	2.10	1.90	1.90
	Copper	1300	MCL	22.0	27.0	27.0	21.0	42.0	140	68.0	27.0	27.0
	Lead	15	MCL	0.140	ND	ND	ND	ND	0.250	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	0.470	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D1-ABEN3327		D1-BENO3330		D1-BLDG1314	D1-BORL3322	D1-BOTH0401	D1-BOTH0409	D1-CCRU3346
				Location Type:	Residence		Residence		Non-Residence	Residence	Residence	Residence	Residence
				Address:	3327A Benoit Place		3330 Benoit Place		Building 1314,CLUB PEARL, 915 N Rd	3322 Orlando Place	401 Bothne Court	409 Bothne Court	3346 Cruse Place
				Field Sample ID:	220109-D1-BT04	220110-D1-BT01	220110-D1-BT03		220110-D1-ET12	220110-D1-GT01	220109-D1-GT07	220109-D1-AT03	220110-D1-CT01
				Sample Date:	2022-01-09	2022-01-10	2022-01-10		2022-01-10	2022-01-10	2022-01-09	2022-01-09	2022-01-10
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND			ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND			ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND			ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND			ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-CHRI0320	D1-CSTO3316	D1-DUNL0207	D1-EOUT1005		D1-EOUT1006	D1-EOUT1007	
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	
		Address:		320 Christopher Court	3316C Stommes Place	207 Dunlap Court	1005 East Outerbridge Court		1006 East Outerbridge Court	1007 East Outerbridge Court	
		Field Sample ID:		220110-D1-AT08	220110-D1-CT13	220109-D1-GT05	220129D1GT01	220130D1FT03	220110-D1-ET03	220110-D1-CT10	220129D1HT01
		Sample Date:		2022-01-10	2022-01-10	2022-01-09	2022-01-29	2022-01-30	2022-01-10	2022-01-10	2022-01-29
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	1900	1530	ND	ND	3870 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	268	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	237	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	505 §	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	0.610	ND
	Barium	2000	MCL	2.10	2.10	1.80	1.80	1.70	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.00	2.30	2.00	1.30	1.40	2.10	2.50	1.20
	Copper	1300	MCL	83.0	25.0	130	58.7	64.6	35.0	50.0	55.2
	Lead	15	MCL	0.280	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	1.10	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	1.90	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	--	--	ND	ND	--
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	--	--	ND	ND	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-CHRI0320	D1-CSTO3316	D1-DUNL0207	D1-EOUT1005		D1-EOUT1006	D1-EOUT1007	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	320 Christopher Court	3316C Stommes Place	207 Dunlap Court	1005 East Outerbridge Court		1006 East Outerbridge Court	1007 East Outerbridge Court	
		Field Sample ID:	220110-D1-AT08	220110-D1-CT13	220109-D1-GT05	220129D1GT01	220130D1FT03	220110-D1-ET03	220110-D1-CT10	220129D1HT01
		Sample Date:	2022-01-10	2022-01-10	2022-01-09	2022-01-29	2022-01-30	2022-01-10	2022-01-10	2022-01-29
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	0.0700	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	0.0700	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-EOUT1007	D1-EOUT1009	D1-EOUT1010	D1-EOUT1018	D1-FISL1810	D1-GOMB1411	D1-GRAH0505	D1-HOOP3303F
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1007 East Outerbridge Court	1009 East Outerbridge Court	1010 East Outerbridge Court	1018 East Outerbridge Court	1810 Fisler Court	1411 Gombasy Court	505 Graham Court	3303F Hooper Place
		Field Sample ID:	220130D1HT01	220110-D1-DT06	220110-D1-ET04	220109-D1-FT07	220109-D1-GT01	220110-D1-FT16	220109-D1-DT08	220110-D1-ET02
		Sample Date:	2022-01-30	2022-01-10	2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-09	2022-01-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.80	3.50
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	2.10	2.00	2.10	2.40	2.50	1.90
	Copper	1300	MCL	46.0	91.0	80.0	42.0	89.0	35.0	27.0
	Lead	15	MCL	0.130	0.460	0.170	ND	0.240	0.130	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	0.0640	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	0.380	ND
	Hexachlorobenzene	--	--	--	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	--	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-EOUT1007	D1-EOUT1009	D1-EOUT1010	D1-EOUT1018	D1-FISL1810	D1-GOMB1411	D1-GRAH0505	D1-HOOP3303F
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1007 East Outerbridge Court	1009 East Outerbridge Court	1010 East Outerbridge Court	1018 East Outerbridge Court	1810 Fisler Court	1411 Gombasy Court	505 Graham Court	3303F Hooper Place
		Field Sample ID:	220130D1HT01	220110-D1-DT06	220110-D1-ET04	220109-D1-FT07	220109-D1-GT01	220110-D1-FT16	220109-D1-DT08	220110-D1-ET02
		Sample Date:	2022-01-30	2022-01-10	2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-09	2022-01-10
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D1-HUTT0905	D1-HUTT0914		D1-HUTT0921	D1-HYD2237	D1-HYD714	D1-HYD731	D1-HYD748
				Location Type:	Residence	Residence		Residence	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	905 Huttenberg Court	914 Huttenberg Court		921 Huttenberg Court	FH ID: 436	FH ID: 714	FH ID: 731	FH ID: 748
				Field Sample ID:	220110-D1-AT10	220109-D1-CT05	220109-D1-CT07	220110-D1-GT07	20220112-D1-YT05	220114-D1-YT02	20220112-D1-YT02	20220112-D1-YT03
				Sample Date:	2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-12	2022-01-14	2022-01-12	2022-01-12
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	0.324	0.330	0.362	0.129	
	Barium	2000	MCL	1.90	1.80	1.90	1.90	10.7	1.70	2.00	15.6	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.20	2.20	2.10	2.30	0.602	1.30	1.52	0.470	
	Copper	1300	MCL	110	91.0	76.0	95.0	0.992	4.30	3.59	0.375	
	Lead	15	MCL	0.450	0.460	0.510	ND	0.236	0.450	0.640	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	--	ND	0.0176	
	Selenium	50	MCL	ND	ND	ND	ND	0.899	1.50	1.94	0.376	
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Not Assigned (ppb)	Pentachlorophenol	1	MCL	--	--	--	--	--	ND	--	--	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	0.0306
	2-Ethylhexyl adipate	--	--	--	--	--	--	ND	--	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	0.0443
	Alachlor	--	--	--	--	--	--	ND	ND	ND	ND	ND
	Atrazine	--	--	--	--	--	--	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.440	1.90	0.610	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	--	--	--	--	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-HUTT0905		D1-HUTT0914		D1-HUTT0921	D1-HYD2237	D1-HYD714	D1-HYD731	D1-HYD748
		Location Type:		Residence		Residence		Residence	Hydrant	Hydrant	Hydrant	Hydrant
		Address:		905 Huttenberg Court		914 Huttenberg Court		921 Huttenberg Court	FH ID: 436	FH ID: 714	FH ID: 731	FH ID: 748
		Field Sample ID:		220110-D1-AT10		220109-D1-CT05	220109-D1-CT07	220110-D1-GT07	20220112-D1-YT05	220114-D1-YT02	20220112-D1-YT02	20220112-D1-YT03
		Sample Date:		2022-01-10		2022-01-09	2022-01-09	2022-01-10	2022-01-12	2022-01-14	2022-01-12	2022-01-12
		Sample Type:		N (Normal)		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Synthetic Organic Compounds (ppb)	Diocetyl adipate	--	--	--	--	--	--	--	--	ND	--	--
	Endrin	--	--	--	--	--	--	--	ND	ND	ND	ND
	gamma-BHC (Lindane)	--	--	--	--	--	--	--	ND	ND	ND	ND
	Heptachlor	--	--	--	--	--	--	--	ND	ND	ND	ND
	Heptachlor epoxide	--	--	--	--	--	--	--	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	--	--	--	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	0.0633
	PCB, Total	--	--	--	--	--	--	--	ND	--	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	--	--	--	--	--	ND	ND	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	--	--	--	--	--	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	--	--	--	ND	--	ND	ND
	Simazine	--	--	--	--	--	--	--	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-HUTT0905	D1-HUTT0914		D1-HUTT0921	D1-HYD2237	D1-HYD714	D1-HYD731	D1-HYD748
		Location Type:		Residence	Residence		Residence	Hydrant	Hydrant	Hydrant	Hydrant
		Address:		905 Huttenberg Court	914 Huttenberg Court		921 Huttenberg Court	FH ID: 436	FH ID: 714	FH ID: 731	FH ID: 748
		Field Sample ID:		220110-D1-AT10	220109-D1-CT05	220109-D1-CT07	220110-D1-GT07	20220112-D1-YT05	220114-D1-YT02	20220112-D1-YT02	20220112-D1-YT03
		Sample Date:		2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-12	2022-01-14	2022-01-12	2022-01-12
		Sample Type:		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	1,2-Dichloroethene (Total)	70	MCL	ND	0.0700	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	0.0700	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-HYD771	D1-KAUF1507	D1-LARS1904	D1-LEAL3332	D1-LEAL3333	D1-LEAL3335	D1-MACK3311	
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:		FH ID: 771	1507 Kaufman Court	1904 Larson Court	3332 Leal Place	3333 Leal Place	3335 Leal Place	3311 Mack Place	
		Field Sample ID:		20220112-D1-YT04	220109-D1-GT03	220109-D1-DT01	220110-D1-FT10	220110-D1-FT07	220110-D1-ET05	220109-D1-AT05	220109-D1-AT06
		Sample Date:		2022-01-12	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.394	ND	ND	ND	ND	0.620	ND	ND
	Barium	2000	MCL	3.81	1.80	1.80	2.00	1.90	1.90	1.90	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.53	2.10	2.20	2.00	2.10	2.40	1.90	2.10
	Copper	1300	MCL	2.66	97.0	17.0	38.0	18.0	34.0	16.0	13.0
	Lead	15	MCL	0.254	ND	ND	0.190	ND	ND	0.820	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	2.10	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	ND	--	--	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	ND	--	--	--	--	--	--	--
	Atrazine	--	--	ND	--	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	0.930	0.730	ND	ND	ND	0.920	1.10
	Chlordane	--	--	ND	--	--	--	--	--	--	--
	Endrin	--	--	ND	--	--	--	--	--	--	--

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-HYD771	D1-KAUF1507	D1-LARS1904	D1-LEAL3332	D1-LEAL3333	D1-LEAL3335	D1-MACK3311	
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:		FH ID: 771	1507 Kaufman Court	1904 Larson Court	3332 Leal Place	3333 Leal Place	3335 Leal Place	3311 Mack Place	
		Field Sample ID:		20220112-D1-YT04	220109-D1-GT03	220109-D1-DT01	220110-D1-FT10	220110-D1-FT07	220110-D1-ET05	220109-D1-AT05	220109-D1-AT06
		Sample Date:		2022-01-12	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	ND	--	--	--	--	--	--	--
	Heptachlor	--	--	ND	--	--	--	--	--	--	--
	Heptachlor epoxide	--	--	ND	--	--	--	--	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	ND	--	--	--	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	PCB, Total	--	--	ND	--	--	--	--	--	--	--
	PCB-1016 (Aroclor 1016)	--	--	ND	--	--	--	--	--	--	--
	PCB-1221 (Aroclor 1221)	--	--	ND	--	--	--	--	--	--	--
	PCB-1232 (Aroclor 1232)	--	--	ND	--	--	--	--	--	--	--
	PCB-1242 (Aroclor 1242)	--	--	ND	--	--	--	--	--	--	--
	PCB-1248 (Aroclor 1248)	--	--	ND	--	--	--	--	--	--	--
	PCB-1254 (Aroclor 1254)	--	--	ND	--	--	--	--	--	--	--
	PCB-1260 (Aroclor 1260)	--	--	ND	--	--	--	--	--	--	--
	Pentachlorophenol	1	MCL	ND	--	--	--	--	--	--	--
	Simazine	--	--	ND	--	--	--	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-HYD771	D1-KAUF1507	D1-LARS1904	D1-LEAL3332	D1-LEAL3333	D1-LEAL3335	D1-MACK3311	
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:		FH ID: 771	1507 Kaufman Court	1904 Larson Court	3332 Leal Place	3333 Leal Place	3335 Leal Place	3311 Mack Place	
		Field Sample ID:		20220112-D1-YT04	220109-D1-GT03	220109-D1-DT01	220110-D1-FT10	220110-D1-FT07	220110-D1-ET05	220109-D1-AT05	220109-D1-AT06
		Sample Date:		2022-01-12	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-MCMU1300	D1-MCMU1303	D1-MCMU1312	D1-MCMU1318		D1-MEAD1204		
		Location Type:		Residence	Residence	Residence	Residence		Residence		
		Address:		1300 McMurtry Court	1303 McMurtry Court	1312 McMurtry Court	1318 McMurtry Court		1204 Mead Place		
		Field Sample ID:		220110-D1-AT01	220109-D1-AT01	220109-D1-ET09	220110-D1-AT04	220110-D1-AT06	220109-D1-DT11	220129D1GT02	220130D1FT04
		Sample Date:		2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-09	2022-01-29	2022-01-30
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	1550
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	0.510	ND	ND	ND
	Barium	2000	MCL	2.30	1.90	1.90	1.80	1.90	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.20	2.20	2.00	2.10	2.10	2.10	1.30	1.50
	Copper	1300	MCL	72.0	45.0	39.0	100	71.0	38.0	27.5	20.2
	Lead	15	MCL	ND	ND	ND	ND	ND	0.140	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	1.10
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.680	0.530	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	--	--
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-MCMU1300	D1-MCMU1303	D1-MCMU1312	D1-MCMU1318		D1-MEAD1204		
		Location Type:		Residence	Residence	Residence	Residence		Residence		
		Address:		1300 McMurtry Court	1303 McMurtry Court	1312 McMurtry Court	1318 McMurtry Court		1204 Mead Place		
		Field Sample ID:		220110-D1-AT01	220109-D1-AT01	220109-D1-ET09	220110-D1-AT04	220110-D1-AT06	220109-D1-DT11	220129D1GT02	220130D1FT04
		Sample Date:		2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-09	2022-01-29	2022-01-30
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D1-MEAD1206								D1-POWE3336
				Location Type:	Residence								Residence
				Address:	1206 Mead Place								3336 Powell Loop Apt C
				Field Sample ID:	220109-D1-CT01	220129D1HT02	220130D1HT02	D1-TW-0000895-22045-N-R1	D1-TW-0000895-22045-N-R2	D1-TW-0000895-22045-N-R3	D1-TW-0000895-22045-N-R4		220110-D1-DT01
				Sample Date:	2022-01-09	2022-01-29	2022-01-30	2022-02-14	2022-02-14	2022-02-15	2022-02-15		2022-01-10
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	14500 §	ND	640	560	240			ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	82.2	ND	ND			ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND			ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND			ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	82.2	ND	ND			ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	--	--	--			ND
	Arsenic	10	MCL	ND	ND	ND	--	--	--	--			ND
	Barium	2000	MCL	2.00	1.90	1.90	--	--	--	--			1.80
	Beryllium	4	MCL	ND	ND	ND	--	--	--	--			ND
	Cadmium	5	MCL	ND	ND	ND	--	--	--	--			ND
	Chromium	100	MCL	2.00	1.30	1.80	--	--	--	--			2.00
	Copper	1300	MCL	230	107	78.0	--	--	--	--			19.0
	Lead	15	MCL	0.130	0.140	0.190	--	--	--	--			0.160
	Mercury	2	MCL	ND	ND	0.0620	--	--	--	--			ND
	Selenium	50	MCL	ND	ND	ND	--	--	--	--			ND
	Thallium	2	MCL	ND	ND	ND	--	--	--	--			ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--			ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--			ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	--	--	--			ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.820	ND	ND	--	--	--	--			ND
	Hexachlorobenzene	--	--	ND	--	--	--	--	--	--			ND
	Hexachlorocyclopentadiene	--	--	ND	--	--	--	--	--	--			ND
	Naphthalene	17	EAL	ND	ND	ND	--	--	--	--			ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	--	--	--			ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D1-MEAD1206								D1-POWE3336
				Location Type:	Residence								Residence
				Address:	1206 Mead Place								3336 Powell Loop Apt C
				Field Sample ID:	220109-D1-CT01	220129D1HT02	220130D1HT02	D1-TW-0000895-22045-N-R1	D1-TW-0000895-22045-N-R2	D1-TW-0000895-22045-N-R3	D1-TW-0000895-22045-N-R4		220110-D1-DT01
				Sample Date:	2022-01-09	2022-01-29	2022-01-30	2022-02-14	2022-02-14	2022-02-15	2022-02-15		2022-01-10
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	--	--	--	--		ND
	Benzene	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	Chlorobenzene	100	MCL	ND	ND	ND	--	--	--	--	--		ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	--	--	--	--		ND
	Ethylbenzene	700	MCL	ND	ND	ND	--	--	--	--	--		ND
	m,p-Xylene	--	--	ND	ND	ND	--	--	--	--	--		ND
	Methylene chloride	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	o-Xylene	--	--	ND	ND	ND	--	--	--	--	--		ND
	Styrene	100	MCL	ND	ND	ND	--	--	--	--	--		ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	Toluene	1000	MCL	ND	ND	ND	--	--	--	--	--		ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	--	--	--	--		ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	--	--	--	--		ND
	Vinyl chloride	2	MCL	ND	ND	ND	--	--	--	--	--		ND
	Xylenes, Total	10000	MCL	ND	ND	ND	--	--	--	--	--		ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-SING0126	D1-SMIT3341	D1-SMIT3342		D1-SMIT3344	D1-STOM3318	D1-TAUS1601	D1-TAUS1604
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	126 Singleton Court	3341 Smith Circle	3342 Smith Circle		3344 Smith Circle	3318 Stommes Place	1601 Taussig Court	1604 Taussig Court
		Field Sample ID:	220109-D1-CT11	220110-D1-DT08	220110-D1-GT03	220110-D1-GT05	220110-D1-BT04	220110-D1-BT06	220109-D1-CT03	220109-D1-ET05
		Sample Date:	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.630	0.810	ND	ND	ND
	Barium	2000	MCL	2.00	1.90	1.90	1.90	1.80	2.10	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.10	2.30	2.20	2.50	1.90	2.10	1.90
	Copper	1300	MCL	88.0	9.30	18.0	89.0	43.0	32.0	87.0
	Lead	15	MCL	ND	ND	ND	ND	0.420	ND	0.260
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	2.20
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-SING0126	D1-SMIT3341	D1-SMIT3342		D1-SMIT3344	D1-STOM3318	D1-TAUS1601	D1-TAUS1604
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	126 Singleton Court	3341 Smith Circle	3342 Smith Circle		3344 Smith Circle	3318 Stommes Place	1601 Taussig Court	1604 Taussig Court
		Field Sample ID:	220109-D1-CT11	220110-D1-DT08	220110-D1-GT03	220110-D1-GT05	220110-D1-BT04	220110-D1-BT06	220109-D1-CT03	220109-D1-ET05
		Sample Date:	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-09	2022-01-09
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-TEAG3315	D1-THAT0613		D1-VALD3306	D1-VALD3307	D1-WAGO1706		D1-WAGO1710
		Location Type:		Residence	Residence		Residence	Residence	Residence		Residence
		Address:		3315 Teague Place	613 Thatcher Court		3306 Valdez Place	3307 Valdez Place	1706 Wagoner Court		1710 Wagoner Court
		Field Sample ID:		220110-D1-FT04	220109-D1-BT06	220109-D1-BT08	220110-D1-ET01	220110-D1-BT08	220110-D1-CT04	220110-D1-CT07	220109-D1-CT09
		Sample Date:		2022-01-10	2022-01-09	2022-01-09	2022-01-10	2022-01-10	2022-01-10	2022-01-10	2022-01-09
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	2.70	2.70	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.00	2.10	2.00	2.10	2.10	2.10	2.10	1.90
	Copper	1300	MCL	35.0	25.0	25.0	18.0	16.0	65.0	65.0	81.0
	Lead	15	MCL	ND	ND	ND	ND	0.160	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	0.0620	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	0.0300	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	0.460	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D1-TEAG3315		D1-THAT0613		D1-VALD3306		D1-VALD3307		D1-WAGO1706		D1-WAGO1710	
		Location Type:		Residence		Residence		Residence		Residence		Residence		Residence	
		Address:		3315 Teague Place		613 Thatcher Court		3306 Valdez Place		3307 Valdez Place		1706 Wagoner Court		1710 Wagoner Court	
		Field Sample ID:		220110-D1-FT04		220109-D1-BT06 220109-D1-BT08		220110-D1-ET01		220110-D1-BT08		220110-D1-CT04 220110-D1-CT07		220109-D1-CT09	
		Sample Date:		2022-01-10		2022-01-09 2022-01-09		2022-01-10		2022-01-10		2022-01-10 2022-01-10		2022-01-09	
		Sample Type:		N (Normal)		N (Normal) N (Normal)		N (Normal)		N (Normal)		N (Normal) FD (Field Duplicate)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level												
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-WOUT1108	D1-WOUT1115	D1-WTEA0811	D1-WTEA0814
		Location Type:	Residence	Residence	Residence	Residence
		Address:	1108 West Outerbridge Court	1115 West Outerbridge Court	811 West Teaff Court	814 West Teaff Court
		Field Sample ID:	220110-D1-FT13	220110-D1-DT10	220110-D1-DT04	220109-D1-BT01
		Sample Date:	2022-01-10	2022-01-10	2022-01-10	2022-01-09
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	192	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	192	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND
	Arsenic	10	MCL	ND	0.910	ND
	Barium	2000	MCL	2.20	1.80	1.90
	Beryllium	4	MCL	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND
	Chromium	100	MCL	2.40	2.40	2.10
	Copper	1300	MCL	200	49.0	63.0
	Lead	15	MCL	0.240	0.160	0.200
	Mercury	2	MCL	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.550	ND	0.660
	Hexachlorobenzene	--	--	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND

Summary of Chemistry Results
Zone D1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D1-WOUT1108	D1-WOUT1115	D1-WTEA0811	D1-WTEA0814
		Location Type:	Residence	Residence	Residence	Residence
		Address:	1108 West Outerbridge Court	1115 West Outerbridge Court	811 West Teaff Court	814 West Teaff Court
		Field Sample ID:	220110-D1-FT13	220110-D1-DT10	220110-D1-DT04	220109-D1-BT01
		Sample Date:	2022-01-10	2022-01-10	2022-01-10	2022-01-09
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND