

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-10TH0206		D2-10TH0207	D2-11TH0108	D2-11TH0201	D2-11TH0205	D2-11TH0210	D2-12TH212A
		Location Type:		Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:		206 10th Street		207 10th Street	108 11th Street	201 11th Street	205 11th Street	210 11th Street	212A 12th Street
		Field Sample ID:		220115-D2-JT01	220115-D2-JT02	220114-D2-FT02	220113-D2-CT03	220115-D2-IT06	220115-D2-HT06	220115-D2-IT01	220111-D2-ET03
		Sample Date:		2022-01-15	2022-01-15	2022-01-14	2022-01-13	2022-01-15	2022-01-15	2022-01-15	2022-01-11
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1560	3420 §	1990	ND	ND	ND	1760	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.10	2.00	1.80	2.10	2.10	2.20	2.40
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.20	1.20	1.90	1.70	1.90	1.90	2.00	2.30
	Copper	1300	MCL	49.0	51.0	21.0	4.00	6.20	11.0	37.0	72.0
	Lead	15	MCL	0.490	0.270	0.350	0.160	0.170	0.170	0.540	0.200
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	0.420	ND	0.370	ND
	Thallium	2	MCL	ND	ND	ND	ND	0.0850	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	--	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	1.10	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-10TH0206		D2-10TH0207	D2-11TH0108	D2-11TH0201	D2-11TH0205	D2-11TH0210	D2-12TH212A
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	206 10th Street		207 10th Street	108 11th Street	201 11th Street	205 11th Street	210 11th Street	212A 12th Street
		Field Sample ID:	220115-D2-JT01	220115-D2-JT02	220114-D2-FT02	220113-D2-CT03	220115-D2-IT06	220115-D2-HT06	220115-D2-IT01	220111-D2-ET03
		Sample Date:	2022-01-15	2022-01-15	2022-01-14	2022-01-13	2022-01-15	2022-01-15	2022-01-15	2022-01-11
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-13TH0206		D2-13TH0210	D2-14TH0210	D2-15TH212A	D2-16TH0205	D2-17TH0211	D2-18TH0116
		Location Type:		Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:		206 13th Street		210 13th Street	210 14th Street	212A 15th Street	205 16th Street	211 17th Street	116 18th Street
		Field Sample ID:		220112-D2-ET01	220114-D2-FT01	220115-D2-IT02	220117-D2-HT04	220111-D2-BT06	220111-D2-BT10	220111-D2-FT04	220113-D2-GT05
		Sample Date:		2022-01-12	2022-01-14	2022-01-15	2022-01-17	2022-01-11	2022-01-11	2022-01-11	2022-01-13
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	329	260	1670	2540 §	ND	ND	383	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	0.600	0.700	ND	ND
	Barium	2000	MCL	1.80	2.00	2.30	2.00	2.00	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.90	1.80	1.80	2.30	1.80	1.70	2.00
	Copper	1300	MCL	12.0	17.0	15.0	11.0	19.0	15.0	7.40	65.0
	Lead	15	MCL	0.130	ND	0.280	0.180	ND	ND	0.190	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	0.360	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-13TH0206		D2-13TH0210	D2-14TH0210	D2-15TH212A	D2-16TH0205	D2-17TH0211	D2-18TH0116
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	206 13th Street		210 13th Street	210 14th Street	212A 15th Street	205 16th Street	211 17th Street	116 18th Street
				Field Sample ID:	220112-D2-ET01	220114-D2-FT01	220115-D2-IT02	220117-D2-HT04	220111-D2-BT06	220111-D2-BT10	220111-D2-FT04	220113-D2-GT05
				Sample Date:	2022-01-12	2022-01-14	2022-01-15	2022-01-17	2022-01-11	2022-01-11	2022-01-11	2022-01-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-18TH0116	D2-18TH0121	D2-18TH0129		D2-18TH0139	D2-19TH0018	D2-19TH0101	D2-19TH0109
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		116 18th Street	121 18th Street	129 18th Street		139 18th Street	18 19th Street	101 19th Street	109 19th Street
		Field Sample ID:		220113-D2-GT06	220113-D2-CT01	220112-D2-JT08	220112-D2-JT09	220117-D2-AT05	220111-D2-GT07	220113-D2-ET01	220112-D2-JT04
		Sample Date:		2022-01-13	2022-01-13	2022-01-12	2022-01-12	2022-01-17	2022-01-11	2022-01-13	2022-01-12
		Sample Type:		FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	1650	376	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.840	0.700	ND	ND	ND	0.600
	Barium	2000	MCL	1.90	1.70	1.80	1.90	1.80	2.00	1.80	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.80	1.80	1.80	1.80	1.70	1.70	1.80
	Copper	1300	MCL	62.0	96.0	50.0	50.0	85.0	22.0	71.0	68.0
	Lead	15	MCL	ND	0.110	ND	ND	0.160	ND	0.290	0.160
	Mercury	2	MCL	ND	ND	ND	ND	0.0850	ND	0.0930	ND
	Selenium	50	MCL	ND	ND	0.350	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-18TH0116	D2-18TH0121	D2-18TH0129		D2-18TH0139	D2-19TH0018	D2-19TH0101	D2-19TH0109
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		116 18th Street	121 18th Street	129 18th Street		139 18th Street	18 19th Street	101 19th Street	109 19th Street
		Field Sample ID:		220113-D2-GT06	220113-D2-CT01	220112-D2-JT08	220112-D2-JT09	220117-D2-AT05	220111-D2-GT07	220113-D2-ET01	220112-D2-JT04
		Sample Date:		2022-01-13	2022-01-13	2022-01-12	2022-01-12	2022-01-17	2022-01-11	2022-01-13	2022-01-12
		Sample Type:		FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-19TH0111		D2-19TH0140		D2-19TH0192	D2-19TH0204	D2-19TH0205	D2-19TH1803
		Location Type:		Residence		Residence		Residence	Residence	Residence	Residence
		Address:		111 19th Street		140 19th Street		192 19th Street	204 19th Street	205 19th Street	1803 19th Way
		Field Sample ID:		20220114-D2-IT05	220114-D2-IT04	220112-D2-AT04	220112-D2-AT06	220112-D2-JT01	220112-D2-IT01	220117-D2-AT06	220111-D2-JT06
		Sample Date:		2022-01-14	2022-01-14	2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-17	2022-01-11
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	332	397	ND	ND	ND	482
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	39.0	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	--	ND	39.0	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	--	ND	ND	ND	0.700	0.970	ND	ND
	Barium	2000	MCL	--	1.90	1.80	1.70	1.80	2.20	2.10	2.40
	Beryllium	4	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	--	1.10	1.70	1.60	1.80	1.80	1.80	1.70
	Copper	1300	MCL	--	95.0	16.0	16.0	20.0	74.0	39.0	31.0
	Lead	15	MCL	--	ND	ND	1.60	ND	0.250	0.230	ND
	Mercury	2	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	--	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH0111		D2-19TH0140		D2-19TH0192	D2-19TH0204	D2-19TH0205	D2-19TH1803
		Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
		Address:	111 19th Street		140 19th Street		192 19th Street	204 19th Street	205 19th Street	1803 19th Way
		Field Sample ID:	20220114-D2-IT05	220114-D2-IT04	220112-D2-AT04	220112-D2-AT06	220112-D2-JT01	220112-D2-IT01	220117-D2-AT06	220111-D2-JT06
		Sample Date:	2022-01-14	2022-01-14	2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-17	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	--	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	--	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	--	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	--	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	--	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	--	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: Location Type: Address: Field Sample ID: Sample Date: Sample Type:		D2-19TH1809 Residence 1809 19th Way 220111-D2-JT01 2022-01-11 N (Normal)	D2-1ST0122 Residence 122 1st Street 22020114-D2-JT01 2022-01-14 N (Normal)		D2-1ST0202 Residence 202 1st Street 220117-D2-LT03 2022-01-17 N (Normal)		D2-20TH0117 Residence 117 20th Street 220113-D2-ET05 2022-01-13 N (Normal)		D2-20TH0124 Residence 124 20th Street 220112-D2-FT11 2022-01-12 N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	264	ND	--	1820	2720 §	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	--	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	--	ND	0.313	0.242	ND	ND	ND
	Barium	2000	MCL	1.80	--	1.90	1.99	1.97	1.90	1.80	1.90
	Beryllium	4	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	--	1.60	1.43	1.36	1.90	1.70	1.70
	Copper	1300	MCL	64.0	--	99.0	32.9	19.0	100	94.0	54.0
	Lead	15	MCL	0.110	--	0.510	ND	ND	0.150	ND	ND
	Mercury	2	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.70	--	ND	1.38	1.14	ND	ND	ND
	Thallium	2	MCL	ND	--	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	--	--	--	ND	ND	--	--	--
	2-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	--	--	--	ND	ND	--	--	--
	Atrazine	--	--	--	--	--	ND	ND	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Endrin	--	--	--	--	--	ND	ND	--	--	--
	gamma-BHC (Lindane)	--	--	--	--	--	ND	ND	--	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-19TH1809		D2-1ST0122		D2-1ST0202		D2-20TH0117		D2-20TH0124	
		Location Type:		Residence		Residence		Residence		Residence		Residence	
		Address:		1809 19th Way		122 1st Street		202 1st Street		117 20th Street		124 20th Street	
		Field Sample ID:		220111-D2-JT01		22020114-D2-JT01 220114-D2-JT01		220117-D2-LT03 220117-D2-LT04		220113-D2-ET05 220113-D2-ET08		220112-D2-FT11	
		Sample Date:		2022-01-11		2022-01-14 2022-01-14		2022-01-17 2022-01-17		2022-01-13 2022-01-13		2022-01-12	
		Sample Type:		N (Normal)		N (Normal) N (Normal)		N (Normal) FD (Field Duplicate)		N (Normal) FD (Field Duplicate)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Synthetic Organic Compounds (ppb)	Heptachlor	--	--	--	--	--	--	ND	ND	--	--	--	--
	Heptachlor epoxide	--	--	--	--	--	--	ND	ND	--	--	--	--
	Hexachlorobenzene	--	--	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	--	--	ND	ND	--	--	--	--
	Naphthalene	17	EAL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	--	--	ND	ND	--	--	--	--
	Simazine	--	--	--	--	--	--	ND	ND	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	--	ND	--	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	--	ND	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH1809	D2-1ST0122		D2-1ST0202		D2-20TH0117		D2-20TH0124	
		Location Type:	Residence	Residence		Residence		Residence		Residence	
		Address:	1809 19th Way	122 1st Street		202 1st Street		117 20th Street		124 20th Street	
		Field Sample ID:	220111-D2-JT01	20220114-D2-JT01	220114-D2-JT01	220117-D2-LT03	220117-D2-LT04	220113-D2-ET05	220113-D2-ET08	220112-D2-FT11	
		Sample Date:	2022-01-11	2022-01-14	2022-01-14	2022-01-17	2022-01-17	2022-01-13	2022-01-13	2022-01-12	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	Styrene	100	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	--	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	--	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-20TH0145	D2-20TH0155	D2-21ST0101	D2-21ST0123	D2-21ST0132	D2-2ND0112	D2-2ND0208	D2-3RD0111
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	145 20th Street	155 20th Street	101 21st Street	123 21st Street	132 21st Street	112 2nd Street	208 2nd Street	111 3rd Street
				Field Sample ID:	220112-D2-AT08	220112-D2-FT05	220111-D2-GT03	220117-D2-IT03	220111-D2-AT14	220115-D2-BT06	220116-D2-AT08	220113-D2-FT05
				Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-17	2022-01-11	2022-01-15	2022-01-16	2022-01-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	335	ND	447	ND	ND	1650	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	--	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	35.0	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	35.0	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	0.900	ND	ND	1.00	ND	ND	ND	
	Barium	2000	MCL	1.80	1.90	1.90	1.80	2.00	2.00	1.80	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	0.0540	ND	ND	
	Chromium	100	MCL	1.60	1.90	1.70	1.10	1.80	1.80	1.10	1.80	
	Copper	1300	MCL	50.0	76.0	110	67.0	88.0	72.0	8.40	320	
	Lead	15	MCL	ND	ND	0.630	ND	0.150	0.150	0.230	0.470	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	0.340	ND	ND	ND	ND	
	Thallium	2	MCL	ND	ND	ND	0.0720	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-20TH0145	D2-20TH0155	D2-21ST0101	D2-21ST0123	D2-21ST0132	D2-2ND0112	D2-2ND0208	D2-3RD0111
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	145 20th Street	155 20th Street	101 21st Street	123 21st Street	132 21st Street	112 2nd Street	208 2nd Street	111 3rd Street
				Field Sample ID:	220112-D2-AT08	220112-D2-FT05	220111-D2-GT03	220117-D2-IT03	220111-D2-AT14	220115-D2-BT06	220116-D2-AT08	220113-D2-FT05
				Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-17	2022-01-11	2022-01-15	2022-01-16	2022-01-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-3RD0111	D2-3RD0212	D2-4TH0118		D2-4TH0127		D2-5TH0101	D2-5TH0113
		Location Type:		Residence	Residence	Residence		Residence		Residence	Residence
		Address:		111 3rd Street	212 3rd Street	118 4th Street		127 4th Street		101 5th Street	113 5th Street
		Field Sample ID:		220115-D2-ET01	220115-D2-IT03	20220114-D2-JT05	220114-D2-JT05	220113-D2-FT04	220115-D2-ET02	220116-D2-FT03	20220114-D2-IT03
		Sample Date:		2022-01-15	2022-01-15	2022-01-14	2022-01-14	2022-01-13	2022-01-15	2022-01-16	2022-01-14
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1590	ND	2810 §	--	ND	ND	2120 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	ND	ND	ND	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	ND	ND	ND	ND	--
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	--	ND	ND	ND	ND	--
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	--	ND	ND	ND	ND	--
Metals (ppb)	Antimony	6	MCL	ND	ND	--	ND	ND	ND	ND	--
	Arsenic	10	MCL	ND	ND	--	ND	ND	ND	ND	--
	Barium	2000	MCL	2.00	2.30	--	1.90	2.00	1.90	1.90	--
	Beryllium	4	MCL	ND	ND	--	ND	ND	ND	ND	--
	Cadmium	5	MCL	ND	ND	--	ND	ND	ND	ND	--
	Chromium	100	MCL	1.90	1.90	--	1.90	1.80	1.80	1.20	--
	Copper	1300	MCL	360	17.0	--	44.0	190	220	190	--
	Lead	15	MCL	1.20	0.320	--	0.220	0.850	0.700	0.410	--
	Mercury	2	MCL	ND	ND	--	ND	ND	ND	ND	--
	Selenium	50	MCL	ND	0.320	--	ND	ND	ND	ND	--
	Thallium	2	MCL	ND	0.0780	--	ND	ND	ND	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	--	ND	ND	ND	ND	--
	2-Methylnaphthalene	10	EAL	ND	ND	--	ND	ND	ND	ND	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	--	ND	ND	ND	ND	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	--	ND	ND	ND	ND	--
	Hexachlorobenzene	--	--	ND	ND	--	ND	ND	ND	ND	--
	Hexachlorocyclopentadiene	--	--	ND	ND	--	ND	ND	ND	ND	--
	Naphthalene	17	EAL	ND	ND	--	ND	ND	ND	ND	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	--	ND	ND	ND	ND	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	--	ND	ND	ND	ND	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-3RD0111	D2-3RD0212	D2-4TH0118		D2-4TH0127		D2-5TH0101	D2-5TH0113
		Location Type:	Residence	Residence	Residence		Residence		Residence	Residence
		Address:	111 3rd Street	212 3rd Street	118 4th Street		127 4th Street		101 5th Street	113 5th Street
		Field Sample ID:	220115-D2-ET01	220115-D2-IT03	20220114-D2-JT05	220114-D2-JT05	220113-D2-FT04	220115-D2-ET02	220116-D2-FT03	20220114-D2-IT03
		Sample Date:	2022-01-15	2022-01-15	2022-01-14	2022-01-14	2022-01-13	2022-01-15	2022-01-16	2022-01-14
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	--	ND	ND	ND	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	--	ND	ND	ND	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	--	ND	ND	ND	--
	1,2-Dichloroethane	5	MCL	ND	ND	--	ND	ND	ND	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	--	ND	ND	ND	--
	1,2-Dichloropropane	5	MCL	ND	ND	--	ND	ND	ND	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	--	ND	ND	ND	--
	Benzene	5	MCL	ND	ND	--	ND	ND	ND	--
	Carbon Tetrachloride	5	MCL	ND	ND	--	ND	ND	ND	--
	Chlorobenzene	100	MCL	ND	ND	--	ND	ND	ND	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	--	ND	ND	ND	--
	Ethylbenzene	700	MCL	ND	ND	--	ND	ND	ND	--
	m,p-Xylene	--	--	ND	ND	--	ND	ND	ND	--
	Methylene chloride	5	MCL	ND	ND	--	ND	ND	ND	--
	o-Xylene	--	--	ND	ND	--	ND	ND	ND	--
	Styrene	100	MCL	ND	ND	--	ND	ND	ND	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	--	ND	ND	ND	--
	Toluene	1000	MCL	ND	ND	--	ND	ND	ND	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	--	ND	ND	ND	--
	Trichloroethene (TCE)	5	MCL	ND	ND	--	ND	ND	ND	--
	Vinyl chloride	2	MCL	ND	ND	--	ND	ND	ND	--
	Xylenes, Total	10000	MCL	ND	ND	--	ND	ND	ND	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-5TH0113	D2-5TH0123	D2-5TH0206	D2-6TH0201	D2-6TH0203	D2-6TH0301	D2-7TH0203	D2-AIMO0138
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		113 5th Street	123 5th Street	206 5th Street	201 6th Street	203 6th Street	301 6th Street	203 7th Street	138 Aimokulani Alley
		Field Sample ID:		220114-D2-IT03	220115-D2-HT01	220117-D2-LT01	220116-D2-AT03	220116-D2-AT04	220116-D2-AT09	220112-D2-GT04	220111-D2-AT08
		Sample Date:		2022-01-14	2022-01-15	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-12	2022-01-11
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	ND	2410 §	ND	1740	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	0.750	0.243	ND	ND	ND	1.50	1.30
	Barium	2000	MCL	1.90	2.00	1.88	2.00	2.00	1.80	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.00	1.00	1.42	1.80	1.90	1.50	2.10	2.00
	Copper	1300	MCL	68.0	52.0	4.34	33.0	16.0	4.60	32.0	12.0
	Lead	15	MCL	0.210	0.490	0.0829	0.250	0.130	ND	0.400	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.720	1.14	ND	0.300	0.340	0.490	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	--	--	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	--	--	ND	--	--	--	--	--
	Atrazine	--	--	--	--	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Endrin	--	--	--	--	ND	--	--	--	--	--
	gamma-BHC (Lindane)	--	--	--	--	ND	--	--	--	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-5TH0113	D2-5TH0123	D2-5TH0206	D2-6TH0201	D2-6TH0203	D2-6TH0301	D2-7TH0203	D2-AIMO0138
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	113 5th Street	123 5th Street	206 5th Street	201 6th Street	203 6th Street	301 6th Street	203 7th Street	138 Aimokulani Alley
		Field Sample ID:	220114-D2-IT03	220115-D2-HT01	220117-D2-LT01	220116-D2-AT03	220116-D2-AT04	220116-D2-AT09	220112-D2-GT04	220111-D2-AT08
		Sample Date:	2022-01-14	2022-01-15	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-12	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Heptachlor	--	--	--	--	ND	--	--	--	--
	Heptachlor epoxide	--	--	--	--	ND	--	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	ND	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	ND	--	--	--	--
	Simazine	--	--	--	--	ND	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	0.663	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-5TH0113	D2-5TH0123	D2-5TH0206	D2-6TH0201	D2-6TH0203	D2-6TH0301	D2-7TH0203	D2-AIMO0138
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	113 5th Street	123 5th Street	206 5th Street	201 6th Street	203 6th Street	301 6th Street	203 7th Street	138 Aimokulani Alley
		Field Sample ID:	220114-D2-IT03	220115-D2-HT01	220117-D2-LT01	220116-D2-AT03	220116-D2-AT04	220116-D2-AT09	220112-D2-GT04	220111-D2-AT08
		Sample Date:	2022-01-14	2022-01-15	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-12	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	--	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-AIMO0138		D2-APOL0124	D2-APOL0352	D2-APOL0358	D2-APOL0641	D2-BEAR0101	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	138 Aimokulani Alley		124 Apollo Avenue	352 Apollo Avenue	358 Apollo Avenue	641 Apollo Avenue	101 Beard Avenue	
				Field Sample ID:	220111-D2-AT10	220111-D2-AT12	220111-D2-AT04	220111-D2-IT03	220113-D2-ET09	220113-D2-GT01	220115-D2-BT01	220115-D2-BT02
				Sample Date:	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-13	2022-01-13	2022-01-15	2022-01-15
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	375	ND	ND	1800	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	191	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	191	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	0.950	0.740	0.660	ND	ND	0.630	ND	ND	
	Barium	2000	MCL	2.10	2.00	2.00	1.90	2.00	2.00	2.00	2.00	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	2.00	1.90	2.50	1.60	1.80	1.80	1.80	1.80	1.10
	Copper	1300	MCL	10.0	11.0	8.40	7.80	14.0	13.0	16.0	17.0	
	Lead	15	MCL	0.130	0.160	ND	0.100	0.270	0.300	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-AIMO0138		D2-APOL0124	D2-APOL0352	D2-APOL0358	D2-APOL0641	D2-BEAR0101	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
		Address:	138 Aimokulani Alley		124 Apollo Avenue	352 Apollo Avenue	358 Apollo Avenue	641 Apollo Avenue	101 Beard Avenue	
		Field Sample ID:	220111-D2-AT10	220111-D2-AT12	220111-D2-AT04	220111-D2-IT03	220113-D2-ET09	220113-D2-GT01	220115-D2-BT01	220115-D2-BT02
		Sample Date:	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-13	2022-01-13	2022-01-15	2022-01-15
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-BEAR0211	D2-BEAR0702		D2-BEAR503A		D2-BLDG0017		D2-BLDG1102H
		Location Type:		Residence	Residence		Residence		Non-Residence		Non-Residence
		Address:		211 Beard Avenue	702 Beard Avenue		503A Beard Avenue		Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd		Building 1102H,HEADQUARTERS MAJOR COMMAND, 25E St
		Field Sample ID:		220115-D2-IT05	220117-D2-AT04	220118-D2-MT09	20220114-D2-FT03	220114-D2-FT03	220116-D2-KT05	220118-D2-MT07	220117-D2-JT05
		Sample Date:		2022-01-15	2022-01-17	2022-01-18	2022-01-14	2022-01-14	2022-01-16	2022-01-18	2022-01-17
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1630	ND	3160 §	--	ND	ND	1750
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	--	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Barium	2000	MCL	2.00	1.90	1.90	--	1.90	2.20	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.80	1.80	--	1.90	1.10	1.70	1.80
	Copper	1300	MCL	12.0	31.0	29.0	--	18.0	79.0	110	97.0
	Lead	15	MCL	ND	0.210	0.250	--	0.330	0.130	ND	0.200
	Mercury	2	MCL	ND	0.0690	ND	--	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	0.100	--	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	--	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BEAR0702		D2-BEAR503A		D2-BLDG0017		D2-BLDG1102H
				Location Type:	Residence		Residence		Non-Residence		Non-Residence
				Address:	211 Beard Avenue		702 Beard Avenue		503A Beard Avenue		Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd
				Field Sample ID:	220115-D2-IT05	220117-D2-AT04	220118-D2-MT09	20220114-D2-FT03	220114-D2-FT03	220116-D2-KT05	220118-D2-MT07
				Sample Date:	2022-01-15	2022-01-17	2022-01-18	2022-01-14	2022-01-14	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
											Building 1102H,HEADQUARTERS MAJOR COMMAND, 25E St
											220117-D2-JT05
											2022-01-17
											N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	--	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	--	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	--	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	--	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	--	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:																				
ND = Not Detected																				
ISP = Incident Specific Parameter																				
EAL = DOH Environmental Action Level																				
EPA MCL = EPA Maximum Contaminant Level																				
All Results shown in Parts per Billion (ppb)																				
§ - Exceeds Screening Level																				
-- = No Information Available																				
N (Normal) = Full compliance sample																				
FD (Field Duplicate) = Extra sample taken for quality control																				
N (Grab, Resample) = Additional follow-up sample																				
				Location ID:	D2-BEAR0211		D2-BEAR0702			D2-BEAR503A			D2-BLDG0017			D2-BLDG1102H				
				Location Type:	Residence		Residence			Residence			Non-Residence			Non-Residence				
				Address:	211 Beard Avenue		702 Beard Avenue			503A Beard Avenue			Building 17,MOBDIVSALVU ONE OPS/HDQTRS, 1092 Fort Kam Rd			Building 1102H,HEADQUARTERS MAJOR COMMAND, 25E St				
				Field Sample ID:	220115-D2-IT05		220117-D2-AT04		220118-D2-MT09		20220114-D2-FT03		220114-D2-FT03		220116-D2-KT05		220118-D2-MT07		220117-D2-JT05	
				Sample Date:	2022-01-15		2022-01-17		2022-01-18		2022-01-14		2022-01-14		2022-01-16		2022-01-18		2022-01-17	
				Sample Type:	N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)	
		DOH Project Screening Level	Basis of Project Screening Level																	
Method Group	Analyte																			
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BLDG1120H	D2-BLDG1166H	D2-BLDG1200H	D2-BLDG1204H	D2-BLDG1222H	D2-BLDG1235H	D2-BLDG2030H	D2-BLDG2050H
				Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address:	Building 1120H,HICKAM MEMORIAL FITNESS CENTER, 1120 Vickers Ave	Building 1166H,NGIS - NAVY TDY	Building 1200H,BASE ENGINEER ADMINISTRATION, 75 H Street	Building 1204H,BASE ENGINEER ADMINISTRATION	Building 1222H,624 CE REGIONAL SPT GRP, 1230 Vickers Ave	Building 1235H,EXHANGE SALES STORE (BXTRA), 20 Hickam Ct	Building 2030H,ENGINE MAINT SHOP, HGR 15&17C, 300 Hangar Ave	Building 2050H,BASE OPERATIONS, 800 Hangar Ave
				Field Sample ID:	220116-D2-HT03	220116-D2-JT02	220116-D2-JT01	220116-D2-JT03	220116-D2-JT04	220117-D2-JT01	220116-D2-KT01	220116-D2-KT02
				Sample Date:	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-17	2022-01-16	2022-01-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP		ND	2250 §	ND	ND	2360 §	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP		ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL		2.00	2.10	2.70	2.40	2.00	1.90	2.50	2.20
	Beryllium	4	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL		1.80	1.80	2.40	1.70	1.90	1.70	1.50	1.20
	Copper	1300	MCL		45.0	25.0	19.0	50.0	170	94.0	76.0	2.40
	Lead	15	MCL		0.170	0.150	0.320	0.610	ND	0.100	0.500	0.160
	Mercury	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL		ND	ND	ND	1.20	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL		ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL		ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG1120H	D2-BLDG1166H	D2-BLDG1200H	D2-BLDG1204H	D2-BLDG1222H	D2-BLDG1235H	D2-BLDG2030H	D2-BLDG2050H
				Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address:	Building 1120H,HICKAM MEMORIAL FITNESS CENTER, 1120 Vickers Ave	Building 1166H,NGIS - NAVY TDY	Building 1200H,BASE ENGINEER ADMINISTRATION, 75 H Street	Building 1204H,BASE ENGINEER ADMINISTRATION	Building 1222H,624 CE REGIONAL SPT GRP, 1230 Vickers Ave	Building 1235H,EXHANGE SALES STORE (BXTRA), 20 Hickam Ct	Building 2030H,ENGINE MAINT SHOP, HGR 15&17C, 300 Hangar Ave	Building 2050H,BASE OPERATIONS, 800 Hangar Ave
				Field Sample ID:	220116-D2-HT03	220116-D2-JT02	220116-D2-JT01	220116-D2-JT03	220116-D2-JT04	220117-D2-JT01	220116-D2-KT01	220116-D2-KT02
				Sample Date:	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-17	2022-01-16	2022-01-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-BLDG1120H	D2-BLDG1166H	D2-BLDG1200H	D2-BLDG1204H	D2-BLDG1222H	D2-BLDG1235H	D2-BLDG2030H	D2-BLDG2050H
		Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
		Address:	Building 1120H,HICKAM MEMORIAL FITNESS CENTER, 1120 Vickers Ave	Building 1166H,NGIS - NAVY TDY	Building 1200H,BASE ENGINEER ADMINISTRATION, 75 H Street	Building 1204H,BASE ENGINEER ADMINISTRATION	Building 1222H,624 CE REGIONAL SPT GRP, 1230 Vickers Ave	Building 1235H,EXHANGE SALES STORE (BXTRA), 20 Hickam Ct	Building 2030H,ENGINE MAINT SHOP, HGR 15&17C, 300 Hangar Ave	Building 2050H,BASE OPERATIONS, 800 Hangar Ave
		Field Sample ID:	220116-D2-HT03	220116-D2-JT02	220116-D2-JT01	220116-D2-JT03	220116-D2-JT04	220117-D2-JT01	220116-D2-KT01	220116-D2-KT02
		Sample Date:	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-17	2022-01-16	2022-01-16
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte									
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG2065H					D2-BLDG2073H	D2-BLDG2093H	D2-BLDG425H
				Location Type:	Non-Residence					Non-Residence	Non-Residence	Non-Residence
				Address:	Building 2065H,SKATEBOARD PARK (INDOOR)					Building 2073H,EXCHANGE SERVICE OUTLET, 2073 Hangar Ave	Building 2093H,STORE, COMMISSARY, 20 Hickam Ct	Building 425H,SWIMMERS BATH HOUSE
				Field Sample ID:	220116-D2-HT06	220116-D2-HT07	220117-D2-JT04	220118-D2-IT06	220118-D2-IT07	220117-D2-JT06	220117-D2-JT02	220116-D2-HT04
				Sample Date:	2022-01-16	2022-01-16	2022-01-17	2022-01-18	2022-01-18	2022-01-17	2022-01-17	2022-01-16
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	2210 §	ND	ND	1860	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.40	2.40	2.00	2.40	2.50	1.90	2.00	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.30	1.80	1.70	1.70	1.80	1.90	1.30	
	Copper	1300	MCL	100	100	140	170	160	14.0	46.0	18.0	
	Lead	15	MCL	ND	ND	1.10	0.120	0.0970	0.140	0.140	0.480	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.320	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	--	--	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	--	--	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG2065H					D2-BLDG2073H	D2-BLDG2093H	D2-BLDG425H
				Location Type:	Non-Residence					Non-Residence	Non-Residence	Non-Residence
				Address:	Building 2065H,SKATEBOARD PARK (INDOOR)					Building 2073H,EXCHANGE SERVICE OUTLET, 2073 Hangar Ave	Building 2093H,STORE, COMMISSARY, 20 Hickam Ct	Building 425H,SWIMMERS BATH HOUSE
				Field Sample ID:	220116-D2-HT06	220116-D2-HT07	220117-D2-JT04	220118-D2-IT06	220118-D2-IT07	220117-D2-JT06	220117-D2-JT02	220116-D2-HT04
				Sample Date:	2022-01-16	2022-01-16	2022-01-17	2022-01-18	2022-01-18	2022-01-17	2022-01-17	2022-01-16
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	0.750
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-BLDG2065H					D2-BLDG2073H	D2-BLDG2093H	D2-BLDG425H
		Location Type:	Non-Residence					Non-Residence	Non-Residence	Non-Residence
		Address:	Building 2065H,SKATEBOARD PARK (INDOOR)					Building 2073H,EXCHANGE SERVICE OUTLET, 2073 Hangar Ave	Building 2093H,STORE, COMMISSARY, 20 Hickam Ct	Building 425H,SWIMMERS BATH HOUSE
		Field Sample ID:	220116-D2-HT06	220116-D2-HT07	220117-D2-JT04	220118-D2-IT06	220118-D2-IT07	220117-D2-JT06	220117-D2-JT02	220116-D2-HT04
		Sample Date:	2022-01-16	2022-01-16	2022-01-17	2022-01-18	2022-01-18	2022-01-17	2022-01-17	2022-01-16
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level								
		Basis of Project Screening Level								
Method Group	Analyte									
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-BLDG425H	D2-BLDG500H	D2-BLDG595H	D2-BLDG900H	D2-BLDG901H		D2-BLDG920H	
		Location Type:		Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence		Non-Residence	
		Address:		Building 425H,SWIMMERS BATH HOUSE	Building 500H,RELIGIOUS WORSHIP FACILITY, 925 Scott Cir	Building 595H,BASE LIBRARY, 990 Mills Blvd	Building 900H,OFFICER OPEN MESS, 10 Julian Ave	Building 901H,OFFICER OPEN MESS		Building 920H,NGIS - NAVY TDY	
		Field Sample ID:		220118-D2-MT10	220117-D2-JT03	220116-D2-HT01	220116-D2-HT02	220116-D2-HT05	220118-D2-LT01	220116-D2-KT04	220118-D2-MT06
		Sample Date:		2022-01-18	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-18
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	1650	ND	ND	2990 §	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	0.300	0.250	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.00	2.00	2.00	2.60	2.40	2.00	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.80	1.90	1.80	0.990	1.40	1.20	1.30
	Copper	1300	MCL	46.0	100	82.0	16.0	120	120	34.0	30.0
	Lead	15	MCL	0.520	1.30	0.160	0.160	0.960	0.540	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	0.320	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	0.0630	ND	ND	0.100	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	0.970	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BLDG425H	D2-BLDG500H	D2-BLDG595H	D2-BLDG900H	D2-BLDG901H		D2-BLDG920H	
				Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence		Non-Residence	
				Address:	Building 425H,SWIMMERS BATH HOUSE	Building 500H,RELIGIOUS WORSHIP FACILITY, 925 Scott Cir	Building 595H,BASE LIBRARY, 990 Mills Blvd	Building 900H,OFFICER OPEN MESS, 10 Julian Ave	Building 901H,OFFICER OPEN MESS		Building 920H,NGIS - NAVY TDY	
				Field Sample ID:	220118-D2-MT10	220117-D2-JT03	220116-D2-HT01	220116-D2-HT02	220116-D2-HT05	220118-D2-LT01	220116-D2-KT04	220118-D2-MT06
				Sample Date:	2022-01-18	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	29.4 §	186 §	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BLDG425H	D2-BLDG500H	D2-BLDG595H	D2-BLDG900H	D2-BLDG901H		D2-BLDG920H	
				Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence		Non-Residence	
				Address:	Building 425H,SWIMMERS BATH HOUSE	Building 500H,RELIGIOUS WORSHIP FACILITY, 925 Scott Cir	Building 595H,BASE LIBRARY, 990 Mills Blvd	Building 900H,OFFICER OPEN MESS, 10 Julian Ave	Building 901H,OFFICER OPEN MESS		Building 920H,NGIS - NAVY TDY	
				Field Sample ID:	220118-D2-MT10	220117-D2-JT03	220116-D2-HT01	220116-D2-HT02	220116-D2-HT05	220118-D2-LT01	220116-D2-KT04	220118-D2-MT06
				Sample Date:	2022-01-18	2022-01-17	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID: D2-BLDG926H		D2-CHAL2405B	D2-CHAL2407A	D2-CHAL2412A	D2-CHAL2415A	D2-CHAL2421A	D2-CHAL2424A
				Location Type: Non-Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address: Building 926H,NGIS - NAVY TDY		2405B Challenger Loop	2407A Challenger Loop	2412A Challenger Loop	2415A Challenger Loop	2421A Challenger Loop	2424A Challenger Loop
				Field Sample ID: 220116-D2-KT03	220118-D2-MT08	220112-D2-GT06	220113-D2-CT04	220112-D2-HT09	220112-D2-GT08	220111-D2-ET05	220111-D2-JT03
				Sample Date: 2022-01-16	2022-01-18	2022-01-12	2022-01-13	2022-01-12	2022-01-12	2022-01-11	2022-01-11
				Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	444
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.520	ND	1.10	ND	0.930	0.910	1.00	ND
	Barium	2000	MCL	2.00	2.00	2.20	1.90	1.90	2.00	2.00	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.60	1.90	1.70	1.90	2.00	1.80	1.70
	Copper	1300	MCL	100	66.0	31.0	58.0	32.0	110	52.0	58.0
	Lead	15	MCL	ND	ND	0.200	1.00	0.160	0.300	0.270	0.370
	Mercury	2	MCL	ND	ND	ND	0.0570	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	0.380	ND	ND	ND	ND	1.60
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID: D2-BLDG926H		D2-CHAL2405B	D2-CHAL2407A	D2-CHAL2412A	D2-CHAL2415A	D2-CHAL2421A	D2-CHAL2424A	
				Location Type: Non-Residence		Residence	Residence	Residence	Residence	Residence	Residence	
				Address: Building 926H,NGIS - NAVY TDY		2405B Challenger Loop	2407A Challenger Loop	2412A Challenger Loop	2415A Challenger Loop	2421A Challenger Loop	2424A Challenger Loop	
				Field Sample ID:	220116-D2-KT03	220118-D2-MT08	220112-D2-GT06	220113-D2-CT04	220112-D2-HT09	220112-D2-GT08	220111-D2-ET05	220111-D2-JT03
				Sample Date:	2022-01-16	2022-01-18	2022-01-12	2022-01-13	2022-01-12	2022-01-12	2022-01-11	2022-01-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	--	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-CHAL2430A	D2-CHAL2437A	D2-CORN1101	D2-CORN1201	D2-FOXB1203	D2-FOXB1304	D2-FOXB1405	D2-FOXB1505
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	2430A Challenger Loop	2437A Challenger Loop	1101 Cornet Avenue	1201 Cornet Avenue	1203 Fox Boulevard	1304 Fox Boulevard	1405 Fox Boulevard	1505 Fox Boulevard
				Field Sample ID:	220111-D2-HT07	220111-D2-BT14	220111-D2-ET04	220111-D2-HT03	220111-D2-FT03	220111-D2-HT05	220111-D2-FT07	220111-D2-GT01
				Sample Date:	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	431	ND	ND	412	356	452	417	352	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	1.00	0.590	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.00	1.90	1.90	1.80	2.10	1.90	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.70	1.80	1.70	1.70	1.70	1.70	1.70	1.70	1.70
	Copper	1300	MCL	83.0	39.0	12.0	55.0	48.0	23.0	16.0	20.0	
	Lead	15	MCL	0.230	ND	0.210	0.280	0.120	0.350	0.220	0.150	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.60	ND	ND	ND	ND	ND	ND	ND	1.70
	Thallium	2	MCL	ND	ND	0.0870	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-CHAL2430A	D2-CHAL2437A	D2-CORN1101	D2-CORN1201	D2-FOXB1203	D2-FOXB1304	D2-FOXB1405	D2-FOXB1505
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	2430A Challenger Loop	2437A Challenger Loop	1101 Cornet Avenue	1201 Cornet Avenue	1203 Fox Boulevard	1304 Fox Boulevard	1405 Fox Boulevard	1505 Fox Boulevard
		Field Sample ID:	220111-D2-HT07	220111-D2-BT14	220111-D2-ET04	220111-D2-HT03	220111-D2-FT03	220111-D2-HT05	220111-D2-FT07	220111-D2-GT01
		Sample Date:	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-FOXB1605		D2-FOXB1713		D2-FOXB1808		D2-FOXB1809	D2-FOXB1904	D2-FOXB1913
		Location Type:		Residence		Residence		Residence		Residence	Residence	Residence
		Address:		1605 Fox Boulevard		1713 Fox Boulevard		1808 Fox Boulevard		1809 Fox Boulevard	1904 Fox Boulevard	1913 Fox Boulevard
		Field Sample ID:		220111-D2-GT06		220116-D2-IT01	220117-D2-HT05	220117-D2-AT07	220117-D2-AT08	220112-D2-IT04	220117-D2-IT04	220112-D2-JT07
		Sample Date:		2022-01-11		2022-01-16	2022-01-17	2022-01-17	2022-01-17	2022-01-12	2022-01-17	2022-01-12
		Sample Type:		N (Normal)		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	285	3260 §	ND		ND	1750	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND		ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND		ND	ND	1.20	ND	0.980
	Barium	2000	MCL	1.90	1.80	1.90		1.80	1.90	1.80	1.80	1.90
	Beryllium	4	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.10	ND		1.80	1.70	1.80	1.40	1.90
	Copper	1300	MCL	19.0	34.0	28.0		99.0	93.0	86.0	63.0	16.0
	Lead	15	MCL	0.200	0.240	0.200		0.190	0.180	ND	0.200	0.190
	Mercury	2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Selenium	50	MCL	1.60	ND	ND		ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND		ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND		ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND		ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-FOXB1605	D2-FOXB1713		D2-FOXB1808		D2-FOXB1809	D2-FOXB1904	D2-FOXB1913
				Location Type:	Residence	Residence		Residence		Residence	Residence	Residence
				Address:	1605 Fox Boulevard	1713 Fox Boulevard		1808 Fox Boulevard		1809 Fox Boulevard	1904 Fox Boulevard	1913 Fox Boulevard
				Field Sample ID:	220111-D2-GT06	220116-D2-IT01	220117-D2-HT05	220117-D2-AT07	220117-D2-AT08	220112-D2-IT04	220117-D2-IT04	220112-D2-JT07
				Sample Date:	2022-01-11	2022-01-16	2022-01-17	2022-01-17	2022-01-17	2022-01-12	2022-01-17	2022-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-FOXB1922	D2-FOXB1930	D2-FOXB2002	D2-FOXB2003	D2-FOXB2031	D2-GEMI0312	D2-GEMI0717	D2-HOAA0902
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1922 Fox Boulevard	1930 Fox Boulevard	2002 Fox Boulevard	2003 Fox Boulevard	2031 Fox Boulevard	312 Gemini Avenue	717 Gemini Avenue	902 Hoaano Alley
				Field Sample ID:	220112-D2-GT01	220112-D2-JT05	220111-D2-GT02	220111-D2-BT12	220111-D2-BT04	220116-D2-IT04	220118-D2-MT01	220112-D2-ET04
				Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-11	2022-01-16	2022-01-18	2022-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	385	ND	ND	2580 §	ND		484
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND		ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Arsenic	10	MCL	1.20	0.940	ND	ND	0.800	ND	ND		ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	2.00		1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Chromium	100	MCL	1.90	2.00	1.70	2.30	2.40	1.30	1.70		1.70
	Copper	1300	MCL	100	48.0	22.0	110	40.0	8.10	10.0		15.0
	Lead	15	MCL	0.200	0.310	0.510	0.200	ND	ND	0.200		0.290
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	0.340	ND		ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.100		ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND		ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND		ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND		ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-FOXB1922	D2-FOXB1930	D2-FOXB2002	D2-FOXB2003	D2-FOXB2031	D2-GEMI0312	D2-GEMI0717	D2-HOAA0902
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1922 Fox Boulevard	1930 Fox Boulevard	2002 Fox Boulevard	2003 Fox Boulevard	2031 Fox Boulevard	312 Gemini Avenue	717 Gemini Avenue	902 Hoaano Alley
				Field Sample ID:	220112-D2-GT01	220112-D2-JT05	220111-D2-GT02	220111-D2-BT12	220111-D2-BT04	220116-D2-IT04	220118-D2-MT01	220112-D2-ET04
				Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-11	2022-01-16	2022-01-18	2022-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HOAA0905	D2-HONU0118	D2-HOOP0911	D2-HOOP0918	D2-HUIL0343	D2-HYD0079		
				Location Type:	Residence	Residence	Residence	Residence	Residence	Hydrant		
				Address:	905 Hoaano Alley	118 Honu Alley	911 Hoopinana Alley	918 Hoopinana Alley	343 Huilanui Alley	20220114-D2-WT03	220114-D2-WT03	D2-DL-0017714-22047-N
				Field Sample ID:	220112-D2-GT03	220111-D2-AT06	220112-D2-HT03	220117-D2-HT03	220111-D2-ET01			
				Sample Date:	2022-01-12	2022-01-11	2022-01-12	2022-01-17	2022-01-11	2022-01-14	2022-01-14	2022-02-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)			
General Chemistry (ppb)	Total Organic Carbon	2000	ISP		ND	ND	ND	ND	ND	2120 §	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	ND	ND	ND	--	120	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	ND	ND	ND	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--		ND	ND	ND	ND	ND	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP		ND	ND	ND	ND	ND	--	120	ND
Metals (ppb)	Antimony	6	MCL		0.110	ND	ND	ND	ND	--	ND	--
	Arsenic	10	MCL		0.690	ND	1.00	ND	0.500	--	0.300	--
	Barium	2000	MCL		2.10	2.00	2.00	1.90	1.90	--	1.80	--
	Beryllium	4	MCL		ND	ND	ND	ND	ND	--	ND	--
	Cadmium	5	MCL		ND	ND	ND	ND	ND	--	ND	--
	Chromium	100	MCL		1.60	2.20	2.10	1.90	2.20	--	1.20	--
	Copper	1300	MCL		12.0	19.0	22.0	12.0	4.90	--	7.90	--
	Lead	15	MCL		0.210	0.500	0.180	0.240	0.200	--	0.710	--
	Mercury	2	MCL		ND	ND	ND	0.0670	ND	--	ND	--
	Selenium	50	MCL		ND	ND	ND	ND	ND	--	1.20	--
	Thallium	2	MCL		ND	0.100	ND	ND	ND	--	ND	--
Not Assigned (ppb)	Pentachlorophenol	1	MCL		--	--	--	--	--	--	ND	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	--	ND	--
	2-Methylnaphthalene	10	EAL		ND	ND	ND	ND	ND	--	ND	--
	Alachlor	--	--		--	--	--	--	--	--	ND	--
	Atrazine	--	--		--	--	--	--	--	--	ND	--
	Benzo(a)pyrene	0.2	MCL		ND	ND	ND	ND	ND	--	ND	--
	Bis(2-ethylhexyl)phthalate	6	MCL		ND	ND	ND	ND	ND	--	ND	--
	Chlordane	--	--		--	--	--	--	--	--	ND	--
	Dioctyl adipate	--	--		--	--	--	--	--	--	ND	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HOAA0905	D2-HONU0118	D2-HOOP0911	D2-HOOP0918	D2-HUIL0343	D2-HYD0079		
		Location Type:		Residence	Residence	Residence	Residence	Residence	Hydrant		
		Address:		905 Hoaano Alley	118 Honu Alley	911 Hoopinana Alley	918 Hoopinana Alley	343 Huilanui Alley	FH:519		
		Field Sample ID:		220112-D2-GT03	220111-D2-AT06	220112-D2-HT03	220117-D2-HT03	220111-D2-ET01	20220114-D2-WT03	220114-D2-WT03	D2-DL-0017714-22047-N
		Sample Date:		2022-01-12	2022-01-11	2022-01-12	2022-01-17	2022-01-11	2022-01-14	2022-01-14	2022-02-16
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Endrin	--	--	--	--	--	--	--	--	ND	--
	gamma-BHC (Lindane)	--	--	--	--	--	--	--	--	ND	--
	Heptachlor	--	--	--	--	--	--	--	--	ND	--
	Heptachlor epoxide	--	--	--	--	--	--	--	--	ND	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	--	ND	--
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	--	ND	--
	Methoxychlor	--	--	--	--	--	--	--	--	ND	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	--	ND	--
	PCB-1016 (Aroclor 1016)	--	--	--	--	--	--	--	--	ND	--
	PCB-1221 (Aroclor 1221)	--	--	--	--	--	--	--	--	ND	--
	PCB-1232 (Aroclor 1232)	--	--	--	--	--	--	--	--	ND	--
	PCB-1242 (Aroclor 1242)	--	--	--	--	--	--	--	--	ND	--
	PCB-1248 (Aroclor 1248)	--	--	--	--	--	--	--	--	ND	--
	PCB-1254 (Aroclor 1254)	--	--	--	--	--	--	--	--	ND	--
	PCB-1260 (Aroclor 1260)	--	--	--	--	--	--	--	--	ND	--
	Simazine	--	--	--	--	--	--	--	--	ND	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	--	ND	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	--	ND	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	--	ND	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HOAA0905	D2-HONU0118	D2-HOOP0911	D2-HOOP0918	D2-HUIL0343	D2-HYD0079		
				Location Type:	Residence	Residence	Residence	Residence	Residence	Hydrant		
				Address:	905 Hoaano Alley	118 Honu Alley	911 Hoopinana Alley	918 Hoopinana Alley	343 Huilanui Alley	FH:519		
				Field Sample ID:	220112-D2-GT03	220111-D2-AT06	220112-D2-HT03	220117-D2-HT03	220111-D2-ET01	20220114-D2-WT03	220114-D2-WT03	D2-DL-0017714-22047-N
				Sample Date:	2022-01-12	2022-01-11	2022-01-12	2022-01-17	2022-01-11	2022-01-14	2022-01-14	2022-02-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	Benzene	5	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	--	ND	--	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	--	ND	--	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	--	ND	--	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	--	ND	--	
	o-Xylene	--	--	ND	ND	ND	ND	ND	--	ND	--	
	Styrene	100	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	--	ND	--	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	--	ND	--	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	--	ND	--	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID: Location Type: Address:			D2-HYD0498 Hydrant FH:509			D2-HYD219 Hydrant FH:219			D2-HYD236 Hydrant FH:236 (Possibly HYD263, HYD-2154)		D2-HYD321 Hydrant FH:321
				Field Sample ID:	20220114-D2-WT04	220114-D2-WT04	D2-DL-0017715-22047 -N	20220114-D2-VT03	220114-D2-VT03	20220114-D2-WT01	220114-D2-WT01	20220114-D2-VT01			
				Sample Date:	2022-01-14	2022-01-14	2022-02-16	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14 <td colspan="2">2022-01-14</td>	2022-01-14		
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal) <td colspan="2">N (Normal)</td>	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level												
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2100 §	--	--		2440 §	--	2000	--	ND			
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND		--	ND	--	ND	--			
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	ND		--	ND	--	ND	--			
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	260	ND		--	ND	--	ND	--			
	Petroleum Hydrocarbons, Total	211	ISP	--	260 §	ND		--	ND	--	ND	--			
Metals (ppb)	Antimony	6	MCL	--	ND	--		--	ND	--	ND	--			
	Arsenic	10	MCL	--	0.330	--		--	0.350	--	0.320	--			
	Barium	2000	MCL	--	1.70	--		--	1.80	--	1.80	--			
	Beryllium	4	MCL	--	ND	--		--	ND	--	ND	--			
	Cadmium	5	MCL	--	ND	--		--	ND	--	ND	--			
	Chromium	100	MCL	--	1.20	--		--	1.90	--	1.20	--			
	Copper	1300	MCL	--	4.20	--		--	7.10	--	3.30	--			
	Lead	15	MCL	--	0.610	--		--	6.10	--	0.550	--			
	Mercury	2	MCL	--	ND	--		--	ND	--	ND	--			
	Selenium	50	MCL	--	1.60	--		--	1.30	--	1.20	--			
Thallium	2	MCL	--	ND	--		--	ND	--	ND	--				
Not Assigned (ppb)	Pentachlorophenol	1	MCL	--	ND	--		--	ND	--	ND	--			
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	ND	--		--	ND	--	ND	--			
	2-Methylnaphthalene	10	EAL	--	ND	--		--	ND	--	ND	--			
	Alachlor	--	--	--	ND	--		--	ND	--	ND	--			
	Atrazine	--	--	--	ND	--		--	ND	--	ND	--			
	Benzo(a)pyrene	0.2	MCL	--	ND	--		--	ND	--	ND	--			
	Bis(2-ethylhexyl)phthalate	6	MCL	--	0.870	--		--	ND	--	ND	--			
	Chlordane	--	--	--	ND	--		--	ND	--	ND	--			

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-HYD0498			D2-HYD219		D2-HYD236		D2-HYD321
				Location Type:	Hydrant			Hydrant		Hydrant		Hydrant
				Address:	FH:509			FH:219		FH:236 (Possibly HYD263, HYD-2154)		FH:321
				Field Sample ID:	20220114-D2-WT04	220114-D2-WT04	D2-DL-0017715-22047-N	20220114-D2-VT03	220114-D2-VT03	20220114-D2-WT01	220114-D2-WT01	20220114-D2-VT01
				Sample Date:	2022-01-14	2022-01-14	2022-02-16	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14
Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)			
Synthetic Organic Compounds (ppb)	Diocetyl adipate	--	--	--	ND	--	--	ND	--	ND	--	
	Endrin	--	--	--	ND	--	--	ND	--	ND	--	
	gamma-BHC (Lindane)	--	--	--	ND	--	--	ND	--	ND	--	
	Heptachlor	--	--	--	ND	--	--	ND	--	ND	--	
	Heptachlor epoxide	--	--	--	ND	--	--	ND	--	ND	--	
	Hexachlorobenzene	--	--	--	ND	--	--	ND	--	ND	--	
	Hexachlorocyclopentadiene	--	--	--	ND	--	--	ND	--	ND	--	
	Methoxychlor	--	--	--	ND	--	--	ND	--	ND	--	
	Naphthalene	17	EAL	--	ND	--	--	ND	--	ND	--	
	PCB-1016 (Aroclor 1016)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1221 (Aroclor 1221)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1232 (Aroclor 1232)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1242 (Aroclor 1242)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1248 (Aroclor 1248)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1254 (Aroclor 1254)	--	--	--	ND	--	--	ND	--	ND	--	
	PCB-1260 (Aroclor 1260)	--	--	--	ND	--	--	ND	--	ND	--	
	Simazine	--	--	--	ND	--	--	ND	--	ND	--	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	--	--	ND	--	ND	--	
	1,1,2-Trichloroethane	5	MCL	--	ND	--	--	ND	--	ND	--	
	1,1-Dichloroethene	7	MCL	--	ND	--	--	ND	--	ND	--	
	1,2,4-Trichlorobenzene	70	MCL	--	ND	--	--	ND	--	ND	--	
	1,2-Dichlorobenzene	600	MCL	--	ND	--	--	ND	--	ND	--	
	1,2-Dichloroethane	5	MCL	--	ND	--	--	ND	--	ND	--	
	1,2-Dichloroethene (Total)	70	MCL	--	ND	--	--	ND	--	ND	--	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-HYD0498			D2-HYD219		D2-HYD236		D2-HYD321
				Location Type:	Hydrant			Hydrant		Hydrant		Hydrant
				Address:	FH:509			FH:219		FH:236 (Possibly HYD263, HYD-2154)		FH:321
				Field Sample ID:	20220114-D2-WT04	220114-D2-WT04	D2-DL-0017715-22047-N	20220114-D2-VT03	220114-D2-VT03	20220114-D2-WT01	220114-D2-WT01	20220114-D2-VT01
				Sample Date:	2022-01-14	2022-01-14	2022-02-16	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichloropropane	5	MCL	--	ND	--	--	ND	--	ND	--	--
	1,4-Dichlorobenzene	75	MCL	--	ND	--	--	ND	--	ND	--	--
	Benzene	5	MCL	--	ND	--	--	ND	--	ND	--	--
	Carbon Tetrachloride	5	MCL	--	ND	--	--	ND	--	ND	--	--
	Chlorobenzene	100	MCL	--	ND	--	--	ND	--	ND	--	--
	cis-1,2-Dichloroethene	70	MCL	--	ND	--	--	ND	--	ND	--	--
	Ethylbenzene	700	MCL	--	ND	--	--	ND	--	ND	--	--
	m,p-Xylene	--	--	--	ND	--	--	ND	--	ND	--	--
	Methylene chloride	5	MCL	--	ND	--	--	ND	--	ND	--	--
	o-Xylene	--	--	--	ND	--	--	ND	--	ND	--	--
	Styrene	100	MCL	--	ND	--	--	ND	--	ND	--	--
	Tetrachloroethene (PCE)	5	MCL	--	ND	--	--	ND	--	ND	--	--
	Toluene	1000	MCL	--	ND	--	--	ND	--	ND	--	--
	trans-1,2-Dichloroethene	100	MCL	--	ND	--	--	ND	--	ND	--	--
	Trichloroethene (TCE)	5	MCL	--	ND	--	--	ND	--	ND	--	--
	Vinyl chloride	2	MCL	--	ND	--	--	ND	--	ND	--	--
	Xylenes, Total	10000	MCL	--	ND	--	--	ND	--	ND	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID: Location Type: Address: Field Sample ID: Sample Date: Sample Type:	D2-HYD321 Hydrant FH:321 220114-D2-VT01 2022-01-14 N (Normal)	D2-HYD365 Hydrant FH:365 20220114-D2-XT01 2022-01-14 N (Normal)		D2-HYD420 Hydrant FH:420 20220114-D2-WT02 2022-01-14 N (Normal)		D2-HYD551 Hydrant FH:551 20220114-D2-WT07 2022-01-14 FD (Field Duplicate)		220114-D2-WT07 2022-01-14 N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	3690 §	--		2900 §	--	2650 §	ND	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	--	ND	--	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	--	ND	--	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	--	ND	--	ND	--	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	--	ND	--	ND	--	--	--	ND
Metals (ppb)	Antimony	6	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Arsenic	10	MCL	ND	--	ND	--	0.320	--	--	--	0.450
	Barium	2000	MCL	1.80	--	1.80	--	2.00	--	--	--	2.00
	Beryllium	4	MCL	ND	--	ND	--	ND	--	--	--	ND
	Cadmium	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	Chromium	100	MCL	1.30	--	0.830	--	1.10	--	--	--	1.60
	Copper	1300	MCL	5.70	--	2.60	--	4.00	--	--	--	2.30
	Lead	15	MCL	0.540	--	0.740	--	0.540	--	--	--	0.500
	Mercury	2	MCL	ND	--	ND	--	ND	--	--	--	ND
	Selenium	50	MCL	1.00	--	0.810	--	1.40	--	--	--	1.30
	Thallium	2	MCL	0.0470	--	ND	--	ND	--	--	--	ND
Not Assigned (ppb)	Pentachlorophenol	1	MCL	ND	--	ND	--	ND	--	--	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	--	ND	--	ND	--	--	--	ND
	2-Methylnaphthalene	10	EAL	ND	--	ND	--	ND	--	--	--	ND
	Alachlor	--	--	ND	--	ND	--	ND	--	--	--	ND
	Atrazine	--	--	ND	--	ND	--	ND	--	--	--	ND
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	--	ND	--	--	--	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	ND	--	ND	--	--	--	ND
	Chlordane	--	--	ND	--	ND	--	ND	--	--	--	ND
	Diocetyl adipate	--	--	ND	--	ND	--	ND	--	--	--	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HYD321	D2-HYD365		D2-HYD420		D2-HYD551		
		Location Type:		Hydrant	Hydrant		Hydrant		Hydrant		
		Address:		FH:321	FH:365		FH:420		FH:551		
		Field Sample ID:		220114-D2-VT01	20220114-D2-XT01	220114-D2-XT01	20220114-D2-WT02	220114-D2-WT02	20220114-D2-WT07	20220114-D2-WT08	220114-D2-WT07
		Sample Date:		2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Synthetic Organic Compounds (ppb)	Endrin	--	--	ND	--	ND	--	ND	--	--	ND
	gamma-BHC (Lindane)	--	--	ND	--	ND	--	ND	--	--	ND
	Heptachlor	--	--	ND	--	ND	--	ND	--	--	ND
	Heptachlor epoxide	--	--	ND	--	ND	--	ND	--	--	ND
	Hexachlorobenzene	--	--	ND	--	ND	--	ND	--	--	ND
	Hexachlorocyclopentadiene	--	--	ND	--	ND	--	ND	--	--	ND
	Methoxychlor	--	--	ND	--	ND	--	ND	--	--	ND
	Naphthalene	17	EAL	ND	--	ND	--	ND	--	--	ND
	PCB-1016 (Aroclor 1016)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1221 (Aroclor 1221)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1232 (Aroclor 1232)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1242 (Aroclor 1242)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1248 (Aroclor 1248)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1254 (Aroclor 1254)	--	--	ND	--	ND	--	ND	--	--	ND
	PCB-1260 (Aroclor 1260)	--	--	ND	--	ND	--	ND	--	--	ND
	Simazine	--	--	ND	--	ND	--	ND	--	--	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	--	ND	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	--	ND	--	--	ND
	1,1-Dichloroethene	7	MCL	ND	--	ND	--	ND	--	--	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	--	ND	--	--	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	--	ND	--	--	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	--	ND	--	--	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	--	ND	--	--	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	--	ND	--	--	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	--	ND	--	--	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HYD321		D2-HYD365		D2-HYD420		D2-HYD551		
		Location Type:		Hydrant		Hydrant		Hydrant		Hydrant		
		Address:		FH:321		FH:365		FH:420		FH:551		
		Field Sample ID:		220114-D2-VT01		20220114-D2-XT01	220114-D2-XT01	20220114-D2-WT02	220114-D2-WT02	20220114-D2-WT07	20220114-D2-WT08	220114-D2-WT07
		Sample Date:		2022-01-14		2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14	2022-01-14
		Sample Type:		N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	Benzene	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	Chlorobenzene	100	MCL	ND	--	ND	--	ND	--	--	--	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	--	ND	--	--	--	ND
	Ethylbenzene	700	MCL	ND	--	ND	--	ND	--	--	--	ND
	m,p-Xylene	--	--	ND	--	ND	--	ND	--	--	--	ND
	Methylene chloride	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	o-Xylene	--	--	ND	--	ND	--	ND	--	--	--	ND
	Styrene	100	MCL	ND	--	ND	--	ND	--	--	--	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	Toluene	1000	MCL	ND	--	ND	--	ND	--	--	--	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	--	ND	--	--	--	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	--	ND	--	--	--	ND
	Vinyl chloride	2	MCL	ND	--	ND	--	ND	--	--	--	ND
	Xylenes, Total	10000	MCL	ND	--	ND	--	ND	--	--	--	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HYD551		D2-HYD56		D2-HYD79		D2-HYD84		D2-JULI0004
		Location Type:		Hydrant		Hydrant		Hydrant		Hydrant		Residence
		Address:		FH:551		FH:056		FH:079		FH:084		4 Julian Avenue
		Field Sample ID:		220114-D2-WT08		20220114-D2-YT05		220114-D2-YT05		20220114-D2-XT02		220115-D2-BT04
		Sample Date:		2022-01-14		2022-01-14		2022-01-14		2022-01-14		2022-01-15
		Sample Type:		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	ND	--	ND	ND	--	1920	--	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	--	ND	--	ND	--	ND	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	--	ND	--	ND	--	ND	--	ND
Metals (ppb)	Antimony	6	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Arsenic	10	MCL	0.370	--	0.420	--	ND	--	0.390	--	ND
	Barium	2000	MCL	1.90	--	2.80	--	4.30	--	1.80	--	2.00
	Beryllium	4	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Cadmium	5	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Chromium	100	MCL	1.60	--	1.10	--	1.20	--	1.10	--	1.80
	Copper	1300	MCL	4.20	--	2.40	--	1.80	--	1.80	--	48.0
	Lead	15	MCL	1.00	--	0.730	--	0.540	--	0.150	--	0.160
	Mercury	2	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Selenium	50	MCL	1.30	--	1.80	--	0.620	--	1.20	--	0.330
	Thallium	2	MCL	ND	--	ND	--	ND	--	ND	--	ND
Not Assigned (ppb)	Pentachlorophenol	1	MCL	ND	--	ND	--	ND	--	ND	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	--	ND	--	ND	--	ND	--	ND
	2-Methylnaphthalene	10	EAL	ND	--	ND	--	ND	--	ND	--	ND
	Alachlor	--	--	ND	--	ND	--	ND	--	ND	--	--
	Atrazine	--	--	ND	--	ND	--	ND	--	ND	--	--
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	--	ND	--	0.0200	--	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	ND	--	ND	--	ND	--	ND
	Chlordane	--	--	ND	--	ND	--	ND	--	ND	--	--
	Dioctyl adipate	--	--	ND	--	ND	--	ND	--	ND	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HYD551		D2-HYD56		D2-HYD79		D2-HYD84		D2-JULI0004	
		Location Type:		Hydrant		Hydrant		Hydrant		Hydrant		Residence	
		Address:		FH:551		FH:056		FH:079		FH:084		4 Julian Avenue	
		Field Sample ID:		220114-D2-WT08		20220114-D2-YT05		220114-D2-YT05		20220114-D2-XT02		220114-D2-XT03	
		Sample Date:		2022-01-14		2022-01-14		2022-01-14		2022-01-14		2022-01-14	
		Sample Type:		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Synthetic Organic Compounds (ppb)	Endrin	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	gamma-BHC (Lindane)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Heptachlor	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Heptachlor epoxide	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Hexachlorobenzene	--	--	ND	--	ND	--	ND	--	ND	--	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	--	ND	--	ND	--	ND	--	ND	ND
	Methoxychlor	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Naphthalene	17	EAL	ND	--	ND	--	ND	--	ND	--	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1221 (Aroclor 1221)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1232 (Aroclor 1232)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1242 (Aroclor 1242)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1248 (Aroclor 1248)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1254 (Aroclor 1254)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	PCB-1260 (Aroclor 1260)	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
	Simazine	--	--	ND	--	ND	--	ND	--	ND	--	ND	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,1-Dichloroethene	7	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-HYD551		D2-HYD56		D2-HYD79		D2-HYD84		D2-JULI0004	
		Location Type:		Hydrant		Hydrant		Hydrant		Hydrant		Residence	
		Address:		FH:551		FH:056		FH:079		FH:084		4 Julian Avenue	
		Field Sample ID:		220114-D2-WT08		20220114-D2-YT05		220114-D2-YT05		20220114-D2-XT02		220114-D2-XT02	
		Sample Date:		2022-01-14		2022-01-14		2022-01-14		2022-01-14		2022-01-14	
		Sample Type:		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)	
												220115-D2-BT04	
												2022-01-15	
												N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	Benzene	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Chlorobenzene	100	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Ethylbenzene	700	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	m,p-Xylene	--	--	ND	--	ND	--	ND	--	ND	--	ND	ND
	Methylene chloride	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	o-Xylene	--	--	ND	--	ND	--	ND	--	ND	--	ND	ND
	Styrene	100	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Toluene	1000	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Vinyl chloride	2	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND
	Xylenes, Total	10000	MCL	ND	--	ND	--	ND	--	ND	--	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-JULI0104	D2-JULI0107	D2-JULI0305	D2-JULI0403	D2-JULI0507		D2-JULI0509	D2-JULI0613
		Location Type:		Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:		104 Julian Avenue	107 Julian Avenue	305 Julian Avenue	403 Julian Avenue	507 Julian Avenue		509 Julian Avenue	613 Julian Way
		Field Sample ID:		220114-D2-IT05	220115-D2-BT08	220117-D2-IT02	220117-D2-HT02	20220114-D2-IT02	220114-D2-IT02	220116-D2-FT02	220112-D2-HT07
		Sample Date:		2022-01-14	2022-01-15	2022-01-17	2022-01-17	2022-01-14	2022-01-14	2022-01-16	2022-01-12
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	1600	ND	ND	ND	--	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	--	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	--	ND	ND	1.20
	Barium	2000	MCL	2.10	2.00	1.90	1.90	--	1.90	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	--	ND	0.140	ND
	Chromium	100	MCL	1.10	1.90	1.30	1.60	--	1.80	1.90	1.90
	Copper	1300	MCL	29.0	110	46.0	110	--	58.0	94.0	110
	Lead	15	MCL	0.280	0.460	ND	0.970	--	0.300	0.740	0.190
	Mercury	2	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	--	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	--	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	--	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	--	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	--	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	--	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-JULI0104	D2-JULI0107	D2-JULI0305	D2-JULI0403	D2-JULI0507		D2-JULI0509	D2-JULI0613
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	104 Julian Avenue	107 Julian Avenue	305 Julian Avenue	403 Julian Avenue	507 Julian Avenue		509 Julian Avenue	613 Julian Way
				Field Sample ID:	220114-D2-IT05	220115-D2-BT08	220117-D2-IT02	220117-D2-HT02	20220114-D2-IT02	220114-D2-IT02	220116-D2-FT02	220112-D2-HT07
				Sample Date:	2022-01-14	2022-01-15	2022-01-17	2022-01-17	2022-01-14	2022-01-14	2022-01-16	2022-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	--	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	--	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	--	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	--	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-JULI0704	D2-KAMA0422		D2-KAUW0631		D2-KAWE0521	D2-KAWE0525	D2-KAWE0671
		Location Type:		Residence	Residence		Residence		Residence	Residence	Residence
		Address:		704 Julian Avenue	422 Kamakakoa Alley		631 Kauwenaole Alley		521 Kawehiwehi Street	525 Kawehiwehi Street	671 Kawehiwehi Street
		Field Sample ID:		220112-D2-FT03	220112-D2-BT04	220112-D2-BT06	220112-D2-BT10	220112-D2-BT12	220111-D2-IT01	220111-D2-AT01	220116-D2-IT05
		Sample Date:		2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-16
		Sample Type:		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	446	359	355	445	403	ND	2600 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	40.0	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	40.0	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	1.30	ND	ND	ND	ND	ND	0.600	ND
	Barium	2000	MCL	1.90	1.80	1.90	1.80	1.90	1.90	2.20	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.90	1.60	1.70	1.60	1.60	1.70	2.40	1.30
	Copper	1300	MCL	25.0	9.40	11.0	12.0	12.0	17.0	11.0	5.30
	Lead	15	MCL	0.170	ND	0.140	0.160	0.170	0.270	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-JULI0704		D2-KAMA0422		D2-KAUW0631		D2-KAWE0521	D2-KAWE0525	D2-KAWE0671
				Location Type:	Residence		Residence		Residence		Residence	Residence	Residence
				Address:	704 Julian Avenue		422 Kamakakoa Alley		631 Kauwenaole Alley		521 Kawehiwehi Street	525 Kawehiwehi Street	671 Kawehiwehi Street
				Field Sample ID:	220112-D2-FT03	220112-D2-BT04	220112-D2-BT06	220112-D2-BT10	220112-D2-BT12	220111-D2-IT01	220111-D2-AT01	220116-D2-IT05	
				Sample Date:	2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-16	
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-KOAA0501		D2-KULE0606	D2-KUMA0281	D2-KUMA0295	D2-LELE0621	D2-LEWA0278	D2-LEWA0321
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	501 Koaaiana Alley		606 Kulekia Alley	281 Kumama Alley	295 Kumama Alley	621 Lelemanu Alley	278 Lewa Hia Loop	321 Lewa Mawaho Loop
				Field Sample ID:	20220114-D2-JT04	220114-D2-JT04	220113-D2-GT03	220112-D2-ET05	220116-D2-AT05	220117-D2-IT01	220117-D2-HT01	220113-D2-GT04
				Sample Date:	2022-01-14	2022-01-14	2022-01-13	2022-01-12	2022-01-16	2022-01-17	2022-01-17	2022-01-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	--	ND	397	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	ND	42.0	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	--	ND	ND	42.0	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	--	ND	0.840	ND	ND	ND	ND	ND	0.910
	Barium	2000	MCL	--	1.90	1.90	1.80	2.00	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	--	1.80	1.70	1.60	1.50	1.40	1.80	1.80	1.80
	Copper	1300	MCL	--	8.60	13.0	7.60	9.30	8.40	8.30	10.0	
	Lead	15	MCL	--	ND	0.320	0.160	0.140	0.200	0.230	0.220	
	Mercury	2	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	--	ND	ND	ND	ND	ND	ND	0.320	
	Thallium	2	MCL	--	0.0710	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	--	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-KOAA0501		D2-KULE0606	D2-KUMA0281	D2-KUMA0295	D2-LELE0621	D2-LEWA0278	D2-LEWA0321
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	501 Koaaia Alley		606 Kulekia Alley	281 Kumama Alley	295 Kumama Alley	621 Lelemanu Alley	278 Lewa Hia Loop	321 Lewa Mawaho Loop
				Field Sample ID:	20220114-D2-JT04	220114-D2-JT04	220113-D2-GT03	220112-D2-ET05	220116-D2-AT05	220117-D2-IT01	220117-D2-HT01	220113-D2-GT04
				Sample Date:	2022-01-14	2022-01-14	2022-01-13	2022-01-12	2022-01-16	2022-01-17	2022-01-17	2022-01-13
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-LEWA0336	D2-LEWA0382	D2-LEWA0409	D2-MERC0212	D2-MERC0222	D2-MERC0232	D2-MILL1001	D2-MONT0300
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	336 Lewa Mawaho Loop	382 Lewahana Loop	409 Lewa Mawaho Loop	212 Mercury Street	222 Mercury Street	232 Mercury Street	1001 Mills Boulevard	300 Monthan Street
				Field Sample ID:	220112-D2-HT05	220112-D2-HT11	220111-D2-JT04	220111-D2-HT11	220111-D2-HT09	220111-D2-BT08	220116-D2-IT03	220115-D2-BT07
				Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-16	2022-01-15
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	403	476	429	ND	2280 §	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	1.20	0.900	ND	ND	ND	0.700	ND	ND	ND
	Barium	2000	MCL	2.10	2.00	2.00	1.90	1.90	2.00	1.90	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.90	1.70	1.70	1.70	2.40	1.50	1.10	
	Copper	1300	MCL	25.0	37.0	11.0	8.40	14.0	6.10	38.0	12.0	
	Lead	15	MCL	0.410	0.290	0.110	0.200	0.230	ND	0.350	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.340	ND	ND	ND	1.60	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-LEWA0336	D2-LEWA0382	D2-LEWA0409	D2-MERC0212	D2-MERC0222	D2-MERC0232	D2-MILL1001	D2-MONT0300
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	336 Lewa Mawaho Loop	382 Lewahana Loop	409 Lewa Mawaho Loop	212 Mercury Street	222 Mercury Street	232 Mercury Street	1001 Mills Boulevard	300 Monthan Street
		Field Sample ID:	220112-D2-HT05	220112-D2-HT11	220111-D2-JT04	220111-D2-HT11	220111-D2-HT09	220111-D2-BT08	220116-D2-IT03	220115-D2-BT07
		Sample Date:	2022-01-12	2022-01-12	2022-01-11	2022-01-11	2022-01-11	2022-01-11	2022-01-16	2022-01-15
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-MONT0303	D2-OPUL0431	D2-PONA0402	D2-PORT0904		D2-PORT1302	D2-PORT1308	D2-PORT1406
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:		303 Monthan Street	431 Opulepule Alley	402 Ponanonana Alley	904 Porter Avenue		1302 Porter Avenue	1308 Porter Avenue	1406 Porter Avenue
		Field Sample ID:		220115-D2-ET05	220112-D2-BT08	220117-D2-LT06	220115-D2-HT02	220115-D2-HT03	220111-D2-FT09	220111-D2-FT06	220111-D2-FT08
		Sample Date:		2022-01-15	2022-01-12	2022-01-17	2022-01-15	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	368	2580 §	1660	1810	581	392	548
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.296	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	1.80	1.82	2.00	1.90	2.00	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.90	1.50	1.41	1.20	1.10	1.80	1.70	1.80
	Copper	1300	MCL	6.20	14.0	9.34	24.0	21.0	21.0	37.0	25.0
	Lead	15	MCL	ND	0.140	0.275	0.410	0.370	0.0920	0.170	0.230
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.480	ND	1.34	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	--	--	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	--	--	ND	--	--	--	--	--
	Atrazine	--	--	--	--	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Endrin	--	--	--	--	ND	--	--	--	--	--
	gamma-BHC (Lindane)	--	--	--	--	ND	--	--	--	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-MONT0303	D2-OPUL0431	D2-PONA0402	D2-PORT0904		D2-PORT1302	D2-PORT1308	D2-PORT1406
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	303 Monthan Street	431 Opulepule Alley	402 Ponanonana Alley	904 Porter Avenue		1302 Porter Avenue	1308 Porter Avenue	1406 Porter Avenue
		Field Sample ID:	220115-D2-ET05	220112-D2-BT08	220117-D2-LT06	220115-D2-HT02	220115-D2-HT03	220111-D2-FT09	220111-D2-FT06	220111-D2-FT08
		Sample Date:	2022-01-15	2022-01-12	2022-01-17	2022-01-15	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Heptachlor	--	--	--	--	ND	--	--	--	--
	Heptachlor epoxide	--	--	--	--	ND	--	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	ND	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	ND	--	--	--	--
	Simazine	--	--	--	--	ND	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-MONT0303	D2-OPUL0431	D2-PONA0402	D2-PORT0904		D2-PORT1302	D2-PORT1308	D2-PORT1406
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	303 Monthan Street	431 Opulepule Alley	402 Ponanonana Alley	904 Porter Avenue		1302 Porter Avenue	1308 Porter Avenue	1406 Porter Avenue
		Field Sample ID:	220115-D2-ET05	220112-D2-BT08	220117-D2-LT06	220115-D2-HT02	220115-D2-HT03	220111-D2-FT09	220111-D2-FT06	220111-D2-FT08
		Sample Date:	2022-01-15	2022-01-12	2022-01-17	2022-01-15	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
			DOH Project Screening Level	Basis of Project Screening Level						
Method Group	Analyte									
Volatile Organic Compounds (ppb)	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-PORT1726	D2-PORT1810	D2-PORT1824	D2-PORT1902	D2-PORT1917	D2-SIGN0202	D2-SIGN0406	D2-SIGN0504A
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1726 Porter Avenue	1810 Porter Avenue	1824 Porter Avenue	1902 Porter Avenue	1917 Porter Avenue	202 Signer Boulevard	406 Signer Boulevard	504A Signer Boulevard
		Field Sample ID:	220112-D2-IT06	220112-D2-FT07	220113-D2-ET04	220117-D2-HT06	220112-D2-FT09	220115-D2-HT04	220118-D2-MT05	220115-D2-IT04
		Sample Date:	2022-01-12	2022-01-12	2022-01-13	2022-01-17	2022-01-12	2022-01-15	2022-01-18	2022-01-15
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	4020 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.610	0.980	ND	ND	1.10	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	2.10	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	--
	Cadmium	5	MCL	ND	ND	ND	ND	ND	0.0590	ND
	Chromium	100	MCL	1.90	2.20	2.00	1.40	1.80	2.10	1.40
	Copper	1300	MCL	63.0	58.0	67.0	81.0	61.0	66.0	54.0
	Lead	15	MCL	0.170	0.130	0.210	0.100	0.140	0.210	0.200
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	0.100	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1726	D2-PORT1810	D2-PORT1824	D2-PORT1902	D2-PORT1917	D2-SIGN0202	D2-SIGN0406	D2-SIGN0504A
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1726 Porter Avenue	1810 Porter Avenue	1824 Porter Avenue	1902 Porter Avenue	1917 Porter Avenue	202 Signer Boulevard	406 Signer Boulevard	504A Signer Boulevard
				Field Sample ID:	220112-D2-IT06	220112-D2-FT07	220113-D2-ET04	220117-D2-HT06	220112-D2-FT09	220115-D2-HT04	220118-D2-MT05	220115-D2-IT04
				Sample Date:	2022-01-12	2022-01-12	2022-01-13	2022-01-17	2022-01-12	2022-01-15	2022-01-18	2022-01-15
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-SIGN0504A			D2-SIGN1001		D2-SIGN203C	D2-SIGN302B	D2-SIGN401A
				Location Type:	Residence			Residence		Residence	Residence	Residence
				Address:	504A Signer Boulevard			1001 Signer Boulevard		203C Signer Boulevard	302B Signer Boulevard	401A Signer Boulevard
				Field Sample ID:	D2-TW-0008451-22047-3-N-R1	D2-TW-0008451-22047-N	D2-TW-0008451-22047-N-R1	20220114-D2-IT01	220114-D2-IT01	220115-D2-HT05	220115-D2-JT03	220117-D2-LT05
				Sample Date:	2022-02-18	2022-02-16	2022-02-18	2022-01-14	2022-01-14	2022-01-15	2022-01-15	2022-01-17
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	--	--	1950	--	ND	2530 §	2540 §	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	--	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	--	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	--	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	--	--	--	--	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	--	ND	ND	ND	0.264	
	Barium	2000	MCL	2.10	2.10	1.90	--	2.00	2.10	2.10	1.89	
	Beryllium	4	MCL	ND	ND	ND	--	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	--	ND	ND	ND	ND	
	Chromium	100	MCL	1.90	1.60	1.90	--	1.90	1.90	1.80	1.35	
	Copper	1300	MCL	88.3	98.3	88.7	--	26.0	31.0	67.0	67.2	
	Lead	15	MCL	0.140	ND	0.140	--	0.140	0.130	0.160	0.141	
	Mercury	2	MCL	ND	ND	ND	--	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	--	ND	ND	ND	1.07	
Thallium	2	MCL	ND	ND	ND	--	ND	ND	ND	ND		
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	--	--	--	ND	ND	ND	ND	
	2-Ethylhexyl adipate	--	--	--	--	--	--	--	--	--	ND	
	2-Methylnaphthalene	10	EAL	--	--	--	--	ND	ND	ND	ND	
	Alachlor	--	--	--	--	--	--	--	--	--	ND	
	Atrazine	--	--	--	--	--	--	--	--	--	ND	
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	--	--	--	--	ND	ND	ND	ND	
	Endrin	--	--	--	--	--	--	--	--	--	ND	

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-SIGN0504A			D2-SIGN1001		D2-SIGN203C	D2-SIGN302B	D2-SIGN401A
		Location Type:	Residence			Residence		Residence	Residence	Residence
		Address:	504A Signer Boulevard			1001 Signer Boulevard		203C Signer Boulevard	302B Signer Boulevard	401A Signer Boulevard
		Field Sample ID:	D2-TW-0008451-22047-3-N-R1	D2-TW-0008451-22047-N	D2-TW-0008451-22047-N-R1	20220114-D2-IT01	220114-D2-IT01	220115-D2-HT05	220115-D2-JT03	220117-D2-LT05
		Sample Date:	2022-02-18	2022-02-16	2022-02-18	2022-01-14	2022-01-14	2022-01-15	2022-01-15	2022-01-17
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	--	--	--	--	--	--	ND
	Heptachlor	--	--	--	--	--	--	--	--	ND
	Heptachlor epoxide	--	--	--	--	--	--	--	--	ND
	Hexachlorobenzene	--	--	--	--	--	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	--	--	--	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	--	--	--	--	ND
	Naphthalene	17	EAL	--	--	--	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	--	--	--	--	ND
	Simazine	--	--	--	--	--	--	--	--	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	--	--	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	--	--	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	--	--	--	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	--	--	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	--	--	--	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	--	--	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	--	--	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	--	--	--	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	--	--	ND	ND	ND	ND
	Benzene	5	MCL	--	--	--	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	--	--	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	--	--	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	--	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	--	--	ND	ND	ND	ND
	m,p-Xylene	--	--	--	--	--	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-SIGN0504A			D2-SIGN1001		D2-SIGN203C	D2-SIGN302B	D2-SIGN401A
		Location Type:	Residence			Residence		Residence	Residence	Residence
		Address:	504A Signer Boulevard			1001 Signer Boulevard		203C Signer Boulevard	302B Signer Boulevard	401A Signer Boulevard
		Field Sample ID:	D2-TW-0008451-22047-3-N-R1	D2-TW-0008451-22047-N	D2-TW-0008451-22047-N-R1	20220114-D2-IT01	220114-D2-IT01	220115-D2-HT05	220115-D2-JT03	220117-D2-LT05
		Sample Date:	2022-02-18	2022-02-16	2022-02-18	2022-01-14	2022-01-14	2022-01-15	2022-01-15	2022-01-17
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	Methylene chloride	5	MCL	--	--	--	--	ND	ND	ND
	o-Xylene	--	--	--	--	--	--	ND	ND	ND
	Styrene	100	MCL	--	--	--	--	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	--	--	--	ND	ND	ND
	Toluene	1000	MCL	--	--	--	--	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	--	--	--	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	--	--	--	ND	ND	ND
	Vinyl chloride	2	MCL	--	--	--	--	ND	ND	ND
	Xylenes, Total	10000	MCL	--	--	--	--	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-SIGN403A		D2-SIGN504B			D2-SIGN504C		D2-SIGN504E	
		Location Type:		Residence		Residence			Residence		Residence	
		Address:		403A Signer Boulevard		504B Signer Boulevard			504C Signer Boulevard		504E Signer Boulevard	
		Field Sample ID:		220116-D2-FT01		D2-TW-0008452-22047-3-N	D2-TW-0008452-22047-N	D2-TW-0008452-22047-N-R1	D2-TW-0008453-22047-N	D2-TW-0008453-22047-N-R1	D2-TW-0008454-22047-N	D2-TW-0008454-22047-N-R1
		Sample Date:		2022-01-16		2022-02-17	2022-02-17	2022-02-18	2022-02-17	2022-02-18	2022-02-17	2022-02-18
		Sample Type:		N (Normal)		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	--	--	--	--	--	--	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	--	--	--	--	--	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	--	--	--	--	--	--	--	--
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	--	--	--	--	--	--	--	--
	Petroleum Hydrocarbons, Total	211	ISP	ND	--	--	--	--	--	--	--	--
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.30	1.90	3.00	1.90	2.00	1.90	2.00	2.00
	Beryllium	4	MCL	ND	0.680	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.90	1.60	1.50	2.10	1.70	1.90	1.70	1.90	1.90
	Copper	1300	MCL	19.0	48.0	52.6	111	69.0	84.0	30.0	61.1	61.1
	Lead	15	MCL	0.180	0.510	ND	0.810	0.160	0.160	0.150	0.160	0.160
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	0.0880	0.0710	ND	0.0760	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	--	--	--	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	--	--	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	--	--	--	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	--	--	--	--	--	--	--
	Hexachlorobenzene	--	--	ND	--	--	--	--	--	--	--	--
	Hexachlorocyclopentadiene	--	--	ND	--	--	--	--	--	--	--	--
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	--	--	--	--	--	--	--	--
	1,1,1-Trichloroethane	--	--	ND	--	--	--	--	--	--	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-SIGN403A			D2-SIGN504B			D2-SIGN504C		D2-SIGN504E	
				Location Type:	Residence			Residence			Residence		Residence	
				Address:	403A Signer Boulevard			504B Signer Boulevard			504C Signer Boulevard		504E Signer Boulevard	
				Field Sample ID:	220116-D2-FT01	D2-TW-0008452-22047-3-N	D2-TW-0008452-22047-N	D2-TW-0008452-22047-N-R1	D2-TW-0008453-22047-N	D2-TW-0008453-22047-N-R1	D2-TW-0008454-22047-N	D2-TW-0008454-22047-N-R1		
				Sample Date:	2022-01-16	2022-02-17	2022-02-17	2022-02-18	2022-02-17	2022-02-18	2022-02-17	2022-02-18		
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level											
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	--	--	--	--	--	--	--	--		
	1,1-Dichloroethene	7	MCL	ND	--	--	--	--	--	--	--	--		
	1,2,4-Trichlorobenzene	70	MCL	ND	--	--	--	--	--	--	--	--		
	1,2-Dichlorobenzene	600	MCL	ND	--	--	--	--	--	--	--	--		
	1,2-Dichloroethane	5	MCL	ND	--	--	--	--	--	--	--	--		
	1,2-Dichloroethene (Total)	70	MCL	ND	--	--	--	--	--	--	--	--		
	1,2-Dichloropropane	5	MCL	ND	--	--	--	--	--	--	--	--		
	1,4-Dichlorobenzene	75	MCL	ND	--	--	--	--	--	--	--	--		
	Benzene	5	MCL	ND	--	--	--	--	--	--	--	--		
	Carbon Tetrachloride	5	MCL	ND	--	--	--	--	--	--	--	--		
	Chlorobenzene	100	MCL	ND	--	--	--	--	--	--	--	--		
	cis-1,2-Dichloroethene	70	MCL	ND	--	--	--	--	--	--	--	--		
	Ethylbenzene	700	MCL	ND	--	--	--	--	--	--	--	--		
	m,p-Xylene	--	--	ND	--	--	--	--	--	--	--	--		
	Methylene chloride	5	MCL	ND	--	--	--	--	--	--	--	--		
	o-Xylene	--	--	ND	--	--	--	--	--	--	--	--		
	Styrene	100	MCL	ND	--	--	--	--	--	--	--	--		
	Tetrachloroethene (PCE)	5	MCL	ND	--	--	--	--	--	--	--	--		
	Toluene	1000	MCL	ND	--	--	--	--	--	--	--	--		
	trans-1,2-Dichloroethene	100	MCL	ND	--	--	--	--	--	--	--	--		
	Trichloroethene (TCE)	5	MCL	ND	--	--	--	--	--	--	--	--		
	Vinyl chloride	2	MCL	ND	--	--	--	--	--	--	--	--		
	Xylenes, Total	10000	MCL	ND	--	--	--	--	--	--	--	--		

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-SIGN504F		D2-SIGN504H		D2-SIGN504I		D2-SIGN504K	
		Location Type:		Residence		Residence		Residence		Residence	
		Address:		504F Signer Boulevard		504H Signer Boulevard		504I Signer Boulevard		504K Signer Boulevard	
		Field Sample ID:		D2-TW-0008455-22047-N	D2-TW-0008455-22047-N-R1	D2-TW-0008456-22047-N	D2-TW-0008456-22047-N-R1	D2-TW-0008457-22047-N	D2-TW-0008457-22047-N-R1	D2-TW-0008458-22047-N	D2-TW-0008458-22047-N-R1
		Sample Date:		2022-02-17	2022-02-18	2022-02-17	2022-02-18	2022-02-17	2022-02-18	2022-02-17	2022-02-18
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	2.00	2.00	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	2.00	1.60	2.00	1.50	2.00	1.80	1.90
	Copper	1300	MCL	38.0	119	59.0	35.1	48.0	28.7	96.1	39.3
	Lead	15	MCL	0.640	0.840	0.230	0.270	5.50	1.20	1.40	0.140
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	0.0670	0.0570	ND	0.0660

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-TINK0102	D2-TINK0108	D2-TINK0114	D2-TINK1616	D2-TINK1705	D2-TINK1814	D2-TINK1901	D2-TINK1926
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		102 Tinker Drive	108 Tinker Drive	114 Tinker Drive	1616 Tinker Avenue	1705 Tinker Avenue	1814 Tinker Avenue	1901 Tinker Avenue	1926 Tinker Avenue
		Field Sample ID:		220113-D2-ET02	220113-D2-ET03	220117-D2-LT02	220117-D2-IT05	220115-D2-JT05	220111-D2-IT05	220111-D2-JT05	220111-D2-BT01
		Sample Date:		2022-01-13	2022-01-13	2022-01-17	2022-01-17	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	1990	ND	ND	334	399	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.281	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.80	2.00	1.90	1.90	2.10	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.70	1.80	1.41	1.80	1.90	1.70	1.70	2.40
	Copper	1300	MCL	79.0	82.0	44.7	23.0	84.0	150	28.0	31.0
	Lead	15	MCL	0.240	ND	ND	ND	0.130	0.200	ND	0.200
	Mercury	2	MCL	0.0710	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	1.31	ND	ND	ND	1.60	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	--	--	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	0.00911	ND	ND	ND	ND	ND
	Alachlor	--	--	--	--	ND	--	--	--	--	--
	Atrazine	--	--	--	--	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Endrin	--	--	--	--	ND	--	--	--	--	--
	gamma-BHC (Lindane)	--	--	--	--	ND	--	--	--	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK0102	D2-TINK0108	D2-TINK0114	D2-TINK1616	D2-TINK1705	D2-TINK1814	D2-TINK1901	D2-TINK1926
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	102 Tinker Drive	108 Tinker Drive	114 Tinker Drive	1616 Tinker Avenue	1705 Tinker Avenue	1814 Tinker Avenue	1901 Tinker Avenue	1926 Tinker Avenue
		Field Sample ID:	220113-D2-ET02	220113-D2-ET03	220117-D2-LT02	220117-D2-IT05	220115-D2-JT05	220111-D2-IT05	220111-D2-JT05	220111-D2-BT01
		Sample Date:	2022-01-13	2022-01-13	2022-01-17	2022-01-17	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Heptachlor	--	--	--	--	ND	--	--	--	--
	Heptachlor epoxide	--	--	--	--	ND	--	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	--	--	ND	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	--	--	ND	--	--	--	--
	Simazine	--	--	--	--	ND	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK0102	D2-TINK0108	D2-TINK0114	D2-TINK1616	D2-TINK1705	D2-TINK1814	D2-TINK1901	D2-TINK1926
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	102 Tinker Drive	108 Tinker Drive	114 Tinker Drive	1616 Tinker Avenue	1705 Tinker Avenue	1814 Tinker Avenue	1901 Tinker Avenue	1926 Tinker Avenue
		Field Sample ID:	220113-D2-ET02	220113-D2-ET03	220117-D2-LT02	220117-D2-IT05	220115-D2-JT05	220111-D2-IT05	220111-D2-JT05	220111-D2-BT01
		Sample Date:	2022-01-13	2022-01-13	2022-01-17	2022-01-17	2022-01-15	2022-01-11	2022-01-11	2022-01-11
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
			DOH Project Screening Level	Basis of Project Screening Level						
Method Group	Analyte									
Volatile Organic Compounds (ppb)	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-TINK2004	D2-WILS0201	D2-WORT0101		D2-WORT0201	D2-WORT0401		D2-WORT0403
				Location Type:	Residence	Residence	Residence		Residence	Residence		Residence
				Address:	2004 Tinker Avenue	201 Wilson Street	101 Worthington Avenue		201 Worthington Avenue	401 Worthington Avenue		403 Worthington Avenue
				Field Sample ID:	220111-D2-GT05	220111-D2-ET02	20220115-D2-BT05	220115-D2-BT05	220115-D2-JT06	220115-D2-JT04	D2-TW-1370975-22047-N	D2-TW-0007884-22047-N
				Sample Date:	2022-01-11	2022-01-11	2022-01-15	2022-01-15	2022-01-15	2022-01-15	2022-02-16	2022-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP		379	ND	1830	--	2630 §	7720 §	640	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--		ND	ND	--	ND	ND	ND	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--		ND	ND	--	ND	ND	ND	--	--
	Petroleum Hydrocarbons (as Motor Oil)	--	--		ND	ND	--	ND	ND	ND	--	--
	Petroleum Hydrocarbons, Total	211	ISP		ND	ND	--	ND	ND	ND	--	--
Metals (ppb)	Antimony	6	MCL		ND	ND	--	ND	ND	ND	--	--
	Arsenic	10	MCL		ND	ND	--	ND	ND	ND	--	--
	Barium	2000	MCL		1.90	1.90	--	2.00	2.10	2.10	--	--
	Beryllium	4	MCL		ND	ND	--	ND	ND	ND	--	--
	Cadmium	5	MCL		ND	ND	--	ND	ND	ND	--	--
	Chromium	100	MCL		1.70	2.30	--	1.10	1.90	1.90	--	--
	Copper	1300	MCL		120	29.0	--	94.0	42.0	33.0	--	--
	Lead	15	MCL		0.0940	0.200	--	0.950	0.240	0.320	--	--
	Mercury	2	MCL		ND	ND	--	ND	ND	ND	--	--
	Selenium	50	MCL		ND	ND	--	ND	ND	0.310	--	--
Synthetic Organic Compounds (ppb)	Thallium	2	MCL		ND	ND	--	ND	ND	ND	--	--
	1-Methylnaphthalene	10	EAL		ND	ND	--	ND	ND	ND	--	--
	2-Methylnaphthalene	10	EAL		ND	ND	--	ND	ND	ND	--	--
	Benzo(a)pyrene	0.2	MCL		ND	ND	--	ND	ND	ND	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL		ND	ND	--	ND	ND	ND	--	--
	Hexachlorobenzene	--	--		ND	ND	--	ND	ND	ND	--	--
	Hexachlorocyclopentadiene	--	--		ND	ND	--	ND	ND	ND	--	--
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL		ND	ND	--	ND	ND	ND	--	--
	1,1,1-Trichloroethane	--	--		ND	ND	--	ND	ND	ND	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-TINK2004	D2-WILS0201	D2-WORT0101		D2-WORT0201	D2-WORT0401		D2-WORT0403
				Location Type:	Residence	Residence	Residence		Residence	Residence		Residence
				Address:	2004 Tinker Avenue	201 Wilson Street	101 Worthington Avenue		201 Worthington Avenue	401 Worthington Avenue		403 Worthington Avenue
				Field Sample ID:	220111-D2-GT05	220111-D2-ET02	20220115-D2-BT05	220115-D2-BT05	220115-D2-JT06	220115-D2-JT04	D2-TW-1370975-22047-N	D2-TW-0007884-22047-N
				Sample Date:	2022-01-11	2022-01-11	2022-01-15	2022-01-15	2022-01-15	2022-01-15	2022-02-16	2022-02-17
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,1-Dichloroethene	7	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,2-Dichloroethane	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,2-Dichloropropane	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Benzene	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Carbon Tetrachloride	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Chlorobenzene	100	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Ethylbenzene	700	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	m,p-Xylene	--	--	ND	ND	--	ND	ND	ND	ND	--	--
	Methylene chloride	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	o-Xylene	--	--	ND	ND	--	ND	ND	ND	ND	--	--
	Styrene	100	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Toluene	1000	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Trichloroethene (TCE)	5	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Vinyl chloride	2	MCL	ND	ND	--	ND	ND	ND	ND	--	--
	Xylenes, Total	10000	MCL	ND	ND	--	ND	ND	ND	ND	--	--

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:				
ND = Not Detected				
ISP = Incident Specific Parameter				
EAL = DOH Environmental Action Level				
EPA MCL = EPA Maximum Contaminant Level				
All Results shown in Parts per Billion (ppb)				
§ - Exceeds Screening Level				
-- = No Information Available				
N (Normal) = Full compliance sample				
FD (Field Duplicate) = Extra sample taken for quality control				
N (Grab, Resample) = Additional follow-up sample				
			Location ID:	D2-WORT0505
			Location Type:	Residence
			Address:	505 Worthington Avenue
			Field Sample ID:	220116-D2-IT02
			Sample Date:	2022-01-16
			Sample Type:	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	3240 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	1.90
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.20
	Copper	1300	MCL	120
	Lead	15	MCL	0.560
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
	Thallium	2	MCL	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Hexachlorobenzene	--	--	ND
	Hexachlorocyclopentadiene	--	--	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND

Summary of Chemistry Results
Zone D2 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-WORT0505	
		Location Type:	Residence	
		Address:	505 Worthington Avenue	
		Field Sample ID:	220116-D2-IT02	
		Sample Date:	2022-01-16	
		Sample Type:	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene (Total)	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
	Xylenes, Total	10000	MCL	ND