

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-AUPA0071	D3-AUPA0117	D3-BLDG1756H	D3-BLDG1852H	D3-HALE1002	D3-HONO0134	D3-HONO0142	D3-HYD0188
		Location Type:	Residence	Residence	Non-Residence	Non-Residence	Residence	Residence	Residence	Hydrant
		Address:	71 Aupaka Street	117 Aupaka Street	Building 1756H,AAFES MINI-MALL	BLDG 1852H - Dorm Airman Perm Party, 326 Moffet St	1002 Halehaka Street	134 Honohono Street	142 Honohono Street	FH 188
		Field Sample ID:	220121-D3-AT02	220122-D3-GT04	220126D3FT01	220121-D3-ET02	220121-D3-GT05	220121-D3-KT03	220121-D3-CT01	220115-D3-WT01
		Sample Date:	2022-01-21	2022-01-22	2022-01-26	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-15
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	370
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	0.260
	Barium	2000	MCL	1.90	1.90	2.00	2.40	2.00	1.90	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.60	1.90	1.70	1.50	1.40	1.30
	Copper	1300	MCL	75.0	55.0	24.0	62.0	10.0	5.00	4.40
	Lead	15	MCL	0.130	0.110	0.180	0.760	0.400	0.130	0.160
	Mercury	2	MCL	ND	0.0860	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	1.10
Not Assigned (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.0930
	Pentachlorophenol	1	MCL	--	--	--	--	--	--	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	--
	Alachlor	--	--	--	--	--	--	--	--	ND
	Atrazine	--	--	--	--	--	--	--	--	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	--	--	--	--	--	--	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-AUPA0071	D3-AUPA0117	D3-BLDG1756H	D3-BLDG1852H	D3-HALE1002	D3-HONO0134	D3-HONO0142	D3-HYD0188
		Location Type:	Residence	Residence	Non-Residence	Non-Residence	Residence	Residence	Residence	Hydrant
		Address:	71 Aupaka Street	117 Aupaka Street	Building 1756H,AAFES MINI- MALL	BLDG 1852H - Dorm Airman Perm Party, 326 Moffet St	1002 Halehaka Street	134 Honohono Street	142 Honohono Street	FH 188
		Field Sample ID:	220121-D3-AT02	220122-D3-GT04	220126D3FT01	220121-D3-ET02	220121-D3-GT05	220121-D3-KT03	220121-D3-CT01	220115-D3-WT01
		Sample Date:	2022-01-21	2022-01-22	2022-01-26	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-15
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	Dioctyl adipate	--	--	--	--	--	--	--	--	ND
	Endrin	--	--	--	--	--	--	--	--	ND
	gamma-BHC (Lindane)	--	--	--	--	--	--	--	--	ND
	Heptachlor	--	--	--	--	--	--	--	--	ND
	Heptachlor epoxide	--	--	--	--	--	--	--	--	ND
	Hexachlorobenzene	--	--	--	--	--	--	--	--	ND
	Hexachlorocyclopentadiene	--	--	--	--	--	--	--	--	ND
	Methoxychlor	--	--	--	--	--	--	--	--	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	--	--	--	--	--	--	ND
	PCB-1221 (Aroclor 1221)	--	--	--	--	--	--	--	--	ND
	PCB-1232 (Aroclor 1232)	--	--	--	--	--	--	--	--	ND
	PCB-1242 (Aroclor 1242)	--	--	--	--	--	--	--	--	ND
	PCB-1248 (Aroclor 1248)	--	--	--	--	--	--	--	--	ND
	PCB-1254 (Aroclor 1254)	--	--	--	--	--	--	--	--	ND
	PCB-1260 (Aroclor 1260)	--	--	--	--	--	--	--	--	ND
	Simazine	--	--	--	--	--	--	--	--	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-AUPA0071	D3-AUPA0117	D3-BLDG1756H	D3-BLDG1852H	D3-HALE1002	D3-HONO0134	D3-HONO0142	D3-HYD0188
		Location Type:	Residence	Residence	Non-Residence	Non-Residence	Residence	Residence	Residence	Hydrant
		Address:	71 Aupaka Street	117 Aupaka Street	Building 1756H,AAFES MINI-MALL	BLDG 1852H - Dorm Airman Perm Party, 326 Moffet St	1002 Halehaka Street	134 Honohono Street	142 Honohono Street	FH 188
		Field Sample ID:	220121-D3-AT02	220122-D3-GT04	220126D3FT01	220121-D3-ET02	220121-D3-GT05	220121-D3-KT03	220121-D3-CT01	220115-D3-WT01
		Sample Date:	2022-01-21	2022-01-22	2022-01-26	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-15
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD0213	D3-HYD0219	D3-HYD0222	D3-HYD0411	D3-HYD0520	D3-HYD0592	D3-HYD2080	
		Location Type:		Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:		FH 213	FH 219	FH 222	FH 411	FH 520	FH 592	FH ID: 473	
		Field Sample ID:		220116-D3-YT01	220115-D3-ZT04	220115-D3-WT02	220115-D3-YT01	220116-D3-YT04	220115-D3-YT02	20220105-D3-ZT01	
		Sample Date:		2022-01-16	2022-01-15	2022-01-15	2022-01-15	2022-01-16	2022-01-15	2022-01-05	2022-01-06
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2170 §	3610 §	380	1690	3740 §	1630	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	60.0	ND	ND	ND	110	ND	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	--
	Petroleum Hydrocarbons, Total	211	ISP	ND	60.0	ND	ND	ND	110	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	--	--
	Arsenic	10	MCL	0.248	0.260	0.350	ND	0.258	ND	--	--
	Barium	2000	MCL	2.20	1.90	2.20	2.00	1.95	2.10	--	--
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	--	--
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	Chromium	100	MCL	1.53	1.70	1.70	1.80	1.55	1.90	--	--
	Copper	1300	MCL	14.5	21.0	4.00	7.00	2.57	2.90	--	--
	Lead	15	MCL	1.70	3.10	0.280	1.40	0.339	1.00	--	--
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	--	--
	Selenium	50	MCL	0.913	0.720	1.10	ND	1.29	0.390	--	--
	Thallium	2	MCL	ND	0.0430	0.0430	ND	ND	ND	--	--
Not Assigned (ppb)	Pentachlorophenol	1	MCL	--	ND	ND	ND	--	ND	--	--
Synthetic Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	--	--	--	--	--	--	ND	--
	1,2-Dichlorobenzene	600	MCL	--	--	--	--	--	--	ND	--
	1,3-Dichlorobenzene	--	--	--	--	--	--	--	--	ND	--
	1,4-Dichlorobenzene	75	MCL	--	--	--	--	--	--	ND	--
	1-Methylnaphthalene	10	EAL	ND	--	--	ND	ND	ND	--	--
	2,4-Dinitrotoluene	--	--	--	--	--	--	--	--	ND	--
	2,6-Dinitrotoluene	--	--	--	--	--	--	--	--	ND	--
	2-Chloronaphthalene	--	--	--	--	--	--	--	--	ND	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD0213	D3-HYD0219	D3-HYD0222	D3-HYD0411	D3-HYD0520	D3-HYD0592	D3-HYD2080	
		Location Type:		Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:		FH 213	FH 219	FH 222	FH 411	FH 520	FH 592	FH ID: 473	
		Field Sample ID:		220116-D3-YT01	220115-D3-ZT04	220115-D3-WT02	220115-D3-YT01	220116-D3-YT04	220115-D3-YT02	20220105-D3-ZT01	
		Sample Date:		2022-01-16	2022-01-15	2022-01-15	2022-01-15	2022-01-16	2022-01-15	2022-01-05	2022-01-06
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	2-Ethylhexyl adipate	--	--	ND	--	--	--	ND	--	--	--
	2-Methylnaphthalene	10	EAL	ND	--	--	ND	ND	ND	--	--
	2-Nitroaniline	--	--	--	--	--	--	--	--	ND	--
	3,3'-Dichlorobenzidine	--	--	--	--	--	--	--	--	ND	--
	3-Nitroaniline	--	--	--	--	--	--	--	--	ND	--
	4-Bromophenyl phenyl ether	--	--	--	--	--	--	--	--	ND	--
	4-Chloroaniline	--	--	--	--	--	--	--	--	ND	--
	4-Chlorophenyl phenyl ether	--	--	--	--	--	--	--	--	ND	--
	4-Nitroaniline	--	--	--	--	--	--	--	--	ND	--
	Acenaphthene	--	--	--	--	--	--	--	--	ND	--
	Acenaphthylene	--	--	--	--	--	--	--	--	ND	--
	Alachlor	--	--	ND	ND	ND	--	ND	--	--	--
	Anthracene	--	--	--	--	--	--	--	--	ND	--
	Atrazine	--	--	ND	ND	ND	--	ND	--	--	--
	Benzo(a)anthracene	--	--	--	--	--	--	--	--	ND	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	--
	Benzo(b)fluoranthene	--	--	--	--	--	--	--	--	ND	--
	Benzo(g,h,i)perylene	--	--	--	--	--	--	--	--	ND	--
	Benzo(k)fluoranthene	--	--	--	--	--	--	--	--	ND	--
	Benzyl butyl phthalate	--	--	--	--	--	--	--	--	ND	--
	Bis(2-chloroethoxy)methane	--	--	--	--	--	--	--	--	ND	--
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	--	--	--	--	--	--	ND	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	--
	Carbazole	--	--	--	--	--	--	--	--	ND	--
	Chlordane	--	--	ND	ND	ND	--	ND	--	--	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD0213	D3-HYD0219	D3-HYD0222	D3-HYD0411	D3-HYD0520	D3-HYD0592	D3-HYD2080	
		Location Type:		Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:		FH 213	FH 219	FH 222	FH 411	FH 520	FH 592	FH ID: 473	
		Field Sample ID:		220116-D3-YT01	220115-D3-ZT04	220115-D3-WT02	220115-D3-YT01	220116-D3-YT04	220115-D3-YT02	20220105-D3-ZT01	
		Sample Date:		2022-01-16	2022-01-15	2022-01-15	2022-01-15	2022-01-16	2022-01-15	2022-01-05	2022-01-06
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Chrysene	--	--	--	--	--	--	--	--	ND	--
	Dibenz(a,h)anthracene	--	--	--	--	--	--	--	--	ND	--
	Dibenzofuran	--	--	--	--	--	--	--	--	ND	--
	Diethyl phthalate	--	--	--	--	--	--	--	--	ND	--
	Dimethyl phthalate	--	--	--	--	--	--	--	--	ND	--
	di-n-Butyl phthalate	--	--	--	--	--	--	--	--	ND	--
	di-n-Octyl phthalate	--	--	--	--	--	--	--	--	ND	--
	Dioctyl adipate	--	--	--	ND	ND	--	--	--	--	--
	Endrin	--	--	ND	ND	ND	--	ND	--	--	--
	Fluoranthene	--	--	--	--	--	--	--	--	ND	--
	Fluorene	--	--	--	--	--	--	--	--	ND	--
	gamma-BHC (Lindane)	--	--	ND	ND	ND	--	ND	--	--	--
	Heptachlor	--	--	ND	ND	ND	--	ND	--	--	--
	Heptachlor epoxide	--	--	ND	ND	ND	--	ND	--	--	--
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	--
	Hexachlorobutadiene	--	--	--	--	--	--	--	--	ND	--
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	--
	Hexachloroethane	--	--	--	--	--	--	--	--	ND	--
	Indeno(1,2,3-c,d)pyrene	--	--	--	--	--	--	--	--	ND	--
	Isophorone	--	--	--	--	--	--	--	--	ND	--
	Methoxychlor	--	--	ND	ND	ND	--	ND	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	--
	Nitrobenzene	--	--	--	--	--	--	--	--	ND	--
	N-Nitrosodi-n-propylamine	--	--	--	--	--	--	--	--	ND	--
	N-Nitrosodiphenylamine	--	--	--	--	--	--	--	--	ND	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD0213	D3-HYD0219	D3-HYD0222	D3-HYD0411	D3-HYD0520	D3-HYD0592	D3-HYD2080	
		Location Type:		Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:		FH 213	FH 219	FH 222	FH 411	FH 520	FH 592	FH ID: 473	
		Field Sample ID:		220116-D3-YT01	220115-D3-ZT04	220115-D3-WT02	220115-D3-YT01	220116-D3-YT04	220115-D3-YT02	20220105-D3-ZT01	
		Sample Date:		2022-01-16	2022-01-15	2022-01-15	2022-01-15	2022-01-16	2022-01-15	2022-01-05	2022-01-06
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	PCB, Total	--	--	ND	--	--	--	ND	--	--	--
	PCB-1016 (Aroclor 1016)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1221 (Aroclor 1221)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1232 (Aroclor 1232)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1242 (Aroclor 1242)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1248 (Aroclor 1248)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1254 (Aroclor 1254)	--	--	ND	ND	ND	--	ND	--	--	--
	PCB-1260 (Aroclor 1260)	--	--	ND	ND	ND	--	ND	--	--	--
	Pentachlorophenol	1	MCL	ND	--	--	--	ND	--	--	--
	Phenanthrene	--	--	--	--	--	--	--	--	ND	--
	Pyrene	--	--	--	--	--	--	--	--	ND	--
	Simazine	--	--	ND	ND	ND	--	ND	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	--	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	--	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	--	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD0213	D3-HYD0219	D3-HYD0222	D3-HYD0411	D3-HYD0520	D3-HYD0592	D3-HYD2080	
		Location Type:		Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:		FH 213	FH 219	FH 222	FH 411	FH 520	FH 592	FH ID: 473	
		Field Sample ID:		220116-D3-YT01	220115-D3-ZT04	220115-D3-WT02	220115-D3-YT01	220116-D3-YT04	220115-D3-YT02	20220105-D3-ZT01	
		Sample Date:		2022-01-16	2022-01-15	2022-01-15	2022-01-15	2022-01-16	2022-01-15	2022-01-05	2022-01-06
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	--	--
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	--	--
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	--	--
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	--	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	--	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	--	--
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	--	--
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	--	--
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	--	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-HYD2080	D3-ILIM0102	D3-ILIM0121	D3-KIKA0708	D3-KIKA0712	D3-KOKI0082	D3-KOKI0084	D3-KOKO0111
		Location Type:	Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	FH ID: 473	102 Ilima Street	121 Ilima Street	708 Kikanai Loop	712 Kikanai Loop	82 Kokio Lane	84 Kokio Lane	111 Kokomalei Street
		Field Sample ID:	20220106-D3-ZT03	220121-D3-JT03	220122-D3-GT03	220122-D3-BT03	220122-D3-CT06	220122-D3-JT02	220122-D3-DT05	220122-D3-FT05
		Sample Date:	2022-01-06	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	180	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	180	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	0.410	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.02	1.80	1.80	2.20	2.40	1.80	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.51	1.60	1.60	ND	ND	ND	1.80
	Copper	1300	MCL	4.10	52.0	6.20	5.40	17.0	34.0	29.0
	Lead	15	MCL	0.347	0.210	0.180	ND	0.280	0.420	0.230
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	1.60	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	ND	--	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	ND	--	--	--	--	--	--
	Atrazine	--	--	ND	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	2.30	ND	ND
	Chlordane	--	--	ND	--	--	--	--	--	--
	Endrin	--	--	ND	--	--	--	--	--	--

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-HYD2080	D3-ILIM0102	D3-ILIM0121	D3-KIKA0708	D3-KIKA0712	D3-KOKI0082	D3-KOKI0084	D3-KOKO0111
		Location Type:	Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	FH ID: 473	102 Ilima Street	121 Ilima Street	708 Kikanai Loop	712 Kikanai Loop	82 Kokio Lane	84 Kokio Lane	111 Kokomalei Street
		Field Sample ID:	20220106-D3-ZT03	220121-D3-JT03	220122-D3-GT03	220122-D3-BT03	220122-D3-CT06	220122-D3-JT02	220122-D3-DT05	220122-D3-FT05
		Sample Date:	2022-01-06	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	ND	--	--	--	--	--	--
	Heptachlor	--	--	ND	--	--	--	--	--	--
	Heptachlor epoxide	--	--	ND	--	--	--	--	--	--
	Hexachlorobenzene	--	--	ND	--	--	--	--	--	--
	Hexachlorocyclopentadiene	--	--	ND	--	--	--	--	--	--
	Methoxychlor	--	--	ND	--	--	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	PCB, Total	--	--	ND	--	--	--	--	--	--
	PCB-1016 (Aroclor 1016)	--	--	ND	--	--	--	--	--	--
	PCB-1221 (Aroclor 1221)	--	--	ND	--	--	--	--	--	--
	PCB-1232 (Aroclor 1232)	--	--	ND	--	--	--	--	--	--
	PCB-1242 (Aroclor 1242)	--	--	ND	--	--	--	--	--	--
	PCB-1248 (Aroclor 1248)	--	--	ND	--	--	--	--	--	--
	PCB-1254 (Aroclor 1254)	--	--	ND	--	--	--	--	--	--
	PCB-1260 (Aroclor 1260)	--	--	ND	--	--	--	--	--	--
	Pentachlorophenol	1	MCL	ND	--	--	--	--	--	--
	Simazine	--	--	ND	--	--	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-HYD2080	D3-ILIM0102	D3-ILIM0121	D3-KIKA0708	D3-KIKA0712	D3-KOKI0082	D3-KOKI0084	D3-KOKO0111
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		FH ID: 473	102 Ilima Street	121 Ilima Street	708 Kikanai Loop	712 Kikanai Loop	82 Kokio Lane	84 Kokio Lane	111 Kokomalei Street
		Field Sample ID:		20220106-D3-ZT03	220121-D3-JT03	220122-D3-GT03	220122-D3-BT03	220122-D3-CT06	220122-D3-JT02	220122-D3-DT05	220122-D3-FT05
		Sample Date:		2022-01-06	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte										
Volatile Organic Compounds (ppb)	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-KOKO0121	D3-KOKO0161	D3-KOKO0163	D3-KOKO0171		D3-KOKO0177	D3-KOPI0121	
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	
		Address:		121 Kokomalei Street	161 Kokomalei Street	163 Kokomalei Street	171 Kokomalei Street		177 Kokomalei Street	121 Kopiko Street	
		Field Sample ID:		220122-D3-KT03	220121-D3-ET03	220121-D3-BT03	220122-D3-JT03	220122-D3-JT04	220122-D3-GT02	220121-D3-JT01	220121-D3-JT02
		Sample Date:		2022-01-22	2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-21	2022-01-21
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	0.380	0.360
	Barium	2000	MCL	1.90	2.00	1.90	1.90	2.00	2.20	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.70	1.40	ND	0.590	1.70	1.60	1.60
	Copper	1300	MCL	210	63.0	87.0	140	140	260	59.0	59.0
	Lead	15	MCL	0.180	ND	0.310	1.20	0.570	0.330	0.150	0.180
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	1.70	1.70
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-KOKO0121	D3-KOKO0161	D3-KOKO0163	D3-KOKO0171		D3-KOKO0177	D3-KOPI0121	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	121 Kokomalei Street	161 Kokomalei Street	163 Kokomalei Street	171 Kokomalei Street		177 Kokomalei Street	121 Kopiko Street	
		Field Sample ID:	220122-D3-KT03	220121-D3-ET03	220121-D3-BT03	220122-D3-JT03	220122-D3-JT04	220122-D3-GT02	220121-D3-JT01	220121-D3-JT02
		Sample Date:	2022-01-22	2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-21	2022-01-21
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-LEHU0304	D3-LILI0141	D3-LILI0152		D3-LILI0162	D3-LILI0251	D3-MAKA1024	D3-MAKA1026
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		304 Lehua Lane	141 Liliwai Street	152 Liliwai Street		162 Liliwai Street	251 Lilia Street	1024 Makalika Loop	1026 Makalika Loop
		Field Sample ID:		220121-D3-HT05	220121-D3-CT04	220121-D3-HT01	220121-D3-HT02	220121-D3-FT03	220121-D3-IT03	220121-D3-HT04	220122-D3-DT04
		Sample Date:		2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	2.00	2.00	2.00	1.90	2.00	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	ND	1.40	1.40	1.40	1.60	1.40	0.530
	Copper	1300	MCL	9.00	36.0	15.0	16.0	23.0	13.0	9.60	7.00
	Lead	15	MCL	0.130	ND	0.180	0.170	0.280	0.220	0.210	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-LEHU0304	D3-LILI0141	D3-LILI0152		D3-LILI0162	D3-LILI0251	D3-MAKA1024	D3-MAKA1026
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	304 Lehua Lane	141 Liliwai Street	152 Liliwai Street		162 Liliwai Street	251 Lilia Street	1024 Makalika Loop	1026 Makalika Loop
		Field Sample ID:	220121-D3-HT05	220121-D3-CT04	220121-D3-HT01	220121-D3-HT02	220121-D3-FT03	220121-D3-IT03	220121-D3-HT04	220122-D3-DT04
		Sample Date:	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-21	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-MAKA1034	D3-MELI0211	D3-MELI0212	D3-MELI0214	D3-MELI0223	D3-MELI0242	D3-MELI0307	D3-MELI0348
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		1034 Makalika Loop	211 Melia Street	212 Melia Street	214 Melia Street	223 Melia Street	242 Melia Street	307 Melia Street	348 Melia Street
		Field Sample ID:		220121-D3-ET05	220121-D3-ET04	220121-D3-JT05	220122-D3-KT01	220121-D3-KT04	220121-D3-FT05	220121-D3-FT04	220122-D3-AT05
		Sample Date:		2022-01-21	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	1860	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.450	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.00	2.00	2.10	1.80	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	0.0600	0.0590	ND
	Chromium	100	MCL	1.60	1.60	1.50	1.70	1.40	0.650	0.650	1.70
	Copper	1300	MCL	7.00	8.80	8.70	14.0	8.30	7.40	6.80	8.70
	Lead	15	MCL	0.450	0.140	0.360	0.270	0.180	ND	0.160	0.270
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	2.00	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	0.0940	0.0740	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D3-MAKA1034	D3-MELI0211	D3-MELI0212	D3-MELI0214	D3-MELI0223	D3-MELI0242	D3-MELI0307	D3-MELI0348
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1034 Makalika Loop	211 Melia Street	212 Melia Street	214 Melia Street	223 Melia Street	242 Melia Street	307 Melia Street	348 Melia Street
				Field Sample ID:	220121-D3-ET05	220121-D3-ET04	220121-D3-JT05	220122-D3-KT01	220121-D3-KT04	220121-D3-FT05	220121-D3-FT04	220122-D3-AT05
				Sample Date:	2022-01-21	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-NANU0881	D3-NANU0947	D3-NEHE1012		D3-NEHE1034	D3-OHAN0101	D3-OHAN0131	D3-OHAN0141
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		881 Nanu Street	947 Nanu Street	1012 Nehe Street		1034 Nehe Street	101 Ohana Nui Circle	131 Ohana Nui Circle	141 Ohana Nui Circle
		Field Sample ID:		220121-D3-BT05	220121-D3-DT02	220122-D3-HT02	220122-D3-HT03	220122-D3-CT02	220121-D3-JT04	220122-D3-JT05	220122-D3-FT04
		Sample Date:		2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-21	2022-01-22	2022-01-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	0.360	ND	ND
	Barium	2000	MCL	1.90	2.00	2.10	2.00	2.00	2.00	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	0.0670	ND	ND	ND
	Chromium	100	MCL	1.50	1.50	0.520	0.590	0.510	1.70	ND	1.70
	Copper	1300	MCL	6.50	7.70	5.90	5.90	6.20	8.30	8.40	9.40
	Lead	15	MCL	0.170	0.250	ND	ND	ND	0.140	0.380	0.260
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	1.80	ND	ND
	Thallium	2	MCL	ND	ND	0.0920	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	2.70	ND	ND	1.90	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-NANU0881	D3-NANU0947	D3-NEHE1012		D3-NEHE1034	D3-OHAN0101	D3-OHAN0131	D3-OHAN0141
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	881 Nanu Street	947 Nanu Street	1012 Nehe Street		1034 Nehe Street	101 Ohana Nui Circle	131 Ohana Nui Circle	141 Ohana Nui Circle
		Field Sample ID:	220121-D3-BT05	220121-D3-DT02	220122-D3-HT02	220122-D3-HT03	220122-D3-CT02	220121-D3-JT04	220122-D3-JT05	220122-D3-FT04
		Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-22	2022-01-21	2022-01-22	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-OHAN0151	D3-OHAN0153	D3-OHAN0202	D3-OHAN0238	D3-OHAN0302	D3-OHAN0304	D3-OHAN0331	D3-OHAN0352
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	151 Ohana Nui Circle	153 Ohana Nui Circle	202 Ohana Nui Circle	238 Ohana Nui Circle	302 Ohana Nui Circle	304 Ohana Nui Circle	331 Ohana Nui Circle	352 Ohana Nui Circle
		Field Sample ID:	220122-D3-KT02	220121-D3-CT05	220121-D3-LT04	220122-D3-FT03	220121-D3-FT02	220121-D3-FT01	220121-D3-LT03	D3-TW-1362356-22020-N
		Sample Date:	2022-01-22	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.290	ND	ND	0.480	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	0.620	1.60	1.70	1.50	1.30	1.60
	Copper	1300	MCL	6.70	14.0	4.10	5.90	12.0	9.80	4.30
	Lead	15	MCL	0.140	1.50	0.0570	0.110	0.320	0.130	0.0670
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	1.70	ND	ND	ND	1.80
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-OHAN0151	D3-OHAN0153	D3-OHAN0202	D3-OHAN0238	D3-OHAN0302	D3-OHAN0304	D3-OHAN0331	D3-OHAN0352
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	151 Ohana Nui Circle	153 Ohana Nui Circle	202 Ohana Nui Circle	238 Ohana Nui Circle	302 Ohana Nui Circle	304 Ohana Nui Circle	331 Ohana Nui Circle	352 Ohana Nui Circle
		Field Sample ID:	220122-D3-KT02	220121-D3-CT05	220121-D3-LT04	220122-D3-FT03	220121-D3-FT02	220121-D3-FT01	220121-D3-LT03	D3-TW-1362356-22020-N
		Sample Date:	2022-01-22	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-OHAN0354	D3-OHAN0408	D3-OHAN0411	D3-OHAN0432	D3-OHAN0451	D3-OHAN0513	D3-OHAN0531	D3-OHAN0561
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		354 Ohana Nui Circle	408 Ohana Nui Circle	411 Ohana Nui Circle	432 Ohana Nui Circle	451 Ohana Nui Circle	513 Ohana Nui Circle	531 Ohana Nui Circle	561 Ohana Nui Circle
		Field Sample ID:		220122-D3-HT05	220122-D3-HT06	220122-D3-DT03	220122-D3-GT01	220122-D3-JT01	220122-D3-IT05	220122-D3-CT05	220122-D3-CT03
		Sample Date:		2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	1560	ND	ND	2350 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	1.80	0.670	1.80	ND	0.540
	Copper	1300	MCL	12.0	6.80	6.20	9.10	7.80	6.50	7.40	5.60
	Lead	15	MCL	0.160	ND	0.130	0.190	0.130	0.230	ND	0.200
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	1.70	ND	1.60	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	2.40	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-OHAN0354	D3-OHAN0408	D3-OHAN0411	D3-OHAN0432	D3-OHAN0451	D3-OHAN0513	D3-OHAN0531	D3-OHAN0561
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	354 Ohana Nui Circle	408 Ohana Nui Circle	411 Ohana Nui Circle	432 Ohana Nui Circle	451 Ohana Nui Circle	513 Ohana Nui Circle	531 Ohana Nui Circle	561 Ohana Nui Circle
		Field Sample ID:	220122-D3-HT05	220122-D3-HT06	220122-D3-DT03	220122-D3-GT01	220122-D3-JT01	220122-D3-IT05	220122-D3-CT05	220122-D3-CT03
		Sample Date:	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D3-OHAN0561	D3-OHAN0731	D3-OHAN0754	D3-OHAN0775	D3-OHAN0783	D3-OHAN0794	D3-OHAN0826	D3-OHAN0851
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	561 Ohana Nui Circle	731 Ohana Nui Circle	754 Ohana Nui Circle	775 Ohana Nui Circle	783 Ohana Nui Circle	794 Ohana Nui Circle	826 Ohana Nui Circle	851 Ohana Nui Circle
				Field Sample ID:	220122-D3-CT04	220122-D3-IT03	220122-D3-ET02	220122-D3-AT02	220122-D3-CT01	220122-D3-BT05	220122-D3-BT04	220122-D3-BT01
				Sample Date:	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	1560	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.20	2.20	2.10	2.20	1.90	2.00	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.570	1.60	1.80	1.80	0.540	ND	ND	0.550	
	Copper	1300	MCL	5.60	5.40	6.10	9.20	4.60	6.80	13.0	5.40	
	Lead	15	MCL	0.190	0.140	0.250	0.200	ND	0.180	0.380	0.280	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	0.160	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	2.40	2.30	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D3-OHAN0561	D3-OHAN0731	D3-OHAN0754	D3-OHAN0775	D3-OHAN0783	D3-OHAN0794	D3-OHAN0826	D3-OHAN0851
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	561 Ohana Nui Circle	731 Ohana Nui Circle	754 Ohana Nui Circle	775 Ohana Nui Circle	783 Ohana Nui Circle	794 Ohana Nui Circle	826 Ohana Nui Circle	851 Ohana Nui Circle
				Field Sample ID:	220122-D3-CT04	220122-D3-IT03	220122-D3-ET02	220122-D3-AT02	220122-D3-CT01	220122-D3-BT05	220122-D3-BT04	220122-D3-BT01
				Sample Date:	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22	2022-01-22
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D3-OHAN0851	D3-OHAN0871		D3-OHAN0907	D3-OHAN0915	D3-OHAN0941	D3-OHAN0944	D3-OHAN0945
		Location Type:		Residence	Residence		Residence	Residence	Residence	Residence	Residence
		Address:		851 Ohana Nui Circle	871 Ohana Nui Circle		907 Ohana Nui Circle	915 Ohana Nui Circle	941 Ohana Nui Circle	944 Ohana Nui Circle	945 Ohana Nui Circle
		Field Sample ID:		220122-D3-BT02	220122-D3-DT01	220122-D3-DT02	220121-D3-KT01	220121-D3-CT03	220121-D3-CT02	220122-D3-BT06	220121-D3-BT01
		Sample Date:		2022-01-22	2022-01-22	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-22	2022-01-21
		Sample Type:		FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	94.0	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	94.0	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	2.00	2.00	2.20	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	0.570	1.40	1.50	1.40	ND	1.40
	Copper	1300	MCL	5.70	7.00	6.90	7.80	6.20	8.50	24.0	6.50
	Lead	15	MCL	0.170	0.170	0.150	0.250	0.160	0.520	0.950	0.330
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	0.110	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	2.00	ND	ND	ND	ND	2.30	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D3-OHAN0851		D3-OHAN0871		D3-OHAN0907	D3-OHAN0915	D3-OHAN0941	D3-OHAN0944	D3-OHAN0945
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence	Residence
				Address:	851 Ohana Nui Circle		871 Ohana Nui Circle		907 Ohana Nui Circle	915 Ohana Nui Circle	941 Ohana Nui Circle	944 Ohana Nui Circle	945 Ohana Nui Circle
				Field Sample ID:	220122-D3-BT02		220122-D3-DT01	220122-D3-DT02	220121-D3-KT01	220121-D3-CT03	220121-D3-CT02	220122-D3-BT06	220121-D3-BT01
				Sample Date:	2022-01-22		2022-01-22	2022-01-22	2022-01-21	2022-01-21	2022-01-21	2022-01-22	2022-01-21
				Sample Type:	FD (Field Duplicate)		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-OHAN0945	D3-OHAN0971	D3-OHAN0981	D3-OHAN1006	D3-OHAN1021	D3-OHAN1025	D3-OHAN1041	D3-OHAN1061
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	945 Ohana Nui Circle	971 Ohana Nui Circle	981 Ohana Nui Circle	1006 Ohana Nui Circle	1021 Ohana Nui Circle	1025 Ohana Nui Circle	1041 Ohana Nui Circle	1061 Ohana Nui Circle
		Field Sample ID:	220121-D3-BT02	220121-D3-LT05	220122-D3-HT04	220121-D3-AT01	220122-D3-IT04	220121-D3-KT02	220122-D3-LT01	220121-D3-LT01
		Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-21
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	1780	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	0.300	ND	ND	ND	ND	0.360
	Barium	2000	MCL	1.90	2.00	1.80	2.00	2.20	2.30	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.60	0.510	1.50	1.80	1.40	1.60
	Copper	1300	MCL	6.70	4.70	6.50	4.70	9.20	11.0	4.30
	Lead	15	MCL	0.350	0.0640	ND	0.140	0.330	0.200	0.210
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	0.0940
	Selenium	50	MCL	ND	1.70	ND	ND	ND	ND	1.60
	Thallium	2	MCL	ND	ND	ND	ND	0.170	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D3-OHAN0945	D3-OHAN0971	D3-OHAN0981	D3-OHAN1006	D3-OHAN1021	D3-OHAN1025	D3-OHAN1041	D3-OHAN1061
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	945 Ohana Nui Circle	971 Ohana Nui Circle	981 Ohana Nui Circle	1006 Ohana Nui Circle	1021 Ohana Nui Circle	1025 Ohana Nui Circle	1041 Ohana Nui Circle	1061 Ohana Nui Circle
				Field Sample ID:	220121-D3-BT02	220121-D3-LT05	220122-D3-HT04	220121-D3-AT01	220122-D3-IT04	220121-D3-KT02	220122-D3-LT01	220121-D3-LT01
				Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-21
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-OHAN1061	D3-OHAN1068	D3-PAKA0401		D3-PILO0161	D3-PUAK0278	D3-PUAK1002	D3-PUAK1007
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	1061 Ohana Nui Circle	1068 Ohana Nui Circle	401 Pakalana Street		161 Pilokea Court	278 Puakauhi Court	1002 Puakala Street	1007 Puakala Street
				Field Sample ID:	220121-D3-LT02	220121-D3-IT04	220122-D3-IT01	220122-D3-IT02	220121-D3-HT03	220122-D3-FT02	220122-D3-DT06	220122-D3-FT01
				Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-21	2022-01-22	2022-01-22	2022-01-22
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	1550
	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.400	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	1.90	1.90	1.90	2.00	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.60	1.60	1.60	1.40	1.70	ND	1.70	1.70
	Copper	1300	MCL	9.50	7.60	8.70	7.70	25.0	45.0	7.50	11.0	11.0
	Lead	15	MCL	0.310	0.130	0.140	0.110	ND	0.260	ND	0.520	0.520
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.60	ND	ND	ND	ND	1.60	ND	1.60	1.60
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-OHAN1061	D3-OHAN1068	D3-PAKA0401		D3-PILO0161	D3-PUAK0278	D3-PUAK1002	D3-PUAK1007
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	1061 Ohana Nui Circle	1068 Ohana Nui Circle	401 Pakalana Street		161 Pilokea Court	278 Puakauhi Court	1002 Puakala Street	1007 Puakala Street
		Field Sample ID:	220121-D3-LT02	220121-D3-IT04	220122-D3-IT01	220122-D3-IT02	220121-D3-HT03	220122-D3-FT02	220122-D3-DT06	220122-D3-FT01
		Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-22	2022-01-21	2022-01-22	2022-01-22	2022-01-22
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-PUAP0202	D3-PUAP0205	D3-PUAP0209	D3-PUAP0225	D3-PUUL0106	D3-PUUL0114	D3-PUUL0118	D3-WELA0254
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	202 Puapilo Court	205 Puapilo Court	209 Puapilo Court	225 Puapilo Court	106 Puuloa Circle	114 Puuloa Circle	118 Puuloa Circle	254 Wela Loop
		Field Sample ID:	220121-D3-GT03	220121-D3-IT05	220122-D3-HT01	220121-D3-DT01	220122-D3-ET06	220122-D3-LT04	220121-D3-GT04	220122-D3-ET05
		Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-22	2022-01-21	2022-01-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	1.90	1.90	1.90	2.20	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.60	0.610	1.40	1.70	1.60	1.50
	Copper	1300	MCL	67.0	35.0	29.0	42.0	33.0	56.0	72.0
	Lead	15	MCL	0.260	ND	0.270	ND	0.140	0.140	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	0.0910	0.0700	ND	0.170	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	2.20	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D3-PUAP0202	D3-PUAP0205	D3-PUAP0209	D3-PUAP0225	D3-PUUL0106	D3-PUUL0114	D3-PUUL0118	D3-WELA0254
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	202 Puapilo Court	205 Puapilo Court	209 Puapilo Court	225 Puapilo Court	106 Puuloa Circle	114 Puuloa Circle	118 Puuloa Circle	254 Wela Loop
				Field Sample ID:	220121-D3-GT03	220121-D3-IT05	220122-D3-HT01	220121-D3-DT01	220122-D3-ET06	220122-D3-LT04	220121-D3-GT04	220122-D3-ET05
				Sample Date:	2022-01-21	2022-01-21	2022-01-22	2022-01-21	2022-01-22	2022-01-22	2022-01-21	2022-01-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-WELA0271		D3-WELA0281	
		Location Type:	Residence		Residence	
		Address:	271 Wela Loop		281 Wela Loop	
		Field Sample ID:	220121-D3-GT01	220121-D3-GT02	220121-D3-IT01	220121-D3-IT02
		Sample Date:	2022-01-21	2022-01-21	2022-01-21	2022-01-21
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2100 §	2440 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND
	Barium	2000	MCL	2.00	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND
	Chromium	100	MCL	1.30	1.50	1.30
	Copper	1300	MCL	6.60	5.70	9.10
	Lead	15	MCL	ND	ND	0.220
	Mercury	2	MCL	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND

Summary of Chemistry Results
Zone D3 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone D3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D3-WELA0271		D3-WELA0281	
		Location Type:	Residence		Residence	
		Address:	271 Wela Loop		281 Wela Loop	
		Field Sample ID:	220121-D3-GT01	220121-D3-GT02	220121-D3-IT01	220121-D3-IT02
		Sample Date:	2022-01-21	2022-01-21	2022-01-21	2022-01-21
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND