

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-ANDE2826	F2-ANDE2848	F2-ANDE2888		F2-ANDE2944	F2-ANDE2978	F2-ANDE3004	
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	
				Address:	2826 Anderson Avenue	2848 Anderson Avenue	2888 Anderson Avenue		2944 Anderson Avenue	2978 Anderson Avenue	3004 Anderson Avenue	
				Field Sample ID:	F2-TW-135165-22023-N	F2-TW-135173-22023-N	F2-TW-136011-22023-3-N	F2-TW-136011-22023-N	220123-F2-KT06	F2-TW-1304118-22023-N	F2-TW-1304154-22023-3-N	F2-TW-1304154-22023-N
				Sample Date:	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-23	2022-01-24	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5580 §	4060 §	ND	ND	ND	ND	--	4730 §	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	96.0	ND	ND	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	--	ND	
	Petroleum Hydrocarbons, Total	211	ISP	96.0	ND	ND	ND	ND	ND	--	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Barium	2000	MCL	2.40	2.30	2.30	2.30	2.10	2.20	2.10	--	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Chromium	100	MCL	1.50	1.50	1.10	1.70	1.80	1.80	1.40	--	
	Copper	1300	MCL	35.9	29.6	9.70	9.00	10.7	12.0	5.40	--	
	Lead	15	MCL	1.70	2.20	0.260	0.240	0.300	0.170	0.480	--	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Selenium	50	MCL	ND	ND	ND	ND	ND	1.60	ND	--	
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	--	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	--	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	--	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	--	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	1.40	ND	ND	--	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	--	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	--	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	--	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	--	ND	

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-ANDE2826	F2-ANDE2848	F2-ANDE2888		F2-ANDE2944	F2-ANDE2978	F2-ANDE3004	
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	
				Address:	2826 Anderson Avenue	2848 Anderson Avenue	2888 Anderson Avenue		2944 Anderson Avenue	2978 Anderson Avenue	3004 Anderson Avenue	
				Field Sample ID:	F2-TW-135165-22023-N	F2-TW-135173-22023-N	F2-TW-136011-22023-3-N	F2-TW-136011-22023-N	220123-F2-KT06	F2-TW-1304118-22023-N	F2-TW-1304154-22023-3-N	F2-TW-1304154-22023-N
				Sample Date:	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-23	2022-01-24	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	--	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	--	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-ANDE3016	F2-ANDE3052		F2-ARIZ2791	F2-ARIZ2793	F2-ARIZ2907	F2-ARIZ2909	
		Location Type:		Residence	Residence		Residence	Residence	Residence	Residence	
		Address:		3016 Anderson Avenue	3052 Anderson Avenue		2791 Arizona Road	2793 Arizona Road	2907 Arizona Road	2909 Arizona Road	
		Field Sample ID:		F2-TW-1304166-22023-N	220123-F2-CT06	220123-F2-CT07	F2-TW-549209-22023-N	F2-TW-2201011-22023-N	F2-TW-1304288-22023-N	F2-TW-22102403-22023-3-N	F2-TW-22102403-22023-N
		Sample Date:		2022-01-25	2022-01-23	2022-01-23	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-24
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5290 §	8530 §	8740 §	ND	ND	4060 §	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	2.10	2.30	2.50	2.40	2.20	1.90	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.80	1.80	1.60	1.70	1.50	0.990	1.10
	Copper	1300	MCL	5.50	4.20	2.70	8.20	4.00	10.0	4.20	6.20
	Lead	15	MCL	ND	0.240	0.490	0.240	0.180	0.550	0.260	0.400
	Mercury	2	MCL	ND	ND	ND	ND	0.0670	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-ANDE3016		F2-ANDE3052		F2-ARIZ2791		F2-ARIZ2793		F2-ARIZ2907		F2-ARIZ2909	
				Location Type:	Residence		Residence		Residence		Residence		Residence		Residence	
				Address:	3016 Anderson Avenue		3052 Anderson Avenue		2791 Arizona Road		2793 Arizona Road		2907 Arizona Road		2909 Arizona Road	
				Field Sample ID:	F2-TW-1304166-22023-N		220123-F2-CT06      220123-F2-CT07		F2-TW-549209-22023-N		F2-TW-2201011-22023-N		F2-TW-1304288-22023-N		F2-TW-22102403-22023-3-N      F2-TW-22102403-22023-N	
				Sample Date:	2022-01-25		2022-01-23      2022-01-23		2022-01-24		2022-01-24		2022-01-24		2022-01-24      2022-01-24	
				Sample Type:	N (Normal)		N (Normal)      N (Normal)		N (Normal)		N (Normal)		N (Normal)		FD (Field Duplicate)      N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level													
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ARIZ2913	F2-ARIZ3004	F2-ARIZ3085	F2-BENF5419	F2-BENF5437			F2-BLDG1928	
		Location Type:	Residence	Residence	Residence	Residence	Residence			Child Development Center	
		Address:	2913 Arizona Road	3004 Arizona Road	3085 Arizona Road	5419 Benfold Lane	5437 Benfold Lane			Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)	
		Field Sample ID:	F2-TW-1303054-22023-N	F2-TW-22102404-22023-N	220123-F2-LT08	220123-F2-FT06	220123-F2-ET06	F2-TW-1303914-22023-3-N	F2-TW-1303914-22023-N	220123-F2-JT01	
		Sample Date:	2022-01-24	2022-01-24	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-23	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (72 Hour Stagnation)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5060 §	ND	8740 §	4570 §	2180 §	570	540	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	190	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	190	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	--	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	--	ND	ND	ND	ND	0.510
	Barium	2000	MCL	2.20	2.10	--	2.10	2.50	2.10	2.20	2.70
	Beryllium	4	MCL	ND	ND	--	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	--	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.10	--	1.30	1.20	1.40	1.70	2.10
	Copper	1300	MCL	4.60	5.20	--	16.8	135	25.1	27.4	50.9
	Lead	15	MCL	0.220	0.180	--	0.340	0.740	0.360	1.40	ND
	Mercury	2	MCL	ND	ND	--	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	--	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	--	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	--	--	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	--	--	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	--	--	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	--	--	ND	ND	ND	0.970
	Naphthalene	17	EAL	ND	ND	--	--	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-ARIZ2913	F2-ARIZ3004	F2-ARIZ3085	F2-BENF5419	F2-BENF5437			F2-BLDG1928
				Location Type:	Residence	Residence	Residence	Residence	Residence			Child Development Center
				Address:	2913 Arizona Road	3004 Arizona Road	3085 Arizona Road	5419 Benfold Lane	5437 Benfold Lane			Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)
				Field Sample ID:	F2-TW-1303054-22023-N	F2-TW-22102404-22023-N	220123-F2-LT08	220123-F2-FT06	220123-F2-ET06	F2-TW-1303914-22023-3-N	F2-TW-1303914-22023-N	220123-F2-JT01
				Sample Date:	2022-01-24	2022-01-24	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>												
ND = Not Detected												
ISP = Incident Specific Parameter												
EAL = DOH Environmental Action Level												
EPA MCL = EPA Maximum Contaminant Level												
All Results shown in Parts per Billion (ppb)												
§ - Exceeds Screening Level												
-- = No Information Available												
N (Normal) = Full compliance sample												
FD (Field Duplicate) = Extra sample taken for quality control												
N (Grab, Resample) = Additional follow-up sample												
				<b>Location ID:</b>	F2-ARIZ2913	F2-ARIZ3004	F2-ARIZ3085	F2-BENF5419	F2-BENF5437			F2-BLDG1928
				<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence			Child Development Center
				<b>Address:</b>	2913 Arizona Road	3004 Arizona Road	3085 Arizona Road	5419 Benfold Lane	5437 Benfold Lane			Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)
				<b>Field Sample ID:</b>	F2-TW-1303054-22023-N	F2-TW-22102404-22023-N	220123-F2-LT08	220123-F2-FT06	220123-F2-ET06	F2-TW-1303914-22023-3-N	F2-TW-1303914-22023-N	220123-F2-JT01
				<b>Sample Date:</b>	2022-01-24	2022-01-24	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-23
				<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (72 Hour Stagnation)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>									
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-BLDG1928	F2-BLDG3349				F2-BLDG4655		F2-BLDG606-POO	F2-BLDG6890
		Location Type:	Child Development Center	Non-Residence				Child Development Center		Non-Residence	Non-Residence
		Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)	Building 3349,LEARNING SERVICE CENTER (3349 Catlin Drive)				Building 4655,CATLIN SCHOOL AGE CENTER		Building 606-POO,COMMUNITY CENTER POOL Street	Building 6890,NEX MINI-MART HALSEY
		Field Sample ID:	220123-F2-KT01	220129F2CT03	F2-TW-0014155-22055-N	F2-TW-0014155-22055-N-R1		220123-F2-JT04	220123-F2-KT05	220129F2CT02	220126F2AT04
		Sample Date:	2022-01-23	2022-01-29	2022-02-24	2022-02-25		2022-01-23	2022-01-23	2022-01-29	2022-01-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	2190 §	--	--	ND	ND	1750	520
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	--	--	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	--	--	ND	0.190	ND	ND
	Arsenic	10	MCL	ND	ND	--	--	ND	ND	ND	ND
	Barium	2000	MCL	2.70	2.00	--	--	2.40	2.60	1.90	3.40
	Beryllium	4	MCL	ND	ND	--	--	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Chromium	100	MCL	2.00	1.50	--	--	2.10	1.60	1.40	1.30
	Copper	1300	MCL	260	74.0	--	--	199	123	4.30	33.3
	Lead	15	MCL	ND	0.700	--	--	0.280	0.400	0.390	0.340
	Mercury	2	MCL	ND	ND	--	--	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	--	--	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	--	--	ND	0.110	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	23.8 §	ND	ND	1.40	1.20	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	--	--	ND	ND	ND	ND



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-BLDG1928	F2-BLDG3349				F2-BLDG4655		F2-BLDG606-POO	F2-BLDG6890
		Location Type:	Child Development Center	Non-Residence				Child Development Center		Non-Residence	Non-Residence
		Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)	Building 3349,LEARNING SERVICE CENTER (3349 Catlin Drive)				Building 4655,CATLIN SCHOOL AGE CENTER		Building 606-POO,COMMUNITY CENTER POOL Street	Building 6890,NEX MINI-MART HALSEY
		Field Sample ID:	220123-F2-KT01	220129F2CT03	F2-TW-0014155-22055-N	F2-TW-0014155-22055-N-R1		220123-F2-JT04	220123-F2-KT05	220129F2CT02	220126F2AT04
		Sample Date:	2022-01-23	2022-01-29	2022-02-24	2022-02-25		2022-01-23	2022-01-23	2022-01-29	2022-01-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	--	--	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	--	--	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	--	--	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	--	--	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	--	--	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	--	--	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	--	--	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	--	--	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	--	--	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	--	--	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-BLDG1928	F2-BLDG3349				F2-BLDG4655		F2-BLDG606-POO	F2-BLDG6890
		Location Type:	Child Development Center	Non-Residence				Child Development Center		Non-Residence	Non-Residence
		Address:	Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)	Building 3349,LEARNING SERVICE CENTER (3349 Catlin Drive)				Building 4655,CATLIN SCHOOL AGE CENTER		Building 606-POO,COMMUNITY CENTER POOL Street	Building 6890,NEX MINI-MART HALSEY
		Field Sample ID:	220123-F2-KT01	220129F2CT03	F2-TW-0014155-22055-N	F2-TW-0014155-22055-N-R1		220123-F2-JT04	220123-F2-KT05	220129F2CT02	220126F2AT04
		Sample Date:	2022-01-23	2022-01-29	2022-02-24	2022-02-25		2022-01-23	2022-01-23	2022-01-29	2022-01-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	Xylenes, Total	10000	MCL	ND	ND	--	--	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-BLDG6890	F2-BLDG7751			F2-BRID3073	F2-BRID3077		F2-CATL5228
		Location Type:		Non-Residence	Non-Residence			Residence	Residence		Residence
		Address:		Building 6890,NEX MINI-MART HALSEY	Building 7751 , Radford Terrace Country Club (811 Murray Drive)			3073 Bridges Street	3077 Bridges Street		5228 Catlin Lane
		Field Sample ID:		220126F2AT05	220129F2CT01	F2-TW-0014158-22055-N	F2-TW-0014158-22055-N-R1	F2-TW-1304165-22023-N	F2-TW-1304142-22023-3-N	F2-TW-1304142-22023-N	220123-F2-GT06
		Sample Date:		2022-01-26	2022-01-29	2022-02-24	2022-02-25	2022-01-24	2022-01-24	2022-01-24	2022-01-23
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	510	ND	--	--	7070 §	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	--	--	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	--	--	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	--	--	ND	ND	ND	ND
	Barium	2000	MCL	3.50	2.60	--	--	2.30	2.00	2.20	2.20
	Beryllium	4	MCL	ND	ND	--	--	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.50	--	--	1.60	0.890	0.950	2.10
	Copper	1300	MCL	33.4	4.30	--	--	28.1	4.60	4.80	17.7
	Lead	15	MCL	0.570	0.200	--	--	0.520	0.130	0.130	0.560
	Mercury	2	MCL	ND	ND	--	--	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	--	--	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	--	--	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	18.3 §	ND	ND	ND	ND	ND	0.910
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	--	--	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	--	--	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	--	--	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-BLDG6890		F2-BLDG7751		F2-BRID3073		F2-BRID3077		F2-CATL5228	
				Location Type:	Non-Residence		Non-Residence		Residence		Residence		Residence	
				Address:	Building 6890,NEX MINI-MART HALSEY		Building 7751, Radford Terrace Country Club (811 Murray Drive)		3073 Bridges Street		3077 Bridges Street		5228 Catlin Lane	
				Field Sample ID:	220126F2AT05		220129F2CT01		F2-TW-0014158-22055-N		F2-TW-0014158-22055-N-R1		220123-F2-GT06	
				Sample Date:	2022-01-26		2022-01-29		2022-02-24		2022-02-25		2022-01-23	
				Sample Type:	FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)	
											</			

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-CATL5260	F2-CATL5280	F2-CATL5300	F2-CATL5318	F2-COLE4109	F2-CURT3001	F2-DALY3049	F2-DEWE3209
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5260 Catlin Lane	5280 Catlin Lane	5300 Catlin Lane	5318 Catlin Lane	4109 Colegrove Street	3001 Curtis Drive	3049 Daly Drive	3209 Dewert Lane
		Field Sample ID:	220123-F2-GT09	220123-F2-FT03	220123-F2-GT10	220123-F2-HT05	F2-TW-1303352-22023-N	F2-TW-22102405-22023-N	F2-TW-133157-22023-N	220123-F2-LT04
		Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-24	2022-01-24	2022-01-24	2022-01-23
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	7880 §	ND	ND	5210 §	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	0.600
	Barium	2000	MCL	2.20	2.10	2.00	2.20	2.50	2.60	3.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	0.180
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.30	1.30	2.10	1.40	1.50	1.20	1.80
	Copper	1300	MCL	11.8	11.3	5.60	47.4	18.3	26.4	197
	Lead	15	MCL	0.310	0.370	0.200	0.410	0.870	0.160	0.950
	Mercury	2	MCL	ND	ND	ND	ND	0.120	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.120
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	1.40	ND	ND	ND	1.50
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-CATL5260	F2-CATL5280	F2-CATL5300	F2-CATL5318	F2-COLE4109	F2-CURT3001	F2-DALY3049	F2-DEWE3209
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5260 Catlin Lane	5280 Catlin Lane	5300 Catlin Lane	5318 Catlin Lane	4109 Colegrove Street	3001 Curtis Drive	3049 Daly Drive	3209 Dewert Lane
		Field Sample ID:	220123-F2-GT09	220123-F2-FT03	220123-F2-GT10	220123-F2-HT05	F2-TW-1303352-22023-N	F2-TW-22102405-22023-N	F2-TW-133157-22023-N	220123-F2-LT04
		Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-24	2022-01-24	2022-01-24	2022-01-23
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-DEWE3234	F2-DORI2267C		F2-DORI2269A	F2-DORI2274C		F2-ENGE4062	F2-ENGE4076
				Location Type:	Residence	Residence		Residence	Residence		Residence	Residence
				Address:	3234 Dewert Lane	2267C Doris Miller Loop		2269A Doris Miller Loop	2274C Doris Miller Loop		4062 Enger Street	4076 Enger Street
				Field Sample ID:	220123-F2-IT01	220123-F2-LT01	220123-F2-LT02	220123-F2-AT04	F2-TW-2201050-22023-3-N	F2-TW-2201050-22023-N	F2-TW-1303371-22023-N	F2-TW-22102406-22023-N
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND		6960 §	1640	1730	4760 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND		ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.40	2.40		2.40	2.50	2.40	2.40	2.30
	Beryllium	4	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Chromium	100	MCL	1.90	1.90	2.10		1.80	1.80	1.80	1.70	1.30
	Copper	1300	MCL	12.3	104	109		39.0	45.0	56.0	13.5	6.90
	Lead	15	MCL	0.370	0.130	0.130		0.170	0.160	0.500	0.500	ND
	Mercury	2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND		ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND		ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	1.30	1.00	1.00		ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND		ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND		ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND		ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND		ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-DORI2267C		F2-DORI2269A	F2-DORI2274C		F2-ENGE4062	F2-ENGE4076		
				Location Type:	Residence		Residence	Residence		Residence	Residence		
				Address:	3234 Dewert Lane		2267C Doris Miller Loop		2269A Doris Miller Loop	2274C Doris Miller Loop		4062 Enger Street	4076 Enger Street
				Field Sample ID:	220123-F2-IT01	220123-F2-LT01	220123-F2-LT02	220123-F2-AT04	F2-TW-2201050-22023-3-N	F2-TW-2201050-22023-N	F2-TW-1303371-22023-N	F2-TW-22102406-22023-N	
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-24	2022-01-24	
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND		



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-FINC4141		F2-FINC4175		F2-GILL3177		F2-GILL3223	F2-GILL3231	F2-GILL3239
		Location Type:		Residence		Residence		Residence		Residence	Residence	Residence
		Address:		4141 Fincher Street		4175 Fincher Street		3177 Gillespie Lane		3223 Gillespie Lane	3231 Gillespie Lane	3239 Gillespie Lane
		Field Sample ID:		F2-TW-22102407-22023-N		F2-TW-1303434-22023-3-N		220123-F2-GT07		220123-F2-HT01	220123-F2-LT07	220123-F2-BT01
		Sample Date:		2022-01-24		2022-01-25		2022-01-23		2022-01-23	2022-01-23	2022-01-23
		Sample Type:		N (Normal)		FD (Field Duplicate)		N (Normal)		N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	4280 §	5520 §	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	0.630	ND
	Barium	2000	MCL	2.30	2.20	2.30	2.20	2.10	2.00	2.10	2.10	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.50	1.60	2.10	2.10	1.90	2.20	2.20	1.40
	Copper	1300	MCL	7.10	7.00	6.40	14.8	14.2	12.0	19.3	19.3	29.1
	Lead	15	MCL	0.210	0.340	0.320	0.370	0.350	2.80	0.320	0.320	0.680
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	1.20	ND	1.70	1.70	0.430
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-FINC4141	F2-FINC4175		F2-GILL3177		F2-GILL3223	F2-GILL3231	F2-GILL3239
				Location Type:	Residence	Residence		Residence		Residence	Residence	Residence
				Address:	4141 Fincher Street	4175 Fincher Street		3177 Gillespie Lane		3223 Gillespie Lane	3231 Gillespie Lane	3239 Gillespie Lane
				Field Sample ID:	F2-TW-22102407-22023-N	F2-TW-1303434-22023-3-N	F2-TW-1303434-22023-N	220123-F2-GT07	220123-F2-GT08	220123-F2-HT01	220123-F2-LT07	220123-F2-BT01
				Sample Date:	2022-01-24	2022-01-25	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-GORD2644	F2-GORD2645	F2-GORD2648	F2-GORD2667	F2-GORD2691	F2-GORD2720	F2-GORD2741	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
				Address:	2644 Gordon Street	2645 Gordon Street	2648 Gordon Street	2667 Gordon Street	2691 Gordon Street	2720 Gordon Street	2741 Gordon Street	
				Field Sample ID:	F2-TW-1304354-22023-N	F2-TW-135782-22023-N	F2-TW-1304323-22023-N	F2-TW-1304327-22023-N	F2-TW-1303642-22023-N	F2-TW-1304262-22023-N	F2-TW-1303639-22023-3-N	F2-TW-1303639-22023-N
				Sample Date:	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-25	2022-01-24	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	5430 §	6230 §	4310 §	4290 §	5170 §	4720 §	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.50	2.30	2.40	2.60	2.60	2.60	2.50	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.00	1.10	1.50	1.40	1.60	1.50	1.50	1.50	1.50
	Copper	1300	MCL	6.00	8.50	23.5	9.70	4.20	6.30	8.30	16.6	
	Lead	15	MCL	0.200	0.180	0.970	0.610	0.350	ND	0.240	0.240	
	Mercury	2	MCL	ND	ND	ND	ND	ND	0.0900	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	0.110	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-GORD2644	F2-GORD2645	F2-GORD2648	F2-GORD2667	F2-GORD2691	F2-GORD2720	F2-GORD2741	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2644 Gordon Street	2645 Gordon Street	2648 Gordon Street	2667 Gordon Street	2691 Gordon Street	2720 Gordon Street	2741 Gordon Street	
		Field Sample ID:	F2-TW-1304354-22023-N	F2-TW-135782-22023-N	F2-TW-1304323-22023-N	F2-TW-1304327-22023-N	F2-TW-1303642-22023-N	F2-TW-1304262-22023-N	F2-TW-1303639-22023-3-N	F2-TW-1303639-22023-N
		Sample Date:	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-25	2022-01-24	2022-01-24	2022-01-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-GORD2775	F2-GORD2784		F2-GORD2838	F2-GORD2856	F2-HAIL3086	F2-HAIL3110	
		Location Type:		Residence	Residence		Residence	Residence	Residence	Residence	
		Address:		2775 Gordon Street	2784 Gordon Street		2838 Gordon Street	2856 Gordon Street	3086 Hailey Court	3110 Hailey Court	
		Field Sample ID:		F2-TW-1303578-22023-N	F2-TW-1304219-22023-3-N	F2-TW-1304219-22023-N	F2-TW-1304288(a)-22023-N	220123-F2-CT03	220123-F2-AT01	220123-F2-AT02	220123-F2-AT03
		Sample Date:		2022-01-24	2022-01-24	2022-01-24	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-23
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	4850 §	1670	ND	4300 §	9200 §	7250 §	7800 §	9790 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	--	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.80	2.70	2.70	2.30	2.30	2.40	2.40	2.40
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.50	1.40	1.50	1.80	1.80	1.90	1.80
	Copper	1300	MCL	5.80	21.9	21.9	8.50	14.0	44.0	27.0	34.0
	Lead	15	MCL	ND	0.530	0.510	0.390	0.540	0.260	0.140	0.140
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-GORD2775		F2-GORD2784		F2-GORD2838	F2-GORD2856	F2-HAIL3086	F2-HAIL3110	
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence	
				Address:	2775 Gordon Street		2784 Gordon Street		2838 Gordon Street	2856 Gordon Street	3086 Hailey Court	3110 Hailey Court	
				Field Sample ID:	F2-TW-1303578-22023-N	F2-TW-1304219-22023-3-N	F2-TW-1304219-22023-N	F2-TW-1304288(a)-22023-N	220123-F2-CT03	220123-F2-AT01	220123-F2-AT02	220123-F2-AT03	
				Sample Date:	2022-01-24	2022-01-24	2022-01-24	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-23	
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-HAMM0812	F2-HAMM5301	F2-HAMP4130	F2-HAMP4138		F2-HAYS0814	F2-HYD0002	
				Location Type:	Residence	Residence	Residence	Residence		Residence	Hydrant	
				Address:	812 Hammerberg Street	5301 Hammond Lane	4130 Hampton Street	4138 Hampton Street		814 Hays Street	FH 2	
				Field Sample ID:	F2-TW-22102408-22023-N	220123-F2-HT02	F2-TW-1303826-22023-N	220123-F2-FT01	220123-F2-FT02	F2-TW-1303482-22023-N	220116-F2-ZT06	220118-F2-XT06
				Sample Date:	2022-01-24	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-24	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	5440 §	11200 §	5500 §	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	0.207	0.320
	Barium	2000	MCL	2.50	2.10	2.30	2.20	2.10	2.40	2.93	2.93	3.08
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.20	1.80	1.50	1.40	1.30	1.80	1.49	1.49	1.44
	Copper	1300	MCL	13.8	9.60	7.70	4.30	4.30	5.50	1.91	1.91	1.21
	Lead	15	MCL	0.700	0.270	0.510	ND	ND	0.190	0.202	0.202	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	2.00	ND	ND	ND	1.60	0.924	0.924	1.57
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	--	--	--	--	--	--	--	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	0.00986
	Alachlor	--	--	--	--	--	--	--	--	--	ND	ND
	Atrazine	--	--	--	--	--	--	--	--	--	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	--	--	--	--	--	--	--	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-HAMM0812	F2-HAMM5301	F2-HAMP4130	F2-HAMP4138		F2-HAYS0814	F2-HYD0002	
				Location Type:	Residence	Residence	Residence	Residence		Residence	Hydrant	
				Address:	812 Hammerberg Street	5301 Hammond Lane	4130 Hampton Street	4138 Hampton Street		814 Hays Street	FH 2	
				Field Sample ID:	F2-TW-22102408-22023-N	220123-F2-HT02	F2-TW-1303826-22023-N	220123-F2-FT01	220123-F2-FT02	F2-TW-1303482-22023-N	220116-F2-ZT06	220118-F2-XT06
				Sample Date:	2022-01-24	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-24	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Endrin	--	--	--	--	--	--	--	--	--	ND	ND
	gamma-BHC (Lindane)	--	--	--	--	--	--	--	--	--	ND	ND
	Heptachlor	--	--	--	--	--	--	--	--	--	ND	ND
	Heptachlor epoxide	--	--	--	--	--	--	--	--	--	ND	ND
	Hexachlorobenzene	--	--	--	--	--	--	--	--	--	ND	ND
	Hexachlorocyclopentadiene	--	--	--	--	--	--	--	--	--	ND	ND
	Methoxychlor	--	--	--	--	--	--	--	--	--	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	0.0147
	PCB, Total	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	--	--	--	--	--	--	--	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	--	--	--	--	--	--	--	ND	ND
	Pentachlorophenol	1	MCL	--	--	--	--	--	--	--	ND	ND
	Simazine	--	--	--	--	--	--	--	--	--	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-HAMM0812	F2-HAMM5301	F2-HAMP4130	F2-HAMP4138		F2-HAYS0814	F2-HYD0002	
				Location Type:	Residence	Residence	Residence	Residence		Residence	Hydrant	
				Address:	812 Hammerberg Street	5301 Hammond Lane	4130 Hampton Street	4138 Hampton Street		814 Hays Street	FH 2	
				Field Sample ID:	F2-TW-22102408-22023-N	220123-F2-HT02	F2-TW-1303826-22023-N	220123-F2-FT01	220123-F2-FT02	F2-TW-1303482-22023-N	220116-F2-ZT06	220118-F2-XT06
				Sample Date:	2022-01-24	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-24	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31
		Field Sample ID:	220118-F2-XT07	220116-F2-XT02	220116-F2-XT04	220116-F2-YT07	220116-F2-ZT05	220116-F2-XT01	220116-F2-ZT04	220116-F2-ZT07
		Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	2110 §	2500 §	ND	358	2660 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.377	0.289	0.299	0.214	0.162	0.227	0.247
	Barium	2000	MCL	3.22	2.33	4.69	2.71	2.69	2.31	4.21
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.49	1.63	1.45	1.52	1.52	1.54	1.49
	Copper	1300	MCL	1.26	3.94	1.26	4.64	13.4	3.11	8.97
	Lead	15	MCL	ND	0.434	0.449	0.563	2.04	0.245	0.610
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.77	1.33	1.35	0.564	0.681	0.942	1.01
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Alachlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Atrazine	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	ND	ND	ND	ND	ND	ND	ND
	Endrin	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31
		Field Sample ID:	220118-F2-XT07	220116-F2-XT02	220116-F2-XT04	220116-F2-YT07	220116-F2-ZT05	220116-F2-XT01	220116-F2-ZT04	220116-F2-ZT07
		Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	ND	ND	ND	ND	ND	ND	ND
	Heptachlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Heptachlor epoxide	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	PCB, Total	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	ND	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	ND	ND	ND	ND	ND	ND	ND
	Simazine	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31
		Field Sample ID:	220118-F2-XT07	220116-F2-XT02	220116-F2-XT04	220116-F2-YT07	220116-F2-ZT05	220116-F2-XT01	220116-F2-ZT04	220116-F2-ZT07
		Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16	2022-01-16
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0031	F2-HYD0039	F2-HYD003A	F2-HYD0047		F2-HYD0213	F2-HYD0520	F2-HYD071A
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant		Hydrant	Hydrant	Hydrant
		Address:	FH 31	FH 39	FH 3A	FH 47		FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A
		Field Sample ID:	220118-F2-XT04	220116-F2-VT01	220116-F2-XT03	220116-F2-ZT01	220118-F2-XT05	220116-F2-YT05	220116-F2-YT06	220118-F2-XT08
		Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-16	2022-01-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1670	1570	1710	ND	1680	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	0.0961	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.365	0.226	0.202	0.189	0.321	0.251	0.321
	Barium	2000	MCL	3.16	2.59	2.06	3.18	2.70	2.79	2.74
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.47	1.51	1.44	1.49	1.44	1.59	1.47
	Copper	1300	MCL	6.62	8.16	4.88	12.7	7.17	3.23	7.31
	Lead	15	MCL	0.410	0.102	0.285	1.48	0.630	0.353	0.865
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.56	0.892	0.865	0.786	1.55	1.16	0.760
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Ethylhexyl adipate	--	--	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	0.0102	ND	ND	ND	ND	ND	0.0124
	Alachlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Atrazine	--	--	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlordane	--	--	ND	ND	ND	ND	ND	ND	ND
	Endrin	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0031	F2-HYD0039	F2-HYD003A	F2-HYD0047		F2-HYD0213	F2-HYD0520	F2-HYD071A
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant		Hydrant	Hydrant	Hydrant
		Address:	FH 31	FH 39	FH 3A	FH 47		FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A
		Field Sample ID:	220118-F2-XT04	220116-F2-VT01	220116-F2-XT03	220116-F2-ZT01	220118-F2-XT05	220116-F2-YT05	220116-F2-YT06	220118-F2-XT08
		Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-16	2022-01-18
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Synthetic Organic Compounds (ppb)	gamma-BHC (Lindane)	--	--	ND	ND	ND	ND	ND	ND	ND
	Heptachlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Heptachlor epoxide	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methoxychlor	--	--	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	0.0165	ND	ND	0.0122	ND	ND	0.0177
	PCB, Total	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1016 (Aroclor 1016)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1221 (Aroclor 1221)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1232 (Aroclor 1232)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1242 (Aroclor 1242)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1248 (Aroclor 1248)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1254 (Aroclor 1254)	--	--	ND	ND	ND	ND	ND	ND	ND
	PCB-1260 (Aroclor 1260)	--	--	ND	ND	ND	ND	ND	ND	ND
	Pentachlorophenol	1	MCL	ND	ND	ND	ND	ND	ND	ND
	Simazine	--	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-HYD0031	F2-HYD0039	F2-HYD003A	F2-HYD0047		F2-HYD0213	F2-HYD0520	F2-HYD071A
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant		Hydrant	Hydrant	Hydrant
				Address:	FH 31	FH 39	FH 3A	FH 47		FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A
				Field Sample ID:	220118-F2-XT04	220116-F2-VT01	220116-F2-XT03	220116-F2-ZT01	220118-F2-XT05	220116-F2-YT05	220116-F2-YT06	220118-F2-XT08
				Sample Date:	2022-01-18	2022-01-16	2022-01-16	2022-01-16	2022-01-18	2022-01-16	2022-01-16	2022-01-18
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-HYD1443	F2-JALU0598	F2-JALU0620	F2-JALU3304	F2-JALU3311	F2-JALU3325		F2-KILM3342
				Location Type:	Hydrant	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	FH ID: FH-17	598 Jaluit Street	620 Jaluit Street	3304 Jaluit Lane	3311 Jaluit Lane	3325 Jaluit Lane		3342 Kilmer Street
				Field Sample ID:	220203F2ZT01	220123-F2-GT05	220123-F2-CT05	220123-F2-FT07	220123-F2-IT04	220123-F2-ET03	F2-TW-1303804-22023-N	220123-F2-ET01
				Sample Date:	2022-02-03	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	ND	8300 §	2080 §	ND	2420 §	220		3750 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	--	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons, Total	211	ISP	--	ND	ND	ND	ND	ND	ND		ND
Metals (ppb)	Antimony	6	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Arsenic	10	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Barium	2000	MCL	--	2.10	2.10	2.10	2.20	2.30	2.20		2.50
	Beryllium	4	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Cadmium	5	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Chromium	100	MCL	--	2.20	1.80	1.30	2.10	1.40	1.50		1.70
	Copper	1300	MCL	--	11.8	12.0	17.0	11.3	49.0	35.1		34.4
	Lead	15	MCL	--	0.390	0.470	0.320	0.280	1.20	0.530		0.610
	Mercury	2	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Selenium	50	MCL	--	ND	ND	ND	ND	ND	ND		ND
	Thallium	2	MCL	--	ND	ND	ND	0.100	ND	ND		ND
Synthetic Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	--	--	--	--	--	--		--
	1,2-Dichlorobenzene	600	MCL	ND	--	--	--	--	--	--		--
	1,3-Dichlorobenzene	--	--	ND	--	--	--	--	--	--		--
	1,4-Dichlorobenzene	75	MCL	ND	--	--	--	--	--	--		--
	1-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	--	ND		--
	2,4-Dinitrotoluene	--	--	ND	--	--	--	--	--	--		--
	2,6-Dinitrotoluene	--	--	ND	--	--	--	--	--	--		--
	2-Chloronaphthalene	--	--	ND	--	--	--	--	--	--		--
	2-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	--	ND		--



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-HYD1443	F2-JALU0598	F2-JALU0620	F2-JALU3304	F2-JALU3311	F2-JALU3325		F2-KILM3342
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		FH ID: FH-17	598 Jaluit Street	620 Jaluit Street	3304 Jaluit Lane	3311 Jaluit Lane	3325 Jaluit Lane		3342 Kilmer Street
		Field Sample ID:		220203F2ZT01	220123-F2-GT05	220123-F2-CT05	220123-F2-FT07	220123-F2-IT04	220123-F2-ET03	F2-TW-1303804-22023-N	220123-F2-ET01
		Sample Date:		2022-02-03	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	2-Methylphenol (o-Cresol)	--	--	0.0740	--	--	--	--	--	--	--
	2-Nitroaniline	--	--	ND	--	--	--	--	--	--	--
	3,3'-Dichlorobenzidine	--	--	ND	--	--	--	--	--	--	--
	3-Nitroaniline	--	--	ND	--	--	--	--	--	--	--
	4-Bromophenyl phenyl ether	--	--	ND	--	--	--	--	--	--	--
	4-Chloroaniline	--	--	ND	--	--	--	--	--	--	--
	4-Chlorophenyl phenyl ether	--	--	ND	--	--	--	--	--	--	--
	4-Nitroaniline	--	--	ND	--	--	--	--	--	--	--
	Acenaphthene	--	--	ND	--	--	--	--	--	--	--
	Acenaphthylene	--	--	ND	--	--	--	--	--	--	--
	Anthracene	--	--	ND	--	--	--	--	--	--	--
	Benzo(a)anthracene	--	--	ND	--	--	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	--	ND	--
	Benzo(b)fluoranthene	--	--	ND	--	--	--	--	--	--	--
	Benzo(g,h,i)perylene	--	--	ND	--	--	--	--	--	--	--
	Benzo(k)fluoranthene	--	--	ND	--	--	--	--	--	--	--
	Benzyl butyl phthalate	--	--	ND	--	--	--	--	--	--	--
	Bis(2-chloroethoxy)methane	--	--	ND	--	--	--	--	--	--	--
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	ND	--	--	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	1.80	ND	ND	0.830	--	ND	--
	Carbazole	--	--	ND	--	--	--	--	--	--	--
	Chrysene	--	--	ND	--	--	--	--	--	--	--
	Cresols, m- & p-	--	--	0.110	--	--	--	--	--	--	--
	Dibenz(a,h)anthracene	--	--	ND	--	--	--	--	--	--	--
	Dibenzofuran	--	--	ND	--	--	--	--	--	--	--

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-HYD1443	F2-JALU0598	F2-JALU0620	F2-JALU3304	F2-JALU3311	F2-JALU3325		F2-KILM3342
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		FH ID: FH-17	598 Jaluit Street	620 Jaluit Street	3304 Jaluit Lane	3311 Jaluit Lane	3325 Jaluit Lane		3342 Kilmer Street
		Field Sample ID:		220203F2ZT01	220123-F2-GT05	220123-F2-CT05	220123-F2-FT07	220123-F2-IT04	220123-F2-ET03	F2-TW-1303804-22023-N	220123-F2-ET01
		Sample Date:		2022-02-03	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Synthetic Organic Compounds (ppb)	Diethyl phthalate	--	--	ND	--	--	--	--	--	--	--
	Dimethyl phthalate	--	--	ND	--	--	--	--	--	--	--
	di-n-Butyl phthalate	--	--	ND	--	--	--	--	--	--	--
	di-n-Octyl phthalate	--	--	ND	--	--	--	--	--	--	--
	Fluoranthene	--	--	ND	--	--	--	--	--	--	--
	Fluorene	--	--	ND	--	--	--	--	--	--	--
	Hexachlorobenzene	--	--	ND	--	--	--	--	--	--	--
	Hexachlorobutadiene	--	--	ND	--	--	--	--	--	--	--
	Hexachlorocyclopentadiene	--	--	ND	--	--	--	--	--	--	--
	Hexachloroethane	--	--	ND	--	--	--	--	--	--	--
	Indeno(1,2,3-c,d)pyrene	--	--	ND	--	--	--	--	--	--	--
	Isophorone	--	--	ND	--	--	--	--	--	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	--	ND	--
	Nitrobenzene	--	--	ND	--	--	--	--	--	--	--
	N-Nitrosodi-n-propylamine	--	--	ND	--	--	--	--	--	--	--
	N-Nitrosodiphenylamine	--	--	ND	--	--	--	--	--	--	--
	Phenanthrene	--	--	ND	--	--	--	--	--	--	--
	Pyrene	--	--	ND	--	--	--	--	--	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-HYD1443	F2-JALU0598	F2-JALU0620	F2-JALU3304	F2-JALU3311	F2-JALU3325		F2-KILM3342
		Location Type:		Hydrant	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		FH ID: FH-17	598 Jaluit Street	620 Jaluit Street	3304 Jaluit Lane	3311 Jaluit Lane	3325 Jaluit Lane		3342 Kilmer Street
		Field Sample ID:		220203F2ZT01	220123-F2-GT05	220123-F2-CT05	220123-F2-FT07	220123-F2-IT04	220123-F2-ET03	F2-TW-1303804-22023-N	220123-F2-ET01
		Sample Date:		2022-02-03	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2-Dichloropropane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	--	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-KILM3342		F2-KILM3365		F2-KILM5408	F2-KILM5416		F2-KIRK1973
		Location Type:		Residence		Residence		Residence	Residence		Residence
		Address:		3342 Kilmer Street		3365 Kilmer Street		5408 Kilmer Lane	5416 Kilmer Lane		1973 Kirkpatrick Loop
		Field Sample ID:		220123-F2-ET02	F2-TW-1302980-22023-N	220123-F2-ET04	F2-TW-1304044-22023-N	220123-F2-HT03	220123-F2-FT04	220123-F2-FT05	F2-TW-1304262-22023-N-02
		Sample Date:		2022-01-23	2022-01-25	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-25
		Sample Type:		FD (Field Duplicate)	N (72 Hour Stagnation)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	2830 §	210	7570 §	ND	330	7010 §	4280 §	540
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.50	2.40	2.20	2.10	2.20	2.10	2.10	2.70
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.50	1.40	1.50	1.40	1.30	1.40	1.50
	Copper	1300	MCL	58.7	26.1	6.90	33.1	24.6	10.0	12.0	12.6
	Lead	15	MCL	1.40	0.440	0.350	0.550	0.290	0.460	0.410	0.270
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	0.0910	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	ND	--	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	ND	--	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	--	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	ND	--	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	--	ND	--	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-KILM3342		F2-KILM3365		F2-KILM5408	F2-KILM5416		F2-KIRK1973
				Location Type:	Residence		Residence		Residence	Residence		Residence
				Address:	3342 Kilmer Street		3365 Kilmer Street		5408 Kilmer Lane	5416 Kilmer Lane		1973 Kirkpatrick Loop
				Field Sample ID:	220123-F2-ET02	F2-TW-1302980-22023-N	220123-F2-ET04	F2-TW-1304044-22023-N	220123-F2-HT03	220123-F2-FT04	220123-F2-FT05	F2-TW-1304262-22023-N-02
				Sample Date:	2022-01-23	2022-01-25	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-25
				Sample Type:	FD (Field Duplicate)	N (72 Hour Stagnation)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-KIRK1975	F2-KIRK1991	F2-KOAI1654	F2-KOAI1657		F2-KOEL5301	F2-KOUH1857	F2-KOUH1877
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:		1975 Kirkpatrick Loop	1991 Kirkpatrick Loop	1654 Koaia Court	1657 Koaia Court		5301 Koelsch Lane	1857 Kou Haole Loop	1877 Kou Haole Loop
		Field Sample ID:		F2-TW-1303639(A)-22023-N	F2-TW-1303578(A)-22023-N	F2-TW-1303642-22023-N-02	F2-TW-2212502-22023-3-N	F2-TW-2212502-22023-N	220123-F2-HT04	F2-TW-2212503-22023-N	F2-TW-2212504-22023-N
		Sample Date:		2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-23	2022-01-25	2022-01-25
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	610	240	5630 §	3060 §	1650	ND	1980	2710 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.50	2.40	2.70	2.40	2.40	2.10	2.60	2.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.50	1.50	1.70	1.80	1.40	1.80	1.70
	Copper	1300	MCL	5.90	9.50	114	150	170	12.8	140	83.0
	Lead	15	MCL	0.130	0.190	ND	0.130	0.110	0.300	ND	0.190
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	0.460	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-KIRK1975	F2-KIRK1991	F2-KOAI1654	F2-KOAI1657		F2-KOEL5301	F2-KOUH1857	F2-KOUH1877
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	1975 Kirkpatrick Loop	1991 Kirkpatrick Loop	1654 Koaia Court	1657 Koaia Court		5301 Koelsch Lane	1857 Kou Haole Loop	1877 Kou Haole Loop
				Field Sample ID:	F2-TW-1303639(A)-22023-N	F2-TW-1303578(A)-22023-N	F2-TW-1303642-22023-N-02	F2-TW-2212502-22023-3-N	F2-TW-2212502-22023-N	220123-F2-HT04	F2-TW-2212503-22023-N	F2-TW-2212504-22023-N
				Sample Date:	2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-23	2022-01-25	2022-01-25
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-LIPP2089		F2-LOUN4108	F2-LOUN4114		F2-MALO0577	F2-MALO3256	F2-MALO3271
		Location Type:		Residence		Residence	Residence		Residence	Residence	Residence
		Address:		2089 Lippia Loop		4108 Lounsbury Street	4114 Lounsbury Street		577 Maloelap Lane	3256 Maloelap Street	3271 Maloelap Street
		Field Sample ID:		F2-TW-1304219(A)- 22023-3-N	F2-TW-1304219(A)- 22023-N	F2-TW-1303533- 22023-N	F2-TW-1303534- 22023-3-N	F2-TW-1303534- 22023-N	220123-F2-JT06	F2-TW-1303075- 22023-N	F2-TW-1303076- 22023-N
		Sample Date:		2022-01-25	2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-01-23	2022-01-24	2022-01-24
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	510	510	4680 §	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.70	2.60	2.40	2.30	2.30	2.10	2.00	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.30	1.40	1.40	1.70	1.60	1.80	1.20	1.10
	Copper	1300	MCL	188	183	11.4	5.00	4.60	13.0	8.10	15.0
	Lead	15	MCL	0.270	0.300	0.250	0.270	0.240	0.430	0.220	0.440
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0980
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.570	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-LIPP2089		F2-LOUN4108		F2-LOUN4114		F2-MALO0577	F2-MALO3256	F2-MALO3271
				Location Type:	Residence		Residence		Residence		Residence	Residence	Residence
				Address:	2089 Lippia Loop		4108 Lounsbury Street		4114 Lounsbury Street		577 Maloelap Lane	3256 Maloelap Street	3271 Maloelap Street
				Field Sample ID:	F2-TW-1304219(A)-22023-3-N	F2-TW-1304219(A)-22023-N	F2-TW-1303533-22023-N	F2-TW-1303534-22023-3-N	F2-TW-1303534-22023-N	220123-F2-JT06	F2-TW-1303075-22023-N	F2-TW-1303076-22023-N	
				Sample Date:	2022-01-25	2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-01-23	2022-01-24	2022-01-24	
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-MCFA0813	F2-MEYE0582		F2-MEYE0604			F2-MEYE0630	
		Location Type:		Residence	Residence		Residence			Residence	
		Address:		813 McFaddin Street	582 Meyerkord Loop		604 Meyerkord Loop			630 Meyerkord Loop	
		Field Sample ID:		F2-TW-1303539-22023-N	F2-TW-1304039-22023-3-N	F2-TW-1304039-22023-N	220123-F2-ET05	F2-TW-1303798-22023-3-N	F2-TW-1303798-22023-N	F2-TW-1304034-22023-3-N	F2-TW-1304034-22023-N
		Sample Date:		2022-01-25	2022-01-24	2022-01-24	2022-01-23	2022-01-25	2022-01-25	2022-01-24	2022-01-24
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (72 Hour Stagnation)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	3860 §	ND	ND	1920	330	670	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	92.0	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	92.0	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.10	2.10	2.40	2.30	2.20	2.00	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.30	1.10	1.40	1.50	1.60	1.10	1.20
	Copper	1300	MCL	26.0	17.3	17.4	48.6	26.9	26.5	8.70	13.2
	Lead	15	MCL	1.30	0.260	0.250	1.70	0.350	0.320	0.220	0.260
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	0.660	0.480	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-MCFA0813	F2-MEYE0582		F2-MEYE0604			F2-MEYE0630	
				Location Type:	Residence	Residence		Residence			Residence	
				Address:	813 McFaddin Street	582 Meyerkord Loop		604 Meyerkord Loop			630 Meyerkord Loop	
				Field Sample ID:	F2-TW-1303539-22023-N	F2-TW-1304039-22023-3-N	F2-TW-1304039-22023-N	220123-F2-ET05	F2-TW-1303798-22023-3-N	F2-TW-1303798-22023-N	F2-TW-1304034-22023-3-N	F2-TW-1304034-22023-N
				Sample Date:	2022-01-25	2022-01-24	2022-01-24	2022-01-23	2022-01-25	2022-01-25	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (72 Hour Stagnation)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-MEYE0654	F2-MEYE0657	F2-MOOR3029	F2-MORE3104	F2-MORE3128	F2-MORE3148	F2-MORE3301	F2-MURR0731
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	654 Meyerkord Loop	657 Meyerkord Loop	3029 Moore Drive	3104 Moreell Circle	3128 Moreell Circle	3148 Moreell Circle	3301 Moreell Drive	731 Murray Drive
				Field Sample ID:	220123-F2-IT03	220123-F2-IT02	220123-F2-KT03	220123-F2-AT07	220123-F2-IT06	220123-F2-JT02	220123-F2-JT05	F2-TW-1304037-22023-N
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	6350 §	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.10	2.40	2.00	2.00	2.10	2.10	2.50	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	2.10	1.90	2.00	1.90	2.20	2.40	2.40	1.50	
	Copper	1300	MCL	74.2	9.30	41.8	90.0	32.5	94.0	81.8	6.40	
	Lead	15	MCL	0.290	0.280	0.270	0.260	0.150	0.550	0.510	0.170	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	1.10	1.20	ND	1.00	0.990	2.70	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-MEYE0654	F2-MEYE0657	F2-MOOR3029	F2-MORE3104	F2-MORE3128	F2-MORE3148	F2-MORE3301	F2-MURR0731
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	654 Meyerkord Loop	657 Meyerkord Loop	3029 Moore Drive	3104 Moreell Circle	3128 Moreell Circle	3148 Moreell Circle	3301 Moreell Drive	731 Murray Drive
				Field Sample ID:	220123-F2-IT03	220123-F2-IT02	220123-F2-KT03	220123-F2-AT07	220123-F2-IT06	220123-F2-JT02	220123-F2-JT05	F2-TW-1304037-22023-N
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-MURR0741	F2-MURR0790		F2-MURR0798	F2-MURR0845	F2-MURR0846	F2-MURR0863	
		Location Type:		Residence	Residence		Residence	Residence	Residence	Residence	
		Address:		741 Murray Drive	790 Murray Drive		798 Murray Drive	845 Murray Drive	846 Murray Drive	863 Murray Drive	
		Field Sample ID:		F2-TW-2212505-22023-N	F2-TW-145069-22023-3-N	F2-TW-145069-22023-N	F2-TW-2201045-22023-N-01	F2-TW-2201013-22023-N	F2-TW-145083-22023-N	F2-TW-143501-22023-3-N	F2-TW-143501-22023-N
		Sample Date:		2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-24	2022-01-25	2022-01-25	2022-01-25
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	4510 §	5840 §	4770 §	ND	6100 §	5520 §	4740 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.40	2.60	2.50	2.50	2.50	2.50	2.60	2.60
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.50	1.30	1.40	1.60	1.40	1.40	1.40
	Copper	1300	MCL	12.2	4.10	4.20	10.3	7.20	7.70	3.00	2.90
	Lead	15	MCL	0.250	0.290	0.360	0.230	0.250	ND	0.220	ND
	Mercury	2	MCL	ND	ND	ND	ND	0.0680	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-MURR0741		F2-MURR0790		F2-MURR0798	F2-MURR0845	F2-MURR0846	F2-MURR0863	
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence	
				Address:	741 Murray Drive		790 Murray Drive		798 Murray Drive	845 Murray Drive	846 Murray Drive	863 Murray Drive	
				Field Sample ID:	F2-TW-2212505-22023-N	F2-TW-145069-22023-3-N	F2-TW-145069-22023-N	F2-TW-2201045-22023-N-01	F2-TW-2201013-22023-N	F2-TW-145083-22023-N	F2-TW-143501-22023-3-N	F2-TW-143501-22023-N	
				Sample Date:	2022-01-25	2022-01-25	2022-01-25	2022-01-25	2022-01-24	2022-01-25	2022-01-25	2022-01-25	
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
				DOH Project Screening Level	Basis of Project Screening Level								
Method Group	Analyte												
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0872	F2-MURR0874	F2-MURR0888	F2-MURR0958	F2-MURR0966	F2-NOON4009	F2-NOON4018	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	872 Murray Drive	874 Murray Drive	888 Murray Drive	958 Murray Drive	966 Murray Drive	4009 Noonan Street	4018 Noonan Street	
		Field Sample ID:	220126F2AT06	F2-TW-549198-22023-N	F2-TW-2201014-22023-N	F2-TW-22012401-22023-N	F2-TW-22012402-22023-N	F2-TW-0010190-22055-N	F2-TW-0010396-22055-N	F2-TW-0010396-22055-N-R1
		Sample Date:	2022-01-26	2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-02-25	2022-02-24	2022-02-25
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	550	4980 §	ND	ND	ND	--	--
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	58.5	53.8
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	58.5	53.8
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	--	--
	Arsenic	10	MCL	ND	ND	ND	ND	ND	--	--
	Barium	2000	MCL	2.40	2.60	2.60	2.40	2.40	--	--
	Beryllium	4	MCL	ND	ND	ND	ND	ND	--	--
	Cadmium	5	MCL	ND	ND	ND	ND	ND	--	--
	Chromium	100	MCL	1.40	1.60	1.60	1.30	1.20	--	--
	Copper	1300	MCL	11.4	7.80	8.50	4.60	3.00	--	--
	Lead	15	MCL	0.470	0.470	0.510	0.340	ND	--	--
	Mercury	2	MCL	ND	ND	0.0580	ND	ND	--	--
	Selenium	50	MCL	ND	ND	ND	ND	ND	--	--
	Thallium	2	MCL	ND	ND	ND	ND	ND	--	--
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	--	--
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	--	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	--	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	--	--
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	--	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	--	--



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-MURR0872	F2-MURR0874	F2-MURR0888	F2-MURR0958	F2-MURR0966	F2-NOON4009	F2-NOON4018	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
				Address:	872 Murray Drive	874 Murray Drive	888 Murray Drive	958 Murray Drive	966 Murray Drive	4009 Noonan Street	4018 Noonan Street	
				Field Sample ID:	220126F2AT06	F2-TW-549198-22023-N	F2-TW-2201014-22023-N	F2-TW-22012401-22023-N	F2-TW-22012402-22023-N	F2-TW-0010190-22055-N	F2-TW-0010396-22055-N	F2-TW-0010396-22055-N-R1
				Sample Date:	2022-01-26	2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-02-25	2022-02-24	2022-02-25
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	--	--	--
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	--	--	--
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	--	--	--
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	--	--	--

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-NOON4018	F2-NOON4036	F2-NOON4061	F2-NYEC1676		F2-NYEC1722	F2-NYEP1932	F2-OCAL1920
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	4018 Noonan Street	4036 Noonan Street	4061 Noonan Street	1676 Nye Circle		1722 Nye Circle	1932 Nye Place	1920 O'Callahan Street
				Field Sample ID:	F2-TW-1303598-22023-N	F2-TW-0010404-22055-N	F2-TW-1303666-22023-N	F2-TW-2212507-22023-3-N	F2-TW-2212507-22023-N	F2-TW-2212508-22023-N	F2-TW-1303642-22023-N-01	F2-TW-2201017-22023-N
				Sample Date:	2022-01-24	2022-02-25	2022-01-24	2022-01-25	2022-01-25	2022-01-25	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5910 §	--	7280 §	3990 §	4520 §	1530	1650	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	180	62.8	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	460	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	640 §	62.8	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.80	--	2.60	2.60	2.60	2.70	2.60	2.40	
	Beryllium	4	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.40	--	1.50	1.70	1.40	1.70	1.70	1.60	
	Copper	1300	MCL	15.7	--	17.1	59.1	63.8	99.0	71.0	3.30	
	Lead	15	MCL	0.650	--	0.530	0.400	0.560	0.150	0.220	0.140	
	Mercury	2	MCL	ND	--	0.110	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	--	ND	ND	ND	1.60	ND	ND	
Thallium	2	MCL	ND	--	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	--	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	--	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	--	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-NOON4018	F2-NOON4036	F2-NOON4061	F2-NYEC1676		F2-NYEC1722	F2-NYEP1932	F2-OCAL1920
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	4018 Noonan Street	4036 Noonan Street	4061 Noonan Street	1676 Nye Circle		1722 Nye Circle	1932 Nye Place	1920 O'Callahan Street
		Field Sample ID:	F2-TW-1303598-22023-N	F2-TW-0010404-22055-N	F2-TW-1303666-22023-N	F2-TW-2212507-22023-3-N	F2-TW-2212507-22023-N	F2-TW-2212508-22023-N	F2-TW-1303642-22023-N-01	F2-TW-2201017-22023-N
		Sample Date:	2022-01-24	2022-02-25	2022-01-24	2022-01-25	2022-01-25	2022-01-25	2022-01-24	2022-01-24
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	--	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	--	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	--	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	--	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	--	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	--	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	--	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	--	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	--	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	--	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-PETE3224	F2-PETE3226	F2-PETE3240		F2-PLUM1650	F2-POOL0617	F2-POOL0683	F2-POOL0726
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		3224 Peterson Court	3226 Peterson Court	3240 Peterson Court		1650 Plumbago Court	617 Pool Street	683 Pool Street	726 Pool Street
		Field Sample ID:		220123-F2-AT06	220123-F2-LT06	220123-F2-CT01	220123-F2-CT02	F2-TW-1304326-22023-N	F2-TW-1303385-22023-N	F2-TW-1304317-22023-N	F2-TW-1303363-22023-N
		Sample Date:		2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-24	2022-01-24	2022-01-24	2022-01-24
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5100 §	ND	7490 §	6930 §	4500 §	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	190	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	190	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.40	2.50	2.40	2.30	2.60	2.40	2.20	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.70	2.10	1.80	1.80	1.50	1.00	1.80	1.60
	Copper	1300	MCL	43.0	31.7	32.0	31.0	55.3	11.5	4.80	9.10
	Lead	15	MCL	3.50	ND	0.720	0.110	ND	0.440	0.140	0.380
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0670
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	0.100	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	2.60	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-PETE3224	F2-PETE3226	F2-PETE3240		F2-PLUM1650	F2-POOL0617	F2-POOL0683	F2-POOL0726
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	3224 Peterson Court	3226 Peterson Court	3240 Peterson Court		1650 Plumbago Court	617 Pool Street	683 Pool Street	726 Pool Street
				Field Sample ID:	220123-F2-AT06	220123-F2-LT06	220123-F2-CT01	220123-F2-CT02	F2-TW-1304326-22023-N	F2-TW-1303385-22023-N	F2-TW-1304317-22023-N	F2-TW-1303363-22023-N
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-24	2022-01-24	2022-01-24	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-RAMA0819	F2-ROGE0830	F2-SAND0721	F2-SCHM2788	F2-SHIE3278	F2-SHIE5230		F2-SHIE5264
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	819 Ramage Street	830 Rogers Street	721 Sanders Circle	2788 Schmitt Parkway	3278 Shields Lane	5230 Shields Street		5264 Shields Street
				Field Sample ID:	220123-F2-KT04	F2-TW-137350-22023-N	220123-F2-DT01	F2-TW-2201045-22023-N-02	220123-F2-KT02	220123-F2-ET07	F2-TW-1304027-22023-N	220123-F2-GT04
				Sample Date:	2022-01-23	2022-01-24	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-25	2022-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	4300 §	4640 §	ND	1870	ND		ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND		ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Barium	2000	MCL	2.20	2.20	2.20	2.60	2.10	2.10	2.10		2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Chromium	100	MCL	2.10	1.60	1.40	1.40	1.90	1.40	1.50		2.00
	Copper	1300	MCL	10.9	6.20	2.30	4.60	13.0	8.50	6.20		26.6
	Lead	15	MCL	0.490	0.170	ND	ND	0.280	0.520	0.380		0.240
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Selenium	50	MCL	ND	ND	ND	ND	2.30	ND	ND		ND
	Thallium	2	MCL	0.0950	ND	ND	ND	ND	ND	ND		ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND		ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND		ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	Bis(2-ethylhexyl)phthalate	6	MCL	1.30	ND	ND	ND	ND	ND	ND		1.50
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND		ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND		ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND		ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND		ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-RAMA0819	F2-ROGE0830	F2-SAND0721	F2-SCHM2788	F2-SHIE3278	F2-SHIE5230		F2-SHIE5264
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	819 Ramage Street	830 Rogers Street	721 Sanders Circle	2788 Schmitt Parkway	3278 Shields Lane	5230 Shields Street		5264 Shields Street
				Field Sample ID:	220123-F2-KT04	F2-TW-137350-22023-N	220123-F2-DT01	F2-TW-2201045-22023-N-02	220123-F2-KT02	220123-F2-ET07	F2-TW-1304027-22023-N	220123-F2-GT04
				Sample Date:	2022-01-23	2022-01-24	2022-01-23	2022-01-25	2022-01-23	2022-01-23	2022-01-25	2022-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-SHIE5294	F2-SHIE5352	F2-SIBL0716	F2-SIBL0722	F2-SNYD3166		F2-STOW2583	F2-STOW2607
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	5294 Shields Street	5352 Shields Street	716 Sibley Street	722 Sibley Street	3166 Snyder Court		2583 Stowell Circle	2607 Stowell Circle
				Field Sample ID:	F2-TW-1304075-22023-N	220123-F2-JT03	F2-TW-1304339-22023-N	F2-TW-1304341-22023-N	220123-F2-LT05	F2-TW-1303363(A)-22023-N	F2-TW-548053-22023-N	F2-TW-548057-22023-N
				Sample Date:	2022-01-25	2022-01-23	2022-01-24	2022-01-25	2022-01-23	2022-01-25	2022-01-25	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	5860 §	ND	ND	ND	ND	220	560	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.10	2.10	2.30	2.50	2.30	2.70	2.30	2.60	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.60	2.00	1.80	1.80	2.20	1.60	1.40	1.70	
	Copper	1300	MCL	8.60	8.30	6.70	11.0	25.1	37.0	3.90	8.00	
	Lead	15	MCL	0.260	0.360	0.350	0.400	0.300	ND	ND	0.330	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0600	
	Selenium	50	MCL	ND	ND	ND	1.60	ND	ND	ND	ND	
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	1.10	ND	ND	1.40	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	



Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-SHIE5294	F2-SHIE5352	F2-SIBL0716	F2-SIBL0722	F2-SNYD3166		F2-STOW2583	F2-STOW2607
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	5294 Shields Street	5352 Shields Street	716 Sibley Street	722 Sibley Street	3166 Snyder Court		2583 Stowell Circle	2607 Stowell Circle
				Field Sample ID:	F2-TW-1304075-22023-N	220123-F2-JT03	F2-TW-1304339-22023-N	F2-TW-1304341-22023-N	220123-F2-LT05	F2-TW-1303363(A)-22023-N	F2-TW-548053-22023-N	F2-TW-548057-22023-N
				Sample Date:	2022-01-25	2022-01-23	2022-01-24	2022-01-25	2022-01-23	2022-01-25	2022-01-25	2022-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte											
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-STOW2608	F2-STOW2643	F2-STOW2708		F2-STOW2731	F2-STOW2760	F2-STOW2784	F2-STOW2787
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		2608 Stowell Circle	2643 Stowell Circle	2708 Stowell Circle		2731 Stowell Circle	2760 Stowell Circle	2784 Stowell Circle	2787 Stowell Circle
		Field Sample ID:		F2-TW-1304262-22023-N-01	F2-TW-549193-22023-N	F2-TW-2201019-22023-3-N	F2-TW-2201019-22023-N	F2-TW-2201020-22023-N	F2-TW-2201021-22023-N	F2-TW-549227-22023-N	F2-TW-2201011(a)-22023-N
		Sample Date:		2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-25
		Sample Type:		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	240	ND	ND	ND	ND	ND	ND	5330 §
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.40	2.70	2.50	2.50	2.60	2.40	2.40	2.50
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.60	1.60	1.70	1.70	1.60	1.70	1.60	1.50
	Copper	1300	MCL	5.50	8.40	3.70	4.30	6.40	4.70	7.30	14.1
	Lead	15	MCL	0.350	0.660	0.180	0.220	0.880	0.280	0.230	0.340
	Mercury	2	MCL	ND	ND	ND	ND	ND	0.0620	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	0.200	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-STOW2608	F2-STOW2643	F2-STOW2708		F2-STOW2731	F2-STOW2760	F2-STOW2784	F2-STOW2787
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	2608 Stowell Circle	2643 Stowell Circle	2708 Stowell Circle		2731 Stowell Circle	2760 Stowell Circle	2784 Stowell Circle	2787 Stowell Circle
				Field Sample ID:	F2-TW-1304262-22023-N-01	F2-TW-549193-22023-N	F2-TW-2201019-22023-3-N	F2-TW-2201019-22023-N	F2-TW-2201020-22023-N	F2-TW-2201021-22023-N	F2-TW-549227-22023-N	F2-TW-2201011(a)-22023-N
				Sample Date:	2022-01-25	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-24	2022-01-25
				Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		F2-TAPP2819	F2-TIAR1705	F2-TOMI3186	F2-TOMI3248	F2-VAES3034		F2-VAES3040	F2-VAES3080
		Location Type:		Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:		2819 Tapp Street	1705 Tiare Court	3186 Tomich Court	3248 Tomich Court	3034 Vaessen Court		3040 Vaessen Court	3080 Vaessen Court
		Field Sample ID:		F2-TW-1303355-22055-N	F2-TW-2212511-22023-N	220123-F2-CT04	220123-F2-IT05	220123-F2-ET08	F2-TW-2212512-22023-N	220123-F2-AT05	220123-F2-LT03
		Sample Date:		2022-02-25	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23	2022-01-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	--	1960	11100 §	ND	1620	620	6230 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	57.9	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	57.9	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	--	2.60	2.10	2.20	2.70	2.60	2.50	2.30
	Beryllium	4	MCL	--	ND	0.0830	ND	ND	ND	ND	ND
	Cadmium	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	--	1.80	1.80	2.00	1.30	1.00	1.80	2.00
	Copper	1300	MCL	--	88.0	78.0	95.6	48.1	138	45.0	26.4
	Lead	15	MCL	--	0.390	0.140	12.7	0.290	3.10	1.80	ND
	Mercury	2	MCL	--	0.0560	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	--	1.60	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	--	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	--	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	ND	ND	2.80	ND	ND	ND	1.50
	Naphthalene	17	EAL	--	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	--	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results  
Zone F2 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-TAPP2819	F2-TIAR1705	F2-TOMI3186	F2-TOMI3248	F2-VAES3034		F2-VAES3040	F2-VAES3080
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	2819 Tapp Street	1705 Tiare Court	3186 Tomich Court	3248 Tomich Court	3034 Vaessen Court		3040 Vaessen Court	3080 Vaessen Court
				Field Sample ID:	F2-TW-1303355-22055-N	F2-TW-2212511-22023-N	220123-F2-CT04	220123-F2-IT05	220123-F2-ET08	F2-TW-2212512-22023-N	220123-F2-AT05	220123-F2-LT03
				Sample Date:	2022-02-25	2022-01-25	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-23	2022-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (72 Hour Stagnation)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	--	ND	ND	ND	ND	ND	ND	ND	ND