



**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	G1-ANDE0739	G1-ANDE0749	G1-ANDE0751	G1-ANDE0755	G1-ANDE0761		G1-ANDE0763	G1-BAUG2133
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	739 Anderson Road	749 Anderson Road	751 Anderson Road	755 Anderson Road	761 Anderson Road		763 Anderson Road	2133 Baugh Road
		Field Sample ID:	G1-TW-2201002-22023-N	G1-TW-2201003-22023-N	G1-TW-2201004-22023-N	G1-TW-2201005-22023-N	G1-TW-2201006-22023-3-N	G1-TW-2201006-22023-N	G1-TW-2201007-22023-N	G1-TW-2201001-22023-3-N
		Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-23
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results**  
**Zone G1 Post Residential and Non-Residential Flushing Data**  
**Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	G1-BAUG2133	G1-BAUG2151	G1-BAUG2165	G1-BAUG2173	G1-BLDG002AA	G1-BLDG0401		G1-BLDG0402
				Location Type:	Residence	Residence	Residence	Residence	Non-Residence	Non-Residence		Non-Residence
				Address:	2133 Baugh Road	2151 Baugh Road	2165 Baugh Road	2173 Baugh Road	Building 2AA, ADMINISTRATIVE OFFICE	Building 401, UNACC ENL HSG		Building 402,INDOPACOM
				Field Sample ID:	G1-TW-2201001-22023-N	G1-TW-2201008-22023-N	G1-TW-2201009-22023-N	G1-TW-2201010-22023-N	G1-TW-2201024-22023-N	G1-TW-2201025-22023-3-N	G1-TW-2201025-22023-N	G1-TW-2201026-22023-N
				Sample Date:	2022-01-23	2022-01-23	2022-01-23	2022-01-23	2022-01-25	2022-01-25	2022-01-25	2022-01-25
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	10500 §	1960	9650 §	2050 §	ND	1550	2010 §	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	150	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	150	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	3.80	3.80	4.40	4.60	2.80	3.60	3.40	3.70	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.70	1.40	1.30	1.30	1.80	1.80	1.90	1.80	
	Copper	1300	MCL	13.0	13.9	15.3	11.9	49.0	54.0	51.0	27.0	
	Lead	15	MCL	0.380	0.230	0.260	0.610	0.360	0.620	0.520	0.360	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	1.60	ND	1.70
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:		Location ID:
				Location Type:	Location Type:	Location Type:	Location Type:	Location Type:	Location Type:		Location Type:
				Address:	Address:	Address:	Address:	Address:	Address:		Address:
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	G1-BLDG0403	G1-BLDG0404	G1-HYD879	
				Location Type:	Non-Residence	Non-Residence	Hydrant	
				Address:	Building 403, UNACC ENL HSG	Building 404, UNACC ENL HSG	FH ID: 3	
				Field Sample ID:	G1-TW-2201027-22023-N	G1-TW-2201028-22023-N	20220108-G1-TY01	220107-G1-YT01
				Sample Date:	2022-01-25	2022-01-25	2022-01-08	2022-01-07
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	1520	217	--	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	
	Arsenic	10	MCL	ND	ND	0.0785	--	
	Barium	2000	MCL	3.60	3.70	2.89	--	
	Beryllium	4	MCL	ND	ND	ND	--	
	Cadmium	5	MCL	ND	ND	ND	--	
	Chromium	100	MCL	1.80	1.80	1.28	--	
	Copper	1300	MCL	56.0	46.0	10.8	--	
	Lead	15	MCL	0.490	0.510	0.812	--	
	Mercury	2	MCL	ND	ND	ND	--	
	Selenium	50	MCL	ND	1.90	0.165	--	
Thallium	2	MCL	ND	ND	ND	--		
Synthetic Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	--	--	--	ND	
	1,2-Dichlorobenzene	600	MCL	--	--	--	ND	
	1,3-Dichlorobenzene	--	--	--	--	--	ND	
	1,4-Dichlorobenzene	75	MCL	--	--	--	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	
	2,4-Dinitrotoluene	--	--	--	--	--	ND	
	2,6-Dinitrotoluene	--	--	--	--	--	ND	
	2-Chloronaphthalene	--	--	--	--	--	ND	

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	
				G1-BLDG0403	G1-BLDG0404	G1-HYD879	
				Non-Residence	Non-Residence	Hydrant	
				Building 403, UNACC ENL HSG	Building 404, UNACC ENL HSG	FH ID: 3	
				G1-TW-2201027-22023-N	G1-TW-2201028-22023-N	20220108-G1-TY01	220107-G1-YT01
				2022-01-25	2022-01-25	2022-01-08	2022-01-07
				N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	2-Ethylhexyl adipate	--	--	--	--	ND	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--
	2-Nitroaniline	--	--	--	--	--	ND
	3,3'-Dichlorobenzidine	--	--	--	--	--	ND
	3-Nitroaniline	--	--	--	--	--	ND
	4-Bromophenyl phenyl ether	--	--	--	--	--	ND
	4-Chloroaniline	--	--	--	--	--	ND
	4-Chlorophenyl phenyl ether	--	--	--	--	--	ND
	4-Nitroaniline	--	--	--	--	--	ND
	Acenaphthene	--	--	--	--	--	ND
	Acenaphthylene	--	--	--	--	--	ND
	Alachlor	--	--	--	--	ND	--
	Anthracene	--	--	--	--	--	ND
	Atrazine	--	--	--	--	ND	--
	Benzo(a)anthracene	--	--	--	--	--	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND
	Benzo(b)fluoranthene	--	--	--	--	--	ND
	Benzo(g,h,i)perylene	--	--	--	--	--	ND
	Benzo(k)fluoranthene	--	--	--	--	--	ND
	Benzyl butyl phthalate	--	--	--	--	--	ND
	Bis(2-chloroethoxy)methane	--	--	--	--	--	ND
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	--	--	--	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND
	Carbazole	--	--	--	--	--	ND

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	
				G1-BLDG0403	G1-BLDG0404	G1-HYD879	
				Non-Residence	Non-Residence	Hydrant	
				Building 403, UNACC ENL HSG	Building 404, UNACC ENL HSG	FH ID: 3	
				G1-TW-2201027-22023-N	G1-TW-2201028-22023-N	20220108-G1-TY01	220107-G1-YT01
				2022-01-25	2022-01-25	2022-01-08	2022-01-07
				N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Chlordane	--	--	--	--	ND	--
	Chrysene	--	--	--	--	--	ND
	Dibenz(a,h)anthracene	--	--	--	--	--	ND
	Dibenzofuran	--	--	--	--	--	ND
	Diethyl phthalate	--	--	--	--	--	ND
	Dimethyl phthalate	--	--	--	--	--	ND
	di-n-Butyl phthalate	--	--	--	--	--	ND
	di-n-Octyl phthalate	--	--	--	--	--	0.300
	Endrin	--	--	--	--	ND	--
	Fluoranthene	--	--	--	--	--	ND
	Fluorene	--	--	--	--	--	ND
	gamma-BHC (Lindane)	--	--	--	--	ND	--
	Heptachlor	--	--	--	--	ND	--
	Heptachlor epoxide	--	--	--	--	ND	--
	Hexachlorobenzene	--	--	--	--	ND	ND
	Hexachlorobutadiene	--	--	--	--	--	ND
	Hexachlorocyclopentadiene	--	--	--	--	ND	--
	Hexachloroethane	--	--	--	--	--	ND
	Indeno(1,2,3-c,d)pyrene	--	--	--	--	--	ND
	Isophorone	--	--	--	--	--	ND
	Methoxychlor	--	--	--	--	ND	--
	Naphthalene	17	EAL	ND	ND	ND	ND
	Nitrobenzene	--	--	--	--	--	ND
	N-Nitrosodi-n-propylamine	--	--	--	--	--	ND

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	
				G1-BLDG0403	G1-BLDG0404	G1-HYD879	
				Non-Residence	Non-Residence	Hydrant	
				Address: Building 403, UNACC ENL HSG	Address: Building 404, UNACC ENL HSG	FH ID: 3	
				Field Sample ID: G1-TW-2201027-22023-N	Field Sample ID: G1-TW-2201028-22023-N	20220108-G1-TY01	220107-G1-YT01
				Sample Date: 2022-01-25	Sample Date: 2022-01-25	2022-01-08	2022-01-07
				Sample Type: N (Normal)	Sample Type: N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	N-Nitrosodiphenylamine	--	--	--	--	--	ND
	PCB, Total	--	--	--	--	ND	--
	PCB-1016 (Aroclor 1016)	--	--	--	--	ND	--
	PCB-1221 (Aroclor 1221)	--	--	--	--	ND	--
	PCB-1232 (Aroclor 1232)	--	--	--	--	ND	--
	PCB-1242 (Aroclor 1242)	--	--	--	--	ND	--
	PCB-1248 (Aroclor 1248)	--	--	--	--	ND	--
	PCB-1254 (Aroclor 1254)	--	--	--	--	ND	--
	PCB-1260 (Aroclor 1260)	--	--	--	--	ND	--
	Pentachlorophenol	1	MCL	--	--	ND	--
	Phenanthrene	--	--	--	--	--	ND
	Pyrene	--	--	--	--	--	ND
	Simazine	--	--	--	--	ND	--
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--
	Benzene	5	MCL	ND	ND	ND	--
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--

**Summary of Chemistry Results  
Zone G1 Post Residential and Non-Residential Flushing Data  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone G1**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	
				G1-BLDG0403	G1-BLDG0404	G1-HYD879	
				Non-Residence	Non-Residence	Hydrant	
				Address: Building 403, UNACC ENL HSG	Address: Building 404, UNACC ENL HSG	FH ID: 3	
				Field Sample ID: G1-TW-2201027-22023-N	Field Sample ID: G1-TW-2201028-22023-N	20220108-G1-TY01	220107-G1-YT01
				Sample Date: 2022-01-25	Sample Date: 2022-01-25	2022-01-08	2022-01-07
				Sample Type: N (Normal)	Sample Type: N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	Chlorobenzene	100	MCL	ND	ND	ND	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--
	Ethylbenzene	700	MCL	ND	ND	ND	--
	m,p-Xylene	--	--	ND	ND	ND	--
	Methylene chloride	5	MCL	ND	ND	ND	--
	o-Xylene	--	--	ND	ND	ND	--
	Styrene	100	MCL	ND	ND	ND	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--
	Toluene	1000	MCL	ND	ND	ND	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--
	Vinyl chloride	2	MCL	ND	ND	ND	--
	Xylenes, Total	--	--	ND	ND	ND	--
Trihalomethanes (ppb)	Bromoform	--	--	--	--	--	2.60
	Dibromochloromethane	--	--	--	--	--	0.780
	Total Trihalomethanes	80	MCL	--	--	--	3.38