

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	I1-EAGL1308	I1-FH1324	I1-HOPS1202	I1-HYD1324A			I1-ICAR1217	
				Location Type:	Residence	Hydrant	Residence	Hydrant			Residence	
				Address:	1308 Eagle Circle	Should be I1-HYD1324A which already exists	1202 Hudson Cr	HYD-1324A			1217 Icarus Way	
				Field Sample ID:	220114-I1-HT03	220118-I1-WT07	220113-I1-IT03	220118-I1-WT07	I1-DWS-I1-1324-122821-A	I1-DWS-I1-1324-122921-A	220114-I1-JT01	
				Sample Date:	2022-01-14	2022-01-18	2022-01-13	2022-01-18	2021-01-28	2021-01-29	2021-12-29	2022-01-14
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	2-Chloronaphthalene	--	--	--	--	--	--	--	ND	--	--	--
	2-Ethylhexyl adipate	--	--	--	--	--	--	ND	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	--	ND	0.0102	ND	--	--	ND	ND
	2-Nitroaniline	--	--	--	--	--	--	ND	--	--	--	--
	3,3'-Dichlorobenzidine	--	--	--	--	--	--	ND	--	--	--	--
	3-Nitroaniline	--	--	--	--	--	--	ND	--	--	--	--
	4-Bromophenyl phenyl ether	--	--	--	--	--	--	ND	--	--	--	--
	4-Chloroaniline	--	--	--	--	--	--	ND	--	--	--	--
	4-Chlorophenyl phenyl ether	--	--	--	--	--	--	ND	--	--	--	--
	4-Nitroaniline	--	--	--	--	--	--	ND	--	--	--	--
	Acenaphthene	--	--	--	--	--	--	ND	--	--	--	--
	Acenaphthylene	--	--	--	--	--	--	ND	--	--	--	--
	Alachlor	--	--	--	--	--	ND	--	--	ND	--	--
	Anthracene	--	--	--	--	--	--	ND	--	--	--	--
	Atrazine	--	--	--	--	--	ND	--	--	ND	--	--
	Benzo(a)anthracene	--	--	--	--	--	--	ND	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	--	ND	ND	ND	--	ND	ND	ND
	Benzo(b)fluoranthene	--	--	--	--	--	--	ND	--	--	--	--
	Benzo(g,h,i)perylene	--	--	--	--	--	--	ND	--	--	--	--
	Benzo(k)fluoranthene	--	--	--	--	--	--	ND	--	--	--	--
	Benzyl butyl phthalate	--	--	--	--	--	--	ND	--	--	--	--
	Bis(2-chloroethoxy)methane	--	--	--	--	--	--	ND	--	--	--	--
	Bis(2-chloroethyl) ether (2-Chloroethyl ether)	--	--	--	--	--	--	ND	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	--	ND	ND	ND	--	ND	ND	ND

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	I1-EAGL1308	I1-FH1324	I1-HOPS1202	I1-HYD1324A			I1-ICAR1217		
				Location Type:	Residence	Hydrant	Residence	Hydrant			Residence		
				Address:	1308 Eagle Circle	Should be I1-HYD1324A which already exists	1202 Hudson Cr	HYD-1324A			1217 Icarus Way		
				Field Sample ID:	220114-I1-HT03	220118-I1-WT07	220113-I1-IT03	220118-I1-WT07	I1-DWS-I1-1324-122821-A	I1-DWS-I1-1324-122921-A	220114-I1-JT01		
				Sample Date:	2022-01-14	2022-01-18	2022-01-13	2022-01-18	2021-01-28	2021-01-29	2021-12-29	2022-01-14	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Synthetic Organic Compounds (ppb)	Carbazole	--	--	--	--	--	--	--	ND	--	--	--	
	Chlordane	--	--	--	--	--	--	ND	--	--	ND	--	
	Chrysene	--	--	--	--	--	--	--	ND	--	--	--	
	Dibenz(a,h)anthracene	--	--	--	--	--	--	--	ND	--	--	--	
	Dibenzofuran	--	--	--	--	--	--	--	ND	--	--	--	
	Diethyl phthalate	--	--	--	--	--	--	--	ND	--	--	--	
	Dimethyl phthalate	--	--	--	--	--	--	--	ND	--	--	--	
	di-n-Butyl phthalate	--	--	--	--	--	--	--	ND	--	--	--	
	di-n-Octyl phthalate	--	--	--	--	--	--	--	ND	--	--	--	
	Diethyl adipate	--	--	--	--	--	--	--	--	--	ND	--	
	Endrin	--	--	--	--	--	--	--	ND	--	ND	--	
	Fluoranthene	--	--	--	--	--	--	--	--	ND	--	--	
	Fluorene	--	--	--	--	--	--	--	--	ND	--	--	
	gamma-BHC (Lindane)	--	--	--	--	--	--	--	ND	--	--	ND	--
	Heptachlor	--	--	--	--	--	--	--	ND	--	--	ND	--
	Heptachlor epoxide	--	--	--	--	--	--	--	ND	--	--	ND	--
	Hexachlorobenzene	--	--	ND	--	--	ND	ND	ND	ND	--	ND	ND
	Hexachlorobutadiene	--	--	--	--	--	--	--	--	ND	--	--	--
	Hexachlorocyclopentadiene	--	--	ND	--	--	ND	ND	ND	ND	--	ND	ND
	Hexachloroethane	--	--	--	--	--	--	--	--	ND	--	--	--
	Indeno(1,2,3-c,d)pyrene	--	--	--	--	--	--	--	--	ND	--	--	--
	Isophorone	--	--	--	--	--	--	--	--	ND	--	--	--
	Methoxychlor	--	--	--	--	--	--	--	ND	--	--	ND	--
	Naphthalene		17	EAL	ND	--	--	ND	0.0161	ND	--	ND	ND

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	I1-EAGL1308	I1-FH1324	I1-HOPS1202	I1-HYD1324A			I1-ICAR1217
				Location Type:	Residence	Hydrant	Residence	Hydrant			Residence
				Address:	1308 Eagle Circle	Should be I1-HYD1324A which already exists	1202 Hudson Cr	HYD-1324A			1217 Icarus Way
				Field Sample ID:	220114-I1-HT03	220118-I1-WT07	220113-I1-IT03	220118-I1-WT07	I1-DWS-I1-1324-122821-A	I1-DWS-I1-1324-122921-A	220114-I1-JT01
				Sample Date:	2022-01-14	2022-01-18	2022-01-13	2022-01-18	2021-01-28	2021-01-29	2021-12-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Synthetic Organic Compounds (ppb)	Nitrobenzene	--	--	--	--	--	--	--	ND	--	--
	N-Nitrosodi-n-propylamine	--	--	--	--	--	--	--	ND	--	--
	N-Nitrosodiphenylamine	--	--	--	--	--	--	--	ND	--	--
	PCB, Total	--	--	--	--	--	--	ND	--	--	--
	PCB-1016 (Aroclor 1016)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1221 (Aroclor 1221)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1232 (Aroclor 1232)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1242 (Aroclor 1242)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1248 (Aroclor 1248)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1254 (Aroclor 1254)	--	--	--	--	--	--	ND	--	--	ND
	PCB-1260 (Aroclor 1260)	--	--	--	--	--	--	ND	--	--	ND
	Pentachlorophenol	1	MCL	--	--	--	--	ND	--	--	--
	Phenanthrene	--	--	--	--	--	--	--	ND	--	--
	Pyrene	--	--	--	--	--	--	--	ND	--	--
	Simazine	--	--	--	--	--	--	ND	--	--	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	--	ND	ND	--	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND	--	ND	ND	--	--	--	ND
	1,1-Dichloroethene	7	MCL	ND	--	ND	ND	--	--	--	ND
	1,2,3-Trichloropropane	--	--	--	--	--	--	--	--	0.0140	--
	1,2,4-Trichlorobenzene	70	MCL	ND	--	ND	ND	--	--	--	ND
	1,2-Dibromo-3-chloropropane	--	--	--	--	--	--	--	--	--	ND
	1,2-Dibromoethane (EDB)	--	--	--	--	--	--	--	--	--	ND
	1,2-Dichlorobenzene	600	MCL	ND	--	ND	ND	--	--	--	ND
	1,2-Dichloroethane	5	MCL	ND	--	ND	ND	--	--	--	ND

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	I1-EAGL1308	I1-FH1324	I1-HOPS1202	I1-HYD1324A			I1-ICAR1217
				Location Type:	Residence	Hydrant	Residence	Hydrant			Residence
				Address:	1308 Eagle Circle	Should be I1-HYD1324A which already exists	1202 Hudson Cr	HYD-1324A			1217 Icarus Way
				Field Sample ID:	220114-I1-HT03	220118-I1-WT07	220113-I1-IT03	220118-I1-WT07	I1-DWS-I1-1324-122821-A	I1-DWS-I1-1324-122921-A	
				Sample Date:	2022-01-14	2022-01-18	2022-01-13	2022-01-18	2021-01-28	2021-01-29	2021-12-29
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2-Dichloroethene (Total)	70	MCL	ND	--	ND	ND	--	--	ND	ND
	1,2-Dichloropropane	5	MCL	ND	--	ND	ND	--	--	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	--	ND	ND	--	--	ND	ND
	Benzene	5	MCL	ND	--	ND	ND	--	--	ND	ND
	Carbon Tetrachloride	5	MCL	ND	--	ND	ND	--	--	ND	ND
	Chlorobenzene	100	MCL	ND	--	ND	ND	--	--	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	--	ND	ND	--	--	ND	ND
	Ethylbenzene	700	MCL	ND	--	ND	ND	--	--	ND	ND
	m,p-Xylene	--	--	ND	--	ND	ND	--	--	ND	ND
	Methylene chloride	5	MCL	ND	--	ND	ND	--	--	ND	ND
	o-Xylene	--	--	ND	--	ND	ND	--	--	ND	ND
	Styrene	100	MCL	ND	--	ND	ND	--	--	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	--	ND	ND	--	--	ND	ND
	Toluene	1000	MCL	ND	--	ND	ND	--	--	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	--	ND	ND	--	--	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	--	ND	ND	--	--	ND	ND
	Vinyl chloride	2	MCL	ND	--	ND	ND	--	--	ND	ND
Xylenes, Total	10000	MCL	ND	--	ND	ND	--	--	ND	ND	
Trihalomethanes (ppb)	Bromoform	--	--	--	--	--	--	8.10	--	--	--
	Dibromochloromethane	--	--	--	--	--	--	1.10	--	--	--
	Total Trihalomethanes	80	MCL	--	--	--	--	9.20	--	--	--

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	I1-MADR1832	I1-MADR1839	I1-PAPA1809		I1-TAMP1558			I1-TAMP1612	
		Location Type:	Residence	Residence	Residence		Residence			Residence	
		Address:	1832 Madrona Place	1839 Madrona Place	1809 Papaw Place		1558 Tampa Drive			1612 Tampa Drive	
		Field Sample ID:	220113-I1-HT03	220113-I1-HT02	220113-I1-HT04	220113-I1-HT05	220112-I1-BT01	220114-I1-JT02	220114-I1-JT03	220113-I1-IT04	
		Sample Date:	2022-01-13	2022-01-13	2022-01-13	2022-01-13	2022-01-12	2022-01-14	2022-01-14	2022-01-13	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	418	2650 §	2710 §	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	140
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	140
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.60	2.80	2.90	3.00	2.60	2.70	2.70	3.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.80	1.80	1.70	1.90	1.70	1.40	1.40	1.90
	Copper	1300	MCL	6.20	6.80	4.80	5.30	5.10	8.10	7.80	4.10
	Lead	15	MCL	0.270	0.160	0.170	0.150	ND	1.30	0.490	0.180
	Mercury	2	MCL	0.0640	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.60	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorobenzene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexachlorocyclopentadiene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	0.0250	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:		Location ID:			Location ID:
				I1-MADR1832	I1-MADR1839	I1-PAPA1809		I1-TAMP1558			I1-TAMP1612
				Residence	Residence	Residence		Residence			Residence
				1832 Madrona Place	1839 Madrona Place	1809 Papaw Place		1558 Tampa Drive			1612 Tampa Drive
				220113-I1-HT03	220113-I1-HT02	220113-I1-HT04	220113-I1-HT05	220112-I1-BT01	220114-I1-JT02	220114-I1-JT03	220113-I1-IT04
				2022-01-13	2022-01-13	2022-01-13	2022-01-13	2022-01-12	2022-01-14	2022-01-14	2022-01-13
				N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone I1 Post Residential and Non-Residential Flushing Data
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	I1-TAMP1630
Location Type:	Residence
Address:	1630 Tampa Drive
Field Sample ID:	220113-I1-JT05
Sample Date:	2022-01-13
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.80
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.90
	Copper	1300	MCL	4.00
	Lead	15	MCL	ND
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
Thallium	2	MCL	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Hexachlorobenzene	--	--	ND
	Hexachlorocyclopentadiene	--	--	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND

**Summary of Chemistry Results
 Zone I1 Post Residential and Non-Residential Flushing Data
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected During Emergency Response in January to March 2022 from Locations in Zone I1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	I1-TAMP1630
Location Type:	Residence
Address:	1630 Tampa Drive
Field Sample ID:	220113-I1-JT05
Sample Date:	2022-01-13
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2-Dichloroethene (Total)	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	Styrene	100	MCL	ND
	Toluene	1000	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Xylenes, Total	10000	MCL	ND