

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-BLDG1655	
Location Type:	Child Development Center	
Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
Field Sample ID:	C1-TW-0014751-22347-N-1	C1-TW-0014751-22347-N-2
Sample Date:	2023-02-03	2023-02-03
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	440-490	440-490
Field Test (ppb)	Free Chlorine	4000	MCL	440-490	440-490
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.80	1.80
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.40	1.50
	Copper	1300	MCL	17.9	11.6
	Lead	15	MCL	ND	ND
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	ND
Thallium	2	MCL	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.450	ND
	Naphthalene	17	EAL	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-BLDG1655	
Location Type:	Child Development Center	
Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
Field Sample ID:	C1-TW-0014751-22347-N-1	C1-TW-0014751-22347-N-2
Sample Date:	2023-02-03	2023-02-03
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND
	Benzene	5	MCL	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND
	Chlorobenzene	100	MCL	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND
	Methylene chloride	5	MCL	ND	ND
	o-Xylene	--	--	ND	ND
	Styrene	100	MCL	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND
	Toluene	1000	MCL	ND	ND
trans-1,2-Dichloroethene	100	MCL	ND	ND	
Trichloroethene (TCE)	5	MCL	ND	ND	

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-BLDG1655	
Location Type:	Child Development Center	
Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
Field Sample ID:	C1-TW-0014751-22347-N-1	C1-TW-0014751-22347-N-2
Sample Date:	2023-02-03	2023-02-03
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	ND
	Dichloroacetic acid	--	--	ND	ND
	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	ND
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG0445		C1-BLDG0448	C1-BLDG0584	C1-BLDG0628	C1-BLDG0644	C1-BLDG0650	
				Location Type:	Non-Residence		Non-Residence	Medical Building	Non-Residence	Non-Residence	Non-Residence	
				Address:	Building 445,WAREHOUSE/CARPENTRY SHOP		Building 448,GENERAL DEPOT WAREHOUSE	Building 584,CAREER INFORMATION CENTER, 2367 North Rd	Building 628,SHARKEY THEATRE	Building 644,MWR ISSUE STORAGE	Building 650,COMSUBPAC BLDG	
				Field Sample ID:	C1-TW-0014679-22347-N	C1-TW-0014681-22347-3-N	C1-TW-0014681-22347-N	C1-TW-0014682-22347-N	C1-TW-0014693-22347-N	C1-TW-0014696-22347-N	C1-TW-0014616-22347-N	C1-TW-0014617-22347-N
				Sample Date:	2023-02-03	2023-04-20	2023-04-20	2023-04-20	2023-04-20	2023-02-03	2023-02-03	2023-04-20
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	470	210	210	420	30.0	70.0	150	20.0	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	63.1	68.3	55.6	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	63.1	68.3	55.6	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	0.650	ND	0.630	0.620	ND	ND	0.610	
	Barium	2000	MCL	1.90	1.90	1.90	2.00	3.10	1.80	1.80	2.80	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.50	ND	ND	ND	ND	1.20	1.50	ND	
	Copper	1300	MCL	77.2	32.5	34.5	22.2	8.10	188	4.70	53.0	
	Lead	15	MCL	ND	0.170	0.150	0.170	0.190	0.210	ND	0.900	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0320	
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	0.0160	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	0.440	0.450	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG0445		C1-BLDG0448	C1-BLDG0584	C1-BLDG0628	C1-BLDG0644	C1-BLDG0650	
				Location Type:	Non-Residence		Non-Residence	Medical Building	Non-Residence	Non-Residence	Non-Residence	
				Address:	Building 445, WAREHOUSE/CARPENTRY SHOP		Building 448, GENERAL DEPOT WAREHOUSE	Building 584, CAREER INFORMATION CENTER, 2367 North Rd	Building 628, SHARKEY THEATRE	Building 644, MWR ISSUE STORAGE	Building 650, COMSUBPAC BLDG	
				Field Sample ID:	C1-TW-0014679-22347-N	C1-TW-0014681-22347-3-N	C1-TW-0014681-22347-N	C1-TW-0014682-22347-N	C1-TW-0014693-22347-N	C1-TW-0014696-22347-N	C1-TW-0014616-22347-N	C1-TW-0014617-22347-N
				Sample Date:	2023-02-03	2023-04-20	2023-04-20	2023-04-20	2023-04-20	2023-02-03	2023-02-03	2023-04-20
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND		

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG0445		C1-BLDG0448	C1-BLDG0584	C1-BLDG0628	C1-BLDG0644	C1-BLDG0650	
				Location Type:	Non-Residence		Non-Residence	Medical Building	Non-Residence	Non-Residence	Non-Residence	
				Address:	Building 445, WAREHOUSE/CARPENTRY SHOP		Building 448, GENERAL DEPOT WAREHOUSE	Building 584, CAREER INFORMATION CENTER, 2367 North Rd	Building 628, SHARKEY THEATRE	Building 644, MWR ISSUE STORAGE	Building 650, COMSUBPAC BLDG	
				Field Sample ID:	C1-TW-0014679-22347-N	C1-TW-0014681-22347-3-N	C1-TW-0014681-22347-N	C1-TW-0014682-22347-N	C1-TW-0014693-22347-N	C1-TW-0014696-22347-N	C1-TW-0014616-22347-N	C1-TW-0014617-22347-N
				Sample Date:	2023-02-03	2023-04-20	2023-04-20	2023-04-20	2023-04-20	2023-02-03	2023-02-03	2023-04-20
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	0.830	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	0.830	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.250	ND	ND	0.250	ND	ND	ND	ND	
	Bromoform	--	--	2.40	0.940	0.990	1.20	2.30	4.30	ND	1.20	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.940	0.560	0.510	0.740	0.640	0.860	ND	0.380	
	Total Trihalomethanes	80	MCL	3.59	1.50	1.50	2.19	2.94	5.16	ND	1.58	

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-BLDG0654	C1-BLDG0661	C1-BLDG0662	C1-BLDG0663	C1-BLDG0667	C1-BLDG0676	C1-BLDG0681	C1-BLDG0718	
		Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	
		Address:	Building 654,BEQ/PAQUET HALL/GALLEY, 655 Cromwell Cir	Building 661,ADMINISTRATIO N BUILDING, 661 Morton St	Building 662,NGIS - NAVY TDY (LOCKWOOD HALL), 1366 Dealey Cir	Building 663,SNIPES SHOWER	Building 667,MWR PIER SIDE FITNESS CENTER	Building 676,SVC DIV CODE 714	Building 681,N2 SECURITY BLDG	Building 718,LAUNDRY-BOQ 1729, 1260 Pierce St	
		Field Sample ID:	C1-TW-0014640-22347-N	C1-TW-0014643-22347-N	C1-TW-0014644-22347-N	C1-TW-0014645-22347-N	C1-TW-0014649-22347-N	C1-TW-0014653-22347-N	C1-TW-0014656-22347-N	C1-TW-0014663-22347-N	
		Sample Date:	2023-04-27	2023-04-27	2023-04-27	2023-02-03	2023-04-27	2023-04-20	2023-02-03	2023-04-27	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	250	180	270	410	230	90.0	60.0	430
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	210
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	59.2	ND	ND	ND	64.3	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	59.2	ND	ND	ND	64.3	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	0.110	ND	0.130	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	0.720	ND	ND
	Barium	2000	MCL	2.00	2.80	2.00	2.40	1.90	2.70	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	0.350	ND	ND
	Chromium	100	MCL	1.80	1.80	1.90	1.60	1.70	ND	ND	1.80
	Copper	1300	MCL	66.7	9.50	56.1	10.5	38.8	220	10.4	28.1
	Lead	15	MCL	0.220	ND	2.60	ND	ND	3.40	0.290	0.880
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	0.0150	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	0.430	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:	Location ID:	
				C1-BLDG0654	C1-BLDG0661	C1-BLDG0662	C1-BLDG0663	C1-BLDG0667	C1-BLDG0676	C1-BLDG0681	C1-BLDG0718
				Location Type:	Location Type:	Location Type:	Location Type:	Location Type:	Location Type:	Location Type:	
				Address:	Address:	Address:	Address:	Address:	Address:	Address:	
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-BLDG0654	C1-BLDG0661	C1-BLDG0662	C1-BLDG0663	C1-BLDG0667	C1-BLDG0676	C1-BLDG0681	C1-BLDG0718
		Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
		Address:	Building 654,BEQ/PAQUET HALL/GALLEY, 655 Cromwell Cir	Building 661,ADMINISTRATIO N BUILDING, 661 Morton St	Building 662,NGIS - NAVY TDY (LOCKWOOD HALL), 1366 Dealey Cir	Building 663,SNIPES SHOWER	Building 667,MWR PIER SIDE FITNESS CENTER	Building 676,SVC DIV CODE 714	Building 681,N2 SECURITY BLDG	Building 718,LAUNDRY-BOQ 1729, 1260 Pierce St
		Field Sample ID:	C1-TW-0014640-22347-N	C1-TW-0014643-22347-N	C1-TW-0014644-22347-N	C1-TW-0014645-22347-N	C1-TW-0014649-22347-N	C1-TW-0014653-22347-N	C1-TW-0014656-22347-N	C1-TW-0014663-22347-N
		Sample Date:	2023-04-27	2023-04-27	2023-04-27	2023-02-03	2023-04-27	2023-04-20	2023-02-03	2023-04-27
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.500	ND	0.290	ND	ND	ND
	Bromoform	--	--	0.540	2.50	ND	3.20	0.510	0.540	0.880
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.320	1.50	ND	1.00	0.330	ND	0.330
	Total Trihalomethanes	80	MCL	0.860	4.50	ND	4.49	0.840	0.540	1.21

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535	C1-BLDG1757	C1-BLDG2186	C1-BLDG451K	C1-BLDG452K	C1-BLDG9478
				Location Type:	Medical Building	Medical Building	Medical Building	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address:	Building 1407, MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd	Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road	Building 1757, FUEL DEPT CENTER MAINTENANCE	Building 2186, NEX MINI-MART HOLOMOKU, 1477 North Rd	Building 451K, PACKING PLANT	Building 452K, SORTING/ASSE MBLY WHSE	Building 9478, OCEAN TERMINAL WTRFRT STRG
				Field Sample ID:	C1-TW-0014730-22347-N	C1-TW-0014738-22347-N	C1-TW-0014739-22347-N	C1-TW-0014772-22347-N	C1-TW-0014788-22347-N	C1-TW-0014793-22347-N	C1-TW-0014794-22347-N	C1-TW-0014619-22347-N
				Sample Date:	2023-02-03	2023-04-20	2023-02-03	2023-04-20	2023-04-27	2023-04-24	2023-04-20	2023-04-20
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	420	320	450	540	530	210	30.0	290	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	55.3	ND	53.0	ND	55.2	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	55.3	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	111	ND	53.0	ND	55.2	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	0.650	ND	0.500	ND	ND	0.640	0.640	
	Barium	2000	MCL	1.80	3.40	1.80	1.80	1.90	1.90	1.90	1.80	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	ND	1.40	ND	1.90	1.60	ND	ND	ND
	Copper	1300	MCL	29.4	28.9	50.1	20.1	28.7	37.3	45.4	42.1	
	Lead	15	MCL	ND	0.650	ND	ND	0.290	0.210	0.400	0.140	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535	C1-BLDG1757	C1-BLDG2186	C1-BLDG451K	C1-BLDG452K	C1-BLDG9478
				Location Type:	Medical Building	Medical Building	Medical Building	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address:	Building 1407, MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd	Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road	Building 1757, FUEL DEPT CENTER MAINTENANCE	Building 2186, NEX MINI-MART HOLOMOKU, 1477 North Rd	Building 451K, PACKING PLANT	Building 452K, SORTING/ASSE MBLY WHSE	Building 9478, OCEAN TERMINAL WTRFRT STRG
				Field Sample ID:	C1-TW-0014730-22347-N	C1-TW-0014738-22347-N	C1-TW-0014739-22347-N	C1-TW-0014772-22347-N	C1-TW-0014788-22347-N	C1-TW-0014793-22347-N	C1-TW-0014794-22347-N	C1-TW-0014619-22347-N
				Sample Date:	2023-02-03	2023-04-20	2023-02-03	2023-04-20	2023-04-27	2023-04-24	2023-04-20	2023-04-20
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Other Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535	C1-BLDG1757	C1-BLDG2186	C1-BLDG451K	C1-BLDG452K	C1-BLDG9478	
		Location Type:	Medical Building	Medical Building	Medical Building	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	
		Address:	Building 1407, MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd	Building 1514, SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	Building 1535, MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road	Building 1757, FUEL DEPT CENTER MAINTENANCE	Building 2186, NEX MINI-MART HOLOMOKU, 1477 North Rd	Building 451K, PACKING PLANT	Building 452K, SORTING/ASSE MBLY WHSE	Building 9478, OCEAN TERMINAL WTRFRT STRG	
		Field Sample ID:	C1-TW-0014730-22347-N	C1-TW-0014738-22347-N	C1-TW-0014739-22347-N	C1-TW-0014772-22347-N	C1-TW-0014788-22347-N	C1-TW-0014793-22347-N	C1-TW-0014794-22347-N	C1-TW-0014619-22347-N	
		Sample Date:	2023-02-03	2023-04-20	2023-02-03	2023-04-20	2023-04-27	2023-04-24	2023-04-20	2023-04-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535	C1-BLDG1757	C1-BLDG2186	C1-BLDG451K	C1-BLDG452K	C1-BLDG9478
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.690	0.950	ND	0.260	ND	0.410	0.730	0.800
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.350	ND	ND	ND	ND	0.320	0.380
	Total Trihalomethanes	80	MCL	0.690	1.30	ND	0.260	ND	0.410	1.05	1.18

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		C1-HYD1183		C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444	
		Location Type:		Hydrant		Hydrant		Hydrant	Hydrant	Hydrant	
		Address:		FH ID: 512		FH ID: FH 503		FHID: 563	FHID: 479	FHID: 413	
		Field Sample ID:		C1-DL-0000531-22347 -3-N	C1-DL-0000531-22347 -N	C1-DL-0000526-22347 -3-N	C1-DL-0000526-22347 -N	C1-DL-0017789-22347 -N	C1-DL-0017791-22347 -N	C1-DL-0017788-22347 -3-N	C1-DL-0017788-22347 -N
		Sample Date:		2023-02-03	2023-02-03	2023-04-26	2023-04-26	2023-04-26	2023-04-26	2023-05-01	2023-05-01
		Sample Type:		FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	30.0	30.0	210	210	50.0	250	260	260
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	240	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	53.8	ND	ND	52.6	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	53.8	ND	ND	52.6	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	0.610	ND
	Barium	2000	MCL	8.70	8.80	1.90	1.80	2.50	1.90	2.80	2.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	1.10	1.70	1.70	1.40	1.80	1.70	1.70
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	0.0150	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	0.480	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-HYD1183		C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444	
		Location Type:	Hydrant		Hydrant		Hydrant	Hydrant	Hydrant	
		Address:	FH ID: 512		FH ID: FH 503		FHID: 563	FHID: 479	FHID: 413	
		Field Sample ID:	C1-DL-0000531-22347 -3-N	C1-DL-0000531-22347 -N	C1-DL-0000526-22347 -3-N	C1-DL-0000526-22347 -N	C1-DL-0017789-22347 -N	C1-DL-0017791-22347 -N	C1-DL-0017788-22347 -3-N	C1-DL-0017788-22347 -N
		Sample Date:	2023-02-03	2023-02-03	2023-04-26	2023-04-26	2023-04-26	2023-04-26	2023-05-01	2023-05-01
		Sample Type:	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
	Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
Chloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Dibromoacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Dichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Trichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Total Haloacetic acids		60	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C1-HYD1183		C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444	
				Field Sample ID	Sample Date	Field Sample ID	Sample Date	Field Sample ID	Sample Date	Field Sample ID	Sample Date
				Location ID: C1-HYD1183		Location ID: C1-HYD1765		Location ID: C1-HYD1769	Location ID: C1-HYD354	Location ID: C1-HYD444	
				Location Type: Hydrant		Location Type: Hydrant		Location Type: Hydrant	Location Type: Hydrant	Location Type: Hydrant	
				Address: FH ID: 512		Address: FH ID: FH 503		Address: FHID: 563	Address: FHID: 479	Address: FHID: 413	
				C1-DL-0000531-22347-3-N	C1-DL-0000531-22347-N	C1-DL-0000526-22347-3-N	C1-DL-0000526-22347-N	C1-DL-0017789-22347-N	C1-DL-0017791-22347-N	C1-DL-0017788-22347-3-N	C1-DL-0017788-22347-N
				2023-02-03	2023-02-03	2023-04-26	2023-04-26	2023-04-26	2023-04-26	2023-05-01	2023-05-01
				FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.520	0.510	ND	ND	1.20	ND	0.260	ND
	Bromoform	--	--	3.70	3.20	0.380	0.340	5.90	0.570	1.20	1.10
	Chloroform	--	--	0.260	ND	ND	ND	0.730	ND	ND	ND
	Dibromochloromethane	--	--	0.940	0.810	0.280	0.290	2.30	0.260	0.700	0.710
	Total Trihalomethanes	80	MCL	5.42	4.52	0.660	0.630	10.1	0.830	2.16	1.81

**Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-HYD817
Location Type:	Hydrant
Address:	FHID: 530A
Field Sample ID:	C1-DL-0017790-22347 -N
Sample Date:	2023-05-01
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	300
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	58.5
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	266	ISP	58.5
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.80
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.80
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
	Thallium	2	MCL	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-HYD817
Location Type:	Hydrant
Address:	FHID: 530A
Field Sample ID:	C1-DL-0017790-22347 -N
Sample Date:	2023-05-01
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene (Total)	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
	Xylenes, Total	10000	MCL	ND
	Haloacetic Acids (ppb)	Bromoacetic acid	--	--
Chloroacetic acid		--	--	ND
Dibromoacetic acid		--	--	ND
Dichloroacetic acid		--	--	ND
Trichloroacetic acid		--	--	ND
Total Haloacetic acids		60	MCL	ND

Summary of Chemistry Results
 Zone C1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in January - April 2023 from Fire Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-HYD817
Location Type:	Hydrant
Address:	FHID: 530A
Field Sample ID:	C1-DL-0017790-22347 -N
Sample Date:	2023-05-01
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.360
	Bromoform	--	--	1.50
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	0.880
	Total Trihalomethanes	80	MCL	2.74