

Summary of Chemistry Results
Zone D1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in June 2023 from Child Development Centers in Zone D1

Notes:					
ND = Not Detected					
ISP = Incident Specific Parameter					
EAL = DOH Environmental Action Level					
EPA MCL = EPA Maximum Contaminant Level					
All Results shown in Parts per Billion (ppb)					
§ - Exceeds Screening Level					
-- = No Information Available					
N (Normal) = Full compliance sample					
FD (Field Duplicate) = Extra sample taken for quality control					
N (Grab, Resample) = Additional follow-up sample					
			Location ID:	D1-BLDG0930	
			Location Type:	Child Development Center	
			Address:	Building 930,CHILD DEVELOPMENT CENTER (HALE MOKU)	
			Field Sample ID:	D1-TW-0015074-23145-N-1	D1-TW-0015074-23145-N-2
			Sample Date:	2023-06-27	2023-06-27
			Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Field Test (ppb)	Free Chlorine	4000	MCL	330-460	330-460
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	64.5	64.1
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	64.5	64.1
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.90	1.90
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	2.00	2.00
	Copper	1300	MCL	49.5	77.4
	Lead	15	MCL	1.10	0.130
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	ND
	Thallium	2	MCL	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND

Summary of Chemistry Results
Zone D1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in June 2023 from Child Development Centers in Zone D1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D1-BLDG0930	
				Location Type:	Child Development Center	
				Address:	Building 930,CHILD DEVELOPMENT CENTER (HALE MOKU)	
				Field Sample ID:	D1-TW-0015074-23145-N-1	D1-TW-0015074-23145-N-2
				Sample Date:	2023-06-27	2023-06-27
				Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	
	Benzene	5	MCL	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	
	m,p-Xylene	--	--	ND	ND	
	Methylene chloride	5	MCL	ND	ND	
	o-Xylene	--	--	ND	ND	
	Styrene	100	MCL	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	
	Toluene	1000	MCL	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	

Summary of Chemistry Results
Zone D1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples collected in June 2023 from Child Development Centers in Zone D1

Notes:					
ND = Not Detected					
ISP = Incident Specific Parameter					
EAL = DOH Environmental Action Level					
EPA MCL = EPA Maximum Contaminant Level					
All Results shown in Parts per Billion (ppb)					
§ - Exceeds Screening Level					
-- = No Information Available					
N (Normal) = Full compliance sample					
FD (Field Duplicate) = Extra sample taken for quality control					
N (Grab, Resample) = Additional follow-up sample					
				Location ID:	D1-BLDG0930
				Location Type:	Child Development Center
				Address:	Building 930,CHILD DEVELOPMENT CENTER (HALE MOKU)
				Field Sample ID:	D1-TW-0015074-23145-N-1 D1-TW-0015074-23145-N-2
				Sample Date:	2023-06-27 2023-06-27
				Sample Type:	N (Normal) N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	ND
	Dichloroacetic acid	--	--	ND	ND
	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	ND
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND