

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-FORD2160
Location Type:	Residence
Address:	2160 Ford Island Way
Field Sample ID:	C3-TW-0015755-22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	360
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.00
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.90
	Copper	1300	MCL	18.5
	Lead	15	MCL	0.130
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND
	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND
	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-FORD2160
Location Type:	Residence
Address:	2160 Ford Island Way
Field Sample ID:	C3-TW-0015755-22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
Xylenes, Total	10000	MCL	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND
	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND

**Summary of Chemistry Results
 Zone C3 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-FORD2160
Location Type:	Residence
Address:	2160 Ford Island Way
Field Sample ID:	C3-TW-0015755-22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	ND
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	ND
	Total Trihalomethanes	80	MCL	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C3-BLDG0007		Location ID: C3-BLDG0013		Location ID: C3-BLDG003B		Location ID: C3-BLDG0067		Location ID: C3-BLDG0136		Location ID: C3-BLDG0207															
				Location Type: Non-Residence	Address: Building 7, WOODWORKING SHOP (X64)	Location Type: Non-Residence	Address: Building 13, EQUIPMENT MAINTENANCE FACILITY	Location Type: Non-Residence	Address: Building 3B, TOOL SHOP	Location Type: Non-Residence		Address: Building 67, INSIDE MACHINE SHOP (X31)	Location Type: Non-Residence	Address: Building 136, PUBLIC TOILET	Location Type: Non-Residence		Address: Building 207, PHNSY PASS AND ID OFFICE												
				Field Sample ID: C3-TW-0015034-22077-N	Sample Date: 2022-04-15	Sample Type: N (Normal)	Field Sample ID: C3-TW-0015039-22077-N	Sample Date: 2022-04-06	Sample Type: N (Normal)	Field Sample ID: C3-TW-0015044-22077-N	Sample Date: 2022-04-15	Sample Type: N (Normal)	Field Sample ID: C3-TW-0014919-22077-3-N	Sample Date: 2022-04-06	Sample Type: FD (Field Duplicate)	Field Sample ID: C3-TW-0014919-22077-N	Sample Date: 2022-04-06	Sample Type: N (Normal)	Field Sample ID: C3-TW-0014930-22077-N	Sample Date: 2022-04-06	Sample Type: N (Normal)	Field Sample ID: C3-TW-0014944-22077-3-N	Sample Date: 2022-04-15	Sample Type: FD (Field Duplicate)	Field Sample ID: C3-TW-0014944-22077-N	Sample Date: 2022-04-15	Sample Type: N (Normal)		
Field Test (ppb)	Free Chlorine	4000	MCL	40.0	160	250	400	400	20.0	280	280																		
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	0.120	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.750	ND	0.980	2.00	1.90	1.90	0.990	0.840																		
	Copper	1300	MCL	161	30.0	227	34.9	31.5	35.3	38.1	28.9																		
	Lead	15	MCL	ND	ND	0.330	1.00	1.20	2.30	2.90	0.410																		
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.350	ND	ND	ND	ND	ND	0.450	0.390																		
Thallium	2	MCL	ND	ND	ND	0.0740	0.0570	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C3-BLDG0007	C3-BLDG0013	C3-BLDG003B	C3-BLDG0067		C3-BLDG0136	C3-BLDG0207			
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location Type:
					Non-Residence	Non-Residence	Non-Residence	Non-Residence		Non-Residence	Non-Residence			
					Building 7, WOODWORKING SHOP (X64)	Building 13, EQUIPMENT MAINTENANCE FACILITY	Building 3B, TOOL SHOP	Building 67, INSIDE MACHINE SHOP (X31)		Building 136, PUBLIC TOILET	Building 207, PHNSY PASS AND ID OFFICE			
					C3-TW-0015034-22077-N	C3-TW-0015039-22077-N	C3-TW-0015044-22077-N	C3-TW-0014919-22077-3-N	C3-TW-0014919-22077-N	C3-TW-0014930-22077-N	C3-TW-0014944-22077-3-N	C3-TW-0014944-22077-N		
					2022-04-15	2022-04-06	2022-04-15	2022-04-06	2022-04-06	2022-04-06	2022-04-15	2022-04-15		
					N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)		
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C3-BLDG0007	C3-BLDG0013	C3-BLDG003B	C3-BLDG0067		C3-BLDG0136	C3-BLDG0207			
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Location Type:
				Non-Residence	Building 7, WOODWORKING SHOP (X64)	Building 13, EQUIPMENT MAINTENANCE FACILITY	Building 3B, TOOL SHOP	Building 67, INSIDE MACHINE SHOP (X31)		Building 136, PUBLIC TOILET	Building 207, PHNSY PASS AND ID OFFICE			
				C3-TW-0015034-22077-N	C3-TW-0015039-22077-N	C3-TW-0015044-22077-N	C3-TW-0014919-22077-3-N	C3-TW-0014919-22077-N	C3-TW-0014930-22077-N	C3-TW-0014944-22077-3-N	C3-TW-0014944-22077-N			
				2022-04-15	2022-04-06	2022-04-15	2022-04-06	2022-04-06	2022-04-06	2022-04-06	2022-04-15	2022-04-15		
				N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)			
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	1.10	ND	ND	ND		
	Bromoform	--	--	0.930	ND	1.20	ND	ND	3.30	ND	0.590	ND		
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Dibromochloromethane	--	--	0.610	ND	0.850	ND	ND	2.30	0.520	0.560	ND		
	Total Trihalomethanes	80	MCL	1.50	ND	2.00	ND	ND	6.70	0.520	1.10	ND		

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-BLDG0215
Location Type:	Non-Residence
Address:	Building 215,OUTSIDE MACHINE SHOP (X38)
Field Sample ID:	C3-TW-0014947- 22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	70.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	1.90
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	2.00
	Copper	1300	MCL	57.4
	Lead	15	MCL	0.520
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
Thallium	2	MCL	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-BLDG0215
Location Type:	Non-Residence
Address:	Building 215,OUTSIDE MACHINE SHOP (X38)
Field Sample ID:	C3-TW-0014947- 22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
Vinyl chloride	2	MCL	ND	
Xylenes, Total	10000	MCL	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND

**Summary of Chemistry Results
 Zone C3 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-BLDG0215
Location Type:	Non-Residence
Address:	Building 215,OUTSIDE MACHINE SHOP (X38)
Field Sample ID:	C3-TW-0014947- 22077-N
Sample Date:	2022-04-06
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND
	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	0.650
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	ND
	Total Trihalomethanes	80	MCL	0.650

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C3-HYD1026	C3-HYD2298
				Location ID: C3-HYD1026	C3-HYD2298
				Location Type: Hydrant	Hydrant
				Address: FH ID: 230	C2-FH177
				Field Sample ID: C3-DL-0000538-22077-N	C3-DL-0017798-22077-N
				Sample Date: 2022-04-06	2022-04-06
				Sample Type: N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	390	200
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	2.00	3.10
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.60	1.80
	Copper	1300	MCL	2.90	3.90
	Lead	15	MCL	0.230	0.290
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	ND
	Thallium	2	MCL	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C3-HYD1026	C3-HYD2298
				Location Type:	Hydrant	Hydrant
				Address:	FH ID: 230	C2-FH177
				Field Sample ID:	C3-DL-0000538-22077 -N	C3-DL-0017798-22077 -N
				Sample Date:	2022-04-06	2022-04-06
				Sample Type:	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND

**Summary of Chemistry Results
 Zone C3 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C3-HYD1026	C3-HYD2298
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.770
	Bromoform	--	--	ND	2.20
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	1.90
	Total Trihalomethanes	80	MCL	ND	4.90

Location ID:	C3-HYD1026	C3-HYD2298
Location Type:	Hydrant	Hydrant
Address:	FH ID: 230	C2-FH177
Field Sample ID:	C3-DL-0000538-22077 -N	C3-DL-0017798-22077 -N
Sample Date:	2022-04-06	2022-04-06
Sample Type:	N (Normal)	N (Normal)