

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D4-BLDG1070H	D4-BLDG1072H	D4-BLDG1342	D4-BLDG1356	D4-BLDG2002H	D4-BLDG3179AH	D4-BLDG3365H
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Non-Residence	Non-Residence	Non-Residence
				D4-BLDG045H	Building 1070H, WAREHOUSE SUPPLY AND EQUIP	Building 1072H, WAREHOUSE SUPPLY AND EQUIP	Building 1342, OFFICE/CHEML AB-NFH WWTP	Building 1356, MAINT BLDG/STORAGE-NFH WWTP	Building 2002H, VEHICLE MAINTENANCE SHOP	Building 3179AH, FAA GATE HOUSE	Building 3365H, CLINICAL LAB EPIDEMIOLOGY - AIR FORCE, 255 Beach Rd
				D4-TW-0015610-22067-N	D4-TW-0015614-22067-N	D4-TW-0015616-22067-N	D4-TW-0015624-22067-N	D4-TW-0015629-22067-N	D4-TW-0015651-22067-N	D4-TW-0015667-22067-N	D4-TW-0015687-22067-N
				2022-03-28	2022-03-30	2022-03-30	2022-03-28	2022-03-28	2022-03-30	2022-03-28	2022-04-01
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	120	340	610	410	90.0	200	40.0	20.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	590	ND	ND	570	580	ND	810	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	52.2	ND	ND	ND	ND	67.8	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	52.2	ND	ND	ND	ND	67.8	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	0.110
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.20	1.90	1.90	1.90	2.30	10.3	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.60	1.70	5.70	1.70	1.70	1.80	1.40
	Copper	1300	MCL	55.7	48.5	30.3	37.8	44.9	53.4	39.4	272
	Lead	15	MCL	0.670	0.700	0.250	0.450	0.230	0.330	0.350	0.560
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.320	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.0510	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D4-BLDG045H	D4-BLDG1070H	D4-BLDG1072H	D4-BLDG1342	D4-BLDG1356	D4-BLDG2002H	D4-BLDG3179AH	D4-BLDG3365H
				Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address:	Building 45H,DPAA ADMIN. BLDG	Building 1070H,WAREHOUSE SUPPLY AND EQUIP	Building 1072H,WAREHOUSE SUPPLY AND EQUIP	Building 1342,OFFICE/CHEML AB-NFH WWTP	Building 1356,MAINT BLDG/STORAGE-NFH WWTP	Building 2002H,VEHICLE MAINTENANCE SHOP	Building 3179AH,FAA GATE HOUSE	Building 3365H,CLINICAL LAB EPIDEMIOLOGY - AIR FORCE, 255 Beach Rd
				Field Sample ID:	D4-TW-0015610-22067-N	D4-TW-0015614-22067-N	D4-TW-0015616-22067-N	D4-TW-0015624-22067-N	D4-TW-0015629-22067-N	D4-TW-0015651-22067-N	D4-TW-0015667-22067-N	D4-TW-0015687-22067-N
				Sample Date:	2022-03-28	2022-03-30	2022-03-30	2022-03-28	2022-03-28	2022-03-30	2022-03-28	2022-04-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D4-BLDG045H	D4-BLDG1070H	D4-BLDG1072H	D4-BLDG1342	D4-BLDG1356	D4-BLDG2002H	D4-BLDG3179AH	D4-BLDG3365H
		Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Medical Building
		Address:	Building 45H, DPAA ADMIN. BLDG	Building 1070H, WAREHOUSE SUPPLY AND EQUIP	Building 1072H, WAREHOUSE SUPPLY AND EQUIP	Building 1342, OFFICE/CHEML AB-NFH WWTP	Building 1356, MAINT BLDG/STORAGE-NFH WWTP	Building 2002H, VEHICLE MAINTENANCE SHOP	Building 3179AH, FAA GATE HOUSE	Building 3365H, CLINICAL LAB EPIDEMIOLOGY - AIR FORCE, 255 Beach Rd
		Field Sample ID:	D4-TW-0015610- 22067-N	D4-TW-0015614- 22067-N	D4-TW-0015616- 22067-N	D4-TW-0015624- 22067-N	D4-TW-0015629- 22067-N	D4-TW-0015651- 22067-N	D4-TW-0015667- 22067-N	D4-TW-0015687- 22067-N
		Sample Date:	2022-03-28	2022-03-30	2022-03-30	2022-03-28	2022-03-28	2022-03-30	2022-03-28	2022-04-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	1.10	ND	1.00
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	1.10	ND	1.00
					ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	0.840	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	5.10	0.610	5.70
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	3.40	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	9.30	0.610	5.70

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-BLDG3392H	D4-BLDG3415H
Field Test (ppb)	Free Chlorine	4000	MCL	480	20.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	570
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	2.00	2.40
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.70	1.50
	Copper	1300	MCL	115	193
	Lead	15	MCL	ND	0.400
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D4-BLDG3392H	D4-BLDG3415H
				Location Type:	Non-Residence	Non-Residence
				Address:	Building 3392H, BASE ENGINEER MAINT SHOP, 335 Gardner Ave	Building 3415H, WAREHOUSE SUP AND EQUIP BASE
				Field Sample ID:	D4-TW-0015701-22067-N	D4-TW-0015712-22067-N
				Sample Date:	2022-03-28	2022-03-28
				Sample Type:	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
Trichloroethene (TCE)	5	MCL	ND	ND	ND	
Vinyl chloride	2	MCL	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March and April 2022 from Other Buildings in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location Information	
				Location ID	Location Type
				D4-BLDG3392H	D4-BLDG3415H
				Non-Residence	Non-Residence
				Building 3392H,BASE ENGINEER MAINT SHOP, 335 Gardner Ave	Building 3415H,WAREHOUSE SUP AND EQUIP BASE
				D4-TW-0015701-22067-N	D4-TW-0015712-22067-N
				2022-03-28	2022-03-28
				N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	1.00
	Dichloroacetic acid	--	--	ND	ND
	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	1.00
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.780
	Bromoform	--	--	ND	3.60
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	2.40
	Total Trihalomethanes	80	MCL	ND	6.80

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-HYD1941	D4-HYD2390
Field Test (ppb)	Free Chlorine	4000	MCL	420	310
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	2.40	2.50
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.60	1.60
	Copper	1300	MCL	1.60	1.30
	Lead	15	MCL	0.300	0.420
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

**Summary of Chemistry Results
Zone D4 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D4-HYD1941 D4-HYD2390	
				Location Type: Hydrant Hydrant	Address: FH 1941 FH 2390
				Field Sample ID: D4-DL-0017801-22067-N	D4-DL-0017802-22067-N
				Sample Date: 2022-03-28	2022-03-28
				Sample Type: N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND
	Benzene	5	MCL	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND
	Chlorobenzene	100	MCL	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND
	Methylene chloride	5	MCL	ND	ND
	o-Xylene	--	--	ND	ND
	Styrene	100	MCL	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND
	Toluene	1000	MCL	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND
	Vinyl chloride	2	MCL	ND	ND
Xylenes, Total	10000	MCL	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	1.50
	Dichloroacetic acid	--	--	ND	ND

**Summary of Chemistry Results
 Zone D4 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone D4

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	D4-HYD1941	D4-HYD2390
Location Type:	Hydrant	Hydrant
Address:	FH 1941	FH 2390
Field Sample ID:	D4-DL-0017801-22067 -N	D4-DL-0017802-22067 -N
Sample Date:	2022-03-28	2022-03-28
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-HYD1941	D4-HYD2390
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	1.50
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	1.30
	Bromoform	--	--	0.880	5.10
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	0.550	3.60
	Total Trihalomethanes	80	MCL	1.40	10.0