

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-BALS5243	H2-CROS6538	H2-ISHI6430	H2-MAHO5460	H2-MORI6804	H2-NAUP6207	H2-NAUP6258	H2-NUHO6795	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residential Child Care	Residential Child Care	Residence	
		Address:	5243 Balsa Lane	6538 Crossandra Street	6430 Ishibashi Lane	5460 Mahogany Lane	6804 Morishige Lane	6207 Naupaka Street (CDH)	6258 Naupaka Street (CDH)	6795 Nuholani Street	
		Field Sample ID:	H2-TW-0013582-22070-A	H2-TW-0013474-22070-A	H2-TW-0013590-22070-A	H2-TW-0013598-22070-A	H2-TW-0013613-22070-A	H2-TW-0013496-22070-A	H2-TW-0013518-22070-A	H2-TW-0013553-22070-A	
		Sample Date:	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	600	860	480	620	350	590	690	550
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	250	ND	ND	240	220	ND	240
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	51.4	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	51.4	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	0.110	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	12.2	9.70	9.90	13.0	11.6	11.3	9.80	11.8
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Copper	1300	MCL	2.50	2.00	4.10	3.80	8.10	1.50	3.30	2.40
	Lead	15	MCL	0.130	ND	0.200	0.180	0.200	ND	0.200	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-BALS5243	H2-CROS6538	H2-ISHI6430	H2-MAHO5460	H2-MORI6804	H2-NAUP6207	H2-NAUP6258	H2-NUHO6795	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residential Child Care	Residential Child Care	Residence	
		Address:	5243 Balsa Lane	6538 Crossandra Street	6430 Ishibashi Lane	5460 Mahogany Lane	6804 Morishige Lane	6207 Naupaka Street (CDH)	6258 Naupaka Street (CDH)	6795 Nuholani Street	
		Field Sample ID:	H2-TW-0013582-22070-A	H2-TW-0013474-22070-A	H2-TW-0013590-22070-A	H2-TW-0013598-22070-A	H2-TW-0013613-22070-A	H2-TW-0013496-22070-A	H2-TW-0013518-22070-A	H2-TW-0013553-22070-A	
		Sample Date:	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		<b>Location ID:</b>	H2-BALS5243	H2-CROS6538	H2-ISHI6430	H2-MAHO5460	H2-MORI6804	H2-NAUP6207	H2-NAUP6258	H2-NUHO6795
		<b>Location Type:</b>	Residence	Residence	Residence	Residence	Residence	Residential Child Care	Residential Child Care	Residence
		<b>Address:</b>	5243 Balsa Lane	6538 Crossandra Street	6430 Ishibashi Lane	5460 Mahogany Lane	6804 Morishige Lane	6207 Naupaka Street (CDH)	6258 Naupaka Street (CDH)	6795 Nuholani Street
		<b>Field Sample ID:</b>	H2-TW-0013582-22070-A	H2-TW-0013474-22070-A	H2-TW-0013590-22070-A	H2-TW-0013598-22070-A	H2-TW-0013613-22070-A	H2-TW-0013496-22070-A	H2-TW-0013518-22070-A	H2-TW-0013553-22070-A
		<b>Sample Date:</b>	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22	2022-03-22
		<b>Sample Type:</b>	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	1.10
	Bromoform	--	--	1.10	1.40	3.80	1.90	ND	0.560	1.50
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.810	0.850	1.70	0.850	ND	ND	0.920
	Total Trihalomethanes	80	MCL	1.90	2.20	5.50	2.80	ND	0.560	2.50

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		<b>Location ID:</b>		H2-PAMA6305	H2-SKYV0479	H2-SKYV0966	H2-TAMA5320	
		<b>Location Type:</b>		Residence	Residence	Residence	Residence	
		<b>Address:</b>		6305 Pamakani Lane	479 Skyview Loop	966 Skyview Loop	5320 Tamarind Lane	
		<b>Field Sample ID:</b>		H2-TW-0013622-22070-A	H2-TW-0013659-22070-A	H2-TW-0013561-22070-A	H2-TW-0013663-22070-3-A	H2-TW-0013663-22070-A
		<b>Sample Date:</b>		2022-03-31	2022-03-22	2022-03-30	2022-03-23	2022-03-23
		<b>Sample Type:</b>		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
<b>Method Group</b>	<b>Analyte</b>	<b>DOH Project Screening Level</b>	<b>Basis of Project Screening Level</b>					
Field Test (ppb)	Free Chlorine	4000	MCL	760	1050	560	330	330
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	540	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	55.4	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	55.4	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	0.120	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND
	Barium	2000	MCL	8.30	12.2	9.50	13.4	13.2
	Beryllium	4	MCL	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	ND	ND
	Copper	1300	MCL	6.50	4.00	8.40	4.10	4.00
	Lead	15	MCL	0.250	0.320	0.260	ND	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	0.340	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-PAMA6305	H2-SKYV0479	H2-SKYV0966	H2-TAMA5320	
				Location Type:	Residence	Residence	Residence	Residence	
				Address:	6305 Pamakani Lane	479 Skyview Loop	966 Skyview Loop	5320 Tamarind Lane	
				Field Sample ID:	H2-TW-0013622-22070-A	H2-TW-0013659-22070-A	H2-TW-0013561-22070-A	H2-TW-0013663-22070-3-A	H2-TW-0013663-22070-A
				Sample Date:	2022-03-31	2022-03-22	2022-03-30	2022-03-23	2022-03-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
 Zone H2 Long Term Monitoring  
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Residences in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-PAMA6305	H2-SKYV0479	H2-SKYV0966	H2-TAMA5320	
				Location Type:	Residence	Residence	Residence	Residence	
				Address:	6305 Pamakani Lane	479 Skyview Loop	966 Skyview Loop	5320 Tamarind Lane	
				Field Sample ID:	H2-TW-0013622-22070-A	H2-TW-0013659-22070-A	H2-TW-0013561-22070-A	H2-TW-0013663-22070-3-A	H2-TW-0013663-22070-A
				Sample Date:	2022-03-31	2022-03-22	2022-03-30	2022-03-23	2022-03-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.690	0.560	1.50	0.660	0.530	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.530	ND	1.00	ND	ND	ND
	Total Trihalomethanes	80	MCL	1.20	0.560	2.60	0.660	0.530	

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Other Buildings in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

<b>Location ID:</b>	H2-BLDG0014
<b>Location Type:</b>	Non-Residence
<b>Address:</b>	18 Crater Rim Drive BLDG14-Maintenance Warehouse
<b>Field Sample ID:</b>	H2-TW-0011908- 22070-A
<b>Sample Date:</b>	2022-03-22
<b>Sample Type:</b>	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	490
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	510
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	6.50
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	ND
	Copper	1300	MCL	12.5
	Lead	15	MCL	0.420
	Mercury	2	MCL	ND
	Selenium	50	MCL	ND
Thallium	2	MCL	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Naphthalene	17	EAL	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Other Buildings in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

<b>Location ID:</b>	H2-BLDG0014
<b>Location Type:</b>	Non-Residence
<b>Address:</b>	18 Crater Rim Drive BLDG14-Maintenance Warehouse
<b>Field Sample ID:</b>	H2-TW-0011908- 22070-A
<b>Sample Date:</b>	2022-03-22
<b>Sample Type:</b>	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
Vinyl chloride	2	MCL	ND	
Xylenes, Total	10000	MCL	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND



**Summary of Chemistry Results  
 Zone H2 Long Term Monitoring  
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Other Buildings in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

<b>Location ID:</b>	H2-BLDG0014
<b>Location Type:</b>	Non-Residence
<b>Address:</b>	18 Crater Rim Drive BLDG14-Maintenance Warehouse
<b>Field Sample ID:</b>	H2-TW-0011908- 22070-A
<b>Sample Date:</b>	2022-03-22
<b>Sample Type:</b>	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND
	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	ND
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	ND
	Total Trihalomethanes	80	MCL	ND

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-HYD1331A	H2-HYD1646A	H2-HYD377A	
		Location Type:	Hydrant	Hydrant	Hydrant	
		Address:	Hydrant 1331	Hydrant 1646	HYD-377A	
		Field Sample ID:	H2-DL-0017758-22070 -A	H2-DL-0000688-22070 -A	H2-DL-0000620-22070 -A	
		Sample Date:	2022-03-22	2022-03-22	2022-03-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Field Test (ppb)	Free Chlorine	4000	MCL	660	340	110
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND
	Barium	2000	MCL	11.9	5.10	6.00
	Beryllium	4	MCL	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND
	Copper	1300	MCL	4.30	1.30	2.90
	Lead	15	MCL	0.990	0.840	1.20
	Mercury	2	MCL	ND	ND	ND
	Selenium	50	MCL	ND	ND	ND
Thallium	2	MCL	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND

**Summary of Chemistry Results  
Zone H2 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-HYD1331A	H2-HYD1646A	H2-HYD377A
		Location Type:	Hydrant	Hydrant	Hydrant
		Address:	Hydrant 1331	Hydrant 1646	HYD-377A
		Field Sample ID:	H2-DL-0017758-22070 -A	H2-DL-0000688-22070 -A	H2-DL-0000620-22070 -A
		Sample Date:	2022-03-22	2022-03-22	2022-03-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND
	Benzene	5	MCL	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND
	Chlorobenzene	100	MCL	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND
	Methylene chloride	5	MCL	ND	ND
	o-Xylene	--	--	ND	ND
	Styrene	100	MCL	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND
	Toluene	1000	MCL	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND
	Vinyl chloride	2	MCL	ND	ND
Xylenes, Total	10000	MCL	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	4.50
	Dichloroacetic acid	--	--	ND	ND

**Summary of Chemistry Results  
 Zone H2 Long Term Monitoring  
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples Collected in March 2022 from Fire Hydrants in Zone H2**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-HYD1331A	H2-HYD1646A	H2-HYD377A	
		Location Type:	Hydrant	Hydrant	Hydrant	
		Address:	Hydrant 1331	Hydrant 1646	HYD-377A	
		Field Sample ID:	H2-DL-0017758-22070 -A	H2-DL-0000688-22070 -A	H2-DL-0000620-22070 -A	
		Sample Date:	2022-03-22	2022-03-22	2022-03-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	4.50
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	1.90
	Bromoform	--	--	0.720	0.780	21.2
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.560	ND	7.50
	Total Trihalomethanes	80	MCL	1.30	0.780	30.6