

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C2-CROM5012		Location ID: C2-HALE4583	
				Location Type: Residence	Address: 5012 Crommelin Street	Location Type: Residence	Address: 4583 Hale Alii Avenue
				Field Sample ID: C2-TW-0012424-22107-N	Sample Date: 2022-05-04	Sample Type: N (Normal)	
							Field Sample ID: C2-TW-0012433-22107-3-N
							Field Sample ID: C2-TW-0012433-22107-N
							Sample Date: 2022-05-11
							Sample Date: 2022-05-11
							Sample Type: FD (Field Duplicate)
							Sample Type: N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	260	260	260	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	
	Barium	2000	MCL	2.10	2.60	2.00	
	Beryllium	4	MCL	ND	0.290	ND	
	Cadmium	5	MCL	ND	0.270	ND	
	Chromium	100	MCL	0.750	1.10	0.720	
	Copper	1300	MCL	16.3	64.3	63.4	
	Lead	15	MCL	ND	0.550	0.210	
	Mercury	2	MCL	ND	ND	ND	
	Selenium	50	MCL	0.880	ND	0.390	
	Thallium	2	MCL	ND	0.410	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C2-CROM5012		Location ID: C2-HALE4583	
				Location Type: Residence	Address: 5012 Crommelin Street	Location Type: Residence	Address: 4583 Hale Alii Avenue
				Field Sample ID: C2-TW-0012424-22107-N	Sample Date: 2022-05-04	Sample Type: N (Normal)	
							Field Sample ID: C2-TW-0012433-22107-3-N
							Field Sample ID: C2-TW-0012433-22107-N
							Sample Date: 2022-05-11
							Sample Date: 2022-05-11
							Sample Type: FD (Field Duplicate)
							Sample Type: N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	
	Dibromoacetic acid	--	--	ND	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	ND	

**Summary of Chemistry Results
 Zone C2 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C2-HALE4583	
				C2-CROM5012	Residence	Residence
				Location Type:	Residence	
				Address:	5012 Crommelin Street	4583 Hale Alii Avenue
				Field Sample ID:	C2-TW-0012424-22107-N	C2-TW-0012433-22107-3-N C2-TW-0012433-22107-N
				Sample Date:	2022-05-04	2022-05-11 2022-05-11
				Sample Type:	N (Normal)	FD (Field Duplicate) N (Normal)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.810	ND	ND
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	0.610	ND	ND
	Total Trihalomethanes	80	MCL	1.40	ND	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C2-BLDG0164		C2-BLDG0206	C2-BLDG0220	C2-BLDG0221	C2-BLDG0268	C2-BLDG0327	C2-BLDG1601																																		
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:																														
				C2-BLDG0164	Non-Residence	Building 164,GENERAL WAREHOUSE SUPPLY	C2-TW-0014803-22107-3-N	2022-05-04	FD (Field Duplicate)	C2-BLDG0206	Non-Residence	Building 206,FIRE STATION	C2-TW-0014859-22107-N	2022-05-05	N (Normal)	C2-BLDG0220	Non-Residence	Building 220,JOINT POW/MIA ACCTG COMMAND	C2-TW-0014862-22107-N	2022-05-09	N (Normal)	C2-BLDG0221	Non-Residence	Building 221,PULLER HALL, MARINE BARRACKS	C2-TW-0014863-22107-N	2022-05-05	N (Normal)	C2-BLDG0268	Non-Residence	Building 268,POLICE STATION & GENERAL ADMIN BLDG	C2-TW-0014867-22107-N	2022-05-05	N (Normal)	C2-BLDG0327	Non-Residence	Building 327,TRANSPORTATION OFFICE	C2-TW-0014882-22107-N	2022-05-05	N (Normal)	C2-BLDG1601	Non-Residence	Building 1601,CHAPEL OFC/FELLOWSHIP HALL	C2-TW-0014819-22107-N	2022-05-06	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	220	220	500	120	100	190	240	270																																		
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND																																		
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND																																		
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Barium	2000	MCL	1.10	1.10	2.00	6.10	2.20	2.30	2.10	1.80																																		
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Cadmium	5	MCL	0.550	0.530	ND	ND	ND	ND	ND	ND																																		
	Chromium	100	MCL	ND	ND	0.730	0.700	0.650	ND	0.970	0.560																																		
	Copper	1300	MCL	3.70	4.10	7.80	62.7	82.0	2.90	8.40	14.7																																		
	Lead	15	MCL	5.70	6.00	ND	2.10	ND	ND	1.30	ND																																		
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Selenium	50	MCL	0.430	0.730	1.30	ND	ND	ND	ND	0.780																																		
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND																																		
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND																																		
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND																																			

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C2-BLDG0164		C2-BLDG0206	C2-BLDG0220	C2-BLDG0221	C2-BLDG0268	C2-BLDG0327	C2-BLDG1601
				Location Type: Non-Residence		Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address: Building 164,GENERAL WAREHOUSE SUPPLY		Building 206,FIRE STATION	Building 220,JOINT POW/MIA ACCTG COMMAND	Building 221,PULLER HALL, MARINE BARRACKS	Building 268,POLICE STATION & GENERAL ADMIN BLDG	Building 327,TRANSPORTATION OFFICE	Building 1601,CHAPEL OFC/FELLOWSHIP HALL
				Field Sample ID: C2-TW-0014803-22107-3-N	C2-TW-0014803-22107-N	C2-TW-0014859-22107-N	C2-TW-0014862-22107-N	C2-TW-0014863-22107-N	C2-TW-0014867-22107-N	C2-TW-0014882-22107-N	C2-TW-0014819-22107-N
				Sample Date: 2022-05-04	2022-05-04	2022-05-05	2022-05-09	2022-05-05	2022-05-05	2022-05-05	2022-05-06
				Sample Type: FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C2-BLDG0164		C2-BLDG0206	C2-BLDG0220	C2-BLDG0221	C2-BLDG0268	C2-BLDG0327	C2-BLDG1601
		Location Type:	Non-Residence		Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
		Address:	Building 164,GENERAL WAREHOUSE SUPPLY		Building 206,FIRE STATION	Building 220,JOINT POW/MIA ACCTG COMMAND	Building 221,PULLER HALL, MARINE BARRACKS	Building 268,POLICE STATION & GENERAL ADMIN BLDG	Building 327,TRANSPORTATION OFFICE	Building 1601,CHAPEL OFC/FELLOWSHIP HALL
		Field Sample ID:	C2-TW-0014803-22107-3-N	C2-TW-0014803-22107-N	C2-TW-0014859-22107-N	C2-TW-0014862-22107-N	C2-TW-0014863-22107-N	C2-TW-0014867-22107-N	C2-TW-0014882-22107-N	C2-TW-0014819-22107-N
		Sample Date:	2022-05-04	2022-05-04	2022-05-05	2022-05-09	2022-05-05	2022-05-05	2022-05-05	2022-05-06
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.850	0.780	0.650	1.30	ND	0.800	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.610	0.590	ND	0.620	ND
	Total Trihalomethanes	80	MCL	0.850	0.780	1.30	1.90	ND	1.40	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C2-BLDG1750
Location Type:	Medical Building
Address:	Building 1750,SHIPYARD MEDICAL CLINIC- PEARL HARBOR, 490 Central Ave
Field Sample ID:	C2-TW-0014833- 22107-N
Sample Date:	2022-05-04
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	40.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.00
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	0.800
	Copper	1300	MCL	107
	Lead	15	MCL	ND
	Mercury	2	MCL	ND
	Selenium	50	MCL	1.50
Thallium	2	MCL	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
	Naphthalene	17	EAL	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID: C2-BLDG1750
Location Type: Medical Building
Address: Building
 1750,SHIPYARD
 MEDICAL CLINIC-
 PEARL HARBOR, 490
 Central Ave
Field Sample ID: C2-TW-0014833-
 22107-N
Sample Date: 2022-05-04
Sample Type: N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND
	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
trans-1,2-Dichloroethene	100	MCL	ND	
Trichloroethene (TCE)	5	MCL	ND	

**Summary of Chemistry Results
 Zone C2 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C2-BLDG1750
Location Type:	Medical Building
Address:	Building 1750,SHIPYARD MEDICAL CLINIC- PEARL HARBOR, 490 Central Ave
Field Sample ID:	C2-TW-0014833- 22107-N
Sample Date:	2022-05-04
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND
	Xylenes, Total	10000	MCL	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND
	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND
	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	ND
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	ND
	Total Trihalomethanes	80	MCL	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C2-HYD1230	C2-HYD2089	C2-HYD421	C2-HYD424	C2-HYD650	C2-HYD656	C2-HYD660	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	C2-FH209B	C2-FH204	C2-FH246	FH ID: 315	Hydrant 268	Hydrant 301	Hydrant 303	
		Field Sample ID:	C2-DL-0017792-22107 -N	C2-DL-0017795-22107 -N	C2-DL-0017796-22107 -N	C2-DL-0000534-22107 -N	C2-DL-0017794-22107 -N	C2-DL-0017793-22107 -N	C2-DL-0017797-22107 -N	
		Sample Date:	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C2-HYD1230	C2-HYD2089	C2-HYD421	C2-HYD424	C2-HYD650	C2-HYD656	C2-HYD660
Field Test (ppb)	Free Chlorine	4000	MCL	430	70.0	70.0	80.0	410	300	30.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	390	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	4.00	3.00	ND	ND	2.30	4.00	ND
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.690	ND	0.700	0.560	0.650	0.950	0.610
	Copper	1300	MCL	2.20	ND	9.20	8.70	4.20	3.60	ND
	Lead	15	MCL	ND	ND	ND	2.80	ND	0.380	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.550	1.10	ND	0.380	ND	0.590
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	0.0720	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C2-HYD1230	C2-HYD2089	C2-HYD421	C2-HYD424	C2-HYD650	C2-HYD656	C2-HYD660
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	C2-FH209B	C2-FH204	C2-FH246	FH ID: 315	Hydrant 268	Hydrant 301	Hydrant 303
		Field Sample ID:	C2-DL-0017792-22107 -N	C2-DL-0017795-22107 -N	C2-DL-0017796-22107 -N	C2-DL-0000534-22107 -N	C2-DL-0017794-22107 -N	C2-DL-0017793-22107 -N	C2-DL-0017797-22107 -N
		Sample Date:	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone C2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C2-HYD1230	C2-HYD2089	C2-HYD421	C2-HYD424	C2-HYD650	C2-HYD656	C2-HYD660
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	C2-FH209B	C2-FH204	C2-FH246	FH ID: 315	Hydrant 268	Hydrant 301	Hydrant 303
		Field Sample ID:	C2-DL-0017792-22107 -N	C2-DL-0017795-22107 -N	C2-DL-0017796-22107 -N	C2-DL-0000534-22107 -N	C2-DL-0017794-22107 -N	C2-DL-0017793-22107 -N	C2-DL-0017797-22107 -N
		Sample Date:	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05	2022-05-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.540	ND	ND	ND	0.710	ND
	Bromoform	--	--	2.80	1.30	ND	ND	1.60	0.910
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	1.60	0.750	ND	ND	1.50	ND
	Total Trihalomethanes	80	MCL	5.00	2.00	ND	ND	3.70	0.910