

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-CROM4935
Location Type:	Residence
Address:	4935 Crommelin Street
Field Sample ID:	C3-TW-0012180-22107-N
Sample Date:	2022-05-13
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	150
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.10
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	0.840
	Copper	1300	MCL	15.0
	Lead	15	MCL	0.480
	Mercury	2	MCL	0.0420
	Selenium	50	MCL	2.10
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND
	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND
	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-CROM4935
Location Type:	Residence
Address:	4935 Crommelin Street
Field Sample ID:	C3-TW-0012180-22107-N
Sample Date:	2022-05-13
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
Xylenes, Total	10000	MCL	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND
	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND

**Summary of Chemistry Results
 Zone C3 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-CROM4935
Location Type:	Residence
Address:	4935 Crommelin Street
Field Sample ID:	C3-TW-0012180-22107-N
Sample Date:	2022-05-13
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	1.10
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	0.700
	Total Trihalomethanes	80	MCL	1.80

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C3-BLDG0056		C3-BLDG0074	C3-BLDG0140	C3-BLDG0141	C3-BLDG1456	C3-BLDG1700	C3-CUSH0658
				Location Type: Non-Residence		Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence
				Address: Building 56, PEARL HAWAII FEDERAL CREDIT UNION		Building 74, PUBLIC TOILET	Building 140, ENVIRONMENTL PROTECTION/OSHA	Building 141, PUBLIC TOILET	Building 1456, PIPE SHOP (X56)	Building 1700, PERSONNEL SUPPORT BUILDING	PUBLIC TOILET
				Field Sample ID: C3-TW-0015048-22107-3-N	C3-TW-0015048-22107-N	C3-TW-0014922-22107-N	C3-TW-0014932-22107-N	C3-TW-0014933-22107-N	C3-TW-0014981-22107-N	C3-TW-0014993-22107-N	C3-TW-0016036-22107-N
				Sample Date: 2022-05-13	2022-05-13	2022-05-13	2022-05-17	2022-05-13	2022-05-13	2022-05-13	2022-05-13
				Sample Type: FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	50.0	50.0	500	320	420	520	260	190
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	50.4	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	50.4	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	0.110	ND	ND	ND	0.110	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.10	2.00	1.90	1.90	1.90	2.10	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	1.10	1.40	0.910	0.910	1.10	1.10
	Copper	1300	MCL	16.1	16.4	15.5	19.4	36.0	40.2	130	24.7
	Lead	15	MCL	0.550	0.480	0.130	ND	ND	ND	0.730	0.320
	Mercury	2	MCL	0.0410	0.0400	0.0350	ND	0.0370	0.0430	0.0350	ND
	Selenium	50	MCL	1.10	ND	2.10	1.70	1.60	1.60	ND	ND
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C3-BLDG0056	C3-BLDG0074	C3-BLDG0140	C3-BLDG0141	C3-BLDG1456	C3-BLDG1700	C3-CUSH0658	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence
					Building 56, PEARL HAWAII FEDERAL CREDIT UNION	Building 74, PUBLIC TOILET	Building 140, ENVIRONMENTL PROTECTION/OSHA	Building 141, PUBLIC TOILET	Building 1456, PIPE SHOP (X56)	Building 1700, PERSONNEL SUPPORT BUILDING	PUBLIC TOILET	
					C3-TW-0015048-22107-3-N	C3-TW-0015048-22107-N	C3-TW-0014922-22107-N	C3-TW-0014932-22107-N	C3-TW-0014933-22107-N	C3-TW-0014981-22107-N	C3-TW-0014993-22107-N	C3-TW-0016036-22107-N
					2022-05-13	2022-05-13	2022-05-13	2022-05-17	2022-05-13	2022-05-13	2022-05-13	2022-05-13
					FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C3-BLDG0056	C3-BLDG0074	C3-BLDG0140	C3-BLDG0141	C3-BLDG1456	C3-BLDG1700	C3-CUSH0658		
		Location Type:	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence	Non-Residence		
		Address:	Building 56,PEARL HAWAII FEDERAL CREDIT UNION	Building 74,PUBLIC TOILET	Building 140,ENVIRONMENTL PROTECTION/OSHA	Building 141,PUBLIC TOILET	Building 1456,PIPE SHOP (X56)	Building 1700,PERSONNEL SUPPORT BUILDING	PUBLIC TOILET		
		Field Sample ID:	C3-TW-0015048-22107-3-N	C3-TW-0015048-22107-N	C3-TW-0014922-22107-N	C3-TW-0014932-22107-N	C3-TW-0014933-22107-N	C3-TW-0014981-22107-N	C3-TW-0014993-22107-N	C3-TW-0016036-22107-N	
		Sample Date:	2022-05-13	2022-05-13	2022-05-13	2022-05-17	2022-05-13	2022-05-13	2022-05-13	2022-05-13	
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	
	Bromoform	--	--	0.840	0.820	0.600	ND	0.670	ND	0.920	1.30
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	ND	0.690	ND	0.510	ND	0.520	0.730
	Total Trihalomethanes	80	MCL	0.840	0.820	1.30	ND	1.20	ND	1.40	2.00

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C3-HYD1026	C3-HYD2298
				Location ID: C3-HYD1026	C3-HYD2298
				Location Type: Hydrant	Hydrant
				Address: FH ID: 230	C2-FH177
				Field Sample ID: C3-DL-0000538-22107-N	C3-DL-0017798-22107-N
				Sample Date: 2022-05-17	2022-05-17
				Sample Type: N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	220	170
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.90	3.80
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.20	1.20
	Copper	1300	MCL	3.40	2.30
	Lead	15	MCL	1.20	0.340
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	1.30	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

**Summary of Chemistry Results
Zone C3 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:
				C3-HYD1026	Hydrant	FH ID: 230	C3-DL-0000538-22107-N	2022-05-17	N (Normal)
				C3-HYD2298	Hydrant	C2-FH177	C3-DL-0017798-22107-N	2022-05-17	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND					
	1,2-Dichlorobenzene	600	MCL	ND					
	1,2-Dichloroethane	5	MCL	ND					
	1,2-Dichloroethene	70	MCL	ND					
	1,2-Dichloropropane	5	MCL	ND					
	1,4-Dichlorobenzene	75	MCL	ND					
	Benzene	5	MCL	ND					
	Carbon Tetrachloride	5	MCL	ND					
	Chlorobenzene	100	MCL	ND					
	cis-1,2-Dichloroethene	70	MCL	ND					
	Ethylbenzene	700	MCL	ND					
	m,p-Xylene	--	--	ND					
	Methylene chloride	5	MCL	ND					
	o-Xylene	--	--	ND					
	Styrene	100	MCL	ND					
	Tetrachloroethene (PCE)	5	MCL	ND					
	Toluene	1000	MCL	ND					
	trans-1,2-Dichloroethene	100	MCL	ND					
	Trichloroethene (TCE)	5	MCL	ND					
	Vinyl chloride	2	MCL	ND					
	Xylenes, Total	10000	MCL	ND					
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND					
	Chloroacetic acid	--	--	ND					
	Dibromoacetic acid	--	--	ND					
	Dichloroacetic acid	--	--	ND					

**Summary of Chemistry Results
 Zone C3 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone C3

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C3-HYD1026	C3-HYD2298
Location Type:	Hydrant	Hydrant
Address:	FH ID: 230	C2-FH177
Field Sample ID:	C3-DL-0000538-22107 -N	C3-DL-0017798-22107 -N
Sample Date:	2022-05-17	2022-05-17
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	C3-HYD1026	C3-HYD2298
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.750
	Bromoform	--	--	0.740	5.60
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	2.40
	Total Trihalomethanes	80	MCL	0.740	8.70