

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ANDE2806	F2-ANDE2924	F2-ANDE2988	F2-ANDE3103	F2-ARIZ2838	F2-ARIZ2863	F2-ARIZ2871	F2-ARIZ2887	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2806 Anderson Avenue	2924 Anderson Avenue	2988 Anderson Avenue	3103 Anderson Avenue	2838 Arizona Road	2863 Arizona Road	2871 Arizona Road	2887 Arizona Road	
		Field Sample ID:	F2-TW-0010734-22100-N	F2-TW-0009593-22100-N	F2-TW-0009606-22100-N	F2-TW-0010769-22100-N	F2-TW-0010997-22100-N	F2-TW-0011007-22100-N	F2-TW-0011011-22100-N	F2-TW-0011016-22100-N	
		Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-29	2022-05-16	2022-04-21	2022-04-21	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	490	420	520	450	320	460	10.0	430
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	86.5	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	86.5	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.00	2.10	2.10	2.10	2.00	2.20	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.980	0.880	1.00	1.30	0.860	0.970	0.830	1.10
	Copper	1300	MCL	13.7	5.40	3.30	9.00	16.6	9.30	15.3	9.80
	Lead	15	MCL	0.190	0.140	0.140	ND	0.760	0.310	0.280	0.240
	Mercury	2	MCL	ND	ND	ND	ND	0.0390	ND	ND	ND
	Selenium	50	MCL	0.610	0.550	0.420	ND	ND	0.780	0.690	0.790
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	0.0710	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ANDE2806	F2-ANDE2924	F2-ANDE2988	F2-ANDE3103	F2-ARIZ2838	F2-ARIZ2863	F2-ARIZ2871	F2-ARIZ2887	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2806 Anderson Avenue	2924 Anderson Avenue	2988 Anderson Avenue	3103 Anderson Avenue	2838 Arizona Road	2863 Arizona Road	2871 Arizona Road	2887 Arizona Road	
		Field Sample ID:	F2-TW-0010734-22100-N	F2-TW-0009593-22100-N	F2-TW-0009606-22100-N	F2-TW-0010769-22100-N	F2-TW-0010997-22100-N	F2-TW-0011007-22100-N	F2-TW-0011011-22100-N	F2-TW-0011016-22100-N	
		Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-29	2022-05-16	2022-04-21	2022-04-21	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-ANDE2806	F2-ANDE2924	F2-ANDE2988	F2-ANDE3103	F2-ARIZ2838	F2-ARIZ2863	F2-ARIZ2871	F2-ARIZ2887
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ANDE2806	F2-ANDE2924	F2-ANDE2988	F2-ANDE3103	F2-ARIZ2838	F2-ARIZ2863	F2-ARIZ2871	F2-ARIZ2887	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2806 Anderson Avenue	2924 Anderson Avenue	2988 Anderson Avenue	3103 Anderson Avenue	2838 Arizona Road	2863 Arizona Road	2871 Arizona Road	2887 Arizona Road	
		Field Sample ID:	F2-TW-0010734-22100-N	F2-TW-0009593-22100-N	F2-TW-0009606-22100-N	F2-TW-0010769-22100-N	F2-TW-0010997-22100-N	F2-TW-0011007-22100-N	F2-TW-0011011-22100-N	F2-TW-0011016-22100-N	
		Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-29	2022-05-16	2022-04-21	2022-04-21	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-ANDE2806	F2-ANDE2924	F2-ANDE2988	F2-ANDE3103	F2-ARIZ2838	F2-ARIZ2863	F2-ARIZ2871	F2-ARIZ2887
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	1.40	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	1.40	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	1.00	ND	ND	ND	ND	2.20	ND
	Bromoform	--	--	ND	1.90	ND	1.30	0.610	ND	34.7	ND
	Chloroform	--	--	ND	0.830	ND	ND	ND	ND	3.20	ND
	Dibromochloromethane	--	--	ND	2.00	ND	ND	ND	ND	12.4	ND
	Total Trihalomethanes	80	MCL	ND	5.70	ND	1.30	0.610	ND	52.5	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ARIZ3005	F2-BENF5433	F2-BRID3089	F2-CATL5215	F2-CATL5219	F2-CATL5220		F2-CATL5266	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence	
		Address:	3005 Arizona Road	5433 Benfold Lane	3089 Bridges Street	5215 Catlin Lane	5219 Catlin Lane	5220 Catlin Lane		5266 Catlin Lane	
		Field Sample ID:	F2-TW-0011027-22100-N	F2-TW-0011061-22100-N	F2-TW-0011077-22100-N	F2-TW-0011083-22100-N	F2-TW-0011085-22100-N	F2-TW-0011086-22100-3-N	F2-TW-0011086-22100-N	F2-TW-0011101-22100-N	
		Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-22	2022-04-21	2022-04-18	2022-04-18	2022-04-21	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	460	520	490	500	140	200	200	350
Field Test (ppb)	Free Chlorine	4000	MCL	460	520	490	500	140	200	200	350
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	0.130	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	2.00	2.10	1.90	2.00	2.00	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.990	1.00	1.00	1.00	1.10	0.800	0.810	1.00
	Copper	1300	MCL	7.70	48.2	7.10	4.90	27.5	9.80	9.30	41.6
	Lead	15	MCL	0.190	1.10	0.240	ND	0.910	0.530	0.470	0.210
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.420	0.430	ND	0.330	0.530	ND	ND	0.500
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-ARIZ3005	F2-BENF5433	F2-BRID3089	F2-CATL5215	F2-CATL5219	F2-CATL5220		F2-CATL5266
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	3005 Arizona Road	5433 Benfold Lane	3089 Bridges Street	5215 Catlin Lane	5219 Catlin Lane	5220 Catlin Lane		5266 Catlin Lane
				Field Sample ID:	F2-TW-0011027-22100-N	F2-TW-0011061-22100-N	F2-TW-0011077-22100-N	F2-TW-0011083-22100-N	F2-TW-0011085-22100-N	F2-TW-0011086-22100-3-N	F2-TW-0011086-22100-N	F2-TW-0011101-22100-N
				Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-22	2022-04-21	2022-04-18	2022-04-18	2022-04-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-ARIZ3005	F2-BENF5433	F2-BRID3089	F2-CATL5215	F2-CATL5219	F2-CATL5220		F2-CATL5266
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	3005 Arizona Road	5433 Benfold Lane	3089 Bridges Street	5215 Catlin Lane	5219 Catlin Lane	5220 Catlin Lane		5266 Catlin Lane
		Field Sample ID:	F2-TW-0011027-22100-N	F2-TW-0011061-22100-N	F2-TW-0011077-22100-N	F2-TW-0011083-22100-N	F2-TW-0011085-22100-N	F2-TW-0011086-22100-3-N	F2-TW-0011086-22100-N	F2-TW-0011101-22100-N
		Sample Date:	2022-04-20	2022-04-21	2022-04-20	2022-04-22	2022-04-21	2022-04-18	2022-04-18	2022-04-21
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	0.530	ND	ND	ND	ND
	Bromoform	--	--	0.540	1.50	1.20	ND	0.750	ND	0.750
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	1.10	1.00	ND	0.770	ND	0.610
	Total Trihalomethanes	80	MCL	0.540	2.60	2.80	ND	1.50	ND	1.40

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-CATL5272	F2-CATL5304	F2-DEWE3235	F2-DICK0582	F2-DORI2266C	F2-DORI2277C	F2-ENGE4038	F2-ENGE4053	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5272 Catlin Lane	5304 Catlin Lane	3235 Dewert Lane	582 Dickson Lane	2266C Doris Miller Loop	2277C Doris Miller Loop	4038 Enger Street	4053 Enger Street	
		Field Sample ID:	F2-TW-0011104-22100-N	F2-TW-0011116-22100-N	F2-TW-0011172-22100-N	F2-TW-0011181-22100-N	F2-TW-0011394-22100-N	F2-TW-0011438-22100-N	F2-TW-0011452-22100-N	F2-TW-0011457-22100-N	
		Sample Date:	2022-04-22	2022-04-19	2022-04-20	2022-04-21	2022-04-21	2022-04-21	2022-04-20	2022-04-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	460	480	430	360	500	460	470	500
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.00	2.00	1.90	2.00	2.00	2.10	2.10
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.950	0.910	0.950	1.10	0.900	1.00	0.970	1.00
	Copper	1300	MCL	14.2	12.2	18.4	8.70	23.7	38.0	3.00	2.80
	Lead	15	MCL	0.230	0.250	0.530	0.180	ND	ND	0.170	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0320
	Selenium	50	MCL	0.480	0.790	ND	0.620	0.650	0.630	0.560	0.750
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	0.810	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-CATL5272	F2-CATL5304	F2-DEWE3235	F2-DICK0582	F2-DORI2266C	F2-DORI2277C	F2-ENGE4038	F2-ENGE4053	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5272 Catlin Lane	5304 Catlin Lane	3235 Dewert Lane	582 Dickson Lane	2266C Doris Miller Loop	2277C Doris Miller Loop	4038 Enger Street	4053 Enger Street	
		Field Sample ID:	F2-TW-0011104-22100-N	F2-TW-0011116-22100-N	F2-TW-0011172-22100-N	F2-TW-0011181-22100-N	F2-TW-0011394-22100-N	F2-TW-0011438-22100-N	F2-TW-0011452-22100-N	F2-TW-0011457-22100-N	
		Sample Date:	2022-04-22	2022-04-19	2022-04-20	2022-04-21	2022-04-21	2022-04-21	2022-04-20	2022-04-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-CATL5272	F2-CATL5304	F2-DEWE3235	F2-DICK0582	F2-DORI2266C	F2-DORI2277C	F2-ENGE4038	F2-ENGE4053
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5272 Catlin Lane	5304 Catlin Lane	3235 Dewert Lane	582 Dickson Lane	2266C Doris Miller Loop	2277C Doris Miller Loop	4038 Enger Street	4053 Enger Street
		Field Sample ID:	F2-TW-0011104-22100-N	F2-TW-0011116-22100-N	F2-TW-0011172-22100-N	F2-TW-0011181-22100-N	F2-TW-0011394-22100-N	F2-TW-0011438-22100-N	F2-TW-0011452-22100-N	F2-TW-0011457-22100-N
		Sample Date:	2022-04-22	2022-04-19	2022-04-20	2022-04-21	2022-04-21	2022-04-21	2022-04-20	2022-04-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	10.3	0.990	ND	ND	ND	0.840	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	2.40	ND	ND	ND	ND	0.690	ND
	Total Trihalomethanes	80	MCL	12.0	0.990	ND	ND	ND	1.50	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-FINC4151	F2-GORD2627	F2-GORD2669	F2-GORD2698	F2-GORD2847	F2-HAIL3104	F2-HAMM0827	F2-HAMM5304	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	4151 Fincher Street	2627 Gordon Street	2669 Gordon Street	2698 Gordon Street	2847 Gordon Street	3104 Hailey Court	827 Hammerberg Street	5304 Hammond Lane	
		Field Sample ID:	F2-TW-0011481-22100-N	F2-TW-0011546-22100-N	F2-TW-0011571-22100-N	F2-TW-0011580-22100-N	F2-TW-0011616-22100-N	F2-TW-0011636-22100-N	F2-TW-0011660-22100-N	F2-TW-0011667-22100-N	
		Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-21	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	520	480	450	470	550	110	420	660
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	2.30	2.30	2.30	2.10	2.30	2.20	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.00	0.950	1.00	0.800	1.00	1.00	0.900
	Copper	1300	MCL	7.90	13.3	4.60	2.80	9.20	35.2	26.2	5.80
	Lead	15	MCL	0.360	0.360	0.320	ND	0.200	0.270	0.180	0.220
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.600	0.570	0.350	0.430	0.670	0.500	0.450	0.710
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-FINC4151	F2-GORD2627	F2-GORD2669	F2-GORD2698	F2-GORD2847	F2-HAIL3104	F2-HAMM0827	F2-HAMM5304
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	4151 Fincher Street	2627 Gordon Street	2669 Gordon Street	2698 Gordon Street	2847 Gordon Street	3104 Hailey Court	827 Hammerberg Street	5304 Hammond Lane
				Field Sample ID:	F2-TW-0011481-22100-N	F2-TW-0011546-22100-N	F2-TW-0011571-22100-N	F2-TW-0011580-22100-N	F2-TW-0011616-22100-N	F2-TW-0011636-22100-N	F2-TW-0011660-22100-N	F2-TW-0011667-22100-N
				Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-FINC4151	F2-GORD2627	F2-GORD2669	F2-GORD2698	F2-GORD2847	F2-HAIL3104	F2-HAMM0827	F2-HAMM5304
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	4151 Fincher Street	2627 Gordon Street	2669 Gordon Street	2698 Gordon Street	2847 Gordon Street	3104 Hailey Court	827 Hammerberg Street	5304 Hammond Lane
		Field Sample ID:	F2-TW-0011481-22100-N	F2-TW-0011546-22100-N	F2-TW-0011571-22100-N	F2-TW-0011580-22100-N	F2-TW-0011616-22100-N	F2-TW-0011636-22100-N	F2-TW-0011660-22100-N	F2-TW-0011667-22100-N
		Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-20	2022-04-21
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.690	0.730	ND	0.580	ND	0.500	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.650	0.660	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	1.30	1.40	ND	0.580	ND	0.500	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-JALU0613	F2-JALU3296		F2-KIRK1936	F2-LIPP2080	F2-MCCU1058	F2-MCFA0822	F2-MEYE3409	
		Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence	
		Address:	613 Jaluit Street	3296 Jaluit Lane		1936 Kirkpatrick Loop	2080 Lippia Loop	1058 McCurry Place	822 McFaddin Street	3409 Meyerkord Place	
		Field Sample ID:	F2-TW-0011697-22100-N	F2-TW-0011705-22100-3-N	F2-TW-0011705-22100-N	F2-TW-0011775-22100-N	F2-TW-0009875-22100-N	F2-TW-0009930-22100-N	F2-TW-0009943-22100-N	F2-TW-0009977-22100-N	
		Sample Date:	2022-04-22	2022-04-21	2022-04-21	2022-04-19	2022-04-21	2022-04-21	2022-04-22	2022-04-21	
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	560	370	370	440	280	420	520	30.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	2.00	1.90	2.40	2.30	2.30	2.10	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.960	0.930	0.880	0.970	0.930	0.940	0.910	0.930
	Copper	1300	MCL	8.80	10.5	9.50	7.00	93.8	6.50	6.30	8.30
	Lead	15	MCL	0.430	0.670	0.580	0.210	0.590	0.290	0.240	0.430
	Mercury	2	MCL	0.0270	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.330	0.920	0.870	0.970	0.610	0.890	0.520	0.820
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	0.600	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-JALU3296		F2-KIRK1936	F2-LIPP2080	F2-MCCU1058	F2-MCFA0822	F2-MEYE3409	
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	3296 Jaluit Lane		1936 Kirkpatrick Loop	2080 Lippia Loop	1058 McCurry Place	822 McFaddin Street	3409 Meyerkord Place	
				Field Sample ID:	F2-TW-0011697-22100-N	F2-TW-0011705-22100-3-N	F2-TW-0011705-22100-N	F2-TW-0011775-22100-N	F2-TW-0009875-22100-N	F2-TW-0009930-22100-N	F2-TW-0009943-22100-N	F2-TW-0009977-22100-N
				Sample Date:	2022-04-22	2022-04-21	2022-04-21	2022-04-19	2022-04-21	2022-04-21	2022-04-22	2022-04-21
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	1.20	ND	ND	
	Bromoform	--	--	ND	1.90	3.00	0.670	ND	3.30	0.850	1.80	
	Chloroform	--	--	ND	ND	ND	ND	ND	0.700	ND	ND	
	Dibromochloromethane	--	--	ND	ND	0.620	0.530	ND	2.80	0.850	1.20	
	Total Trihalomethanes	80	MCL	ND	1.90	3.60	1.20	ND	8.00	1.70	2.90	

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	F2-MURR0739	F2-MURR0796	F2-MURR0797	F2-MURR0835	F2-MURR0852	F2-MURR0876	F2-MURR0878		
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence		
				Address:	739 Murray Drive	796 Murray Drive	797 Murray Drive	835 Murray Drive	852 Murray Drive	876 Murray Drive	878 Murray Drive		
				Field Sample ID:	F2-TW-0010093-22100-N	F2-TW-0010114-22100-N	F2-TW-0010115-22100-N	F2-TW-0010123-22100-N	F2-TW-0010132-22100-N	F2-TW-0010148-22100-N	F2-TW-0010149-22100-3-N	F2-TW-0010149-22100-N	
				Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-19	2022-04-25	2022-04-19	2022-04-20	2022-04-20	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Field Test (ppb)	Free Chlorine	4000	MCL	240	440	460	380	530	420	440	440		
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.20	2.30	2.40	2.20	2.40	2.20	2.20	2.20	2.20	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.940	1.10	1.10	1.10	1.10	0.950	1.00	0.980	0.980	
	Copper	1300	MCL	9.70	13.8	4.80	8.10	3.30	2.00	9.80	10.1	10.1	
	Lead	15	MCL	0.640	0.340	0.180	0.240	0.170	0.300	0.600	0.360	0.360	
	Mercury	2	MCL	ND	0.0250	ND	ND	ND	ND	ND	ND	0.0270	0.0270
	Selenium	50	MCL	0.760	0.670	0.740	0.720	0.440	0.540	0.560	0.520	0.520	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0739	F2-MURR0796	F2-MURR0797	F2-MURR0835	F2-MURR0852	F2-MURR0876	F2-MURR0878	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	739 Murray Drive	796 Murray Drive	797 Murray Drive	835 Murray Drive	852 Murray Drive	876 Murray Drive	878 Murray Drive	
		Field Sample ID:	F2-TW-0010093-22100-N	F2-TW-0010114-22100-N	F2-TW-0010115-22100-N	F2-TW-0010123-22100-N	F2-TW-0010132-22100-N	F2-TW-0010148-22100-N	F2-TW-0010149-22100-3-N	F2-TW-0010149-22100-N
		Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-19	2022-04-25	2022-04-19	2022-04-20	2022-04-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
 Zone F2 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0739	F2-MURR0796	F2-MURR0797	F2-MURR0835	F2-MURR0852	F2-MURR0876	F2-MURR0878	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	739 Murray Drive	796 Murray Drive	797 Murray Drive	835 Murray Drive	852 Murray Drive	876 Murray Drive	878 Murray Drive	
		Field Sample ID:	F2-TW-0010093-22100-N	F2-TW-0010114-22100-N	F2-TW-0010115-22100-N	F2-TW-0010123-22100-N	F2-TW-0010132-22100-N	F2-TW-0010148-22100-N	F2-TW-0010149-22100-3-N	F2-TW-0010149-22100-N
		Sample Date:	2022-04-21	2022-04-22	2022-04-20	2022-04-19	2022-04-25	2022-04-19	2022-04-20	2022-04-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.990	0.530	ND	ND	0.560	ND	ND
	Bromoform	--	--	3.00	1.50	0.860	ND	1.50	ND	0.720
	Chloroform	--	--	0.620	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	2.50	1.30	0.620	ND	1.30	ND	0.630
	Total Trihalomethanes	80	MCL	7.10	3.30	1.50	ND	3.30	ND	1.40

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0947	F2-MURR0950	F2-NOON4072	F2-NOON4073		F2-NOON4076	F2-NYEC1674	F2-NYEC1724	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence	
		Address:	947 Murray Drive	950 Murray Drive	4072 Noonan Street	4073 Noonan Street		4076 Noonan Street	1674 Nye Circle	1724 Nye Circle	
		Field Sample ID:	F2-TW-0010176-22100-N	F2-TW-0010179-22100-N	F2-TW-0010420-22100-N	F2-TW-0010421-22100-3-N	F2-TW-0010421-22100-N	F2-TW-0010422-22100-N	F2-TW-0010432-22100-N	F2-TW-0010436-22100-N	
		Sample Date:	2022-04-20	2022-04-20	2022-04-18	2022-04-20	2022-04-20	2022-04-19	2022-04-21	2022-04-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	500	290	30.0	160	160	490	ND	360
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.20	2.30	2.20	2.20	2.30	2.30	2.20	2.20
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.980	1.10	0.840	0.960	1.00	1.00	0.970	1.00
	Copper	1300	MCL	4.40	3.40	4.80	5.90	6.30	10.4	48.4	66.2
	Lead	15	MCL	0.210	0.510	0.580	0.280	0.360	0.570	0.200	0.290
	Mercury	2	MCL	0.0260	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.460	0.710	ND	0.520	0.650	0.780	0.800	0.440
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0947	F2-MURR0950	F2-NOON4072	F2-NOON4073		F2-NOON4076	F2-NYEC1674	F2-NYEC1724
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	947 Murray Drive	950 Murray Drive	4072 Noonan Street	4073 Noonan Street		4076 Noonan Street	1674 Nye Circle	1724 Nye Circle
		Field Sample ID:	F2-TW-0010176-22100-N	F2-TW-0010179-22100-N	F2-TW-0010420-22100-N	F2-TW-0010421-22100-3-N	F2-TW-0010421-22100-N	F2-TW-0010422-22100-N	F2-TW-0010432-22100-N	F2-TW-0010436-22100-N
		Sample Date:	2022-04-20	2022-04-20	2022-04-18	2022-04-20	2022-04-20	2022-04-19	2022-04-21	2022-04-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-MURR0947	F2-MURR0950	F2-NOON4072	F2-NOON4073		F2-NOON4076	F2-NYEC1674	F2-NYEC1724
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	947 Murray Drive	950 Murray Drive	4072 Noonan Street	4073 Noonan Street		4076 Noonan Street	1674 Nye Circle	1724 Nye Circle
		Field Sample ID:	F2-TW-0010176-22100-N	F2-TW-0010179-22100-N	F2-TW-0010420-22100-N	F2-TW-0010421-22100-3-N	F2-TW-0010421-22100-N	F2-TW-0010422-22100-N	F2-TW-0010432-22100-N	F2-TW-0010436-22100-N
		Sample Date:	2022-04-20	2022-04-20	2022-04-18	2022-04-20	2022-04-20	2022-04-19	2022-04-21	2022-04-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	3.20	ND	ND
	Bromoform	--	--	0.620	0.970	1.90	ND	12.1	ND	2.20
	Chloroform	--	--	ND	ND	ND	ND	2.10	ND	ND
	Dibromochloromethane	--	--	ND	0.700	0.940	ND	8.90	ND	0.860
	Total Trihalomethanes	80	MCL	0.620	1.70	2.90	ND	24.5	ND	3.10

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-NYEP1934		F2-NYEP1938	F2-NYEP1948	F2-OCAL1911	F2-PAUL0586	F2-PLUM1674	F2-POOL0629
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:
				1934 Nye Place	Residence	1938 Nye Place (CDH)	1948 Nye Place	1911 O'Callahan Street	586 Paul Lane	1674 Plumbago Court	629 Pool Street
				F2-TW-0010447-22100-3-N	F2-TW-0010447-22100-N	F2-TW-0010449-22100-N	F2-TW-0010453-22100-N	F2-TW-0010459-22100-N	F2-TW-0010535-22100-N	F2-TW-0010813-22100-N	F2-TW-0010822-22100-N
				2022-04-20	2022-04-20	2022-04-22	2022-04-19	2022-04-22	2022-04-20	2022-04-21	2022-04-21
				FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	340	340	220	360	480	690	450	550
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.30	2.20	2.30	2.20	1.90	2.20	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.00	0.870	0.900	1.20	0.970	0.920	0.900
	Copper	1300	MCL	41.5	43.7	65.8	98.5	6.30	5.20	47.3	6.00
	Lead	15	MCL	0.280	0.340	0.260	0.350	0.620	0.150	0.300	0.190
	Mercury	2	MCL	ND	ND	0.0280	ND	ND	0.0260	ND	ND
	Selenium	50	MCL	0.490	0.640	0.670	0.840	0.420	0.620	0.810	0.520
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-NYEP1934		F2-NYEP1938	F2-NYEP1948	F2-OCAL1911	F2-PAUL0586	F2-PLUM1674	F2-POOL0629
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:
				F2-TW-0010447-22100-3-N	F2-TW-0010447-22100-N	F2-TW-0010449-22100-N	F2-TW-0010453-22100-N	F2-TW-0010459-22100-N	F2-TW-0010535-22100-N	F2-TW-0010813-22100-N	F2-TW-0010822-22100-N
				2022-04-20	2022-04-20	2022-04-22	2022-04-19	2022-04-22	2022-04-20	2022-04-21	2022-04-21
				FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				1934 Nye Place	1938 Nye Place (CDH)	1948 Nye Place	1911 O'Callahan Street	586 Paul Lane	1674 Plumbago Court	629 Pool Street	
				Residence	Residential Child Care	Residence	Residence	Residence	Residence	Residence	Residence
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-NYEP1934		F2-NYEP1938	F2-NYEP1948	F2-OCAL1911	F2-PAUL0586	F2-PLUM1674	F2-POOL0629																			
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type															
				Location ID: F2-NYEP1934 Location Type: Residence Address: 1934 Nye Place		Residential Child Care	Residence	Residence	Residence	Residence	Residence																			
				F2-TW-0010447-22100-3-N	2022-04-20	FD (Field Duplicate)	F2-TW-0010447-22100-N	2022-04-20	N (Normal)	F2-TW-0010449-22100-N	2022-04-22	N (Normal)	F2-TW-0010453-22100-N	2022-04-19	N (Normal)	F2-TW-0010459-22100-N	2022-04-22	N (Normal)	F2-TW-0010535-22100-N	2022-04-20	N (Normal)	F2-TW-0010813-22100-N	2022-04-21	N (Normal)	F2-TW-0010822-22100-N	2022-04-21	N (Normal)			
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Bromoform	--	--	ND	0.530	0.550	0.770	0.580	0.520	ND	0.640	ND	0.580	0.770	1.10	0.520	ND	1.20	ND	0.580	0.770	1.10	0.520	ND	1.20	ND	0.580	0.770	1.10	0.520
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Total Trihalomethanes	80	MCL	ND	0.530	0.550	0.770	1.10	0.520	ND	1.20	ND	0.580	0.770	1.10	0.520	ND	1.20	ND	0.580	0.770	1.10	0.520	ND	1.20	ND	0.580	0.770	1.10	0.520

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-ROGE0825	F2-SAND0729	F2-SCHM2754		F2-SCHM2778	F2-SHIE5254	F2-SHIE5332	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residential Child Care	Residence
					825 Rogers Street	729 Sanders Circle	2754 Schmitt Parkway (CDH)		2778 Schmitt Parkway	5254 Shields Street	5332 Shields Street	
					F2-TW-0010861-22100-N	F2-TW-0010871-22100-N	F2-TW-0010877-22100-3-N	F2-TW-0010877-22100-N	F2-TW-0010887-22100-N	F2-TW-0010913-22100-N	F2-TW-0010930-22100-3-N	F2-TW-0010930-22100-N
					2022-04-19	2022-04-22	2022-04-22	2022-04-22	2022-04-20	2022-04-20	2022-04-19	2022-04-19
					N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	520	590	530	530	530	40.0	150	150	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	1.90	1.90	2.30	2.20	2.00	2.00	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.880	1.00	1.10	1.10	1.10	1.00	0.930	1.20	
	Copper	1300	MCL	3.20	1.70	12.9	3.40	3.80	51.1	7.90	7.70	
	Lead	15	MCL	0.150	ND	ND	ND	0.150	0.590	0.200	0.160	
	Mercury	2	MCL	ND	0.0270	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.780	0.490	0.540	0.900	0.560	0.510	0.810	0.970	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	0.470	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-ROGE0825	F2-SAND0729	F2-SCHM2754		F2-SCHM2778	F2-SHIE5254	F2-SHIE5332	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residence	Residential Child Care	Residence
					825 Rogers Street	729 Sanders Circle	2754 Schmitt Parkway (CDH)		2778 Schmitt Parkway	5254 Shields Street	5332 Shields Street	
					F2-TW-0010861-22100-N	F2-TW-0010871-22100-N	F2-TW-0010877-22100-3-N	F2-TW-0010877-22100-N	F2-TW-0010887-22100-N	F2-TW-0010913-22100-N	F2-TW-0010930-22100-3-N	F2-TW-0010930-22100-N
					2022-04-19	2022-04-22	2022-04-22	2022-04-22	2022-04-20	2022-04-20	2022-04-19	2022-04-19
					N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-ROGE0825	F2-SAND0729	F2-SCHM2754		F2-SCHM2778	F2-SHIE5254	F2-SHIE5332	
				Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:	Residence	Residential Child Care	Residence	Residence
					825 Rogers Street	729 Sanders Circle	2754 Schmitt Parkway (CDH)		2778 Schmitt Parkway	5254 Shields Street	5332 Shields Street	
					F2-TW-0010861-22100-N	F2-TW-0010871-22100-N	F2-TW-0010877-22100-3-N	F2-TW-0010877-22100-N	F2-TW-0010887-22100-N	F2-TW-0010913-22100-N	F2-TW-0010930-22100-3-N	F2-TW-0010930-22100-N
					2022-04-19	2022-04-22	2022-04-22	2022-04-22	2022-04-20	2022-04-20	2022-04-19	2022-04-19
					N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	0.530
	Bromoform	--	--	0.640	ND	ND	0.930	0.600	1.00	ND	ND	1.50
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.590	ND	ND	0.810	ND	0.600	ND	ND	1.20
	Total Trihalomethanes	80	MCL	1.20	ND	ND	1.70	0.600	1.60	ND	ND	3.20

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-SNYD3168	F2-SNYD3190	F2-STOW2592	F2-STOW2654	F2-STOW2776	F2-TALB0810	F2-TALB0830	F2-TIAR1707	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	3168 Snyder Court	3190 Snyder Court	2592 Stowell Circle	2654 Stowell Circle	2776 Stowell Circle	810 Talbot Street	830 Talbot Street	1707 Tiare Court	
		Field Sample ID:	F2-TW-0010585-22100-N	F2-TW-0010966-22100-N	F2-TW-0010988-22100-N	F2-TW-0009253-22100-N	F2-TW-0009288-22100-N	F2-TW-0009300-22100-N	F2-TW-0009306-22100-N	F2-TW-0009315-22100-N	
		Sample Date:	2022-04-20	2022-04-22	2022-04-21	2022-04-22	2022-04-21	2022-04-20	2022-04-19	2022-04-26	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	280	200	560	500	860	460	440	80.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.30	2.30	2.20	2.10	2.20	2.00	2.10	2.30
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	0.970	0.930	1.10	0.940	0.980	0.920	0.800
	Copper	1300	MCL	28.1	33.0	4.50	8.10	4.50	4.10	2.70	135
	Lead	15	MCL	ND	0.760	0.210	0.310	0.250	0.140	0.190	0.180
	Mercury	2	MCL	0.0260	0.0350	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.500	ND	0.760	0.530	0.700	0.580	0.760	0.360
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	5.10	ND	3.70	ND	ND	0.430	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-SNYD3168	F2-SNYD3190	F2-STOW2592	F2-STOW2654	F2-STOW2776	F2-TALB0810	F2-TALB0830	F2-TIAR1707
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	3168 Snyder Court	3190 Snyder Court	2592 Stowell Circle	2654 Stowell Circle	2776 Stowell Circle	810 Talbot Street	830 Talbot Street	1707 Tiare Court
		Field Sample ID:	F2-TW-0010585-22100-N	F2-TW-0010966-22100-N	F2-TW-0010988-22100-N	F2-TW-0009253-22100-N	F2-TW-0009288-22100-N	F2-TW-0009300-22100-N	F2-TW-0009306-22100-N	F2-TW-0009315-22100-N
		Sample Date:	2022-04-20	2022-04-22	2022-04-21	2022-04-22	2022-04-21	2022-04-20	2022-04-19	2022-04-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
 Zone F2 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-SNYD3168	F2-SNYD3190	F2-STOW2592	F2-STOW2654	F2-STOW2776	F2-TALB0810	F2-TALB0830	F2-TIAR1707
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	3168 Snyder Court	3190 Snyder Court	2592 Stowell Circle	2654 Stowell Circle	2776 Stowell Circle	810 Talbot Street	830 Talbot Street	1707 Tiare Court
		Field Sample ID:	F2-TW-0010585-22100-N	F2-TW-0010966-22100-N	F2-TW-0010988-22100-N	F2-TW-0009253-22100-N	F2-TW-0009288-22100-N	F2-TW-0009300-22100-N	F2-TW-0009306-22100-N	F2-TW-0009315-22100-N
		Sample Date:	2022-04-20	2022-04-22	2022-04-21	2022-04-22	2022-04-21	2022-04-20	2022-04-19	2022-04-26
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.600	2.50	0.700	0.600	0.830	ND	0.650
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.540	0.500	ND	0.630	ND	ND
	Total Trihalomethanes	80	MCL	0.600	3.00	1.20	0.600	1.50	ND	0.650

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	F2-TIAR1730
Location Type:	Residence
Address:	1730 Tiare Court
Field Sample ID:	F2-TW-0009322-22100-N
Sample Date:	2022-04-28
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Result
Field Test (ppb)	Free Chlorine	4000	MCL	330
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND
Metals (ppb)	Antimony	6	MCL	ND
	Arsenic	10	MCL	ND
	Barium	2000	MCL	2.20
	Beryllium	4	MCL	ND
	Cadmium	5	MCL	ND
	Chromium	100	MCL	1.30
	Copper	1300	MCL	24.5
	Lead	15	MCL	0.150
	Mercury	2	MCL	0.0760
	Selenium	50	MCL	0.700
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND
	1-Methylnaphthalene	10	EAL	ND
	2-Methylnaphthalene	10	EAL	ND
	Benzo(a)pyrene	0.2	MCL	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND
	1,1,1-Trichloroethane	--	--	ND
	1,1,2-Trichloroethane	5	MCL	ND
	1,1-Dichloroethene	7	MCL	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	F2-TIAR1730
Location Type:	Residence
Address:	1730 Tiare Court
Field Sample ID:	F2-TW-0009322-22100-N
Sample Date:	2022-04-28
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND
	1,2-Dichlorobenzene	600	MCL	ND
	1,2-Dichloroethane	5	MCL	ND
	1,2-Dichloroethene	70	MCL	ND
	1,2-Dichloropropane	5	MCL	ND
	1,4-Dichlorobenzene	75	MCL	ND
	Benzene	5	MCL	ND
	Carbon Tetrachloride	5	MCL	ND
	Chlorobenzene	100	MCL	ND
	cis-1,2-Dichloroethene	70	MCL	ND
	Ethylbenzene	700	MCL	ND
	m,p-Xylene	--	--	ND
	Methylene chloride	5	MCL	ND
	o-Xylene	--	--	ND
	Styrene	100	MCL	ND
	Tetrachloroethene (PCE)	5	MCL	ND
	Toluene	1000	MCL	ND
	trans-1,2-Dichloroethene	100	MCL	ND
	Trichloroethene (TCE)	5	MCL	ND
	Vinyl chloride	2	MCL	ND
Xylenes, Total	10000	MCL	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND
	Chloroacetic acid	--	--	ND
	Dibromoacetic acid	--	--	ND
	Dichloroacetic acid	--	--	ND

**Summary of Chemistry Results
 Zone F2 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Residences in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	F2-TIAR1730
Location Type:	Residence
Address:	1730 Tiare Court
Field Sample ID:	F2-TW-0009322-22100-N
Sample Date:	2022-04-28
Sample Type:	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND
	Total Haloacetic acids	60	MCL	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND
	Bromoform	--	--	0.990
	Chloroform	--	--	ND
	Dibromochloromethane	--	--	0.500
	Total Trihalomethanes	80	MCL	1.50

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Child Development Centers in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-BLDG1928		F2-BLDG4655						
				Location ID:	Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	
				Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)	Child Development Center	Building 4655,CATLIN SCHOOL AGE CENTER	Child Development Center					
				F2-TW-0014145-22100-N-1	F2-TW-0014145-22100-N-2	F2-TW-0014156-22100-3-N-2	F2-TW-0014156-22100-N-1	F2-TW-0014156-22100-N-2				
				2022-05-06	2022-05-06	2022-05-09	2022-05-09	2022-05-09				
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)				
Field Test (ppb)	Free Chlorine	4000	MCL	170-370	170-370	70.0-260	70.0-260	70.0-260				
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND				
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND				
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	0.160	ND				
	Arsenic	10	MCL	ND	ND	ND	ND	ND				
	Barium	2000	MCL	2.10	2.10	2.20	2.30	2.30				
	Beryllium	4	MCL	ND	ND	ND	ND	ND				
	Cadmium	5	MCL	ND	ND	ND	ND	ND				
	Chromium	100	MCL	0.570	0.570	0.820	0.830	0.870				
	Copper	1300	MCL	28.3	20.5	75.3	130	75.0				
	Lead	15	MCL	ND	ND	0.240	0.290	0.250				
	Mercury	2	MCL	ND	ND	ND	ND	ND				
	Selenium	50	MCL	1.70	1.20	ND	ND	ND				
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND				
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND				
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND				
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND				
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	1.60	ND				
Naphthalene	17	EAL	ND	ND	ND	ND	ND					

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Child Development Centers in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-BLDG1928		F2-BLDG4655		
				Location ID:	Location Type:	Field Sample ID:	Sample Date:	Sample Type:
				Child Development Center		Child Development Center		
				Building 1928,CHILD DEVELOPMT CENTER (530 PELTIER AVE)		Building 4655,CATLIN SCHOOL AGE CENTER		
				F2-TW-0014145-22100-N-1	F2-TW-0014145-22100-N-2	F2-TW-0014156-22100-3-N-2	F2-TW-0014156-22100-N-1	F2-TW-0014156-22100-N-2
				2022-05-06	2022-05-06	2022-05-09	2022-05-09	2022-05-09
				N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Child Development Centers in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: F2-BLDG1928		Location ID: F2-BLDG4655		
				Location Type: Child Development Center	Address: Building 1928, CHILD DEVELOPMT CENTER (530 PELTIER AVE)	Location Type: Child Development Center	Address: Building 4655, CATLIN SCHOOL AGE CENTER	Field Sample ID:
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	0.620
	Bromoform	--	--	0.710	0.770	ND	1.30	4.90
	Chloroform	--	--	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.610	2.10
	Total Trihalomethanes	80	MCL	0.710	0.770	ND	1.90	7.60

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Other Buildings in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location Information		
				Location ID	Location Type	Address
				F2-BLDG3349	F2-BLDG7751	F2-BLDG7753
				Non-Residence	Non-Residence	Non-Residence
				Building 3349, LEARNING SERVICE CENTER (3349 Catlin Drive)	Building 7751, Radford Terrace Country Club (811 Murray Drive)	Building 7753, RECREATION BUILDING (MURRY DR)
				Field Sample ID: F2-TW-0014155-22100-N	F2-TW-0014158-22100-N	F2-TW-0014159-22100-N
				Sample Date: 2022-04-26	2022-05-06	2022-04-25
				Sample Type: N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	210	450	500
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND
	Barium	2000	MCL	1.90	2.40	2.40
	Beryllium	4	MCL	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND
	Chromium	100	MCL	0.720	0.520	1.00
	Copper	1300	MCL	75.2	5.30	5.00
	Lead	15	MCL	0.630	0.340	0.270
	Mercury	2	MCL	ND	ND	ND
	Selenium	50	MCL	0.420	1.20	0.480
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Other Buildings in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location ID:	Location ID:
				F2-BLDG3349	F2-BLDG7751	F2-BLDG7753
				Non-Residence	Non-Residence	Non-Residence
				Building 3349, LEARNING SERVICE CENTER (3349 Catlin Drive)	Building 7751, Radford Terrace Country Club (811 Murray Drive)	Building 7753, RECREATION BUILDING (MURRY DR)
				F2-TW-0014155-22100-N	F2-TW-0014158-22100-N	F2-TW-0014159-22100-N
				2022-04-26	2022-05-06	2022-04-25
				N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April and May 2022 from Other Buildings in Zone F2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-BLDG3349	F2-BLDG7751	F2-BLDG7753	
		Location Type:	Non-Residence	Non-Residence	Non-Residence	
		Address:	Building 3349,LEARNING SERVICE CENTER (3349 Catlin Drive)	Building 7751, Radford Terrace Country Club (811 Murray Drive)	Building 7753,RECREATION BUILDING (MURRY DR)	
		Field Sample ID:	F2-TW-0014155- 22100-N	F2-TW-0014158- 22100-N	F2-TW-0014159- 22100-N	
		Sample Date:	2022-04-26	2022-05-06	2022-04-25	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.710	1.40	1.20
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.900	0.670
	Total Trihalomethanes	80	MCL	0.710	2.30	1.90

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31	
		Field Sample ID:	F2-DL-0017744-22100 -N	F2-DL-0017772-22100 -N	F2-DL-0017745-22100 -N	F2-DL-0017776-22100 -N	F2-DL-0017746-22100 -N	F2-DL-0017771-22100 -N	F2-DL-0017747-22100 -N	F2-DL-0017748-22100 -N	
		Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031
Field Test (ppb)	Free Chlorine	4000	MCL	510	310	400	460	490	70.0	110	270
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.10	2.30	2.90	2.30	2.00	4.20	4.00	3.40
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	0.980	1.00	0.990	0.950	0.930	0.690	0.900
	Copper	1300	MCL	5.60	8.50	3.80	4.30	5.20	4.20	1.20	3.40
	Lead	15	MCL	0.330	0.620	0.250	0.250	0.420	0.680	0.520	0.520
	Mercury	2	MCL	ND	ND	0.0280	0.0300	ND	ND	ND	ND
	Selenium	50	MCL	0.490	0.510	0.320	0.450	0.490	0.450	ND	0.400
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31	
		Field Sample ID:	F2-DL-0017744-22100 -N	F2-DL-0017772-22100 -N	F2-DL-0017745-22100 -N	F2-DL-0017776-22100 -N	F2-DL-0017746-22100 -N	F2-DL-0017771-22100 -N	F2-DL-0017747-22100 -N	F2-DL-0017748-22100 -N	
		Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0002	F2-HYD0003	F2-HYD0011	F2-HYD0012	F2-HYD0014	F2-HYD0026	F2-HYD0030	F2-HYD0031
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
		Address:	FH 2	FH 3	FH 11	FH 12 (Correct LOCID is F2-HYD1338)	FH 14	FH 26	FH 30	FH 31
		Field Sample ID:	F2-DL-0017744-22100 -N	F2-DL-0017772-22100 -N	F2-DL-0017745-22100 -N	F2-DL-0017776-22100 -N	F2-DL-0017746-22100 -N	F2-DL-0017771-22100 -N	F2-DL-0017747-22100 -N	F2-DL-0017748-22100 -N
		Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	1.30	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	1.30	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	0.550
	Bromoform	--	--	ND	0.660	5.20	ND	ND	4.20	4.40
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.520	0.810	ND	ND	0.980	1.00
	Total Trihalomethanes	80	MCL	ND	1.20	6.00	ND	ND	5.20	5.50

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	F2-HYD0039	F2-HYD003A	F2-HYD0047	F2-HYD0213	F2-HYD0520	F2-HYD071A
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH 39	FH 3A	FH 47	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A
				Field Sample ID:	F2-DL-0017749-22100 -N	F2-DL-0017773-22100 -N	F2-DL-0017750-22100 -N	F2-DL-0017774-22100 -N	F2-DL-0017775-22100 -N	F2-DL-0017751-22100 -N
				Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	480	550	440	460	410	450	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.10	2.00	2.00	2.30	2.30	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.860	0.980	1.10	1.00	1.00	1.00	
	Copper	1300	MCL	3.50	3.70	4.90	4.50	4.00	5.40	
	Lead	15	MCL	0.540	0.580	0.630	0.620	0.680	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	0.710	0.380	0.520	0.350	0.360	0.570	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0039	F2-HYD003A	F2-HYD0047	F2-HYD0213	F2-HYD0520	F2-HYD071A	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH 39	FH 3A	FH 47	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A	
		Field Sample ID:	F2-DL-0017749-22100 -N	F2-DL-0017773-22100 -N	F2-DL-0017750-22100 -N	F2-DL-0017774-22100 -N	F2-DL-0017775-22100 -N	F2-DL-0017751-22100 -N	
		Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-HYD0039	F2-HYD003A	F2-HYD0047	F2-HYD0213	F2-HYD0520	F2-HYD071A
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone F2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in April 2022 from Fire Hydrants in Zone f2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	F2-HYD0039	F2-HYD003A	F2-HYD0047	F2-HYD0213	F2-HYD0520	F2-HYD071A	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH 39	FH 3A	FH 47	FH 213 (Possibly F2-HYD0020)	FH 520 (Possibly F2-HYD0018)	FH 71A	
		Field Sample ID:	F2-DL-0017749-22100 -N	F2-DL-0017773-22100 -N	F2-DL-0017750-22100 -N	F2-DL-0017774-22100 -N	F2-DL-0017775-22100 -N	F2-DL-0017751-22100 -N	
		Sample Date:	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	2022-04-22	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	F2-HYD0039	F2-HYD003A	F2-HYD0047	F2-HYD0213	F2-HYD0520	F2-HYD071A
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.570	ND	ND	0.840	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.570	ND	ND
	Total Trihalomethanes	80	MCL	0.570	ND	ND	1.40	ND	ND