

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		B1-HAPU2879B	B1-HEKA1167	B1-KAEE2853F		B1-KAEE2855D	B1-KOKI2862B	B1-KUPA2888C	B1-MCGR0394
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:		2879B Hapue Loop	1167 Hekau Street	2853F Kaee Loop		2855D Kaee Loop	2862B Kokio Loop	2888C Kupalii Loop	394 McGrew Loop
		Field Sample ID:		B1-TW-0017614-22122-N	B1-TW-0010486-22122-N	B1-TW-0016055-22122-3-N	B1-TW-0016055-22122-N	B1-TW-0017590-22122-N	B1-TW-0017596-22122-N	B1-TW-0017633-22122-N	B1-TW-0010521-22122-N
		Sample Date:		2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-19	2022-05-19	2022-05-18
		Sample Type:		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	340	570	200	200	240	390	370	470
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	2.00	1.90	2.00	2.00	2.00	2.20	2.10	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	1.10	1.00	1.20	1.10	1.10	1.20	1.10
	Copper	1300	MCL	31.2	12.4	26.0	23.4	19.3	10.8	6.50	21.2
	Lead	15	MCL	0.130	0.180	ND	ND	0.400	0.130	0.290	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	ND	0.310	ND	ND	0.300	ND	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	0.840
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	B1-HAPU2879B	B1-HEKA1167	B1-KAEE2853F		B1-KAEE2855D	B1-KOKI2862B	B1-KUPA2888C	B1-MCGR0394
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	2879B Hapue Loop	1167 Hekau Street	2853F Kae Loop		2855D Kae Loop	2862B Kokio Loop	2888C Kupalii Loop	394 McGrew Loop
		Field Sample ID:	B1-TW-0017614-22122-N	B1-TW-0010486-22122-N	B1-TW-0016055-22122-3-N	B1-TW-0016055-22122-N	B1-TW-0017590-22122-N	B1-TW-0017596-22122-N	B1-TW-0017633-22122-N	B1-TW-0010521-22122-N
		Sample Date:	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-19	2022-05-19	2022-05-18
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)				
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	2.00	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	19.1	ND	ND	0.910	0.520	ND
	Chloroform	--	--	ND	0.830	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	9.20	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	31.1	ND	ND	0.910	0.520	ND

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	B1-MCGR0579	B1-MCGR0584	B1-MCGR0680	B1-MCGR0744		B1-OLIA2927D
				Location Type:	Residence	Residence	Residence	Residence		Residence
				Address:	579 McGrew Loop	584 McGrew Loop	680 McGrew Loop	744 McGrew Loop		2927D Oliana Loop
				Field Sample ID:	B1-TW-0009393-22122-N	B1-TW-0009394-22122-N	B1-TW-0009407-22122-N	B1-TW-0009416-22122-3-N	B1-TW-0009416-22122-N	B1-TW-0017578-22122-N
				Sample Date:	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-19
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Field Test (ppb)	Free Chlorine	4000	MCL	570	460	200	500	500	360	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	0.110	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	1.90	1.90	2.00	1.90	2.00	2.10	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.10	1.10	1.10	0.810	1.20	1.10	
	Copper	1300	MCL	7.30	10.5	13.3	2.70	2.70	8.60	
	Lead	15	MCL	0.150	0.270	0.310	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	0.410	0.470	0.690	ND	ND	ND	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	B1-MCGR0579	B1-MCGR0584	B1-MCGR0680	B1-MCGR0744		B1-OLIA2927D
		Location Type:	Residence	Residence	Residence	Residence		Residence
		Address:	579 McGrew Loop	584 McGrew Loop	680 McGrew Loop	744 McGrew Loop		2927D Oliana Loop
		Field Sample ID:	B1-TW-0009393-22122-N	B1-TW-0009394-22122-N	B1-TW-0009407-22122-N	B1-TW-0009416-22122-3-N	B1-TW-0009416-22122-N	B1-TW-0017578-22122-N
		Sample Date:	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-19
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level					
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Residences in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	B1-MCGR0579	B1-MCGR0584	B1-MCGR0680	B1-MCGR0744		B1-OLIA2927D
				Location Type:	Residence	Residence	Residence	Residence		Residence
				Address:	579 McGrew Loop	584 McGrew Loop	680 McGrew Loop	744 McGrew Loop		2927D Oliana Loop
				Field Sample ID:	B1-TW-0009393-22122-N	B1-TW-0009394-22122-N	B1-TW-0009407-22122-N	B1-TW-0009416-22122-3-N	B1-TW-0009416-22122-N	B1-TW-0017578-22122-N
				Sample Date:	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-18	2022-05-19
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.510	0.920	1.50	1.80	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.690	ND	0.940	0.750	0.880	ND	ND
	Total Trihalomethanes	80	MCL	0.690	0.510	1.90	2.30	2.70	ND	ND

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: B1-BLDG0501			Location ID: B1-BLDG0S2A		
				Location Type: Non-Residence	Address: Building 501, ARIZONA MUSEUM (OFFICE/RESTROOM), 1 Arizona Place		Location Type: Non-Residence	Address: Building S2A, SUBSTATION/HALAWA PUMP	
				Field Sample ID: B1-TW-0014426-22122-N	B1-TW-0014402-22122-3-N	B1-TW-0014402-22122-N	Sample Date: 2022-05-18	2022-05-23	2022-05-23
				Sample Type: N (Normal)	FD (Field Duplicate)	N (Normal)			
Field Test (ppb)	Free Chlorine	4000	MCL	600	310	310			
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND			
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND			
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND			
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND			
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND	ND			
Metals (ppb)	Antimony	6	MCL	ND	ND	ND			
	Arsenic	10	MCL	ND	0.590	ND			
	Barium	2000	MCL	1.90	2.10	2.00			
	Beryllium	4	MCL	ND	ND	ND			
	Cadmium	5	MCL	ND	ND	ND			
	Chromium	100	MCL	1.10	1.40	1.10			
	Copper	1300	MCL	2.90	32.0	39.1			
	Lead	15	MCL	0.240	0.510	0.380			
	Mercury	2	MCL	0.390	ND	0.0330			
	Selenium	50	MCL	ND	0.530	0.770			
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND			
	1-Methylnaphthalene	10	EAL	ND	ND	ND			
	2-Methylnaphthalene	10	EAL	ND	ND	ND			
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND			
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND			
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND			
	1,1,1-Trichloroethane	--	--	ND	ND	ND			

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: B1-BLDG0501		Location ID: B1-BLDG0S2A	
				Location Type: Non-Residence	Address: Building 501, ARIZONA MUSEUM (OFFICE/RESTROOM), 1 Arizona Place	Location Type: Non-Residence	Address: Building S2A, SUBSTATION/HALAWA PUMP
				Field Sample ID: B1-TW-0014426-22122-N	Sample Date: 2022-05-18	Sample Type: N (Normal)	
							Field Sample ID: B1-TW-0014402-22122-3-N
							Field Sample ID: B1-TW-0014402-22122-N
							Sample Date: 2022-05-23
							Sample Date: 2022-05-23
							Sample Type: FD (Field Duplicate)
							Sample Type: N (Normal)
Volatile Organic Compounds (ppb)	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	
	1,2-Dichloroethene	70	MCL	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	
	Vinyl chloride	2	MCL	ND	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	ND	

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Other Buildings in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	B1-BLDG0S2A	
				Location Type:	Field Sample ID:	Sample Date:
				B1-BLDG0501 Non-Residence Building 501, ARIZONA MUSEUM (OFFICE/RESTROOM), 1 Arizona Place	B1-BLDG0S2A Non-Residence Building S2A, SUBSTATION/HALAWA PUMP	
				B1-TW-0014426-22122-N	B1-TW-0014402-22122-3-N	B1-TW-0014402-22122-N
				2022-05-18	2022-05-23	2022-05-23
				N (Normal)	FD (Field Duplicate)	N (Normal)
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	ND	3.00	4.00
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.690	0.990
	Total Trihalomethanes	80	MCL	ND	3.70	5.00

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	B1-HYD0006	B1-HYD541
				Location ID: B1-HYD0006	B1-HYD541
				Location Type: Hydrant	Hydrant
				Address: FH 6 (B1-HYD545)	FH ID: 8
				Field Sample ID: B1-DL-0017728-22122-N	B1-DL-0000512-22122-N
				Sample Date: 2022-05-20	2022-05-20
				Sample Type: N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	500	470
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	0.150	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	2.00	2.00
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	0.930	0.900
	Copper	1300	MCL	4.00	2.10
	Lead	15	MCL	0.170	0.170
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	1.30	1.90
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

**Summary of Chemistry Results
Zone B1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location Information	
				Location ID	Location Type
				B1-HYD0006	B1-HYD541
				Hydrant	Hydrant
				Address: FH 6 (B1-HYD545)	FH ID: 8
				Field Sample ID: B1-DL-0017728-22122-N	B1-DL-0000512-22122-N
				Sample Date: 2022-05-20	2022-05-20
				Sample Type: N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND
	Benzene	5	MCL	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND
	Chlorobenzene	100	MCL	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND
	Methylene chloride	5	MCL	ND	ND
	o-Xylene	--	--	ND	ND
	Styrene	100	MCL	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND
	Toluene	1000	MCL	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND
	Vinyl chloride	2	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	ND
	Dichloroacetic acid	--	--	ND	ND

**Summary of Chemistry Results
 Zone B1 Long Term Monitoring
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in May 2022 from Fire Hydrants in Zone B1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	B1-HYD0006	B1-HYD541
Location Type:	Hydrant	Hydrant
Address:	FH 6 (B1-HYD545)	FH ID: 8
Field Sample ID:	B1-DL-0017728-22122 -N	B1-DL-0000512-22122 -N
Sample Date:	2022-05-20	2022-05-20
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	B1-HYD0006	B1-HYD541
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	ND
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND