

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-BLDG0019		D4-BLDG2010H	D4-BLDG3305	D4-BLDG3424H	D4-BLDG3425H	D4-BLDG3465H	D4-BLDG3572H
				Non-Residence Building 19,MDSU-1 SHOP/OFFICES/STORAGE		Non-Residence Building 2010H,SHOP, REFUELING VEHICLE	Non-Residence Building 3305,PRETREATMEN T BR OFF NFH WWTP	Non-Residence Building 3424H,VEHICLE MAINTENANCE SHOP, 390 Mamala Bay Dr	Non-Residence Building 3425H,COMMON LAUNDRY ROOM	Non-Residence Building 3465H,OFFICER OPEN MESS, 3465 Mamala Bay Dr	Non-Residence Building 3572H,GOLF CLUBHOUSE
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
Field Test (ppb)	Free Chlorine	4000	MCL	D4-TW-0015607-22127-3-N-R1	D4-TW-0015607-22127-N-R1	D4-TW-0015654-22127-N	D4-TW-0015680-22127-N-R1	D4-TW-0015717-22127-N-R1	D4-TW-0015718-22127-N-R1	D4-TW-0015731-22127-N	D4-TW-0015603-22127-3-N
				2022-06-15	2022-06-15	2022-05-23	2022-06-15	2022-06-15	2022-06-15	2022-05-25	2022-05-23
				FD (Grab, Resample)	N (Grab, Resample)	N (Normal)	N (Grab, Resample)	N (Grab, Resample)	N (Grab, Resample)	N (Normal)	FD (Field Duplicate)
				470	470	730	520	450	410	590	420
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	51.8	ND	ND	ND	ND	68.2	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	77.8
	Petroleum Hydrocarbons, Total	211	ISP	ND	51.8	ND	ND	ND	ND	68.2	77.8
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.80	1.90	2.10	1.90	2.00	2.70
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.800	0.910	1.10	1.10	0.910	0.870	0.770	1.20
	Copper	1300	MCL	34.4	36.7	80.3	33.5	78.9	112	8.60	44.3
	Lead	15	MCL	0.230	0.320	0.770	0.800	0.200	0.140	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.350	ND	ND	ND	ND	ND	1.00	0.590
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D4-BLDG0019		Location ID: D4-BLDG2010H		Location ID: D4-BLDG3305		Location ID: D4-BLDG3424H		Location ID: D4-BLDG3425H		Location ID: D4-BLDG3465H		Location ID: D4-BLDG3572H	
				Location Type: Non-Residence	Address: Building 19,MDSU-1 SHOP/OFFICES/STORAGE	Location Type: Non-Residence	Address: Building 2010H,SHOP, REFUELING VEHICLE	Location Type: Non-Residence	Address: Building 3305,PRETREATMEN T BR OFF NFH WWTP	Location Type: Non-Residence	Address: Building 3424H,VEHICLE MAINTENANCE SHOP, 390 Mamala Bay Dr	Location Type: Non-Residence	Address: Building 3425H,COMMON LAUNDRY ROOM	Location Type: Non-Residence	Address: Building 3465H,OFFICER OPEN MESS, 3465 Mamala Bay Dr	Location Type: Non-Residence	Address: Building 3572H,GOLF CLUBHOUSE
				Field Sample ID: D4-TW-0015607-22127-3-N-R1	Field Sample ID: D4-TW-0015607-22127-N-R1	Field Sample ID: D4-TW-0015654-22127-N	Field Sample ID: D4-TW-0015680-22127-N-R1	Field Sample ID: D4-TW-0015717-22127-N-R1	Field Sample ID: D4-TW-0015718-22127-N-R1	Field Sample ID: D4-TW-0015731-22127-N	Field Sample ID: D4-TW-0015603-22127-3-N						
				Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-05-23	Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-05-25	Sample Date: 2022-05-23						
				Sample Type: FD (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Normal)	Sample Type: N (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Normal)	Sample Type: FD (Field Duplicate)						
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D4-BLDG0019		Location ID: D4-BLDG2010H		Location ID: D4-BLDG3305		Location ID: D4-BLDG3424H		Location ID: D4-BLDG3425H		Location ID: D4-BLDG3465H		Location ID: D4-BLDG3572H	
				Location Type: Non-Residence	Address: Building 19,MDSU-1 SHOP/OFFICES/STORAGE	Location Type: Non-Residence	Address: Building 2010H,SHOP, REFUELING VEHICLE	Location Type: Non-Residence	Address: Building 3305,PRETREATMENT BR OFF NFH WWTP	Location Type: Non-Residence	Address: Building 3424H,VEHICLE MAINTENANCE SHOP, 390 Mamala Bay Dr	Location Type: Non-Residence	Address: Building 3425H,COMMON LAUNDRY ROOM	Location Type: Non-Residence	Address: Building 3465H,OFFICER OPEN MESS, 3465 Mamala Bay Dr	Location Type: Non-Residence	Address: Building 3572H,GOLF CLUBHOUSE
				Field Sample ID: D4-TW-0015607-22127-3-N-R1	Field Sample ID: D4-TW-0015607-22127-N-R1	Field Sample ID: D4-TW-0015654-22127-N	Field Sample ID: D4-TW-0015680-22127-N-R1	Field Sample ID: D4-TW-0015717-22127-N-R1	Field Sample ID: D4-TW-0015718-22127-N-R1	Field Sample ID: D4-TW-0015731-22127-N	Field Sample ID: D4-TW-0015603-22127-3-N						
				Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-05-23	Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-06-15	Sample Date: 2022-05-25						
				Sample Type: FD (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Normal)	Sample Type: N (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Grab, Resample)	Sample Type: N (Normal)						
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.730	0.670	ND	2.00	0.640	ND	ND	ND	0.870	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.520	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.730	0.670	ND	2.50	0.640	ND	ND	ND	0.870	ND	ND	ND	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-BLDG3572H	D4-BLDG3578H
Field Test (ppb)	Free Chlorine	4000	MCL	420	230
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	2.60	2.30
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.10	1.30
	Copper	1300	MCL	46.7	89.0
	Lead	15	MCL	ND	ND
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	1.90	1.40
Thallium	2	MCL	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D4-BLDG3572H	D4-BLDG3578H
				Location Type:	Non-Residence	Non-Residence
				Address:	Building 3572H,GOLF CLUBHOUSE	Building 3578H,GOLF EQUIPMENT BUILDING
				Field Sample ID:	D4-TW-0015603-22127-N	D4-TW-0015606-22127-N
				Sample Date:	2022-05-23	2022-05-23
				Sample Type:	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Other Buildings in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D4-BLDG3572H	D4-BLDG3578H
				Location Type:	Non-Residence	Non-Residence
				Address:	Building 3572H,GOLF CLUBHOUSE	Building 3578H,GOLF EQUIPMENT BUILDING
				Field Sample ID:	D4-TW-0015603-22127-N	D4-TW-0015606-22127-N
				Sample Date:	2022-05-23	2022-05-23
				Sample Type:	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	0.700	2.00	2.00
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	1.40	1.40
	Total Trihalomethanes	80	MCL	0.700	3.40	3.40

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Fire Hydrants in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-HYD1941	D4-HYD2390
Field Test (ppb)	Free Chlorine	4000	MCL	550	570
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Motor Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	211	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	0.510
	Barium	2000	MCL	1.90	2.00
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	1.30	1.30
	Copper	1300	MCL	4.20	2.80
	Lead	15	MCL	0.270	0.220
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	ND	0.620
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

**Summary of Chemistry Results  
Zone D4 Long Term Monitoring  
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Fire Hydrants in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: D4-HYD1941		Location ID: D4-HYD2390	
				Location Type: Hydrant	Address: FH 1941	Location Type: Hydrant	Address: FH 2390
				Field Sample ID: D4-DL-0017801-22127-N		Field Sample ID: D4-DL-0017802-22127-N	
				Sample Date: 2022-05-23		Sample Date: 2022-05-23	
				Sample Type: N (Normal)		Sample Type: N (Normal)	
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND		ND	
	1,2-Dichlorobenzene	600	MCL	ND		ND	
	1,2-Dichloroethane	5	MCL	ND		ND	
	1,2-Dichloroethene	70	MCL	ND		ND	
	1,2-Dichloropropane	5	MCL	ND		ND	
	1,4-Dichlorobenzene	75	MCL	ND		ND	
	Benzene	5	MCL	ND		ND	
	Carbon Tetrachloride	5	MCL	ND		ND	
	Chlorobenzene	100	MCL	ND		ND	
	cis-1,2-Dichloroethene	70	MCL	ND		ND	
	Ethylbenzene	700	MCL	ND		ND	
	m,p-Xylene	--	--	ND		ND	
	Methylene chloride	5	MCL	ND		ND	
	o-Xylene	--	--	ND		ND	
	Styrene	100	MCL	ND		ND	
	Tetrachloroethene (PCE)	5	MCL	ND		ND	
	Toluene	1000	MCL	ND		ND	
	trans-1,2-Dichloroethene	100	MCL	ND		ND	
	Trichloroethene (TCE)	5	MCL	ND		ND	
	Vinyl chloride	2	MCL	ND		ND	
	Xylenes, Total	10000	MCL	ND		ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND		ND	
	Chloroacetic acid	--	--	ND		ND	
	Dibromoacetic acid	--	--	ND		ND	
	Dichloroacetic acid	--	--	ND		ND	

**Summary of Chemistry Results  
 Zone D4 Long Term Monitoring  
 Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

**Drinking Water Samples collected in May - June 2022 from Fire Hydrants in Zone D4**

<b>Notes:</b>
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	D4-HYD1941	D4-HYD2390
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	0.640
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	0.660
	Total Trihalomethanes	80	MCL	ND	1.30

<b>Location ID:</b>	D4-HYD1941	D4-HYD2390
<b>Location Type:</b>	Hydrant	Hydrant
<b>Address:</b>	FH 1941	FH 2390
<b>Field Sample ID:</b>	D4-DL-0017801-22127 -N	D4-DL-0017802-22127 -N
<b>Sample Date:</b>	2022-05-23	2022-05-23
<b>Sample Type:</b>	N (Normal)	N (Normal)