



Joint Base Pearl Harbor-Hickam (JBPHH) Public Water System No. HI0000360

Drinking Water Distribution System Recovery Plan: *Stage 5 Long-Term Monitoring (LTM) Month 3 Sampling Results Report for Zone A3* 17 August 2022



Neighborhoods included in Zone A3: Iroquois Point




EXECUTIVE SUMMARY FOR ZONE A3

This report documents the results of long-term monitoring (LTM) testing for Zone A3. We are sharing this information with you to keep you updated on your water quality.

This LTM testing was performed after the November 29, 2021 [Public Health Advisory for the JBPHH Public Water System](#) for Zone A3 was amended by the Hawaii Department of Health (DOH) on March 13, 2022. The amended health advisory for Zone A3 can be found online at: <https://jbphh-safewaters.org>. The amended health advisory states that tap water can be used for all purposes including drinking, cooking, oral hygiene, and consumption by pets. The health advisory was amended based on a final review of all sample data and how the Navy water system maintains operations to ensure safe drinking water. Test results that led to the advisory amendment are summarized in the Stage 4 Residential Sampling Report. After the health advisory was amended, residents were informed that they can safely use their water for all purposes.

Zone A3 has been thoroughly flushed, sampled, and tested. This zone has completed each stage (i.e., Stage 1 – Distribution System Flushing through Stage 4 – Building Sampling) outlined in the Drinking Water Distribution System Recovery Plan.¹ Based on the samples collected and tested from water mains (Stage 2), residences, buildings, and schools (Stage 4), this zone meets the U.S. Environmental Protection Agency (EPA) and DOH drinking water standards used during this investigation. Zone A3 is now in the LTM phase (a.k.a., Stage 5), which is described below. For additional information on the Stage 2, Stage 4, and Stage 5 sample results by zone, please visit: <https://jbphh-safewaters.org>.



¹ The Drinking Water Distribution System Recovery Plan was developed and approved by the Interagency Drinking Water System Team (IDWST). The DOH, EPA, Navy, and Army formed the IDWST to restore safe drinking water to all Navy Water System users. The JBPHH PWS #HI0000360 & ARM PWS #HI0000337 will continue the work of the IDWST by working to restore consumer confidence by ensuring tap water continues to be safe for human consumption (e.g., drinking, cooking, oral hygiene).



Long-Term Monitoring

LTM will be performed as outlined in the Drinking Water Sampling Plan, dated December 2021. LTM will take place for two years after the date of the amended health advisory. The purpose of LTM is to ensure tap water continues to be safe for human consumption (e.g., drinking, cooking, oral hygiene). Residents/occupants will be notified if and when their house/building is scheduled to be sampled. Below is the schedule for LTM in Zone A3.

LTM Schedule for Zone A3

| Sampling Event ¹ | Summary of Sampling Activities | Completion Date ² |
|-----------------------------|--|------------------------------|
| Month 1 | 5% of houses/buildings (minimum of 5 houses/buildings) | April 4 – April 7, 2022 |
| Month 2 | 5% of houses/buildings (minimum of 5 houses/buildings) | April 25 – May 11, 2022 |
| Month 3 | 5% of houses/buildings (minimum of 5 houses/buildings) | May 31 – June 22, 2022 |
| Month 9 | 10% of houses/buildings (minimum of 15 houses/buildings) | December 2022 |
| Month 15 | 10% of houses/buildings (minimum of 15 houses/buildings) | June 2023 |
| Month 21 | 10% of houses/buildings (minimum of 15 houses/buildings) | December 2023 |
| Month 24 | 10% of houses/buildings (minimum of 15 houses/buildings) | March 2024 |

Notes:

¹ Sampling events are scheduled based on the amount of time (months) since the DOH health advisory was amended for this zone.

² Completion dates are estimated based on the date the DOH health advisory was amended for this zone.



Tables Included in this Stage 5 Sampling Results Report for Zone A3

| Table | Description | Page |
|--------------|--|-------------|
| Table 1-1. | Contaminants Detected in Drinking Water Samples Collected from Residences in Zone A3..... | 1 |
| Table 1-2. | Contaminants Detected in Drinking Water Samples Collected from Schools in Zone A3 | 3 |
| Table 1-3. | Contaminants Detected in Drinking Water Samples Collected from Child Development Centers in Zone A3 | 5 |
| Table 1-4. | Contaminants Detected in Drinking Water Samples Collected from Other Buildings in Zone A3 | 6 |
| Table 1-5. | Contaminants Detected in Drinking Water Samples Collected from Fire Hydrants in Zone A3 | 8 |
| Table 1-6. | Contaminants Detected in Drinking Water Samples Collected from JBPHH’s Source Water (Waiawa Shaft – Post Chlorination) | 10 |



Table 1-1. Contaminants Detected in Drinking Water Samples Collected from Residences in Zone A3

| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Stage 4 Sampling Summary | | Stage 5 LTM Sampling Summary Month 1 | | Stage 5 LTM Sampling Summary Month 2 | | Stage 5 LTM Sampling Summary Month 3 | | Stage 5 LTM Sampling Summary Month 9 | | Stage 5 LTM Sampling Summary Month 15 | | Stage 5 LTM Sampling Summary Month 21 | | Stage 5 LTM Sampling Summary Month 24 | | |
|--|--|------------------|-----------------------------|---|-------------------------------|--|--------------------------------------|--|--------------------------------------|--|--------------------------------------|--|--|--|--|--|---------------------------------------|--|---------------------------------------|--|-------------------------------|
| | | | | | 02/04/22 – 02/09/22 | | 04/04/22 – 04/07/22 | | 04/26/22 – 05/11/22 | | 05/31/2022 – 06/22/22 | | December 2022 | | June 2023 | | December 2023 | | March 2024 | | |
| | | | | | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples |
| Contaminants of Concern¹ | | | | | | | | | | | | | | | | | | | | | |
| Benzene | Discharge from factories; Leaching from gas storage tanks and landfills | ppb ⁶ | 5.0 | MCL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Ethylbenzene | Discharge from petroleum refineries | ppb | 700 | MCL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | | | | | | | | | |
| Toluene | Discharge from petroleum factories | ppb | 1,000 | MCL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | | | | | | | | | |
| Xylenes (total) | Discharge from petroleum factories; Discharge from chemical factories | ppb | 10,000 | MCL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | | | | | | | | | |
| 1-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also, present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites. | ppb | 10 | EAL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | | | | | | | | | |
| 2-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also used to make vitamin K; and is present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | EAL | 0/180 | - | 0/83 | - | 0/82 | - | 0/82 | - | | | | | | | | | |
| Naphthalene | Naphthalene is found in coal tar or crude oil and is used in the manufacture of plastics, resins, fuels, and dyes, and as a fumigant | ppb | 17 | EAL | 0/180 | - | 0/83 | - | 0/82 | - | 1/82 | ND - 1.6 (1.6) | | | | | | | | | |
| Total TPH ⁴ | TPH is petroleum and can contaminate drinking water through spills and other releases into the environment | ppb | 211 | ISP | 14/180 | ND - 179 (77) | 16/83 | ND - 163 (65) | 7/82 | ND - 159 (71) | 21/82 | ND - 148 (67) | | | | | | | | | |
| Total Organic Carbon (TOC) ⁵ | Naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources | ppb | 4,000 | ISP | 75/180 | ND - 7,410 (2,058) | 0/83 | - | 2/82 | ND - 620 (475) | 0/82 | - | | | | | | | | | |
| Free Chlorine (Field Test) ⁸ | Water additive used to control microbes | ppb | 4,000 | ISP | - | - | 73/73 | 30 - 860 (544) | 75/75 | 20 - 1,690 (462) | 76/76 | 20 - 900 (516) | | | | | | | | | |
| Metals | | | | | | | | | | | | | | | | | | | | | |
| Antimony | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | ppb | 6.0 | MCL | 1/180 | ND - 0.077 (0.077) | 0/83 | - | 8/82 | ND - 0.18 (0.14) | 12/85 | ND - 0.23 (0.16) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Arsenic | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes | ppb | 10 | MCL | 0/180 | - | 0/83 | - | 0/82 | - | 4/85 | ND - 0.66 (0.59) | | | | | | | | | |
| Barium | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | ppb | 2,000 | MCL | 180/180 | 0.33 - 29 (2.2) | 83/83 | 1.8 - 2.6 (2.0) | 82/82 | 1.9 - 2.3 (2.0) | 85/85 | 1.9 - 2.5 (2.1) | | | | | | | | | |



| | | | | | | | | | | | | | | | | |
|---|--|-----|-------|-----|---------|--------------------|-------|--------------------|-------|--------------------|-------|------------------------------|--|--|--|--|
| Beryllium | Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries | ppb | 4.0 | MCL | 1/180 | ND - 0.12 (0.12) | 0/83 | - | 1/82 | ND - 0.16 (0.16) | 0/85 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Cadmium | By-product of drinking water disinfection | ppb | 5.0 | MCL | 1/180 | ND - 0.066 (0.066) | 0/83 | - | 1/82 | ND - 0.14 (0.14) | 0/85 | - | | | | |
| Chromium | Discharge from steel and pulp mills; Erosion of natural deposits | ppb | 100 | MCL | 171/180 | ND - 1.8 (1.5) | 83/83 | 1.1 - 2.0 (1.6) | 82/82 | 0.58 - 1.5 (1.1) | 82/85 | ND - 1.4 (1.1) | | | | |
| Copper | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 1,300 | MCL | 180/180 | 7.8 - 201 (40) | 83/83 | 5.2 - 72 (29) | 82/82 | 3.8 - 118 (32) | 85/85 | 0.81 - 61 (22) | | | | |
| Lead | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 15 | MCL | 162/180 | ND - 2.2 (0.38) | 69/83 | ND - 1.4 (0.32) | 72/82 | ND - 3.1 (0.42) | 70/85 | ND - 3.2 (0.36) ⁹ | | | | |
| Mercury | Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland | ppb | 2.0 | MCL | 15/180 | ND - 0.34 (0.17) | 0/83 | - | 7/82 | ND - 0.055 (0.038) | 4/82 | ND - 0.041 (0.034) | | | | |
| Selenium | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines | ppb | 50 | MCL | 20/180 | ND - 2.1 (1.6) | 0/83 | - | 44/82 | ND - 1.5 (0.81) | 58/85 | ND - 2.5 (1.1) | | | | |
| Thallium | Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories | ppb | 2.0 | MCL | 17/180 | ND - 0.12 (0.10) | 5/83 | ND - 0.077 (0.07) | 3/82 | ND - 0.22 (0.12) | 2/85 | ND - 0.17 (0.17) | | | | |
| Volatile Organic Compounds (VOCs) | | | | | | | | | | | | | | | | |
| Total trihalomethanes (sum of chloroform, bromoform, bromodichloromethane, and di-bromochloromethane) | By-product of drinking water disinfection | ppb | 80 | MCL | - | - | 9/83 | ND - 2.4 (1.2) | 17/82 | ND - 4.5 (1.3) | 58/82 | ND - 6.5 (1.6) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| trans-1,2-Dichloroethene | Discharge from industrial chemical factories | ppb | 100 | MCL | 2/180 | ND - 0.54 (0.41) | 0/83 | - | 0/82 | - | 0/82 | - | | | | |
| Trichloroethene (TCE) | Discharge from metal degreasing sites and other factories | ppb | 5.0 | MCL | 1/180 | ND - 0.060 (0.060) | 0/83 | - | 0/82 | - | 0/82 | - | | | | |
| Synthetic Organic Compounds (SOCs) or Semi-Volatile Organic Compounds (SVOCs) | | | | | | | | | | | | | | | | |
| Benzo(a)pyrene | Leaching from linings of water storage tanks and distribution lines | ppb | 0.20 | MCL | 0/180 | - | 1/83 | ND - 0.038 (0.038) | 1/82 | ND - 0.031 (0.031) | 0/82 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Bis(2-ethylhexyl)phthalate | Discharge from rubber and chemical factories | ppb | 6.0 | MCL | 1/180 | ND - 1.9 (1.9) | 1/83 | ND - 1.4 (1.4) | 1/82 | ND - 0.41 (0.41) | 3/82 | ND - 3.8 (1.9) | | | | |

Notes:

1. These contaminants are listed whether detected or non-detect (ND) because these are incident specific. All other contaminants are only listed if detected.
2. The DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established environmental action levels (EALs) and incident specific parameters (ISPs).
3. These numbers are the minimum and maximum values from all the sample test results. The average (or mathematical mean) includes all sample test results with a detectable contaminant. An average is the sum of the results (excluding non-detects) divided by the total number results with detection only. Acronyms and explanation of terms used in this table are presented on the following pages.
4. For more information regarding Total Petroleum Hydrocarbons, refer to the FACT SHEET What Are Petroleum Hydrocarbons?, available online at: https://health.hawaii.gov/about/files/2021/12/21.12.16_What-Are-Petroleum-Hydrocarbons.pdf.
5. Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 2,000 ppb under Stage 4. Each exceedance was investigated by reviewing the associated water quality data (e.g., BTEX results, TPH) and the IDWST determined that all TOC exceedances were inconclusive in association with petroleum hydrocarbons. Under the Drinking Water Long Term Monitoring Plan (under review during the LTM Month 3 report for Zone A3), DOH revised the TOC screening level to 4,000 ppb (previously 2,000 ppb).
6. Parts per billion (ppb) refers to the amount (or concentration) of a contaminant in the water.
7. Cells highlighted in green indicate the water sample results were below DOH Screening Levels.
8. On January 30 and February 25, 2022, DOH revised the LTM requirements to include the analysis of free chlorine. Chlorine is typically used as an additive to drinking water for disinfection purposes.
9. This does not include the June 16, 2022 (initial) lead sample from 6733B 108th Street (Field Sample Number: A3-TW-0016179-22132-N-R1). This does include the resampled results from the residence. This exceedance was associated with Premise Plumbing and is not associated with the JPHH water distribution system. Therefore, it was not included in this table. See section "What was Found?" in the main text of this report for a complete discussion of this exceedance.
 - a) The sample result taken from 6733B 108th Street on June 16, 2022 was 15.3 ppb for lead. This exceeded the action level of 15 ppb. The family was advised not to consume water and was provided bottled water. The faucet with the exceedance was flushed on June 22, 2022, and the Navy conducted sampling of all 3 faucets in the home that same day. The resample results at the original location (Field Sample Number: A3-TW-0016179-22132-N-R1), as well as the additional samples, did not exceed the action level.



Table 1-2. Contaminants Detected in Drinking Water Samples Collected from Schools in Zone A3

| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Stage 4 Sampling Summary | | Stage 5 LTM Sampling Summary Month 1 | | Stage 5 LTM Sampling Summary Month 2 | | Stage 5 LTM Sampling Summary Month 3 | | Stage 5 LTM Sampling Summary Month 9 | | Stage 5 LTM Sampling Summary Month 15 | | Stage 5 LTM Sampling Summary Month 21 | | Stage 5 LTM Sampling Summary Month 24 | | |
|--|--|------------------|-----------------------------|---|-------------------------------|--|--------------------------------------|--|--------------------------------------|--|--------------------------------------|--|--|--|--|--|---------------------------------------|--|---------------------------------------|--|-------------------------------|
| | | | | | 01/31/22 – 02/04/22 | | 04/05/22 | | 04/27/22 – 04/29/22 | | 05/31/22 – 06/01/22 | | December 2022 | | June 2023 | | December 2023 | | March 2024 | | |
| | | | | | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples |
| Contaminants of Concern¹ | | | | | | | | | | | | | | | | | | | | | |
| Benzene | Discharge from factories; Leaching from gas storage tanks and landfills | ppb ⁶ | 5.0 | MCL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Ethylbenzene | Discharge from petroleum refineries | ppb | 700 | MCL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| Toluene | Discharge from petroleum factories | ppb | 1,000 | MCL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| Xylenes (total) | Discharge from petroleum factories; Discharge from chemical factories | ppb | 10,000 | MCL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| 1-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also, present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites. | ppb | 10 | EAL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| 2-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also used to make vitamin K; and is present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | EAL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| Naphthalene | Naphthalene is found in coal tar or crude oil and is used in the manufacture of plastics, resins, fuels, and dyes, and as a fumigant | ppb | 17 | EAL | 0/12 | - | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| Total TPH ⁴ | TPH is petroleum and can contaminate drinking water through spills and other releases into the environment | ppb | 211 | ISP | 0/12 | - | 1/11 | ND - 54 (54) | 0/10 | - | 2/12 | ND - 54 (54) | | | | | | | | | |
| Total Organic Carbon (TOC) ⁵ | Naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources | ppb | 4,000 | ISP | 8/13 | ND – 11,600 (3,403) | 0/11 | - | 0/10 | - | 0/12 | - | | | | | | | | | |
| Free Chlorine (Field Test) ⁶ | Water additive used to control microbes | ppb | 4,000 | ISP | - | - | 11/11 | 20 – 570 (353) | 10/10 | 10 - 720 (340) | 10/10 | 60 – 690 (319) | | | | | | | | | |
| Metals | | | | | | | | | | | | | | | | | | | | | |
| Antimony | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | ppb | 6.0 | MCL | 0/12 | - | 0/11 | - | 1/10 | ND - 0.15 (0.15) | 0/12 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Arsenic | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes | ppb | 10 | MCL | 0/12 | - | 0/11 | - | 0/10 | - | 2/12 | ND - 0.76 (0.68) | | | | | | | | | |
| Barium | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | ppb | 2,000 | MCL | 12/12 | 1.9 - 2.2 (2.0) | 11/11 | 1.9 - 2.1 (2.0) | 10/10 | 2.0 - 2.1 (2.1) | 12/12 | 1.9 - 2.3 (2.1) | | | | | | | | | |
| Chromium | Discharge from steel and pulp mills; Erosion of natural deposits | ppb | 100 | MCL | 12/12 | 1.1 - 1.5 (1.3) | 11/11 | 1.7 - 1.9 (1.8) | 10/10 | 0.80 - 1.3 (1.1) | 12/12 | 0.90 - 1.2 (1.0) | | | | | | | | | |
| Copper | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 1,300 | MCL | 12/12 | 10 - 182 (82) | 11/11 | 17 - 180 (70) | 10/10 | 7.5 - 147 (61) | 12/12 | 15 - 169 (77) | | | | | | | | | |
| Lead | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 15 | MCL | 12/12 | 0.13 - 8.4 (1.3) | 9/11 | ND - 0.27 (0.2) | 8/10 | ND - 1.8 (0.44) | 11/12 | ND - 1.1 (0.35) | | | | | | | | | |
| Mercury | Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland | ppb | 2 | MCL | 0/12 | - | 0/11 | - | 2/10 | ND - 0.044 (0.035) | 1/12 | ND - 0.031 (0.031) | | | | | | | | | |



| | | | | | | | | | | | | | | | | |
|---|--|-----|------|-----|------|---|------|--------------------|------|------------------|-------|------------------|--|--|--|--|
| Selenium | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines | ppb | 50 | MCL | 0/12 | - | 0/11 | - | 6/10 | ND - 0.83 (0.65) | 12/12 | 0.67 - 2.2 (1.2) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Volatile Organic Compounds (VOCs) | | | | | | | | | | | | | | | | |
| Total Haloacetic acids (sum of mono-, di-, trichloroacetic acids and mono- and dibromo acetic acids) | By-product of drinking water disinfection | ppb | 60 | MCL | - | - | 1/11 | ND - 2.4 (2.4) | 1/10 | ND - 2.5 (2.5) | 0/12 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Total trihalomethanes (sum of chloroform, bromoform, bromodichloromethane, and di-bromochloromethane) | By-product of drinking water disinfection | ppb | 80 | MCL | - | - | 5/11 | ND - 3.5 (1.8) | 2/10 | ND - 1.0 (0.96) | 10/12 | ND - 3.0 (2.0) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Synthetic Organic Compounds (SOCs) or Semi-Volatile Organic Compounds (SVOCs) | | | | | | | | | | | | | | | | |
| Benzo(a)pyrene | Leaching from linings of water storage tanks and distribution lines | ppb | 0.20 | MCL | 0/12 | - | 2/11 | ND - 0.016 (0.015) | 0/10 | - | 0/12 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |

- Notes:
1. These contaminants are listed whether detected or non-detect (ND) because these are incident specific. All other contaminants are only listed if detected.
 2. The DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established environmental action levels (EALs) and incident specific parameters (ISPs).
 3. These numbers are the minimum and maximum values from all the sample test results. The average (or mathematical mean) includes all sample test results with a detectable contaminant. An average is the sum of the results (excluding non-detects) divided by the total number results with detection only. Acronyms and explanation of terms used in this table are presented on the following pages.
 4. For more information regarding Total Petroleum Hydrocarbons, refer to the FACT SHEET What Are Petroleum Hydrocarbons?, available online at: https://health.hawaii.gov/about/files/2021/12/21.12.16_What-Are-Petroleum-Hydrocarbons.pdf.
 5. Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 2,000 ppb under Stage 4. Each exceedance was investigated by reviewing the associated water quality data (e.g., BTEX results, TPH) and the IDWST determined that all TOC exceedances were inconclusive in association with petroleum hydrocarbons. Under the Drinking Water Long Term Monitoring Plan (under review during the LTM Month 3 report for Zone A3). DOH revised the TOC screening level to 4,000 ppb (previously 2,000 ppb).
 6. Parts per billion (ppb) refers to the amount (or concentration) of a contaminant in the water.
 7. Cells highlighted in green indicate the water sample results were below DOH Screening Levels.
 8. On January 30 and February 25, 2022, DOH revised the LTM requirements to include the analysis of free chlorine. Chlorine is typically used as an additive to drinking water for disinfection purposes.



Table 1-3. Contaminants Detected in Drinking Water Samples Collected from Child Development Centers in Zone A3

There are no Child Development Centers in this zone.



Table 1-4. Contaminants Detected in Drinking Water Samples Collected from Other Buildings in Zone A3

| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Stage 4 Sampling Summary | | Stage 5 LTM Sampling Summary Month 1 | | Stage 5 LTM Sampling Summary Month 2 | | Stage 5 LTM Sampling Summary Month 3 | | Stage 5 LTM Sampling Summary Month 9 | | Stage 5 LTM Sampling Summary Month 15 | | Stage 5 LTM Sampling Summary Month 21 | | Stage 5 LTM Sampling Summary Month 24 | | |
|--|--|------------------|-----------------------------|---|-------------------------------|--|--------------------------------------|--|--------------------------------------|--|--------------------------------------|--|--|--|--|--|---------------------------------------|--|---------------------------------------|--|-------------------------------|
| | | | | | 02/05/22 | | 04/04/22 – 04/05/22 | | 04/26/22 | | 06/01/22 | | December 2022 | | June 2023 | | December 2023 | | March 2024 | | |
| | | | | | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples | Minimum – Maximum (Average) ³ | No. of Detects out of Samples |
| Contaminants of Concern¹ | | | | | | | | | | | | | | | | | | | | | |
| Benzene | Discharge from factories; Leaching from gas storage tanks and landfills | ppb ⁶ | 5.0 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Ethylbenzene | Discharge from petroleum refineries | ppb | 700 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| Toluene | Discharge from petroleum factories | ppb | 1,000 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| Xylenes (total) | Discharge from petroleum factories; Discharge from chemical factories | ppb | 10,000 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| 1-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also, present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites. | ppb | 10 | EAL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| 2-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also used to make vitamin K; and is present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | EAL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| Naphthalene | Naphthalene is found in coal tar or crude oil and is used in the manufacture of plastics, resins, fuels, and dyes, and as a fumigant | ppb | 17 | EAL | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| Total TPH ⁴ | TPH is petroleum and can contaminate drinking water through spills and other releases into the environment | ppb | 211 | ISP | 0/1 | - | 1/2 | ND - 53 (53) | 0/2 | - | 1/3 | ND - 55 (55) | | | | | | | | | |
| Total Organic Carbon (TOC) ⁵ | Naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources | ppb | 4,000 | ISP | 0/1 | - | 0/2 | - | 0/2 | - | 0/3 | - | | | | | | | | | |
| Free Chlorine (Field Test) ⁸ | Water additive used to control microbes | ppb | 4,000 | ISP | - | - | 2/2 | 30 - 410 (220) | 2/2 | 100 - 360 (230) | 2/2 | 190 - 320 (255) | | | | | | | | | |
| Metals | | | | | | | | | | | | | | | | | | | | | |
| Antimony | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | ppb | 6 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 1/3 | ND - 0.14 (0.14) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Barium | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | ppb | 2,000 | MCL | 1/1 | 2.1 - 2.1 (2.1) | 2/2 | 1.9 - 3.2 (2.6) | 2/2 | 2.0 - 3.3 (2.7) | 3/3 | 2.1 - 2.2 (2.1) | | | | | | | | | |
| Chromium | Discharge from steel and pulp mills; Erosion of natural deposits | ppb | 100 | MCL | 1/1 | 1.6 - 1.6 (1.6) | 2/2 | 1.4 - 1.9 (1.7) | 2/2 | 0.71 - 0.71 (0.71) | 3/3 | 1.0 - 1.1 (1.1) | | | | | | | | | |
| Copper | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 1,300 | MCL | 1/1 | 35 - 35 (35) | 2/2 | 51 - 58 (54.5) | 2/2 | 69 - 101 (85) | 3/3 | 24 - 333 (227) | | | | | | | | | |
| Lead | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 15 | MCL | 1/1 | 0.26 - 0.26 (0.26) | 1/2 | ND - 0.21 (0.21) | 1/2 | ND - 0.36 (0.36) | 1/3 | ND - 0.29 (0.29) | | | | | | | | | |



| | | | | | | | | | | | | | | | | |
|---|---|-----|----|-----|-----|---|-----|------------------|-----|------------------|-----|--------------------|--|--|--|--|
| Mercury | Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland | ppb | 2 | MCL | 0/1 | - | 0/2 | - | 0/2 | - | 1/3 | ND - 0.033 (0.033) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Selenium | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines | ppb | 50 | MCL | 0/1 | - | 0/2 | - | 1/2 | ND - 0.35 (0.35) | 3/3 | 0.83 - 1.1 (0.98) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Volatile Organic Compounds (VOCs) | | | | | | | | | | | | | | | | |
| Total Haloacetic acids (sum of mono-, di-, trichloroacetic acids and mono- and dibromo acetic acids) | By-product of drinking water disinfection | ppb | 60 | MCL | - | - | 0/2 | - | 1/2 | ND - 1.1 (1.1) | 0/3 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Total trihalomethanes (sum of chloroform, bromoform, bromodichloromethane, and di-bromochloromethane) | By-product of drinking water disinfection | ppb | 80 | MCL | - | - | 1/2 | ND - 0.78 (0.78) | 2/2 | 0.59 - 8.5 (4.5) | 3/3 | 1.3 - 1.4 (1.3) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Synthetic Organic Compounds (SOCs) or Semi-Volatile Organic Compounds (SVOCs) – ND | | | | | | | | | | | | | | | | |

- Notes:
1. These contaminants are listed whether detected or non-detect (ND) because these are incident specific. All other contaminants are only listed if detected.
 2. The DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established environmental action levels (EALs) and incident specific parameters (ISPs).
 3. These numbers are the minimum and maximum values from all the sample test results. The average (or mathematical mean) includes all sample test results with a detectable contaminant. An average is the sum of the results (excluding non-detects) divided by the total number results with detection only. Acronyms and explanation of terms used in this table are presented on the following pages.
 4. For more information regarding Total Petroleum Hydrocarbons, refer to the FACT SHEET What Are Petroleum Hydrocarbons?, available online at: https://health.hawaii.gov/about/files/2021/12/21_12.16_What-Are-Petroleum-Hydrocarbons.pdf.
 5. Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 2,000 ppb under Stage 4. Each exceedance was investigated by reviewing the associated water quality data (e.g., BTEX results, TPH) and the IDWST determined that all TOC exceedances were inconclusive in association with petroleum hydrocarbons. Under the Drinking Water Long Term Monitoring Plan (under review during the LTM Month 3 report for Zone A3). DOH revised the TOC screening level to 4,000 ppb (previously 2,000 ppb).
 6. Parts per billion (ppb) refers to the amount (or concentration) of a contaminant in the water.
 7. Cells highlighted in green indicate the water sample results were below DOH Screening Levels.
 8. On January 30 and February 25, 2022, DOH revised the LTM requirements to include the analysis of free chlorine. Chlorine is typically used as an additive to drinking water for disinfection purposes.



Table 1-5. Contaminants Detected in Drinking Water Samples Collected from Fire Hydrants in Zone A3

| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Stage 4 Sampling Summary | | Stage 5 LTM Sampling Summary Month 1 | | Stage 5 LTM Sampling Summary Month 2 | | Stage 5 LTM Sampling Summary Month 3 | | Stage 5 LTM Sampling Summary Month 9 | | Stage 5 LTM Sampling Summary Month 15 | | Stage 5 LTM Sampling Summary Month 21 | | Stage 5 LTM Sampling Summary Month 24 | | |
|--|--|------------------|-----------------------------|---|-------------------------------|--|--------------------------------------|--|--------------------------------------|--|--------------------------------------|--|--|--|--|--|---------------------------------------|--|---------------------------------------|--|-------------------------------|
| | | | | | 01/01/22 - 01/13/22 | | 04/04/22 | | 04/25/22 | | 06/06/22 | | December 2022 | | June 2023 | | December 2023 | | March 2024 | | |
| | | | | | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples | Minimum - Maximum (Average) ³ | No. of Detects out of Samples |
| Contaminants of Concern¹ | | | | | | | | | | | | | | | | | | | | | |
| Benzene | Discharge from factories; Leaching from gas storage tanks and landfills | ppb ⁶ | 5.0 | MCL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Ethylbenzene | Discharge from petroleum refineries | ppb | 700 | MCL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| Toluene | Discharge from petroleum factories | ppb | 1,000 | MCL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| Xylenes (total) | Discharge from petroleum factories; Discharge from chemical factories | ppb | 10,000 | MCL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| 1-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also, present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites. | ppb | 10 | EAL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| 2-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also used to make vitamin K; and is present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | EAL | 0/8 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| Naphthalene | Naphthalene is found in coal tar or crude oil and is used in the manufacture of plastics, resins, fuels, and dyes, and as a fumigant | ppb | 17 | EAL | 0/11 | - | 0/8 | - | 0/10 | - | 0/8 | - | | | | | | | | | |
| Total TPH ⁴ | TPH is petroleum and can contaminate drinking water through spills and other releases into the environment | ppb | 211 | ISP | 1/9 | ND - 48 (48) | 0/8 | - | 1/10 | ND - 59 (59) | 2/8 | ND - 73 (72) | | | | | | | | | |
| Total Organic Carbon (TOC) ⁵ | Naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources | ppb | 4,000 | ISP | 2/8 | ND - 842 (820) | 0/8 | - | 1/10 | ND - 390 (390) | 1/8 | ND - 580 (580) | | | | | | | | | |
| Free Chlorine (Field Test) ⁹ | Water additive used to control microbes | ppb | 4,000 | ISP | - | - | 8/8 | 120 - 700 (444) | 8/8 | 40 - 510 (274) | 8/8 | 30 - 590 (366) | | | | | | | | | |
| Metals | | | | | | | | | | | | | | | | | | | | | |
| Antimony | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | ppb | 6 | MCL | 0/8 | - | 0/8 | - | 1/10 | ND - 0.13 (0.13) | 0/8 | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. | | | | | |
| Arsenic | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes | ppb | 10 | MCL | 8/8 | 0.13 - 0.74 (0.42) | 1/8 | ND - 0.65 (0.65) | 0/10 | - | 0/8 | - | | | | | | | | | |
| Barium | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | ppb | 2,000 | MCL | 8/8 | 1.9 - 74 (20) | 8/8 | 2.0 - 2.6 (2.2) | 10/10 | 1.9 - 5.9 (2.4) | 8/8 | 1.9 - 15 (3.9) | | | | | | | | | |
| Chromium | Discharge from steel and pulp mills; Erosion of natural deposits | ppb | 100 | MCL | 8/8 | 1.0 - 1.5 (1.3) | 8/8 | 1.2 - 1.3 (1.3) | 10/10 | 1.1 - 1.2 (1.1) | 8/8 | 0.85 - 1.2 (0.96) | | | | | | | | | |
| Copper | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 1,300 | MCL | 8/8 | 0.86 - 50 (7.6) | 8/8 | 3.1 - 11 (4.9) | 10/10 | 1.1 - 5.3 (2.4) | 8/8 | 3.2 - 10 (5.9) | | | | | | | | | |



| | | | | | | | | | | | | | | | | |
|---|--|-----|----------------|----------------|------|-----------------------|-----|-----------------------|-------|-----------------------|-----|----------------------|--|--|--|--|
| Lead | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 15 | MCL | 8/8 | 0.12 - 7.6 (1.1) | 7/8 | ND - 0.51 (0.29) | 6/10 | ND - 0.31 (0.24) | 8/8 | 0.14 - 1.1 (0.43) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Selenium | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines | ppb | 50 | MCL | 7/8 | ND - 4.1 (2.3) | 0/8 | - | 10/10 | 0.52 - 1.2 (0.73) | 7/8 | ND - 1.6 (1.0) | | | | |
| Thallium | Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories | ppb | 2.0 | MCL | 0/8 | - | 1/8 | ND - 0.056 (0.056) | 1/10 | ND - 0.055 (0.055) | 0/8 | - | | | | |
| Volatile Organic Compounds (VOCs) – ND | | | | | | | | | | | | | | | | |
| Total trihalomethanes (sum of chloroform, bromoform, bromodichloromethane, and di-bromochloromethane) | By-product of drinking water disinfection | ppb | 80 | MCL | - | - | 0/8 | - | 3/10 | ND - 63 (22) | 4/8 | ND - 64 (17) | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Synthetic Organic Compounds (SOCs) or Semi-Volatile Organic Compounds (SVOCs) | | | | | | | | | | | | | | | | |
| 2-Methylphenol (o-Cresol) | Used to make other chemicals such as dyes, resins, and textiles; Used in the manufacturing of pesticides | ppb | - ⁷ | - ⁷ | 1/2 | ND - 0.062 (0.062) | 0/8 | - | 0/10 | - | - | - | These samples will be collected 9 months after the health advisory was amended. Results will be reported in a LTM Month 9 Sampling Results Report. | These samples will be collected 15 months after the health advisory was amended. Results will be reported in a LTM Month 15 Sampling Results Report. | These samples will be collected 21 months after the health advisory was amended. Results will be reported in a LTM Month 21 Sampling Results Report. | These samples will be collected 24 months after the health advisory was amended. Results will be reported in a LTM Month 24 Sampling Results Report. |
| Benzo(a)pyrene | Leaching from linings of water storage tanks and distribution lines | ppb | 0.20 | MCL | 0/11 | - | 1/8 | ND - 0.021 (0.021) | 0/10 | - | 0/8 | - | | | | |
| Di-n-butyl phthalate | Discharge from chemical factories; Used in the manufacturing of plastics. | ppb | - ⁷ | - ⁷ | 3/3 | 0.34 - 0.45 (0.38) | 0/8 | - | 0/10 | - | - | - | | | | |

Notes:

1. These contaminants are listed whether detected or non-detect (ND) because these are incident specific. All other contaminants are only listed if detected.
2. The DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established environmental action levels (EALs) and incident specific parameters (ISPs).
3. These numbers are the minimum and maximum values from all the sample test results. The average (or mathematical mean) includes all sample test results with a detectable contaminant. An average is the sum of the results (excluding non-detects) divided by the total number results with detection only. Acronyms and explanation of terms used in this table are presented on the following pages.
4. For more information regarding Total Petroleum Hydrocarbons, refer to the FACT SHEET What Are Petroleum Hydrocarbons?, available online at: https://health.hawaii.gov/about/files/2021/12/21.12.16_What-Are-Petroleum-Hydrocarbons.pdf.
5. Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 2,000 ppb under Stage 4. Each exceedance was investigated by reviewing the associated water quality data (e.g., BTEX results, TPH) and the IDWST determined that all TOC exceedances were inconclusive in association with petroleum hydrocarbons. Under the Drinking Water Long Term Monitoring Plan (under review during the LTM Month 3 report for Zone A3), DOH revised the TOC screening level to 4,000 ppb (previously 2,000 ppb).
6. Parts per billion (ppb) refers to the amount (or concentration) of a contaminant in the water.
7. This contaminant does not have a DOH Screening Level and was only detected at low concentrations. It is not associated with fuels and is not considered a risk to human health associated with the fuel release that occurred at Red Hill in November 2021.
8. Cells highlighted in green indicate the water sample results were below DOH Screening Levels.
9. On January 30 and February 25, 2022, DOH revised the LTM requirements to include the analysis of free chlorine. Chlorine is typically used as an additive to drinking water for disinfection purposes.



Table 1-6. Contaminants Detected in Drinking Water Samples Collected from JBPHH’s Source Water (Waiawa Shaft – Post Chlorination)

| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Sample Date: 01/11/2022 | | | Sample Date: 05/06/2022 | | |
|--|--|------------------|-----------------------------|---|-------------------------------|-----------------------------|--|-------------------------------|-----------------------------|--|
| | | | | | No. of Detects out of Samples | Level Detected ³ | Meets DOH Screening Level? (Yes / No) ⁷ | No. of Detects out of Samples | Level Detected ³ | Meets DOH Screening Level? (Yes / No) ⁷ |
| Contaminants of Concern¹ | | | | | | | | | | |
| Benzene | Discharge from factories; Leaching from gas storage tanks and landfills | ppb ⁶ | 5.0 | MCL | 0/1 | - | Yes | 0/1 | - | Yes |
| Ethylbenzene | Discharge from petroleum refineries | ppb | 700 | MCL | 0/1 | - | Yes | 0/1 | - | Yes |
| Toluene | Discharge from petroleum factories | ppb | 1,000 | MCL | 0/1 | - | Yes | 0/1 | - | Yes |
| m,p,o-Xylenes | Discharge from petroleum factories; Discharge from chemical factories | ppb | 10,000 | MCL | 0/1 | - | Yes | 0/1 | - | Yes |
| 1-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also, present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | ISP | 0/1 | - | Yes | 0/1 | - | Yes |
| 2-Methylnaphthalene | Used to make other chemicals such as dyes, and resins; also used to make vitamin K; and is present in cigarette smoke, wood smoke, tar, asphalt, and at some hazardous waste sites | ppb | 10 | ISP | 0/1 | - | Yes | 0/1 | - | Yes |
| Naphthalene | Naphthalene is found in coal tar or crude oil and is used in the manufacture of plastics, resins, fuels, and dyes, and as a fumigant | ppb | 17 | ISP | 0/1 | - | Yes | 0/1 | - | Yes |
| Total Petroleum Hydrocarbons (TPHs) ⁴ | TPH is petroleum and can contaminate drinking water through spills and other releases into the environment | ppb | 211 | ISP | 0/1 | - | Yes | 0/1 | - | Yes |
| Total Organic Carbon (TOC) ⁵ | Naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources | ppb | 4,000 | ISP | 0/1 | - | Yes | 0/1 | - | Yes |
| Free Chlorine (Field Test) ⁸ | Water Additive | ppb | 4,000 | MCL | - | - | - | 1/1 | 670 – 670 (670) | Yes |
| Metals | | | | | | | | | | |
| Antimony | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | ppb | 6.0 | MCL | 1/1 | 0.092 - 0.092 (0.92) | Yes | 0/1 | - | Yes |
| Arsenic | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production waste | ppb | 10 | MCL | 1/1 | 0.027 - 0.027 (0.027) | Yes | 0/1 | - | Yes |
| Barium | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits | ppb | 2,000 | MCL | 1/1 | 1.7 - 1.7 (1.7) | Yes | 1/1 | 1.7 - 1.7 (1.7) | Yes |



| Contaminant | Typical Source of Contaminant | Units | DOH Project Screening Level | Basis of DOH Screening Level ² | Sample Date: 01/11/2022 | | | Sample Date: 05/06/2022 | | |
|--|---|-------|-----------------------------|---|-------------------------------|-----------------------------|--|-------------------------------|-----------------------------|--|
| | | | | | No. of Detects out of Samples | Level Detected ³ | Meets DOH Screening Level? (Yes / No) ⁷ | No. of Detects out of Samples | Level Detected ³ | Meets DOH Screening Level? (Yes / No) ⁷ |
| Chromium | Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints | ppb | 100 | MCL | 1/1 | 1.5 - 1.5 (1.5) | Yes | 1/1 | 0.55 - 0.55 (0.55) | Yes |
| Copper | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 1,300 | EAL | 1/1 | 21 - 21 (21) | Yes | 1/1 | 18.7 - 18.7 (18.7) | Yes |
| Lead | Corrosion of household plumbing systems; Erosion of natural deposits | ppb | 15 | EAL | 1/1 | 0.27 - 0.27 (0.27) | Yes | 1/1 | 0.23 - 0.23 (0.23) | Yes |
| Selenium | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines | ppb | 50 | MCL | 1/1 | 0.70 - 0.70 (0.70) | Yes | 1/1 | 1.3 - 1.3 (1.3) | Yes |
| Volatile Organic Compounds (VOCs) – ND | | | | | | | | | | |
| Synthetic Organic Compounds (SOCs) or Semi-Volatile Organic Compounds (SVOCs) | | | | | | | | | | |
| Bis(2-ethylhexyl)phthalate | Discharge from rubber and chemical factories | ppb | 6.0 | MCL | 0/1 | - | Yes | 1/1 | 0.52 - 0.52 (0.52) | Yes |

1. These contaminants are listed whether detected or non-detect (ND) because these are incident specific. All other contaminants are only listed if detected.
2. The DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established environmental action levels (EALs) and incident specific parameters (ISPs).
3. These numbers are the minimum and maximum values from all the sample test results. The average (or mathematical mean) includes all sample test results with a detectable contaminant. An average is the sum of the results (excluding non-detects) divided by the total number results with detection only. Acronyms and explanation of terms used in this table are presented on the following pages.
4. For more information regarding Total Petroleum Hydrocarbons, refer to the FACT SHEET What Are Petroleum Hydrocarbons?, available online at: https://health.hawaii.gov/about/files/2021/12/21.12.16_What-Are-Petroleum-Hydrocarbons.pdf.
5. Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 2,000 ppb under Stage 4. Each exceedance was investigated by reviewing the associated water quality data (e.g., BTEX results, TPH) and the IDWST determined that all TOC exceedances were inconclusive in association with petroleum hydrocarbons. Under the Drinking Water Long Term Monitoring Plan (under review during the LTM Month 3 report for Zone D4), DOH revised the TOC screening level to 4,000 ppb (previously 2,000 ppb).
6. Parts per billion (ppb) refers to the amount (or concentration) of a contaminant in the water.
7. Cells highlighted in green indicate the water sample results were below DOH Screening Levels.
8. On January 30 and February 25, 2022, DOH revised the LTM requirements to include the analysis of free chlorine. Chlorine is typically used as an additive to drinking water for disinfection purposes.



Drinking Water Distribution System Recovery Plan: Stage 5 LTM Month 3 Sampling Results Report for Zone A3

What is the purpose of this Stage 5 LTM Month 3 Sampling Results Report?

This progress report presents the testing results from drinking water samples that have been collected from residences, schools, other buildings, and fire hydrants. These samples were collected after the health advisory had been amended and DOH determined drinking water was safe for human consumption. The health advisory was amended after the first four stages of the [Drinking Water Distribution System Recovery Plan](#) were completed in your zone. The JBPHH PWS #HI0000360 is committed to ensuring tap water is safe for human consumption after residents have returned home.

We are sharing this information with you to keep you updated on your community's water quality.

What was found?

The tables on the previous pages present all contaminants that were detected in drinking water samples that have been collected from residences, schools, other buildings, and fire hydrants in your zone during Stage 5 LTM Month 1, LTM Month 2, and LTM Month 3. The DOH used multiple standards/criteria (called DOH Project Screening Levels) to assess the safety of the drinking water to include:

- EPA and Hawaii DOH Maximum Contaminant Levels (MCLs) standards for drinking water;
- Previously established Environmental Action Levels (EALs); and
- Incident Specific Parameters (ISPs).

This report together with the data demonstrates that the drinking water in your area (Zone A3) meets U.S. EPA and DOH standards that are applicable to the Navy Water System Incident.

All exceedances of DOH Project Screening Levels are thoroughly reviewed and investigated by the Navy, Army, and DOH, to (1) determine if the exceedance is associated with the JBPHH water distribution system or if it is associated with premise plumbing (i.e., it is localized to a specific faucet) and (2) determine the appropriate course of action to address the exceedance (e.g., re-flushing, replacing a faucet).



The following Premise Plumbing exceedances were detected (and were investigated/addressed) in Zone A3 during LTM Month 3:

| Exceedance Location | Plumbing Fixture | Contaminant | Initial Result | Action Taken | Final Result |
|--------------------------------|------------------|-------------|----------------|--------------------------------|--------------|
| 6733B 108 th Street | Indoor Faucet | Lead | 15.3 ppb | Fixture Flushed and Re-sampled | 0.16 ppb |

6733B 108th Street (Premise Plumbing Exceedance)

- The sample result collected from 6733B 108th Street on June 16, 2022 was 15.3 ppb for lead. This exceeded the action level of 15 ppb. Investigation into this exceedance determined that it was likely to be a premise plumbing issue and further investigation was warranted through additional sampling. The source faucet and two other faucets within the residence were then flushed and re-sampled on June 22, 2022 and all were below the action level. The resident was notified on June 21, 2022 of the initial exceedance, and provided bottled water until results of the re-sampling were received. Results of the re-sample and additional samples were below the action level of 15 ppb.

Total Organic Carbon (TOC) test results report any constituent containing carbon, many of which are naturally occurring and some of which may be man-made. The DOH selected a TOC project screening level of 4,000 parts per billion (ppb) for long term monitoring. Each potential exceedance is investigated by reviewing the associated water quality data (e.g., Disinfection Byproducts and TPH results) for association with petroleum hydrocarbons. No TOC exceedances occurred in LTM Month 1, LTM Month 2, or LTM Month 3 for Zone A3.

What contaminants were tested?

Drinking water, including bottled water, can contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants tested can be obtained by calling the Hawaii DOH Safe Drinking Water Branch at 808-586-4258.

In order to ensure that drinking water is safe to drink, EPA and Hawaii DOH regulate the amount of certain contaminants in water provided by public water systems. For this incident, the primary categories of monitored contaminants include volatile organic compounds (VOCs), synthetic organic chemicals (SOCs)/semi-volatile organic compounds (SVOCs), metals, Total Petroleum Hydrocarbons (TPH), and Total Organic Carbon (TOC). A description of these contaminant categories can be found under *Explanation of Terms* located at the end of this report. The full list of contaminants that were tested for this zone are presented in the laboratory reports that are located at: <https://jbphh-safewaters.org>. For complete information on the interagency response, please visit: <https://www.cpf.navy.mil/JPBPHH-Water-Updates/>.



What happened leading up to the public health advisory being issued?

The Red Hill Bulk Fuel Storage Facility jet fuel spill event was reported to have taken place on November 20, 2021. Subsequent reporting of fuel-like smell or visual sheen in addition to complaints of health issues from ingestion or dermal contact with the Navy and Army system water were received by the Navy and DOH. On November 28, 2021, the Navy reported that a chemical release of petroleum, which is a hazardous substance, entered the JBPHH drinking water distribution system from the Red Hill Shaft source. This release triggered an emergency response and DOH issuance of a public health advisory on November 29, 2021, for the entire JBPHH Public Water System No. HI0000360 (JBPHH System) and the consecutive Aliamanu Military Reservation Public Water System No. HI0000337 (AMR System).

The Hawaii DOH, EPA, Navy, and Army formed the Interagency Drinking Water System Team (IDWST) to work on a coordinated effort to restore safe drinking water to all Navy Water System users.

Has the public health advisory been amended or lifted?

The health advisory for Zone A3 was amended on March 13, 2022 but has not been lifted for the entire JBPHH System. The amendment to the health advisory was based on the results of extensive flushing, sampling (10% of buildings), and testing activities performed in Zone A3. The IDWST evaluated multiple lines of evidence to determine whether or not drinking water was safe for consumption. DOH determine that the water in Zone A3 was safe and residents/occupants could use their tap water for all purposes include drinking, cooking, oral hygiene, and consumption by pets. LTM of drinking water will be performed to ensure drinking water remains safe for all residents and occupants of JBPHH. If new information becomes available that indicates contaminants are present in the drinking water that poses a threat to public health, additional investigation may be required.

Where does our water come from?

The source of water for the Navy Water System now comes from the Navy Waiawa Shaft, which was not impacted by the release of Jet Fuel (JP-5) that occurred at Red Hill in late November 2021. The Waiawa Shaft has been sampled, and EPA and the DOH confirmed that it meets all federal and state drinking water standards. The Waiawa Shaft will be sampled (in subsequent months during LTM) in accordance with EPA and the DOH requirements.

What has the IDWST done to clean the drinking water distribution system?

The IDWST evaluated multiple options for cleaning the Navy drinking water distribution system and determined that high-volume flushing of the Navy drinking water distribution system (all water mains/laterals/buildings) with 3 to 5 volumes of clean water from the



Waiawa Shaft, followed by extensive testing to confirm that flushing worked, would restore safe drinking water to all Navy Water System users.

When was Long-Term Monitoring (LTM) water quality sampling conducted in Zone A3?

Between April 4, 2022 and April 7, 2022, drinking water samples were collected from residences, schools, other buildings, and fire hydrants in Zone A3 for LTM Month 1.

Between April 25, 2022 and May 11, 2022, drinking water samples were collected from residences, schools, other buildings, and fire hydrants in Zone A3 for LTM Month 2.

Between May 31, 2022 and June 22, 2022, drinking water samples were collected from residences, schools, other buildings, and fire hydrants in Zone A3 for LTM Month 3.

Where were samples taken?

Per the IDWST approved sampling plan, five percent (5%) of all homes and buildings within Zone A3 were sampled with a minimum of 5 homes/buildings sampled. There are no Child Development Centers in this zone. These houses/buildings will be geographically distributed throughout the area to provide spatial coverage along the water supply line. In addition, the list of houses/buildings may be augmented based on additional information (e.g., houses/buildings where occupants reported specific health impacts, houses/buildings that are referred to the team by medical providers) may also be sampled.

Where can I get more information about the potential health effects associated with these contaminants?

Hawaii Department of Health (DOH)

<https://health.hawaii.gov/about/navy-water-system-quality-updates/>.

Call the DOH Safe Drinking Water Branch at 808-586-4258

US Environmental Protection Agency (EPA)

<https://www.epa.gov/ground-water-and-drinking-water/forms/online-form-epas-office-ground-water-and-drinking-water>.

Call EPA Region 9's Environmental Information Center at 1-866-372-9378



Explanation of Terms and Acronyms used in this Report

Action Level (AL). This AL is for Lead and Copper. The AL is a measure of the effectiveness of the corrosion control treatment in water systems. The AL is not a standard for establishing a safe level of lead or copper. The AL is the point at which certain provisions of the proposed standards must be initiated.

Contaminant. Contaminant is any physical, chemical, biological, or radiological substance or matter in water, and can be either healthy or unhealthy, depending on the particular substance and concentration. It could also be a physical parameter monitored such as pH or temperature.

DOH. Hawaii Department of Health

EPA. U.S. Environmental Protection Agency

Incident Specific Parameter (ISP). To more comprehensively monitor and respond to this specific petroleum contamination of drinking water, the DOH identified contaminants that require additional action prior to amending the Health Advisory. The ISPs are used as a line of evidence to evaluate the data generated in each zone during the investigation conducted by the IDWST.

Maximum Contaminant Level (MCL). An MCL is the maximum permissible level of a contaminant in water which is delivered to any user of a public water system. The MCL is set to protect the public from acute and chronic health risks associated with consuming water containing these contaminants.

Metals. Metals are not derived from living sources and in general do not contain carbon. Metals include antimony, arsenic, asbestos, barium, beryllium, cadmium, chromium, copper, cyanide, fluoride, lead, mercury, nitrate, nitrite, selenium, and thallium. These contaminants get into drinking water supplies through industrial discharge or spills, erosion of natural deposits, corrosion, sewage discharge, fertilizer runoff, and other sources.

ND. Non-Detect

Project Specific Screening Level. DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs) previously established environmental action levels (EALs) and incident specific parameters (ISPs).

Synthetic Organic Compounds (SOCs)/Semi-Volatile Organic Compounds (SVOCs). SOC and SVOC may be used interchangeably and are man-made, organic



(carbon-based) chemicals that are less volatile than Volatile Organic Contaminants (VOCs). They are used as pesticides, defoliants, fuel additives, and as ingredients for other organic chemicals.

DOH Environmental Action Level (EAL). The DOH Environmental Action Levels (EALs) are concentrations of contaminants in drinking water and other media (e.g., soil, soil gas, and groundwater) below which the contaminants are assumed to not pose a significant threat to human health or the environment. Exceeding these EAL does not necessarily indicate that contamination at the site poses environmental hazards but generally warrants additional investigation.

Total Petroleum Hydrocarbons (TPH). TPH is a term used to describe a large family of several hundred chemical compounds that come from crude oil. Crude oil is used to make petroleum products, which can contaminate the environment. TPH is comprised of detected results from TPH-Gasoline, TPH-Diesel, and TPH-Oil.

Total Organic Carbon (TOC). TOC is naturally present in the environment, but also can be an indicator of contamination, including petroleum or other sources.

Free Chlorine. Chlorine is added to drinking water as part of the treatment process. Adding chlorine is the most common way to disinfect drinking water. Disinfection kills bacteria, viruses, and other microorganisms that could cause disease or illness. Chlorine is effective and continues to keep the water safe as it travels from the treatment plant to the consumer's tap. Chlorine measurements provide another line-of-evidence for evaluating drinking water quality.

Total Trihalomethanes (TTHM). TTHM is the sum of the concentration in milligrams per liter of the trihalomethane compounds (trichloromethane [chloroform], dibromochloromethane, bromodichloromethane and tribromomethane [bromoform]).

Units. A unit is the concentration of contaminant found in the water. For this report, the units are expressed in U.S. Standard Units.

| U.S. Standard Unit (Name) | Acronym | Equivalent International System of Units (Name) | Acronym |
|---------------------------|---------|---|---------|
| parts per billion | ppb | micrograms per Liter | µg/L |

Volatile Organic Compounds (VOCs). VOCs are a class of chemicals that contain carbon and evaporate, or volatilize, easily into air at room temperature. VOCs are found in a variety of commercial, industrial, and residential products, including gasoline, solvents, cleaners and degreasers, paints, inks and dyes, and pesticides.