

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location Information	
				Location ID	Location Type
				C1-BLDG1655	Child Development Center
				Address: Building 1655, CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
				Field Sample ID: C1-TW-0014751-23342-N-1	C1-TW-0014751-23342-N-2
				Sample Date: 2024-01-31	2024-01-31
				Sample Type: N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	350-440	350-440
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.90	1.90
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	0.580	0.600
	Copper	1300	MCL	20.2	14.4
	Lead	15	MCL	ND	ND
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	0.830	0.850
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-BLDG1655	
Location Type:	Child Development Center	
Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
Field Sample ID:	C1-TW-0014751-23342-N-1	C1-TW-0014751-23342-N-2
Sample Date:	2024-01-31	2024-01-31
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND
	Benzene	5	MCL	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND
	Chlorobenzene	100	MCL	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND
	Ethylbenzene	700	MCL	ND	ND
	m,p-Xylene	--	--	ND	ND
	Methylene chloride	5	MCL	ND	ND
	o-Xylene	--	--	ND	ND
	Styrene	100	MCL	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND
	Toluene	1000	MCL	ND	ND
trans-1,2-Dichloroethene	100	MCL	ND	ND	
Trichloroethene (TCE)	5	MCL	ND	ND	

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Location ID:	C1-BLDG1655	
Location Type:	Child Development Center	
Address:	Building 1655,CHILD CARE CENTER-NAVAL STATION CDC, 915 North Rd	
Field Sample ID:	C1-TW-0014751-23342-N-1	C1-TW-0014751-23342-N-2
Sample Date:	2024-01-31	2024-01-31
Sample Type:	N (Normal)	N (Normal)

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	ND
	Dichloroacetic acid	--	--	ND	ND
	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	ND
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-HYD1183	C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444		C1-HYD817	
		Location Type:	Hydrant	Hydrant		Hydrant	Hydrant	Hydrant		Hydrant	
		Address:	FH ID: 512	FH ID: FH 503		FHID: 563	FHID: 479	FHID: 413		FHID: 530A	
		Field Sample ID:	C1-DL-0000531-23342 -N	C1-DL-0000526-23342 -N	C1-DL-0000526-23342 -N-P	C1-DL-0017789-23342 -N	C1-DL-0017791-23342 -N	C1-DL-0017788-23342 -N	C1-DL-0017788-23342 -3-N	C1-DL-0017790-23342 -N	
		Sample Date:	2024-01-31	2024-02-20	2024-02-20	2024-02-20	2024-02-20	2024-03-08	2024-03-08	2024-02-20	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	80.0	160	160	290	390	540	540	310
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	8.00	2.10	2.10	2.20	2.00	2.00	2.00	5.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.730	ND	1.40	ND	ND	0.510	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.570	ND	ND	0.650	0.630	0.460	0.760	0.320
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	C1-HYD1183	C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444		C1-HYD817
		Location Type:	Hydrant	Hydrant		Hydrant	Hydrant	Hydrant		Hydrant
		Address:	FH ID: 512	FH ID: FH 503		FHID: 563	FHID: 479	FHID: 413		FHID: 530A
		Field Sample ID:	C1-DL-0000531-23342 -N	C1-DL-0000526-23342 -N	C1-DL-0000526-23342 -N-P	C1-DL-0017789-23342 -N	C1-DL-0017791-23342 -N	C1-DL-0017788-23342 -N	C1-DL-0017788-23342 -3-N	C1-DL-0017790-23342 -N
		Sample Date:	2024-01-31	2024-02-20	2024-02-20	2024-02-20	2024-02-20	2024-03-08	2024-03-08	2024-02-20
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
	Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
Chloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Dibromoacetic acid		--	--	ND	1.00	0.930	1.20	ND	ND	1.70
Dichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Trichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND	ND
Total Haloacetic acids		60	MCL	ND	1.00	0.930	1.20	ND	ND	1.70

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-HYD1765		C1-HYD1769	C1-HYD354	C1-HYD444		C1-HYD817	
				Location Type:	Hydrant		Hydrant	Hydrant	Hydrant	Hydrant		Hydrant
				Address:	FH ID: 512		FH ID: 503	FHID: 563	FHID: 479	FHID: 413		FHID: 530A
				Field Sample ID:	C1-DL-0000531-23342 -N	C1-DL-0000526-23342 -N	C1-DL-0000526-23342 -N-P	C1-DL-0017789-23342 -N	C1-DL-0017791-23342 -N	C1-DL-0017788-23342 -N	C1-DL-0017788-23342 -3-N	C1-DL-0017790-23342 -N
				Sample Date:	2024-01-31	2024-02-20	2024-02-20	2024-02-20	2024-02-20	2024-03-08	2024-03-08	2024-02-20
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Trihalomethanes (ppb)	Bromodichloromethane	--	--	1.80	0.760	ND	0.810	ND	ND	ND	0.790	
	Bromoform	--	--	13.6	3.30	3.10	2.30	0.480	ND	ND	8.80	
	Chloroform	--	--	0.770	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	4.30	2.00	1.70	1.80	0.270	ND	ND	3.10	
	Total Trihalomethanes	80	MCL	20.5	6.06	4.80	4.91	0.750	ND	ND	12.7	

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: C1-BLDG0584		Location ID: C1-BLDG1407		Location ID: C1-BLDG1514		Location ID: C1-BLDG1535								
				Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type	Field Sample ID	Sample Date	Sample Type			
				Medical Building Building 584,CAREER INFORMATION CENTER, 2367 North Rd		Medical Building Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd		Medical Building Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd		Medical Building Building 1535,MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road								
				C1-TW-0014693-23342-N	2024-02-20	N (Normal)	C1-TW-0014693-23342-3-N	2024-02-20	FD (Field Duplicate)	C1-TW-0014730-23342-N	2024-02-20	N (Normal)	C1-TW-0014738-23342-N	2024-02-20	N (Normal)	C1-TW-0014739-23342-N	2024-02-20	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	100	100		130	500	460									
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND		ND	ND	ND									
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND		ND	ND	ND									
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND		ND	ND	ND									
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND		ND	ND	ND									
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND		ND	ND	ND									
Metals (ppb)	Antimony	6	MCL	ND	ND		ND	ND	ND									
	Arsenic	10	MCL	ND	ND		ND	ND	ND									
	Barium	2000	MCL	3.80	3.80		1.90	3.70	1.80									
	Beryllium	4	MCL	ND	ND		ND	ND	ND									
	Cadmium	5	MCL	ND	ND		ND	ND	ND									
	Chromium	100	MCL	ND	ND		ND	0.640	ND									
	Copper	1300	MCL	3.80	3.60		79.0	16.0	20.0									
	Lead	15	MCL	ND	ND		0.210	0.610	ND									
	Mercury	2	MCL	ND	ND		ND	ND	ND									
	Selenium	50	MCL	ND	ND		0.300	0.470	0.600									
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND		ND	ND	ND									
	1-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND									
	2-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND									
	Benzo(a)pyrene	0.2	MCL	ND	ND		ND	ND	ND									
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND		ND	ND	ND									
Naphthalene	17	EAL	ND	ND		ND	ND	ND										

Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	C1-BLDG0584	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535	
				Location Type:	Medical Building	Medical Building	Medical Building	Medical Building	
				Address:	Building 584,CAREER INFORMATION CENTER, 2367 North Rd	Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd	Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	Building 1535,MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road	
				Field Sample ID:	C1-TW-0014693-23342-N	C1-TW-0014693-23342-3-N	C1-TW-0014730-23342-N	C1-TW-0014738-23342-N	C1-TW-0014739-23342-N
				Sample Date:	2024-02-20	2024-02-20	2024-02-20	2024-02-20	2024-02-20
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	
	Benzene	5	MCL	ND	ND	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	
	o-Xylene	--	--	ND	ND	ND	ND	ND	
	Styrene	100	MCL	ND	ND	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	
	Toluene	1000	MCL	ND	ND	ND	ND	ND	
trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND		
Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND		

**Summary of Chemistry Results
Zone C1 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii**

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone C1

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location Information							
				Location ID:	Location Type:	Address:	Field Sample ID:	Sample Date:	Sample Type:		
				C1-BLDG0584	C1-BLDG1407	C1-BLDG1514	C1-BLDG1535				
				Medical Building	Medical Building	Medical Building	Medical Building				
				Building 584,CAREER INFORMATION CENTER, 2367 North Rd	Building 1407,MAKALAPA MEDICAL/DENTAL CLINIC-PEARL HARBOR, 1253 Makalapa Rd	Building 1514,SMART CLINIC/NAVY RELIEF-PEARL HARBOR, 1514 Makalapa Rd	Building 1535,MEDICAL CLINIC/SARP-PEARL HARBOR, B1535 North Road				
				C1-TW-0014693-23342-N	C1-TW-0014693-23342-3-N	C1-TW-0014730-23342-N	C1-TW-0014738-23342-N	C1-TW-0014739-23342-N			
				2024-02-20	2024-02-20	2024-02-20	2024-02-20	2024-02-20			
				N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)			
				ND	ND	ND	ND	ND			
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND			
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND			
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND			
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND			
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND			
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND			
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND			
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND			
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND			
	Bromoform	--	--	0.320	0.350	1.40	1.80	ND			
	Chloroform	--	--	ND	ND	ND	ND	ND			
	Dibromochloromethane	--	--	0.280	0.300	0.270	0.540	ND			
	Total Trihalomethanes	80	MCL	0.600	0.650	1.67	2.34	ND			