

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-10TH0209	D2-10TH0211	D2-11TH0122		D2-11TH0203	D2-11TH0208	D2-12TH0212C	D2-13TH0203
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	209 10th Street	211 10th Street	122 11th Street		203 11th Street	208 11th Street	212C 12th Street	203 13th Street
				Field Sample ID:	D2-TW-0008315-23337-N	D2-TW-0008317-23337-N	D2-TW-0008357-23337-N	D2-TW-0008357-23337-3-N	D2-TW-0008361-23337-N	D2-TW-0008365-23337-N	D2-TW-0008387-23337-N	D2-TW-0008392-23337-N
				Sample Date:	2024-02-22	2024-01-08	2024-01-31	2024-01-31	2024-01-31	2024-01-04	2024-01-08	2024-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	510	380	460	460	1010	480	520	730	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	74.3	ND	ND	ND	67.6	98.9	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	55.0	ND	ND	ND	59.4	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	129	ND	ND	ND	127	98.9	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	1.00	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.80	1.90	1.90	2.50	1.80	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.860	0.570	0.610	0.620	0.840	0.930	0.600	
	Copper	1300	MCL	19.5	11.3	15.0	14.8	3.70	21.4	62.6	15.4	
	Lead	15	MCL	0.140	ND	ND	ND	0.150	0.160	0.240	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	2.70	1.10	1.10	1.20	0.790	0.820	0.890	0.910	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	0.0680	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	0.0150	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-10TH0209	D2-10TH0211	D2-11TH0122		D2-11TH0203	D2-11TH0208	D2-12TH0212C	D2-13TH0203
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
				Address:	209 10th Street	211 10th Street	122 11th Street		203 11th Street	208 11th Street	212C 12th Street	203 13th Street
				Field Sample ID:	D2-TW-0008315-23337-N	D2-TW-0008317-23337-N	D2-TW-0008357-23337-N	D2-TW-0008357-23337-3-N	D2-TW-0008361-23337-N	D2-TW-0008365-23337-N	D2-TW-0008387-23337-N	D2-TW-0008392-23337-N
				Sample Date:	2024-02-22	2024-01-08	2024-01-31	2024-01-31	2024-01-31	2024-01-04	2024-01-08	2024-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-10TH0209	D2-10TH0211	D2-11TH0122		D2-11TH0203	D2-11TH0208	D2-12TH0212C	D2-13TH0203
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	Residence
		Address:	209 10th Street	211 10th Street	122 11th Street		203 11th Street	208 11th Street	212C 12th Street	203 13th Street
		Field Sample ID:	D2-TW-0008315-23337-N	D2-TW-0008317-23337-N	D2-TW-0008357-23337-N	D2-TW-0008357-23337-3-N	D2-TW-0008361-23337-N	D2-TW-0008365-23337-N	D2-TW-0008387-23337-N	D2-TW-0008392-23337-N
		Sample Date:	2024-02-22	2024-01-08	2024-01-31	2024-01-31	2024-01-31	2024-01-04	2024-01-08	2024-01-31
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	0.250	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.250	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-13TH0206		D2-13TH0211A	D2-13TH0211E	D2-13TH0214	D2-14TH0203A		D2-14TH0203C
		Location Type:		Residence		Residence	Residence	Residence	Residence		Residence
		Address:		206 13th Street		211A 13th Street	211E 13th Street	214 13th Street	203A 14th Street		203C 14th Street
		Field Sample ID:		D2-TW-0008395-23337-N	D2-TW-0008395-23337-N-P	D2-TW-0008401-23337-N	D2-TW-0008405-23337-N	D2-TW-0008400-23337-N	D2-TW-0007540-23337-N	D2-TW-0007540-23337-3-N	D2-TW-0007542-23337-N
		Sample Date:		2024-02-08	2024-02-08	2024-01-31	2024-02-22	2024-01-04	2024-01-31	2024-01-31	2024-01-31
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	510	510	530	470	220	620	620	590
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	67.0	ND	ND	70.7	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	65.9	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	67.0	ND	ND	137	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	0.860	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.70	2.00	1.90	1.80	1.90	2.00	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.30	0.650	ND	0.840	0.580	0.620	0.590
	Copper	1300	MCL	13.9	12.7	19.8	29.9	37.4	16.5	17.2	32.1
	Lead	15	MCL	ND	ND	0.160	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.70	0.960	0.710	2.10	0.590	0.800	0.940	0.900
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-13TH0206		D2-13TH0211A	D2-13TH0211E	D2-13TH0214	D2-14TH0203A		D2-14TH0203C
				Location Type:	Residence		Residence	Residence	Residence	Residence		Residence
				Address:	206 13th Street		211A 13th Street	211E 13th Street	214 13th Street	203A 14th Street		203C 14th Street
				Field Sample ID:	D2-TW-0008395-23337-N	D2-TW-0008395-23337-N-P	D2-TW-0008401-23337-N	D2-TW-0008405-23337-N	D2-TW-0008400-23337-N	D2-TW-0007540-23337-N	D2-TW-0007540-23337-3-N	D2-TW-0007542-23337-N
				Sample Date:	2024-02-08	2024-02-08	2024-01-31	2024-02-22	2024-01-04	2024-01-31	2024-01-31	2024-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	0.430	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	0.750	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-13TH0206		D2-13TH0211A	D2-13TH0211E	D2-13TH0214	D2-14TH0203A		D2-14TH0203C
		Location Type:	Residence		Residence	Residence	Residence	Residence		Residence
		Address:	206 13th Street		211A 13th Street	211E 13th Street	214 13th Street	203A 14th Street		203C 14th Street
		Field Sample ID:	D2-TW-0008395-23337-N	D2-TW-0008395-23337-N-P	D2-TW-0008401-23337-N	D2-TW-0008405-23337-N	D2-TW-0008400-23337-N	D2-TW-0007540-23337-N	D2-TW-0007540-23337-3-N	D2-TW-0007542-23337-N
		Sample Date:	2024-02-08	2024-02-08	2024-01-31	2024-02-22	2024-01-04	2024-01-31	2024-01-31	2024-01-31
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	1.18	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	0.320	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	0.320	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-14TH0203E	D2-14TH0203G		D2-15TH0201	D2-15TH0203C	D2-15TH0203D	D2-15TH0211	D2-15TH0212D
		Location Type:		Residence	Residence		Residence	Residence	Residence	Residence	Residence
		Address:		203E 14th Street	203G 14th Street		201 15th Street	203C 15th Street	203D 15th Street	211 15th Street	212D 15th Street
		Field Sample ID:		D2-TW-0007544-23337-N	D2-TW-0007546-23337-N	D2-TW-0007546-23337-N-P	D2-TW-0007101-23337-N	D2-TW-0007486-23337-N	D2-TW-0007487-23337-N	D2-TW-0007482-23337-N	D2-TW-0007492-23337-N
		Sample Date:		2024-02-23	2024-01-31	2024-01-31	2024-01-08	2024-01-04	2024-01-31	2024-01-31	2024-01-04
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	560	600	600	750	490	500	490	610
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	69.0	59.9	56.0	ND	ND	62.5
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	69.0	59.9	56.0	ND	ND	62.5
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.80	1.80	1.80	2.00	1.90	5.30	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.590	1.30	0.820	0.880	0.620	0.590	0.940
	Copper	1300	MCL	6.50	20.3	19.7	4.00	27.3	25.0	5.20	18.2
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	0.0270	ND	ND	ND
	Selenium	50	MCL	0.640	1.20	ND	0.570	0.700	1.10	0.630	1.80
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	0.0150	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-14TH0203E	D2-14TH0203G		D2-15TH0201	D2-15TH0203C	D2-15TH0203D	D2-15TH0211	D2-15TH0212D
				Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence
				Address:	203E 14th Street	203G 14th Street		201 15th Street	203C 15th Street	203D 15th Street	211 15th Street	212D 15th Street
				Field Sample ID:	D2-TW-0007544-23337-N	D2-TW-0007546-23337-N	D2-TW-0007546-23337-N-P	D2-TW-0007101-23337-N	D2-TW-0007486-23337-N	D2-TW-0007487-23337-N	D2-TW-0007482-23337-N	D2-TW-0007492-23337-N
				Sample Date:	2024-02-23	2024-01-31	2024-01-31	2024-01-08	2024-01-04	2024-01-31	2024-01-31	2024-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-14TH0203E	D2-14TH0203G		D2-15TH0201	D2-15TH0203C	D2-15TH0203D	D2-15TH0211	D2-15TH0212D
		Location Type:	Residence	Residence		Residence	Residence	Residence	Residence	Residence
		Address:	203E 14th Street	203G 14th Street		201 15th Street	203C 15th Street	203D 15th Street	211 15th Street	212D 15th Street
		Field Sample ID:	D2-TW-0007544-23337-N	D2-TW-0007546-23337-N	D2-TW-0007546-23337-N-P	D2-TW-0007101-23337-N	D2-TW-0007486-23337-N	D2-TW-0007487-23337-N	D2-TW-0007482-23337-N	D2-TW-0007492-23337-N
		Sample Date:	2024-02-23	2024-01-31	2024-01-31	2024-01-08	2024-01-04	2024-01-31	2024-01-31	2024-01-04
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-16TH0203C		D2-16TH0207	D2-16TH0212E	D2-16TH0214		D2-17TH0203E	D2-18TH0120
				Location Type:	Residence		Residence	Residence	Residence		Residence	Residence
				Address:	203C 16th Street		207 16th Street	212E 16th Street	214 16th Street		203 17th Street	120 18th Street
				Field Sample ID:	D2-TW-0007826-23337-N	D2-TW-0007826-23337-N-P	D2-TW-0007503-23337-N	D2-TW-0008171-23337-N	D2-TW-0007823-23337-N	D2-TW-0007823-23337-N-P	D2-TW-0008187-23337-N	D2-TW-0007055-23337-N
				Sample Date:	2024-01-31	2024-01-31	2024-01-31	2024-01-31	2024-02-01	2024-02-01	2024-01-31	2024-02-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	540	540	520	600	420	420	360	670	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	0.530	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.80	1.80	2.00	1.90	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.610	1.20	0.610	0.590	0.530	0.990	0.580	ND	
	Copper	1300	MCL	21.1	20.0	8.10	18.3	3.70	3.90	12.6	54.0	
	Lead	15	MCL	ND	ND	ND	0.130	ND	ND	0.130	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.10	ND	0.880	0.950	1.10	ND	0.880	0.620	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.0600	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-16TH0203C		D2-16TH0207	D2-16TH0212E	D2-16TH0214		D2-17TH0203E	D2-18TH0120
				Location Type:	Residence		Residence	Residence	Residence		Residence	Residence
				Address:	203C 16th Street		207 16th Street	212E 16th Street	214 16th Street		203 17th Street	120 18th Street
				Field Sample ID:	D2-TW-0007826-23337-N	D2-TW-0007826-23337-N-P	D2-TW-0007503-23337-N	D2-TW-0008171-23337-N	D2-TW-0007823-23337-N	D2-TW-0007823-23337-N-P	D2-TW-0008187-23337-N	D2-TW-0007055-23337-N
				Sample Date:	2024-01-31	2024-01-31	2024-01-31	2024-01-31	2024-02-01	2024-02-01	2024-01-31	2024-02-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-16TH0203C		D2-16TH0207	D2-16TH0212E	D2-16TH0214		D2-17TH0203E	D2-18TH0120
				Location Type:	Residence		Residence	Residence	Residence		Residence	Residence
				Address:	203C 16th Street		207 16th Street	212E 16th Street	214 16th Street		203 17th Street	120 18th Street
				Field Sample ID:	D2-TW-0007826-23337-N	D2-TW-0007826-23337-N-P	D2-TW-0007503-23337-N	D2-TW-0008171-23337-N	D2-TW-0007823-23337-N	D2-TW-0007823-23337-N-P	D2-TW-0008187-23337-N	D2-TW-0007055-23337-N
				Sample Date:	2024-01-31	2024-01-31	2024-01-31	2024-01-31	2024-02-01	2024-02-01	2024-01-31	2024-02-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte											
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.260	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.260	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-18TH0131	D2-18TH0132	D2-18TH0134	D2-18TH0135	D2-18TH0136	D2-18TH0140	D2-18TH0158	D2-18TH0160
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	131 18th Street	132 18th Street	134 18th Street	135 18th Street	136 18th Street	140 18th Street	158 18th Street	160 18th Street
				Field Sample ID:	D2-TW-0008280-23337-N	D2-TW-0008281-23337-N	D2-TW-0008283-23337-N	D2-TW-0008284-23337-N	D2-TW-0008285-23337-N	D2-TW-0007123-23337-N	D2-TW-0007132-23337-N	D2-TW-0007133-23337-N
				Sample Date:	2024-01-04	2024-01-04	2024-02-22	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	240	370	500	120	410	360	520	370	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	75.5	ND	ND	ND	ND	ND	ND	55.0
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	75.2	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	151	ND	ND	ND	ND	ND	ND	55.0
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.660	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.80	1.90	1.90	1.30	1.90	1.80	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.870	0.900	ND	ND	0.510	0.980	ND		0.810
	Copper	1300	MCL	69.2	37.8	44.5	29.3	45.5	7.20	56.6		66.0
	Lead	15	MCL	0.130	ND	ND	ND	ND	1.00	0.170		0.210
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.760	0.580	1.20	1.30	1.10	1.50	0.920		0.790
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	0.0180	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-18TH0131	D2-18TH0132	D2-18TH0134	D2-18TH0135	D2-18TH0136	D2-18TH0140	D2-18TH0158	D2-18TH0160
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	131 18th Street	132 18th Street	134 18th Street	135 18th Street	136 18th Street	140 18th Street	158 18th Street	160 18th Street
		Field Sample ID:	D2-TW-0008280-23337-N	D2-TW-0008281-23337-N	D2-TW-0008283-23337-N	D2-TW-0008284-23337-N	D2-TW-0008285-23337-N	D2-TW-0007123-23337-N	D2-TW-0007132-23337-N	D2-TW-0007133-23337-N
		Sample Date:	2024-01-04	2024-01-04	2024-02-22	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-18TH0131	D2-18TH0132	D2-18TH0134	D2-18TH0135	D2-18TH0136	D2-18TH0140	D2-18TH0158	D2-18TH0160
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	131 18th Street	132 18th Street	134 18th Street	135 18th Street	136 18th Street	140 18th Street	158 18th Street	160 18th Street
		Field Sample ID:	D2-TW-0008280-23337-N	D2-TW-0008281-23337-N	D2-TW-0008283-23337-N	D2-TW-0008284-23337-N	D2-TW-0008285-23337-N	D2-TW-0007123-23337-N	D2-TW-0007132-23337-N	D2-TW-0007133-23337-N
		Sample Date:	2024-01-04	2024-01-04	2024-02-22	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-18TH0162		D2-19TH0012		D2-19TH0014	D2-19TH0016	D2-19TH0020		D2-19TH0103
				Location Type:	Residence		Residence		Residence	Residence	Residence		Residence
				Address:	162 18th Street		12 19th Street		14 19th Street	16 19th Street	20 19th Street		103 19th Street
				Field Sample ID:	D2-TW-0007164-23337-N	D2-TW-0007243-23337-N	D2-TW-0007243-23337-N-P	D2-TW-0007245-23337-N	D2-TW-0007246-23337-N	D2-TW-0007248-23337-N	D2-TW-0007248-23337-N-P	D2-TW-0007253-23337-N	
				Sample Date:	2024-03-12	2024-01-17	2024-01-17	2024-01-05	2024-02-01	2024-02-22	2024-02-22	2024-02-01	
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Field Test (ppb)	Free Chlorine	4000	MCL	580	500	500	400	630	600	600	510		
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	72.3	55.9	ND	ND	59.8		
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	58.5	71.5	ND	ND	ND		
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	131	127	ND	ND	59.8		
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Arsenic	10	MCL	ND	0.630	ND	ND	ND	0.710	ND	ND		
	Barium	2000	MCL	1.90	1.90	2.10	1.90	1.90	1.90	2.00	1.80		
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Chromium	100	MCL	ND	0.530	1.00	1.10	ND	ND	1.50	ND		
	Copper	1300	MCL	39.1	29.1	30.2	35.7	38.6	34.1	35.5	42.8		
	Lead	15	MCL	ND	ND	ND	0.130	ND	ND	ND	ND		
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Selenium	50	MCL	1.30	0.520	ND	1.50	0.890	1.10	1.10	0.850		
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND		
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND		
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND		
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND		
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND		

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-18TH0162		D2-19TH0012		D2-19TH0014	D2-19TH0016	D2-19TH0020		D2-19TH0103
				Location Type:	Residence		Residence		Residence	Residence	Residence		Residence
				Address:	162 18th Street		12 19th Street		14 19th Street	16 19th Street	20 19th Street		103 19th Street
				Field Sample ID:	D2-TW-0007164-23337-N		D2-TW-0007243-23337-N	D2-TW-0007243-23337-N-P	D2-TW-0007245-23337-N	D2-TW-0007246-23337-N	D2-TW-0007248-23337-N	D2-TW-0007248-23337-N-P	D2-TW-0007253-23337-N
				Sample Date:	2024-03-12		2024-01-17	2024-01-17	2024-01-05	2024-02-01	2024-02-22	2024-02-22	2024-02-01
				Sample Type:	N (Normal)		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-18TH0162	D2-19TH0012		D2-19TH0014	D2-19TH0016	D2-19TH0020		D2-19TH0103
		Location Type:	Residence	Residence		Residence	Residence	Residence		Residence
		Address:	162 18th Street	12 19th Street		14 19th Street	16 19th Street	20 19th Street		103 19th Street
		Field Sample ID:	D2-TW-0007164-23337-N	D2-TW-0007243-23337-N	D2-TW-0007243-23337-N-P	D2-TW-0007245-23337-N	D2-TW-0007246-23337-N	D2-TW-0007248-23337-N	D2-TW-0007248-23337-N-P	D2-TW-0007253-23337-N
		Sample Date:	2024-03-12	2024-01-17	2024-01-17	2024-01-05	2024-02-01	2024-02-22	2024-02-22	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-19TH0103	D2-19TH0104	D2-19TH0105	D2-19TH0126	D2-19TH0130	D2-19TH0131	D2-19TH0139	D2-19TH0150
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		103 19th Street	104 19th Street	105 19th Street	126 19th Street	130 19th Street	131 19th Street	139 19th Street	150 19th Street
		Field Sample ID:		D2-TW-0007253-23337-3-N	D2-TW-0007314-23337-N	D2-TW-0008289-23337-N	D2-TW-0008306-23337-N	D2-TW-0008240-23337-N	D2-TW-0008241-23337-N	D2-TW-0007114-23337-N	D2-TW-0007120-23337-N
		Sample Date:		2024-02-01	2024-01-05	2024-02-22	2024-02-01	2024-02-22	2024-01-08	2024-02-01	2024-01-05
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	510	400	550	510	160	410	180	410
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	68.9	ND	ND	ND	ND	ND	52.2
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	68.9	ND	ND	ND	ND	ND	52.2
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.720	ND	0.810	ND	ND	ND
	Barium	2000	MCL	1.80	1.90	1.90	1.90	1.90	1.90	2.00	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.00	ND	0.560	ND	0.800	0.570	1.10
	Copper	1300	MCL	38.6	20.3	44.0	25.0	60.2	69.4	125	82.5
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	0.380	0.130
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.20	1.70	1.30	1.20	2.10	0.540	0.870	1.10
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0560
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH0103	D2-19TH0104	D2-19TH0105	D2-19TH0126	D2-19TH0130	D2-19TH0131	D2-19TH0139	D2-19TH0150
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	103 19th Street	104 19th Street	105 19th Street	126 19th Street	130 19th Street	131 19th Street	139 19th Street	150 19th Street
		Field Sample ID:	D2-TW-0007253-23337-3-N	D2-TW-0007314-23337-N	D2-TW-0008289-23337-N	D2-TW-0008306-23337-N	D2-TW-0008240-23337-N	D2-TW-0008241-23337-N	D2-TW-0007114-23337-N	D2-TW-0007120-23337-N
		Sample Date:	2024-02-01	2024-01-05	2024-02-22	2024-02-01	2024-02-22	2024-01-08	2024-02-01	2024-01-05
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH0103	D2-19TH0104	D2-19TH0105	D2-19TH0126	D2-19TH0130	D2-19TH0131	D2-19TH0139	D2-19TH0150
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	103 19th Street	104 19th Street	105 19th Street	126 19th Street	130 19th Street	131 19th Street	139 19th Street	150 19th Street
		Field Sample ID:	D2-TW-0007253-23337-3-N	D2-TW-0007314-23337-N	D2-TW-0008289-23337-N	D2-TW-0008306-23337-N	D2-TW-0008240-23337-N	D2-TW-0008241-23337-N	D2-TW-0007114-23337-N	D2-TW-0007120-23337-N
		Sample Date:	2024-02-01	2024-01-05	2024-02-22	2024-02-01	2024-02-22	2024-01-08	2024-02-01	2024-01-05
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.250	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.250	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-19TH0162	D2-19TH0178	D2-19TH0194	D2-19TH0202	D2-19TH0206	D2-19TH0207	D2-19TH0214	D2-19TH0220
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	162 19th Street	178 19th Street	194 19th Street	202 19th Street	206 19th Street	207 19th Street	214 19th Street	220 19th Street
				Field Sample ID:	D2-TW-0007318-23337-N	D2-TW-0007446-23337-N	D2-TW-0007829-23337-N	D2-TW-0007833-23337-N	D2-TW-0007837-23337-N	D2-TW-0007838-23337-N	D2-TW-0007844-23337-N	D2-TW-0007847-23337-N
				Sample Date:	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04	2024-02-01	2024-02-01	2024-02-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	190	390	430	300	290	980	390	260	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	52.5	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	52.5	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	2.20	2.10	2.10	2.00	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.540	0.510	0.620	0.520	0.950	ND	ND	0.580	
	Copper	1300	MCL	66.4	42.4	54.4	83.6	51.5	47.5	40.3	165	
	Lead	15	MCL	ND	ND	ND	0.230	1.50	0.510	0.280	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.00	1.20	1.10	1.50	0.630	0.870	0.810	1.30	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	0.0820	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH0162	D2-19TH0178	D2-19TH0194	D2-19TH0202	D2-19TH0206	D2-19TH0207	D2-19TH0214	D2-19TH0220
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	162 19th Street	178 19th Street	194 19th Street	202 19th Street	206 19th Street	207 19th Street	214 19th Street	220 19th Street
		Field Sample ID:	D2-TW-0007318-23337-N	D2-TW-0007446-23337-N	D2-TW-0007829-23337-N	D2-TW-0007833-23337-N	D2-TW-0007837-23337-N	D2-TW-0007838-23337-N	D2-TW-0007844-23337-N	D2-TW-0007847-23337-N
		Sample Date:	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04	2024-02-01	2024-02-01	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH0162	D2-19TH0178	D2-19TH0194	D2-19TH0202	D2-19TH0206	D2-19TH0207	D2-19TH0214	D2-19TH0220
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	162 19th Street	178 19th Street	194 19th Street	202 19th Street	206 19th Street	207 19th Street	214 19th Street	220 19th Street
		Field Sample ID:	D2-TW-0007318-23337-N	D2-TW-0007446-23337-N	D2-TW-0007829-23337-N	D2-TW-0007833-23337-N	D2-TW-0007837-23337-N	D2-TW-0007838-23337-N	D2-TW-0007844-23337-N	D2-TW-0007847-23337-N
		Sample Date:	2024-02-01	2024-02-01	2024-01-31	2024-02-01	2024-01-04	2024-02-01	2024-02-01	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.250	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.250	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-19TH1907	D2-20TH0131	D2-20TH0132	D2-20TH0141		D2-20TH0143	D2-20TH0151	D2-20TH0152
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:		1907 19th Way	131 20th Street	132 20th Street	141 20th Street		143 20th Street	151 20th Street	152 20th Street
		Field Sample ID:		D2-TW-0008072-23337-N	D2-TW-0007953-23337-N	D2-TW-0007954-23337-N	D2-TW-0007963-23337-N	D2-TW-0007963-23337-3-N	D2-TW-0007965-23337-N	D2-TW-0007973-23337-N	D2-TW-0007974-23337-N
		Sample Date:		2024-02-01	2024-02-12	2024-02-12	2024-02-22	2024-02-22	2024-02-01	2024-02-01	2024-02-01
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	230	640	460	630	630	330	440	390
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	0.700	0.780	ND	ND	ND
	Barium	2000	MCL	2.20	1.90	1.90	1.90	1.80	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	ND	ND	2.20	0.520	0.580
	Copper	1300	MCL	73.7	81.0	34.4	20.8	20.8	28.1	25.5	47.1
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.00	1.10	0.860	1.60	1.50	ND	1.00	1.30
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-19TH1907	D2-20TH0131	D2-20TH0132	D2-20TH0141		D2-20TH0143	D2-20TH0151	D2-20TH0152
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	1907 19th Way	131 20th Street	132 20th Street	141 20th Street		143 20th Street	151 20th Street	152 20th Street
				Field Sample ID:	D2-TW-0008072-23337-N	D2-TW-0007953-23337-N	D2-TW-0007954-23337-N	D2-TW-0007963-23337-N	D2-TW-0007963-23337-3-N	D2-TW-0007965-23337-N	D2-TW-0007973-23337-N	D2-TW-0007974-23337-N
				Sample Date:	2024-02-01	2024-02-12	2024-02-12	2024-02-22	2024-02-22	2024-02-01	2024-02-01	2024-02-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-19TH1907	D2-20TH0131	D2-20TH0132	D2-20TH0141		D2-20TH0143	D2-20TH0151	D2-20TH0152
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	1907 19th Way	131 20th Street	132 20th Street	141 20th Street		143 20th Street	151 20th Street	152 20th Street
		Field Sample ID:	D2-TW-0008072-23337-N	D2-TW-0007953-23337-N	D2-TW-0007954-23337-N	D2-TW-0007963-23337-N	D2-TW-0007963-23337-3-N	D2-TW-0007965-23337-N	D2-TW-0007973-23337-N	D2-TW-0007974-23337-N
		Sample Date:	2024-02-01	2024-02-12	2024-02-12	2024-02-22	2024-02-22	2024-02-01	2024-02-01	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.480	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.290	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.770	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-20TH0153		D2-20TH0154	D2-20TH0168	D2-20TH0174	D2-20TH0184	D2-21ST0105	D2-21ST0106
		Location Type:		Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:		153 20th Street		154 20th Street	168 20th Street	174 20th Street	184 20th Street	105 21st Street	106 21st Street
		Field Sample ID:		D2-TW-0007975-23337-N	D2-TW-0007975-23337-3-N	D2-TW-0006996-23337-N	D2-TW-0007169-23337-N	D2-TW-0007172-23337-N	D2-TW-0007177-23337-N	D2-TW-0007189-23337-N	D2-TW-0007190-23337-N
		Sample Date:		2024-02-01	2024-02-01	2024-01-08	2024-01-08	2024-02-01	2024-01-08	2024-01-08	2024-02-22
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	90.0	90.0	1000	30.0	470	740	230	240
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	80.7	50.8	ND	ND	83.5	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	71.9	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	80.7	50.8	ND	ND	155	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	0.810
	Barium	2000	MCL	2.00	1.90	1.90	1.90	1.80	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.500	0.610	0.860	0.790	0.570	0.920	0.860	ND
	Copper	1300	MCL	56.1	53.7	21.8	78.8	71.5	27.4	57.5	37.4
	Lead	15	MCL	0.140	0.180	ND	0.320	0.190	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.30	1.50	1.20	0.670	1.30	0.850	1.00	1.70
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	0.0540	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	3.10	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-20TH0153		D2-20TH0154	D2-20TH0168	D2-20TH0174	D2-20TH0184	D2-21ST0105	D2-21ST0106
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	153 20th Street		154 20th Street	168 20th Street	174 20th Street	184 20th Street	105 21st Street	106 21st Street
				Field Sample ID:	D2-TW-0007975-23337-N	D2-TW-0007975-23337-3-N	D2-TW-0006996-23337-N	D2-TW-0007169-23337-N	D2-TW-0007172-23337-N	D2-TW-0007177-23337-N	D2-TW-0007189-23337-N	D2-TW-0007190-23337-N
				Sample Date:	2024-02-01	2024-02-01	2024-01-08	2024-01-08	2024-02-01	2024-01-08	2024-01-08	2024-02-22
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-20TH0153		D2-20TH0154	D2-20TH0168	D2-20TH0174	D2-20TH0184	D2-21ST0105	D2-21ST0106
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	153 20th Street		154 20th Street	168 20th Street	174 20th Street	184 20th Street	105 21st Street	106 21st Street
		Field Sample ID:	D2-TW-0007975-23337-N	D2-TW-0007975-23337-3-N	D2-TW-0006996-23337-N	D2-TW-0007169-23337-N	D2-TW-0007172-23337-N	D2-TW-0007177-23337-N	D2-TW-0007189-23337-N	D2-TW-0007190-23337-N
		Sample Date:	2024-02-01	2024-02-01	2024-01-08	2024-01-08	2024-02-01	2024-01-08	2024-01-08	2024-02-22
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	0.670	ND	ND	0.520
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	0.410
	Total Trihalomethanes	80	MCL	ND	ND	ND	0.670	ND	ND	0.930

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-21ST0109		D2-21ST0118	D2-21ST0121	D2-21ST0130		D2-21ST0131	D2-2ND0117
		Location Type:		Residence		Residence	Residence	Residence		Residence	Residence
		Address:		109 21st Street		118 21st Street	121 21st Street	130 21st Street		131 21st Street	117 2nd Street
		Field Sample ID:		D2-TW-0007193-23337-N	D2-TW-0007193-23337-N-P	D2-TW-0008372-23337-N	D2-TW-0008375-23337-N	D2-TW-0007092-23337-N	D2-TW-0007092-23337-3-N	D2-TW-0007093-23337-N	D2-TW-0008104-23337-N
		Sample Date:		2024-02-22	2024-02-22	2024-01-05	2024-01-08	2024-02-22	2024-02-22	2024-01-05	2024-01-08
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	610	610	300	790	280	280	290	190
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	63.6	63.7	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	63.6	63.7	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.640	0.520	ND	ND	0.800	0.700	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.80	1.90	1.80	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	3.60	1.10	0.820	ND	ND	1.10	0.810
	Copper	1300	MCL	80.2	77.7	64.9	31.3	46.6	46.1	53.2	65.4
	Lead	15	MCL	ND	ND	0.140	ND	0.300	0.370	0.200	0.300
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.60	1.00	1.70	0.580	1.70	1.00	1.40	0.630
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	0.0820	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-21ST0109		D2-21ST0118	D2-21ST0121	D2-21ST0130		D2-21ST0131	D2-2ND0117
				Location Type:	Residence		Residence	Residence	Residence		Residence	Residence
				Address:	109 21st Street		118 21st Street	121 21st Street	130 21st Street		131 21st Street	117 2nd Street
				Field Sample ID:	D2-TW-0007193-23337-N	D2-TW-0007193-23337-N-P	D2-TW-0008372-23337-N	D2-TW-0008375-23337-N	D2-TW-0007092-23337-N	D2-TW-0007092-23337-3-N	D2-TW-0007093-23337-N	D2-TW-0008104-23337-N
				Sample Date:	2024-02-22	2024-02-22	2024-01-05	2024-01-08	2024-02-22	2024-02-22	2024-01-05	2024-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-21ST0109		D2-21ST0118	D2-21ST0121	D2-21ST0130		D2-21ST0131	D2-2ND0117
		Location Type:	Residence		Residence	Residence	Residence		Residence	Residence
		Address:	109 21st Street		118 21st Street	121 21st Street	130 21st Street		131 21st Street	117 2nd Street
		Field Sample ID:	D2-TW-0007193-23337-N	D2-TW-0007193-23337-N-P	D2-TW-0008372-23337-N	D2-TW-0008375-23337-N	D2-TW-0007092-23337-N	D2-TW-0007092-23337-3-N	D2-TW-0007093-23337-N	D2-TW-0008104-23337-N
		Sample Date:	2024-02-22	2024-02-22	2024-01-05	2024-01-08	2024-02-22	2024-02-22	2024-01-05	2024-01-08
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte									
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	0.530	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	1.20	0.360	0.320
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	1.40	0.380	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	3.13	0.740	0.320

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-2ND0118		D2-2ND0123		D2-2ND0124	D2-2ND0126	D2-2ND0135	D2-2ND0137
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
				Address:	118 2nd Street		123 2nd Street		124 2nd Street	126 2nd Street	135 2nd Street	137 2nd Street
				Field Sample ID:	D2-TW-0008105-23337-N	D2-TW-0008105-23337-3-N	D2-TW-0008108-23337-N	D2-TW-0008108-23337-N-P	D2-TW-0007731-23337-N	D2-TW-0006953-23337-N	D2-TW-0006959-23337-N	D2-TW-0006961-23337-N
				Sample Date:	2024-02-22	2024-02-22	2024-02-15	2024-02-15	2024-01-05	2024-02-22	2024-02-22	2024-01-05
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	590	590		20.0	20.0	280	560	500	70.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND		ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND		ND	ND	69.6	ND	ND	65.7
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND		ND	ND	69.6	ND	ND	65.7
Metals (ppb)	Antimony	6	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.550	0.570		0.730	ND	ND	0.660	0.610	ND
	Barium	2000	MCL	1.80	1.90		2.00	1.90	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND		ND	1.90	1.00	ND	ND	1.00
	Copper	1300	MCL	59.5	61.6		35.2	34.2	32.4	45.8	73.8	54.7
	Lead	15	MCL	0.210	0.210		0.180	ND	0.200	0.190	0.370	0.190
	Mercury	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.980	1.30		ND	ND	1.90	1.10	1.10	1.60
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND		ND	ND	1.90	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-2ND0118		D2-2ND0123		D2-2ND0124	D2-2ND0126	D2-2ND0135	D2-2ND0137
		Location Type:		Residence		Residence		Residence	Residence	Residence	Residence
		Address:		118 2nd Street		123 2nd Street		124 2nd Street	126 2nd Street	135 2nd Street	137 2nd Street
		Field Sample ID:		D2-TW-0008105-23337-N	D2-TW-0008105-23337-3-N	D2-TW-0008108-23337-N	D2-TW-0008108-23337-N-P	D2-TW-0007731-23337-N	D2-TW-0006953-23337-N	D2-TW-0006959-23337-N	D2-TW-0006961-23337-N
		Sample Date:		2024-02-22	2024-02-22	2024-02-15	2024-02-15	2024-01-05	2024-02-22	2024-02-22	2024-01-05
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-2ND0118		D2-2ND0123		D2-2ND0124	D2-2ND0126	D2-2ND0135	D2-2ND0137
		Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
		Address:	118 2nd Street		123 2nd Street		124 2nd Street	126 2nd Street	135 2nd Street	137 2nd Street
		Field Sample ID:	D2-TW-0008105-23337-N	D2-TW-0008105-23337-3-N	D2-TW-0008108-23337-N	D2-TW-0008108-23337-N-P	D2-TW-0007731-23337-N	D2-TW-0006953-23337-N	D2-TW-0006959-23337-N	D2-TW-0006961-23337-N
		Sample Date:	2024-02-22	2024-02-22	2024-02-15	2024-02-15	2024-01-05	2024-02-22	2024-02-22	2024-01-05
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	0.270	ND	0.290
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	0.270	ND	0.290

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-2ND0137	D2-2ND0201B	D2-2ND0204A	D2-2ND0206	D2-3RD0136		D2-3RD0201A	D2-3RD0202A
		Location Type:		Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:		137 2nd Street	201B 2nd Street	204A 2nd Street	206 2nd Street	136 3rd Street		201A 3rd Street	202A 3rd Street
		Field Sample ID:		D2-TW-0006961-23337-3-N	D2-TW-0007556-23337-N	D2-TW-0007561-23337-N	D2-TW-0006963-23337-N	D2-TW-0007006-23337-N	D2-TW-0007006-23337-N-P	D2-TW-0007016-23337-N	D2-TW-0007018-23337-N
		Sample Date:		2024-01-05	2024-01-04	2024-02-01	2024-02-22	2024-02-01	2024-02-01	2024-02-01	2024-01-08
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	70.0	290	500	580	420	420	440	800
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	81.1	ND	ND	ND	ND	ND	ND	50.6
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	57.1	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	138	ND	ND	ND	ND	ND	ND	50.6
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	1.30	ND	0.560	ND	ND
	Barium	2000	MCL	1.90	1.80	2.00	1.90	1.80	2.10	1.90	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.10	0.980	0.540	ND	ND	0.940	ND	0.780
	Copper	1300	MCL	54.5	16.1	15.5	6.90	27.3	28.9	12.5	3.10
	Lead	15	MCL	0.180	ND	ND	0.140	0.170	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.40	0.850	1.00	3.80	0.940	ND	1.30	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	0.0580	ND	0.0950	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	0.0170	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-2ND0137	D2-2ND0201B	D2-2ND0204A	D2-2ND0206	D2-3RD0136		D2-3RD0201A	D2-3RD0202A
		Location Type:		Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:		137 2nd Street	201B 2nd Street	204A 2nd Street	206 2nd Street	136 3rd Street		201A 3rd Street	202A 3rd Street
		Field Sample ID:		D2-TW-0006961-23337-3-N	D2-TW-0007556-23337-N	D2-TW-0007561-23337-N	D2-TW-0006963-23337-N	D2-TW-0007006-23337-N	D2-TW-0007006-23337-N-P	D2-TW-0007016-23337-N	D2-TW-0007018-23337-N
		Sample Date:		2024-01-05	2024-01-04	2024-02-01	2024-02-22	2024-02-01	2024-02-01	2024-02-01	2024-01-08
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-2ND0137	D2-2ND0201B	D2-2ND0204A	D2-2ND0206	D2-3RD0136		D2-3RD0201A	D2-3RD0202A
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	137 2nd Street	201B 2nd Street	204A 2nd Street	206 2nd Street	136 3rd Street		201A 3rd Street	202A 3rd Street
		Field Sample ID:	D2-TW-0006961-23337-3-N	D2-TW-0007556-23337-N	D2-TW-0007561-23337-N	D2-TW-0006963-23337-N	D2-TW-0007006-23337-N	D2-TW-0007006-23337-N-P	D2-TW-0007016-23337-N	D2-TW-0007018-23337-N
		Sample Date:	2024-01-05	2024-01-04	2024-02-01	2024-02-22	2024-02-01	2024-02-01	2024-02-01	2024-01-08
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.280	ND	0.440	ND	ND	ND	0.260
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.300	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.280	ND	0.740	ND	ND	ND	0.260

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-3RD0203B	D2-3RD0204	D2-3RD0205A	D2-3RD0214		D2-4TH0102	D2-4TH0104	
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	
		Address:		203B 3rd Street	204 3rd Street	205A 3rd Street	214 3rd Street		102 4th Street	104 4th Street	
		Field Sample ID:		D2-TW-0007021-23337-N	D2-TW-0007009-23337-N	D2-TW-0007022-23337-N	D2-TW-0007015-23337-N	D2-TW-0007015-23337-3-N	D2-TW-0007024-23337-N	D2-TW-0007025-23337-N	D2-TW-0007025-23337-N-P
		Sample Date:		2024-02-12	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-02-23	2024-02-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	700	600	470	470	470	290	490	490
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	71.0	54.3	68.0	54.3	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	84.9	ND	51.9	69.0	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	156	54.3	120	123	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	0.140	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	2.00	1.90	1.90	1.80	1.80	2.00
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.860	0.870	0.790	0.940	0.810	ND	1.30
	Copper	1300	MCL	9.20	12.0	9.40	3.40	2.70	53.1	38.4	36.2
	Lead	15	MCL	ND	0.240	ND	ND	ND	0.430	0.630	0.790
	Mercury	2	MCL	ND	ND	ND	0.0280	0.0280	0.0280	ND	ND
	Selenium	50	MCL	0.920	0.700	0.730	0.610	0.750	0.710	0.780	0.870
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	0.0150	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-3RD0203B	D2-3RD0204	D2-3RD0205A	D2-3RD0214		D2-4TH0102	D2-4TH0104	
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	
		Address:		203B 3rd Street	204 3rd Street	205A 3rd Street	214 3rd Street		102 4th Street	104 4th Street	
		Field Sample ID:		D2-TW-0007021-23337-N	D2-TW-0007009-23337-N	D2-TW-0007022-23337-N	D2-TW-0007015-23337-N	D2-TW-0007015-23337-3-N	D2-TW-0007024-23337-N	D2-TW-0007025-23337-N	D2-TW-0007025-23337-N-P
		Sample Date:		2024-02-12	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-02-23	2024-02-23
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	0.540
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-3RD0203B	D2-3RD0204	D2-3RD0205A	D2-3RD0214		D2-4TH0102	D2-4TH0104	
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	
		Address:	203B 3rd Street	204 3rd Street	205A 3rd Street	214 3rd Street		102 4th Street	104 4th Street	
		Field Sample ID:	D2-TW-0007021-23337-N	D2-TW-0007009-23337-N	D2-TW-0007022-23337-N	D2-TW-0007015-23337-N	D2-TW-0007015-23337-3-N	D2-TW-0007024-23337-N	D2-TW-0007025-23337-N	D2-TW-0007025-23337-N-P
		Sample Date:	2024-02-12	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-01-04	2024-02-23	2024-02-23
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	0.540
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.250	0.300	0.470	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.380	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	0.250	0.300	0.850	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-4TH0112	D2-4TH0117	D2-4TH0122	D2-4TH0123	D2-4TH0124	D2-4TH0201A	D2-4TH0202B	D2-4TH0209
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		112 4th Street	117 4th Street	122 4th Street	123 4th Street	124 4th Street	201A 4th Street	202B 4th Street	209 4th Street
		Field Sample ID:		D2-TW-0008213-23337-N	D2-TW-0008218-23337-N	D2-TW-0008014-23337-N	D2-TW-0008015-23337-N	D2-TW-0008016-23337-N	D2-TW-0008029-23337-N	D2-TW-0008032-23337-N	D2-TW-0008025-23337-N
		Sample Date:		2024-02-12	2024-01-04	2024-02-14	2024-01-31	2024-02-12	2024-02-12	2024-02-22	2024-01-04
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	800	490	510	310	670	850	700	310
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	72.0	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	63.5	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	136	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.910	ND	ND	ND	0.800	ND
	Barium	2000	MCL	2.00	1.90	1.90	2.10	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.840	ND	0.680	ND	ND	ND	0.960
	Copper	1300	MCL	28.8	35.3	53.0	82.0	48.2	2.50	3.90	4.30
	Lead	15	MCL	0.140	0.210	0.150	1.10	0.260	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0330
	Selenium	50	MCL	1.10	0.720	0.830	0.720	1.20	0.470	1.90	1.70
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	0.110	ND	ND	ND	ND	0.0560	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	0.0180	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-4TH0112	D2-4TH0117	D2-4TH0122	D2-4TH0123	D2-4TH0124	D2-4TH0201A	D2-4TH0202B	D2-4TH0209
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	112 4th Street	117 4th Street	122 4th Street	123 4th Street	124 4th Street	201A 4th Street	202B 4th Street	209 4th Street
				Field Sample ID:	D2-TW-0008213-23337-N	D2-TW-0008218-23337-N	D2-TW-0008014-23337-N	D2-TW-0008015-23337-N	D2-TW-0008016-23337-N	D2-TW-0008029-23337-N	D2-TW-0008032-23337-N	D2-TW-0008025-23337-N
				Sample Date:	2024-02-12	2024-01-04	2024-02-14	2024-01-31	2024-02-12	2024-02-12	2024-02-22	2024-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-4TH0112	D2-4TH0117	D2-4TH0122	D2-4TH0123	D2-4TH0124	D2-4TH0201A	D2-4TH0202B	D2-4TH0209
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	112 4th Street	117 4th Street	122 4th Street	123 4th Street	124 4th Street	201A 4th Street	202B 4th Street	209 4th Street
				Field Sample ID:	D2-TW-0008213-23337-N	D2-TW-0008218-23337-N	D2-TW-0008014-23337-N	D2-TW-0008015-23337-N	D2-TW-0008016-23337-N	D2-TW-0008029-23337-N	D2-TW-0008032-23337-N	D2-TW-0008025-23337-N
				Sample Date:	2024-02-12	2024-01-04	2024-02-14	2024-01-31	2024-02-12	2024-02-12	2024-02-22	2024-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
				DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	0.370
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.280	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.280	ND	ND	0.370

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-4TH0209	D2-5TH0111	D2-5TH0117	D2-5TH0121	D2-5TH0126	D2-6TH0123	D2-6TH0208	D2-8TH0201
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		209 4th Street	111 5th Street	117 5th Street	121 5th Street	126 5th Street	123 6th Street	208 6th Street	201 8th Street
		Field Sample ID:		D2-TW-0008025-23337-3-N	D2-TW-0007061-23337-N	D2-TW-0007067-23337-N	D2-TW-0008110-23337-N	D2-TW-0007590-23337-N	D2-TW-0007604-23337-N	D2-TW-0007614-23337-N	D2-TW-0007459-23337-N
		Sample Date:		2024-01-04	2024-01-08	2024-02-12	2024-01-04	2024-02-01	2024-02-12	2024-01-05	2024-02-22
		Sample Type:		FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	310	500	780	450	850	780	80.0	630
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	53.7	ND	ND	ND	67.5	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	53.7	ND	ND	ND	67.5	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	0.600
	Barium	2000	MCL	1.90	1.90	1.90	1.80	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.910	0.810	ND	0.880	0.630	ND	1.10	ND
	Copper	1300	MCL	4.40	59.4	38.3	39.8	24.9	5.90	34.1	52.3
	Lead	15	MCL	ND	0.250	0.160	0.200	0.180	ND	0.180	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	2.10	0.530	1.30	1.70	1.10	1.30	2.20	0.880
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-4TH0209	D2-5TH0111	D2-5TH0117	D2-5TH0121	D2-5TH0126	D2-6TH0123	D2-6TH0208	D2-8TH0201
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	209 4th Street	111 5th Street	117 5th Street	121 5th Street	126 5th Street	123 6th Street	208 6th Street	201 8th Street
				Field Sample ID:	D2-TW-0008025-23337-3-N	D2-TW-0007061-23337-N	D2-TW-0007067-23337-N	D2-TW-0008110-23337-N	D2-TW-0007590-23337-N	D2-TW-0007604-23337-N	D2-TW-0007614-23337-N	D2-TW-0007459-23337-N
				Sample Date:	2024-01-04	2024-01-08	2024-02-12	2024-01-04	2024-02-01	2024-02-12	2024-01-05	2024-02-22
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-4TH0209	D2-5TH0111	D2-5TH0117	D2-5TH0121	D2-5TH0126	D2-6TH0123	D2-6TH0208	D2-8TH0201
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	209 4th Street	111 5th Street	117 5th Street	121 5th Street	126 5th Street	123 6th Street	208 6th Street	201 8th Street
		Field Sample ID:	D2-TW-0008025-23337-3-N	D2-TW-0007061-23337-N	D2-TW-0007067-23337-N	D2-TW-0008110-23337-N	D2-TW-0007590-23337-N	D2-TW-0007604-23337-N	D2-TW-0007614-23337-N	D2-TW-0007459-23337-N
		Sample Date:	2024-01-04	2024-01-08	2024-02-12	2024-01-04	2024-02-01	2024-02-12	2024-01-05	2024-02-22
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.330	0.260	ND	ND	ND	0.270	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.330	0.260	ND	ND	ND	0.270	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-8TH0201		D2-9TH0306		D2-AIMO0134		D2-APOL0346		D2-APOL0511		D2-APOL0533	
		Location Type:		Residence		Residence		Residence		Residence		Residence		Residence	
		Address:		201 8th Street		306 9th Street		134 Aimokulani Alley		346 Apollo Avenue		511 Apollo Avenue		533 Apollo Avenue	
		Field Sample ID:		D2-TW-0007459-23337-3-N		D2-TW-0007473-23337-N		D2-TW-0007473-23337-N-P		D2-TW-0008093-23337-N		D2-TW-0008328-23337-N		D2-TW-0008328-23337-3-N	
		Sample Date:		2024-02-22		2024-01-08		2024-01-08		2024-01-05		2024-01-31		2024-01-31	
		Sample Type:		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level												
Field Test (ppb)	Free Chlorine	4000	MCL	630	520	520		280		170	170	360		570	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND		ND		ND	ND	ND		ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	97.2	ND		68.8		ND	ND	84.1		ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND		ND		ND	ND	ND		ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND		ND		ND	ND	ND		ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	97.2	ND		68.8		ND	ND	84.1		ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	Arsenic	10	MCL	0.720	ND	ND		ND		ND	ND	ND		0.660	
	Barium	2000	MCL	1.90	1.90	2.20		1.90		1.90	1.90	1.80		1.90	
	Beryllium	4	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	Cadmium	5	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	Chromium	100	MCL	ND	0.820	1.40		1.00		0.650	0.600	0.990		ND	
	Copper	1300	MCL	52.1	12.7	13.6		6.90		4.40	4.40	18.4		10.1	
	Lead	15	MCL	ND	0.150	ND		0.130		0.250	ND	0.300		ND	
	Mercury	2	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	Selenium	50	MCL	1.70	1.00	ND		1.80		0.990	1.00	1.40		1.00	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND		ND		ND	ND	ND		ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND		ND		ND	ND	ND		ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND		0.0160		ND	ND	ND		ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND		ND		ND	ND	ND		ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND		ND		ND	ND	ND		ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND		ND		ND	ND	ND		ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND		ND		ND	ND	ND		ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-8TH0201	D2-9TH0306			D2-AIMO0134	D2-APOL0346		D2-APOL0511	D2-APOL0533
		Location Type:	Residence	Residence			Residence	Residence		Residence	Residence
		Address:	201 8th Street	306 9th Street			134 Aimokulani Alley	346 Apollo Avenue		511 Apollo Avenue	533 Apollo Avenue
		Field Sample ID:	D2-TW-0007459-23337-3-N	D2-TW-0007473-23337-N	D2-TW-0007473-23337-N-P		D2-TW-0008093-23337-N	D2-TW-0008328-23337-N	D2-TW-0008328-23337-3-N	D2-TW-0007582-23337-N	D2-TW-0007195-23337-N
		Sample Date:	2024-02-22	2024-01-08	2024-01-08		2024-01-05	2024-01-31	2024-01-31	2024-01-05	2024-02-22
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)		N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	0.750	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-8TH0201	D2-9TH0306		D2-AIMO0134	D2-APOL0346		D2-APOL0511	D2-APOL0533
		Location Type:	Residence	Residence		Residence	Residence		Residence	Residence
		Address:	201 8th Street	306 9th Street		134 Aimokulani Alley	346 Apollo Avenue		511 Apollo Avenue	533 Apollo Avenue
		Field Sample ID:	D2-TW-0007459-23337-3-N	D2-TW-0007473-23337-N	D2-TW-0007473-23337-N-P	D2-TW-0008093-23337-N	D2-TW-0008328-23337-N	D2-TW-0008328-23337-3-N	D2-TW-0007582-23337-N	D2-TW-0007195-23337-N
		Sample Date:	2024-02-22	2024-01-08	2024-01-08	2024-01-05	2024-01-31	2024-01-31	2024-01-05	2024-02-22
		Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte									
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	0.750	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	0.460	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	0.270	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	0.730	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-APOL0533	D2-APOL0742	D2-APOL0746	D2-APOL0823		D2-APOL0825	D2-BEAR0201	D2-BEAR0202B
		Location Type:		Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:		533 Apollo Avenue	742 Apollo Avenue	746 Apollo Avenue	823 Apollo Avenue		825 Apollo Avenue	201 Beard Avenue	202B Beard Avenue
		Field Sample ID:		D2-TW-0007195-23337-N-P	D2-TW-0007200-23337-N	D2-TW-0007202-23337-N	D2-TW-0007206-23337-N	D2-TW-0007206-23337-3-N	D2-TW-0007208-23337-N	D2-TW-0007070-23337-N	D2-TW-0007236-23337-N
		Sample Date:		2024-02-22	2024-01-05	2024-02-12	2024-02-22	2024-02-22	2024-01-05	2024-01-05	2024-02-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	570	420	1670	820	820	350	110	720
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	54.2	ND	ND	ND	99.6	62.9	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	73.7	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	54.2	ND	ND	ND	173	62.9	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.530	ND	ND	0.850	0.690	ND	ND	0.660
	Barium	2000	MCL	2.00	2.00	1.90	1.90	1.90	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.50	1.00	ND	ND	ND	1.10	1.10	ND
	Copper	1300	MCL	10.7	19.2	9.30	10.9	10.1	8.80	7.20	20.7
	Lead	15	MCL	ND	1.00	0.140	0.190	0.140	0.130	ND	0.290
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.10	1.80	1.00	1.70	1.60	1.50	1.80	1.20
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	0.0840	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-APOL0533	D2-APOL0742	D2-APOL0746	D2-APOL0823		D2-APOL0825	D2-BEAR0201	D2-BEAR0202B
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	533 Apollo Avenue	742 Apollo Avenue	746 Apollo Avenue	823 Apollo Avenue		825 Apollo Avenue	201 Beard Avenue	202B Beard Avenue
		Field Sample ID:	D2-TW-0007195-23337-N-P	D2-TW-0007200-23337-N	D2-TW-0007202-23337-N	D2-TW-0007206-23337-N	D2-TW-0007206-23337-3-N	D2-TW-0007208-23337-N	D2-TW-0007070-23337-N	D2-TW-0007236-23337-N
		Sample Date:	2024-02-22	2024-01-05	2024-02-12	2024-02-22	2024-02-22	2024-01-05	2024-01-05	2024-02-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-APOL0533	D2-APOL0742	D2-APOL0746	D2-APOL0823		D2-APOL0825	D2-BEAR0201	D2-BEAR0202B
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	533 Apollo Avenue	742 Apollo Avenue	746 Apollo Avenue	823 Apollo Avenue		825 Apollo Avenue	201 Beard Avenue	202B Beard Avenue
				Field Sample ID:	D2-TW-0007195-23337-N-P	D2-TW-0007200-23337-N	D2-TW-0007202-23337-N	D2-TW-0007206-23337-N	D2-TW-0007206-23337-3-N	D2-TW-0007208-23337-N	D2-TW-0007070-23337-N	D2-TW-0007236-23337-N
				Sample Date:	2024-02-22	2024-01-05	2024-02-12	2024-02-22	2024-02-22	2024-01-05	2024-01-05	2024-02-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level									
Method Group	Analyte											
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.440	ND	ND	0.340	ND	0.360	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.290	ND	ND	0.420	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	0.730	ND	ND	0.760	ND	0.360	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BEAR0207		D2-CHAL2405D		D2-CHAL2410A	D2-CHAL2411A	D2-CHAL2411C	D2-CHAL2414A
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
				Address:	207 Beard Avenue		2405D Challenger Loop		2410A Challenger Loop	2411A Challenger Loop	2411C Challenger Loop	2414A Challenger Loop
				Field Sample ID:	D2-TW-0007075-23337-N	D2-TW-0007075-23337-N-P	D2-TW-0008044-23337-N	D2-TW-0008044-23337-N-P	D2-TW-0007795-23337-N	D2-TW-0007796-23337-N	D2-TW-0007802-23337-N	D2-TW-0007798-23337-N
				Sample Date:	2024-02-22	2024-02-22	2024-03-07	2024-03-07	2024-01-04	2024-02-12	2024-01-04	2024-02-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	700	700		390	390	430	470	430	290
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND		ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND		ND	67.0	ND	51.1	79.7	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND		ND	ND	ND	ND	54.7	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND		ND	67.0	ND	51.1	134	ND
Metals (ppb)	Antimony	6	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.740	0.530		ND	ND	ND	ND	ND	0.660
	Barium	2000	MCL	1.90	1.90		1.90	1.80	1.90	2.00	1.80	1.90
	Beryllium	4	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.50		0.540	1.20	0.920	ND	0.880	ND
	Copper	1300	MCL	7.40	8.60		16.7	14.7	26.9	30.9	37.4	52.1
	Lead	15	MCL	ND	ND		ND	ND	0.210	0.270	0.340	ND
	Mercury	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.80	1.00		0.550	1.00	0.850	0.990	0.650	1.60
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND		ND	ND	0.0840	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND		ND	ND	0.0240	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND		ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BEAR0207		D2-CHAL2405D		D2-CHAL2410A	D2-CHAL2411A	D2-CHAL2411C	D2-CHAL2414A
				Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
				Address:	207 Beard Avenue		2405D Challenger Loop		2410A Challenger Loop	2411A Challenger Loop	2411C Challenger Loop	2414A Challenger Loop
				Field Sample ID:	D2-TW-0007075-23337-N	D2-TW-0007075-23337-N-P	D2-TW-0008044-23337-N	D2-TW-0008044-23337-N-P	D2-TW-0007795-23337-N	D2-TW-0007796-23337-N	D2-TW-0007802-23337-N	D2-TW-0007798-23337-N
				Sample Date:	2024-02-22	2024-02-22	2024-03-07	2024-03-07	2024-01-04	2024-02-12	2024-01-04	2024-02-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-BEAR0207		D2-CHAL2405D		D2-CHAL2410A	D2-CHAL2411A	D2-CHAL2411C	D2-CHAL2414A
		Location Type:	Residence		Residence		Residence	Residence	Residence	Residence
		Address:	207 Beard Avenue		2405D Challenger Loop		2410A Challenger Loop	2411A Challenger Loop	2411C Challenger Loop	2414A Challenger Loop
		Field Sample ID:	D2-TW-0007075-23337-N	D2-TW-0007075-23337-N-P	D2-TW-0008044-23337-N	D2-TW-0008044-23337-N-P	D2-TW-0007795-23337-N	D2-TW-0007796-23337-N	D2-TW-0007802-23337-N	D2-TW-0007798-23337-N
		Sample Date:	2024-02-22	2024-02-22	2024-03-07	2024-03-07	2024-01-04	2024-02-12	2024-01-04	2024-02-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	0.270
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	0.270

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-CHAL2430B	D2-CHAL2434D	D2-CHAL2436B	D2-FOXB1104	D2-FOXB1114	D2-FOXB1202	D2-FOXB1701	
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:		2430B Challenger Loop	2434D Challenger Loop	2436B Challenger Loop	1104 Fox Boulevard	1114 Fox Boulevard	1202 Fox Boulevard	1701 Fox Boulevard	
		Field Sample ID:		D2-TW-0007984-23337-N	D2-TW-0008342-23337-N	D2-TW-0007987-23337-N	D2-TW-0008343-23337-N	D2-TW-0008468-23337-N	D2-TW-0008474-23337-N	D2-TW-0007864-23337-N	D2-TW-0007864-23337-3-N
		Sample Date:		2024-01-08	2024-01-04	2024-01-04	2024-02-22	2024-01-04	2024-01-04	2024-03-07	2024-03-07
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	550	390	460	950	290	270	640	640
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	101	63.0	65.1	ND	81.0	70.5	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	50.8	64.6	ND	57.8	59.2	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	101	114	130	ND	139	130	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	0.610	ND	ND	ND	ND
	Barium	2000	MCL	2.10	1.90	1.80	1.80	1.90	1.80	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.790	0.860	0.880	ND	0.850	0.900	0.580	0.540
	Copper	1300	MCL	27.4	30.6	25.7	14.7	22.2	23.1	14.9	15.0
	Lead	15	MCL	0.210	0.260	ND	ND	ND	0.170	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	0.0260	ND	ND
	Selenium	50	MCL	0.980	0.650	0.820	1.30	0.790	0.690	0.690	0.480
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	0.0150	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-CHAL2430B	D2-CHAL2434D	D2-CHAL2436B	D2-FOXB1104	D2-FOXB1114	D2-FOXB1202	D2-FOXB1701	
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
				Address:	2430B Challenger Loop	2434D Challenger Loop	2436B Challenger Loop	1104 Fox Boulevard	1114 Fox Boulevard	1202 Fox Boulevard	1701 Fox Boulevard	
				Field Sample ID:	D2-TW-0007984-23337-N	D2-TW-0008342-23337-N	D2-TW-0007987-23337-N	D2-TW-0008343-23337-N	D2-TW-0008468-23337-N	D2-TW-0008474-23337-N	D2-TW-0007864-23337-N	D2-TW-0007864-23337-3-N
				Sample Date:	2024-01-08	2024-01-04	2024-01-04	2024-02-22	2024-01-04	2024-01-04	2024-03-07	2024-03-07
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-CHAL2430B	D2-CHAL2434D	D2-CHAL2436B	D2-FOXB1104	D2-FOXB1114	D2-FOXB1202	D2-FOXB1701	
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	2430B Challenger Loop	2434D Challenger Loop	2436B Challenger Loop	1104 Fox Boulevard	1114 Fox Boulevard	1202 Fox Boulevard	1701 Fox Boulevard	
		Field Sample ID:	D2-TW-0007984-23337-N	D2-TW-0008342-23337-N	D2-TW-0007987-23337-N	D2-TW-0008343-23337-N	D2-TW-0008468-23337-N	D2-TW-0008474-23337-N	D2-TW-0007864-23337-N	D2-TW-0007864-23337-3-N
		Sample Date:	2024-01-08	2024-01-04	2024-01-04	2024-02-22	2024-01-04	2024-01-04	2024-03-07	2024-03-07
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.340	ND	ND	0.460	0.510	0.770	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.260	ND	ND	0.390	0.370	0.670	ND
	Total Trihalomethanes	80	MCL	0.600	ND	ND	0.850	0.880	1.44	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-FOXB1711	D2-FOXB1721	D2-FOXB1802	D2-FOXB1807	D2-FOXB1827	D2-FOXB1831		D2-FOXB1833
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		1711 Fox Boulevard	1721 Fox Boulevard	1802 Fox Boulevard	1807 Fox Boulevard	1827 Fox Boulevard	1831 Fox Boulevard		1833 Fox Boulevard
		Field Sample ID:		D2-TW-0007871-23337-N	D2-TW-0007876-23337-N	D2-TW-0007879-23337-N	D2-TW-0006907-23337-N	D2-TW-0007416-23337-N	D2-TW-0007418-23337-N	D2-TW-0007418-23337-N-P	D2-TW-0007419-23337-N
		Sample Date:		2024-01-04	2024-02-01	2024-02-12	2024-01-04	2024-02-22	2024-01-29	2024-01-29	2024-02-22
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	160	190	140	180	690	220	220	830
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	0.940	ND	ND	0.650
	Barium	2000	MCL	1.80	1.90	1.90	1.80	1.80	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.890	0.500	ND	0.850	ND	ND	1.30	ND
	Copper	1300	MCL	35.6	92.7	42.6	72.5	32.1	43.3	41.1	40.2
	Lead	15	MCL	0.160	0.230	ND	ND	ND	0.180	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.650	1.00	1.30	0.760	3.00	1.10	ND	1.60
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	0.0150	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	1.20	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-FOXB1711	D2-FOXB1721	D2-FOXB1802	D2-FOXB1807	D2-FOXB1827	D2-FOXB1831		D2-FOXB1833
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
				Address:	1711 Fox Boulevard	1721 Fox Boulevard	1802 Fox Boulevard	1807 Fox Boulevard	1827 Fox Boulevard	1831 Fox Boulevard		1833 Fox Boulevard
				Field Sample ID:	D2-TW-0007871-23337-N	D2-TW-0007876-23337-N	D2-TW-0007879-23337-N	D2-TW-0006907-23337-N	D2-TW-0007416-23337-N	D2-TW-0007418-23337-N	D2-TW-0007418-23337-N-P	D2-TW-0007419-23337-N
				Sample Date:	2024-01-04	2024-02-01	2024-02-12	2024-01-04	2024-02-22	2024-01-29	2024-01-29	2024-02-22
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-FOXB1711	D2-FOXB1721	D2-FOXB1802	D2-FOXB1807	D2-FOXB1827	D2-FOXB1831		D2-FOXB1833
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	1711 Fox Boulevard	1721 Fox Boulevard	1802 Fox Boulevard	1807 Fox Boulevard	1827 Fox Boulevard	1831 Fox Boulevard		1833 Fox Boulevard
		Field Sample ID:	D2-TW-0007871-23337-N	D2-TW-0007876-23337-N	D2-TW-0007879-23337-N	D2-TW-0006907-23337-N	D2-TW-0007416-23337-N	D2-TW-0007418-23337-N	D2-TW-0007418-23337-N-P	D2-TW-0007419-23337-N
		Sample Date:	2024-01-04	2024-02-01	2024-02-12	2024-01-04	2024-02-22	2024-01-29	2024-01-29	2024-02-22
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.300	0.320	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	0.300	0.320	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		<div>Location ID: D2-FOXB1833 Location Type: Residence Address: 1833 Fox Boulevard Field Sample ID: D2-TW-0007419-23337-N-P Sample Date: 2024-02-22 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1906 Location Type: Residence Address: 1906 Fox Boulevard Field Sample ID: D2-TW-0007430-23337-N Sample Date: 2024-02-22 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1912 Location Type: Residence Address: 1912 Fox Boulevard Field Sample ID: D2-TW-0007436-23337-N Sample Date: 2024-01-08 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1915 Location Type: Residence Address: 1915 Fox Boulevard Field Sample ID: D2-TW-0007439-23337-N Sample Date: 2024-02-13 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1921 Location Type: Residence Address: 1921 Fox Boulevard Field Sample ID: D2-TW-0007767-23337-N Sample Date: 2024-01-04 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1935 Location Type: Residence Address: 1935 Fox Boulevard Field Sample ID: D2-TW-0007027-23337-N Sample Date: 2024-03-18 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB1937 Location Type: Residence Address: 1937 Fox Boulevard Field Sample ID: D2-TW-0007028-23337-N Sample Date: 2024-03-15 Sample Type: N (Normal)</div>									
		<div>Location ID: D2-FOXB2006 Location Type: Residence Address: 2006 Fox Boulevard Field Sample ID: D2-TW-0007033-23337-N Sample Date: 2024-01-31 Sample Type: N (Normal)</div>									
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	830	550	550	630	420	310	530	340
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	144	ND	64.2	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	66.0	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	144	ND	130	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.520	0.760	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.80	1.90	1.90	1.80	1.70	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.40	ND	0.900	ND	0.890	0.680	0.830	0.550
	Copper	1300	MCL	43.7	29.6	54.3	32.3	34.1	41.2	41.4	52.1
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	0.130	0.220
	Mercury	2	MCL	ND	ND	ND	ND	0.0250	ND	ND	ND
	Selenium	50	MCL	1.00	1.50	0.960	1.30	1.50	2.00	1.10	0.970
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	0.0540	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-FOXB1833	D2-FOXB1906	D2-FOXB1912	D2-FOXB1915	D2-FOXB1921	D2-FOXB1935	D2-FOXB1937	D2-FOXB2006
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1833 Fox Boulevard	1906 Fox Boulevard	1912 Fox Boulevard	1915 Fox Boulevard	1921 Fox Boulevard	1935 Fox Boulevard	1937 Fox Boulevard	2006 Fox Boulevard
		Field Sample ID:	D2-TW-0007419-23337-N-P	D2-TW-0007430-23337-N	D2-TW-0007436-23337-N	D2-TW-0007439-23337-N	D2-TW-0007767-23337-N	D2-TW-0007027-23337-N	D2-TW-0007028-23337-N	D2-TW-0007033-23337-N
		Sample Date:	2024-02-22	2024-02-22	2024-01-08	2024-02-13	2024-01-04	2024-03-18	2024-03-15	2024-01-31
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-FOXB1833	D2-FOXB1906	D2-FOXB1912	D2-FOXB1915	D2-FOXB1921	D2-FOXB1935	D2-FOXB1937	D2-FOXB2006
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1833 Fox Boulevard	1906 Fox Boulevard	1912 Fox Boulevard	1915 Fox Boulevard	1921 Fox Boulevard	1935 Fox Boulevard	1937 Fox Boulevard	2006 Fox Boulevard
		Field Sample ID:	D2-TW-0007419-23337-N-P	D2-TW-0007430-23337-N	D2-TW-0007436-23337-N	D2-TW-0007439-23337-N	D2-TW-0007767-23337-N	D2-TW-0007027-23337-N	D2-TW-0007028-23337-N	D2-TW-0007033-23337-N
		Sample Date:	2024-02-22	2024-02-22	2024-01-08	2024-02-13	2024-01-04	2024-03-18	2024-03-15	2024-01-31
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-FOXB2013	D2-GEMI0711	D2-HOOL0705	D2-HOOL0708	D2-HOOP0917	D2-JULI0015		D2-JULI0116
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		2013 Fox Boulevard	711 Gemini Avenue	705 Hoolaulima Alley	708 Hoolaulima Alley	917 Hoopinana Alley	15 Julian Avenue		116 Julian Avenue
		Field Sample ID:		D2-TW-0007040-23337-N	D2-TW-0007154-23337-N	D2-TW-0008147-23337-N	D2-TW-0008111-23337-N	D2-TW-0008118-23337-N	D2-TW-0008053-23337-N	D2-TW-0008053-23337-N-P	D2-TW-0007259-23337-N
		Sample Date:		2024-01-04	2024-01-04	2024-01-04	2024-02-22	2024-01-31	2024-02-12	2024-02-12	2024-01-08
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	330	590	400	730	580	650	650	430
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	129	ND	ND	ND	ND	55.2
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	58.1	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	187	ND	ND	ND	ND	55.2
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	0.540	ND	ND	ND	ND
	Barium	2000	MCL	1.80	1.90	1.80	1.90	1.80	1.80	1.70	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.990	0.840	0.840	ND	0.560	ND	1.20	0.790
	Copper	1300	MCL	36.6	7.20	8.10	39.9	10.1	32.8	31.5	15.5
	Lead	15	MCL	ND	0.150	ND	2.40	0.180	0.190	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.780	0.700	0.690	0.710	1.00	0.420	ND	0.930
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-FOXB2013	D2-GEMI0711	D2-HOOL0705	D2-HOOL0708	D2-HOOP0917	D2-JULI0015		D2-JULI0116
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	2013 Fox Boulevard	711 Gemini Avenue	705 Hoolaulima Alley	708 Hoolaulima Alley	917 Hoopinana Alley	15 Julian Avenue		116 Julian Avenue
		Field Sample ID:	D2-TW-0007040-23337-N	D2-TW-0007154-23337-N	D2-TW-0008147-23337-N	D2-TW-0008111-23337-N	D2-TW-0008118-23337-N	D2-TW-0008053-23337-N	D2-TW-0008053-23337-N-P	D2-TW-0007259-23337-N
		Sample Date:	2024-01-04	2024-01-04	2024-01-04	2024-02-22	2024-01-31	2024-02-12	2024-02-12	2024-01-08
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	0.710	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-FOXB2013	D2-GEMI0711	D2-HOOL0705	D2-HOOL0708	D2-HOOP0917	D2-JULI0015		D2-JULI0116
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	2013 Fox Boulevard	711 Gemini Avenue	705 Hoolaulima Alley	708 Hoolaulima Alley	917 Hoopinana Alley	15 Julian Avenue		116 Julian Avenue
		Field Sample ID:	D2-TW-0007040-23337-N	D2-TW-0007154-23337-N	D2-TW-0008147-23337-N	D2-TW-0008111-23337-N	D2-TW-0008118-23337-N	D2-TW-0008053-23337-N	D2-TW-0008053-23337-N-P	D2-TW-0007259-23337-N
		Sample Date:	2024-01-04	2024-01-04	2024-01-04	2024-02-22	2024-01-31	2024-02-12	2024-02-12	2024-01-08
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	0.710	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-JULI0504	D2-JULI0603	D2-KAMA0105	D2-KAMA0426	D2-KAWE0732	D2-KOAA0502		D2-KOAA0503
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		504 Julian Avenue	603 Julian Avenue	105 Kamakaaina Alley	426 Kamakakoa Alley	732 Kawehiwehi Street	502 Koaaina Alley		503 Koaaina Alley
		Field Sample ID:		D2-TW-0007519-23337-N	D2-TW-0007356-23337-N	D2-TW-0006917-23337-N	D2-TW-0006926-23337-N	D2-TW-0007774-23337-N	D2-TW-0007782-23337-N	D2-TW-0007782-23337-3-N	D2-TW-0007783-23337-N
		Sample Date:		2024-01-05	2024-01-08	2024-01-05	2024-02-22	2024-01-05	2024-01-05	2024-01-05	2024-02-01
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	480	460	360	750	470	560	560	480
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	69.7	ND	ND	ND	62.3	67.7	54.2	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	69.7	ND	ND	ND	62.3	67.7	54.2	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	0.670	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	1.00	0.840	1.00	ND	1.00	0.990	1.10	ND
	Copper	1300	MCL	2.60	73.9	8.30	6.40	15.3	8.10	8.40	14.3
	Lead	15	MCL	ND	0.220	0.240	ND	0.130	0.130	0.130	0.160
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.90	1.20	1.80	1.30	2.40	1.70	1.90	0.780
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-JULI0504	D2-JULI0603	D2-KAMA0105	D2-KAMA0426	D2-KAWE0732	D2-KOAA0502		D2-KOAA0503
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:		504 Julian Avenue	603 Julian Avenue	105 Kamakaaina Alley	426 Kamakakoa Alley	732 Kawehiwehi Street	502 Koaaina Alley		503 Koaaina Alley
		Field Sample ID:		D2-TW-0007519-23337-N	D2-TW-0007356-23337-N	D2-TW-0006917-23337-N	D2-TW-0006926-23337-N	D2-TW-0007774-23337-N	D2-TW-0007782-23337-N	D2-TW-0007782-23337-3-N	D2-TW-0007783-23337-N
		Sample Date:		2024-01-05	2024-01-08	2024-01-05	2024-02-22	2024-01-05	2024-01-05	2024-01-05	2024-02-01
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-JULI0504	D2-JULI0603	D2-KAMA0105	D2-KAMA0426	D2-KAWE0732	D2-KOAA0502		D2-KOAA0503
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence		Residence
		Address:	504 Julian Avenue	603 Julian Avenue	105 Kamakaaina Alley	426 Kamakakoa Alley	732 Kawehiwehi Street	502 Koaaina Alley		503 Koaaina Alley
		Field Sample ID:	D2-TW-0007519-23337-N	D2-TW-0007356-23337-N	D2-TW-0006917-23337-N	D2-TW-0006926-23337-N	D2-TW-0007774-23337-N	D2-TW-0007782-23337-N	D2-TW-0007782-23337-3-N	D2-TW-0007783-23337-N
		Sample Date:	2024-01-05	2024-01-08	2024-01-05	2024-02-22	2024-01-05	2024-01-05	2024-01-05	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-KOAA0505	D2-KULE0601	D2-KUMA0286	D2-LELE0623	D2-LELE0724	D2-LEWA0265	D2-LEWA0327	D2-LEWA0333
		Location Type:		Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:		505 Koaina Alley	601 Kulekia Alley	286 Kumama Alley	623 Lelemanu Alley	724 Lelemanu Alley	265 Lewa Hia Loop	327 Lewa Mawaho Loop	333 Lewa Mawaho Loop
		Field Sample ID:		D2-TW-0007785-23337-N	D2-TW-0007789-23337-N	D2-TW-0007925-23337-N	D2-TW-0006992-23337-N	D2-TW-0007617-23337-N	D2-TW-0007634-23337-N	D2-TW-0008231-23337-N	D2-TW-0008234-23337-N
		Sample Date:		2024-01-05	2024-01-31	2024-01-05	2024-01-31	2024-01-08	2024-01-05	2024-01-05	2024-01-05
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	430	600	460	470	720	410	400	500
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	67.4	85.8	57.9	52.7
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	60.3	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	67.4	146	57.9	52.7
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.970	0.790	0.980	0.560	0.810	0.990	1.00	1.00
	Copper	1300	MCL	8.20	17.3	11.2	9.80	9.10	9.80	5.60	5.10
	Lead	15	MCL	0.130	0.630	0.170	0.140	ND	0.210	0.160	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.80	1.10	2.10	1.00	ND	1.70	1.90	1.90
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-KOAA0505	D2-KULE0601	D2-KUMA0286	D2-LELE0623	D2-LELE0724	D2-LEWA0265	D2-LEWA0327	D2-LEWA0333
				Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address:	505 Koaina Alley	601 Kulekia Alley	286 Kumama Alley	623 Lelemanu Alley	724 Lelemanu Alley	265 Lewa Hia Loop	327 Lewa Mawaho Loop	333 Lewa Mawaho Loop
				Field Sample ID:	D2-TW-0007785-23337-N	D2-TW-0007789-23337-N	D2-TW-0007925-23337-N	D2-TW-0006992-23337-N	D2-TW-0007617-23337-N	D2-TW-0007634-23337-N	D2-TW-0008231-23337-N	D2-TW-0008234-23337-N
				Sample Date:	2024-01-05	2024-01-31	2024-01-05	2024-01-31	2024-01-08	2024-01-05	2024-01-05	2024-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-KOAA0505	D2-KULE0601	D2-KUMA0286	D2-LELE0623	D2-LELE0724	D2-LEWA0265	D2-LEWA0327	D2-LEWA0333
		Location Type:	Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
		Address:	505 Koaina Alley	601 Kulekia Alley	286 Kumama Alley	623 Lelemanu Alley	724 Lelemanu Alley	265 Lewa Hia Loop	327 Lewa Mawaho Loop	333 Lewa Mawaho Loop
		Field Sample ID:	D2-TW-0007785-23337-N	D2-TW-0007789-23337-N	D2-TW-0007925-23337-N	D2-TW-0006992-23337-N	D2-TW-0007617-23337-N	D2-TW-0007634-23337-N	D2-TW-0008231-23337-N	D2-TW-0008234-23337-N
		Sample Date:	2024-01-05	2024-01-31	2024-01-05	2024-01-31	2024-01-08	2024-01-05	2024-01-05	2024-01-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	0.400	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.290	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	0.690	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-LEWA0371	D2-LEWA0397	D2-LEWA0404	D2-MERC0204	D2-MERC0226		D2-MONT0304	D2-PONA0407
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	371 Lewahana Loop	397 Lewahana Loop	404 Lewa Mawaho Loop	204 Mercury Street	226 Mercury Street		304 Monthan Street	407 Ponanonano Alley
				Field Sample ID:	D2-TW-0008160-23337-N	D2-TW-0007280-23337-N	D2-TW-0007283-23337-N	D2-TW-0007291-23337-N	D2-TW-0007300-23337-N	D2-TW-0007300-23337-3-N	D2-TW-0007706-23337-N	D2-TW-0007719-23337-N
				Sample Date:	2024-01-31	2024-01-08	2024-01-05	2024-02-01	2024-01-31	2024-01-31	2024-01-08	2024-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	630	600	480	480	560	560	560	450	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	89.3	61.6	ND	ND	ND	ND	61.2	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	89.3	61.6	ND	ND	ND	ND	61.2	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	1.90	1.80	1.90	2.00	1.90	1.90	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.630	0.880	1.10	ND	0.560	0.550	0.850	1.00	
	Copper	1300	MCL	9.20	7.40	14.7	4.80	18.6	18.3	15.3	8.70	
	Lead	15	MCL	0.210	ND	ND	ND	0.180	0.150	0.460	0.140	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	0.890	0.830	2.00	1.20	1.10	0.650	1.20	1.90	
	Thallium	2	MCL	ND	ND	ND	ND	0.0640	ND	ND	0.0520	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0160	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-LEWA0371	D2-LEWA0397	D2-LEWA0404	D2-MERC0204	D2-MERC0226		D2-MONT0304	D2-PONA0407
				Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
				Address:	371 Lewahana Loop	397 Lewahana Loop	404 Lewa Mawaho Loop	204 Mercury Street	226 Mercury Street		304 Monthan Street	407 Ponanonano Alley
				Field Sample ID:	D2-TW-0008160-23337-N	D2-TW-0007280-23337-N	D2-TW-0007283-23337-N	D2-TW-0007291-23337-N	D2-TW-0007300-23337-N	D2-TW-0007300-23337-3-N	D2-TW-0007706-23337-N	D2-TW-0007719-23337-N
				Sample Date:	2024-01-31	2024-01-08	2024-01-05	2024-02-01	2024-01-31	2024-01-31	2024-01-08	2024-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-LEWA0371	D2-LEWA0397	D2-LEWA0404	D2-MERC0204	D2-MERC0226		D2-MONT0304	D2-PONA0407
		Location Type:	Residence	Residence	Residence	Residence	Residence		Residence	Residence
		Address:	371 Lewahana Loop	397 Lewahana Loop	404 Lewa Mawaho Loop	204 Mercury Street	226 Mercury Street		304 Monthan Street	407 Ponanonano Alley
		Field Sample ID:	D2-TW-0008160-23337-N	D2-TW-0007280-23337-N	D2-TW-0007283-23337-N	D2-TW-0007291-23337-N	D2-TW-0007300-23337-N	D2-TW-0007300-23337-3-N	D2-TW-0007706-23337-N	D2-TW-0007719-23337-N
		Sample Date:	2024-01-31	2024-01-08	2024-01-05	2024-02-01	2024-01-31	2024-01-31	2024-01-08	2024-01-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.810	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.440	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	1.25	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-PORT1508		D2-PORT1606	D2-PORT1704	D2-PORT1722	D2-PORT1724		D2-PORT1730
		Location Type:		Residence		Residence	Residence	Residence	Residence		Residence
		Address:		1508 Porter Avenue		1606 Porter Avenue	1704 Porter Avenue	1722 Porter Avenue	1724 Porter Avenue		1730 Porter Avenue
		Field Sample ID:		D2-TW-0008426-23337-N	D2-TW-0008426-23337-3-N	D2-TW-0008429-23337-N	D2-TW-0008432-23337-N	D2-TW-0007680-23337-N	D2-TW-0007681-23337-N	D2-TW-0007681-23337-N-P	D2-TW-0007684-23337-N
		Sample Date:		2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-01-08
		Sample Type:		N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	360	360	750	370	280	510	510	210
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	99.7	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	99.7	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.80	1.80	1.90	1.90	1.80	1.80	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.530	0.610	0.590	ND	0.790	0.590	1.20	0.880
	Copper	1300	MCL	41.8	43.0	26.9	25.0	44.1	51.2	45.6	49.1
	Lead	15	MCL	0.160	0.180	0.360	ND	ND	ND	ND	0.270
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.560	0.580	0.510	1.30	0.560	0.650	0.990	1.80
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	0.0550
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1508		D2-PORT1606	D2-PORT1704	D2-PORT1722	D2-PORT1724		D2-PORT1730
				Location Type:	Residence		Residence	Residence	Residence	Residence		Residence
				Address:	1508 Porter Avenue		1606 Porter Avenue	1704 Porter Avenue	1722 Porter Avenue	1724 Porter Avenue		1730 Porter Avenue
				Field Sample ID:	D2-TW-0008426-23337-N	D2-TW-0008426-23337-3-N	D2-TW-0008429-23337-N	D2-TW-0008432-23337-N	D2-TW-0007680-23337-N	D2-TW-0007681-23337-N	D2-TW-0007681-23337-N-P	D2-TW-0007684-23337-N
				Sample Date:	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-01-08
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-PORT1508		D2-PORT1606	D2-PORT1704	D2-PORT1722	D2-PORT1724		D2-PORT1730
		Location Type:	Residence		Residence	Residence	Residence	Residence		Residence
		Address:	1508 Porter Avenue		1606 Porter Avenue	1704 Porter Avenue	1722 Porter Avenue	1724 Porter Avenue		1730 Porter Avenue
		Field Sample ID:	D2-TW-0008426-23337-N	D2-TW-0008426-23337-3-N	D2-TW-0008429-23337-N	D2-TW-0008432-23337-N	D2-TW-0007680-23337-N	D2-TW-0007681-23337-N	D2-TW-0007681-23337-N-P	D2-TW-0007684-23337-N
		Sample Date:	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-01-08
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	0.260	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	0.490	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.580	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	1.33	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1824	D2-PORT1830		D2-PORT1908		D2-PORT1912	D2-PORT1921	
				Location Type:	Residence	Residence		Residence		Residence	Residence	
				Address:	1824 Porter Avenue	1830 Porter Avenue		1908 Porter Avenue		1912 Porter Avenue	1921 Porter Avenue	
				Field Sample ID:	D2-TW-0007735-23337-N	D2-TW-0007738-23337-N	D2-TW-0007738-23337-N-P	D2-TW-0007743-23337-N	D2-TW-0007743-23337-3-N	D2-TW-0007745-23337-N	D2-TW-0007750-23337-N	D2-TW-0007750-23337-N-P
				Sample Date:	2024-02-28	2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-02-02	2024-02-02
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	690	610	610	610	680	680	280	350	350
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	73.0	73.0	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	73.0	73.0	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.740	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.80	1.80	1.80	1.80	1.80	1.80	1.90	2.20	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.550	1.20	1.20	0.590	0.620	0.560	0.600	ND
	Copper	1300	MCL	36.8	36.1	32.0	32.0	45.1	36.4	48.1	58.4	60.0
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	0.160	0.260	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.690	0.780	1.00	1.00	0.880	0.730	1.10	0.940	1.10
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1824		D2-PORT1830		D2-PORT1908		D2-PORT1912	D2-PORT1921	
				Location Type:	Residence		Residence		Residence		Residence	Residence	
				Address:	1824 Porter Avenue		1830 Porter Avenue		1908 Porter Avenue		1912 Porter Avenue	1921 Porter Avenue	
				Field Sample ID:	D2-TW-0007735-23337-N		D2-TW-0007738-23337-N	D2-TW-0007738-23337-N-P	D2-TW-0007743-23337-N	D2-TW-0007743-23337-3-N	D2-TW-0007745-23337-N	D2-TW-0007750-23337-N	D2-TW-0007750-23337-N-P
				Sample Date:	2024-02-28		2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-02-02	2024-02-02
				Sample Type:	N (Normal)		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1824		D2-PORT1830		D2-PORT1908		D2-PORT1912	D2-PORT1921	
				Location Type:	Residence		Residence		Residence		Residence	Residence	
				Address:	1824 Porter Avenue		1830 Porter Avenue		1908 Porter Avenue		1912 Porter Avenue	1921 Porter Avenue	
				Field Sample ID:	D2-TW-0007735-23337-N		D2-TW-0007738-23337-N	D2-TW-0007738-23337-N-P	D2-TW-0007743-23337-N	D2-TW-0007743-23337-3-N	D2-TW-0007745-23337-N	D2-TW-0007750-23337-N	D2-TW-0007750-23337-N-P
				Sample Date:	2024-02-28		2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-02-02	2024-02-02
				Sample Type:	N (Normal)		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level										
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-PORT1923	D2-SIGN0101B	D2-SIGN0201C		D2-SIGN0201D		D2-SIGN0301A	D2-SIGN0303A
		Location Type:		Residence	Residence	Residence		Residence		Residence	Residence
		Address:		1923 Porter Avenue	101B Signer Boulevard	201C Signer Boulevard		201D Signer Boulevard		301A Signer Boulevard	303A Signer Boulevard
		Field Sample ID:		D2-TW-0007751-23337-N	D2-TW-0007929-23337-N	D2-TW-0007934-23337-N	D2-TW-0007934-23337-3-N	D2-TW-0007935-23337-N	D2-TW-0007935-23337-N-P	D2-TW-0007944-23337-N	D2-TW-0006972-23337-N
		Sample Date:		2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-03-08
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	270	570	320	320	690	690	480	490
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	73.5	ND	ND	ND	69.0	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	73.5	ND	ND	ND	69.0	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.80	1.90	2.00	1.90	2.00	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	0.790	0.500	ND	0.540	1.20	ND	ND
	Copper	1300	MCL	127	19.7	18.6	18.4	13.1	10.7	6.70	2.80
	Lead	15	MCL	0.190	ND	ND	ND	ND	ND	0.210	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	1.30	0.330	0.530	0.450	0.490	1.00	1.40	0.720
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	0.0150	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-PORT1923	D2-SIGN0101B	D2-SIGN0201C		D2-SIGN0201D		D2-SIGN0301A	D2-SIGN0303A
				Location Type:	Residence	Residence	Residence		Residence		Residence	Residence
				Address:	1923 Porter Avenue	101B Signer Boulevard	201C Signer Boulevard		201D Signer Boulevard		301A Signer Boulevard	303A Signer Boulevard
				Field Sample ID:	D2-TW-0007751-23337-N	D2-TW-0007929-23337-N	D2-TW-0007934-23337-N	D2-TW-0007934-23337-3-N	D2-TW-0007935-23337-N	D2-TW-0007935-23337-N-P	D2-TW-0007944-23337-N	D2-TW-0006972-23337-N
				Sample Date:	2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-03-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-PORT1923	D2-SIGN0101B	D2-SIGN0201C		D2-SIGN0201D		D2-SIGN0301A	D2-SIGN0303A
		Location Type:		Residence	Residence	Residence		Residence		Residence	Residence
		Address:		1923 Porter Avenue	101B Signer Boulevard	201C Signer Boulevard		201D Signer Boulevard		301A Signer Boulevard	303A Signer Boulevard
		Field Sample ID:		D2-TW-0007751-23337-N	D2-TW-0007929-23337-N	D2-TW-0007934-23337-N	D2-TW-0007934-23337-3-N	D2-TW-0007935-23337-N	D2-TW-0007935-23337-N-P	D2-TW-0007944-23337-N	D2-TW-0006972-23337-N
		Sample Date:		2024-02-01	2024-01-08	2024-03-07	2024-03-07	2024-03-07	2024-03-07	2024-02-01	2024-03-08
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	0.310	ND
	Bromoform	--	--	0.500	ND	0.290	0.300	0.260	ND	0.830	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	0.250	ND	ND	0.840	0.270
	Total Trihalomethanes	80	MCL	0.500	ND	0.290	0.550	0.260	ND	1.98	0.270

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-SIGN0403C	D2-SIGN0403F	D2-SIGN0408		D2-SIGN0504E		D2-SIGN0504F	D2-SIGN1002
		Location Type:		Residence	Residence	Residence		Residence		Residence	Residence
		Address:		403C Signer Boulevard	403F Signer Boulevard	408 Signer Boulevard		504E Signer Boulevard		504F Signer Boulevard	1002 Signer Boulevard
		Field Sample ID:		D2-TW-0008439-23337-N	D2-TW-0008442-23337-N	D2-TW-0007759-23337-N	D2-TW-0007759-23337-3-N	D2-TW-0008454-23337-N	D2-TW-0008454-23337-N-P	D2-TW-0008455-23337-N	D2-TW-0007926-23337-N
		Sample Date:		2024-02-22	2024-02-15	2024-02-01	2024-02-01	2024-02-23	2024-02-23	2024-02-22	2024-03-19
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	220	610	610	610	530	530	580	370
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.930	0.810	ND	ND	ND	ND	0.720	ND
	Barium	2000	MCL	1.90	2.00	1.80	1.80	1.80	1.90	1.90	1.80
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	0.540	ND	ND	1.50	ND	0.660
	Copper	1300	MCL	27.5	22.2	38.1	37.2	14.6	15.4	66.5	8.50
	Lead	15	MCL	ND	ND	0.160	0.160	ND	ND	0.270	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	3.10	0.860	1.40	1.10	0.510	0.940	1.30	2.10
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-SIGN0403C	D2-SIGN0403F	D2-SIGN0408		D2-SIGN0504E		D2-SIGN0504F	D2-SIGN1002
		Location Type:		Residence	Residence	Residence		Residence		Residence	Residence
		Address:		403C Signer Boulevard	403F Signer Boulevard	408 Signer Boulevard		504E Signer Boulevard		504F Signer Boulevard	1002 Signer Boulevard
		Field Sample ID:		D2-TW-0008439-23337-N	D2-TW-0008442-23337-N	D2-TW-0007759-23337-N	D2-TW-0007759-23337-3-N	D2-TW-0008454-23337-N	D2-TW-0008454-23337-N-P	D2-TW-0008455-23337-N	D2-TW-0007926-23337-N
		Sample Date:		2024-02-22	2024-02-15	2024-02-01	2024-02-01	2024-02-23	2024-02-23	2024-02-22	2024-03-19
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-SIGN0403C	D2-SIGN0403F	D2-SIGN0408		D2-SIGN0504E		D2-SIGN0504F	D2-SIGN1002
		Location Type:	Residence	Residence	Residence		Residence		Residence	Residence
		Address:	403C Signer Boulevard	403F Signer Boulevard	408 Signer Boulevard		504E Signer Boulevard		504F Signer Boulevard	1002 Signer Boulevard
		Field Sample ID:	D2-TW-0008439-23337-N	D2-TW-0008442-23337-N	D2-TW-0007759-23337-N	D2-TW-0007759-23337-3-N	D2-TW-0008454-23337-N	D2-TW-0008454-23337-N-P	D2-TW-0008455-23337-N	D2-TW-0007926-23337-N
		Sample Date:	2024-02-22	2024-02-15	2024-02-01	2024-02-01	2024-02-23	2024-02-23	2024-02-22	2024-03-19
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.320	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	1.50	ND	ND	ND	ND	ND	0.330
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.810	ND	ND	ND	ND	ND	0.340
	Total Trihalomethanes	80	MCL	2.63	ND	ND	ND	ND	ND	0.670

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-TINK0105	D2-TINK0106	D2-TINK1604		D2-TINK1701	D2-TINK1722	D2-TINK1734	
		Location Type:		Residence	Residence	Residence		Residence	Residence	Residence	
		Address:		105 Tinker Drive	106 Tinker Drive	1604 Tinker Avenue		1701 Tinker Avenue	1722 Tinker Avenue	1734 Tinker Avenue	
		Field Sample ID:		D2-TW-0008462-23337-N	D2-TW-0008463-23337-N	D2-TW-0008253-23337-N	D2-TW-0008253-23337-3-N	D2-TW-0008264-23337-N	D2-TW-0007312-23337-N	D2-TW-0007325-23337-N	D2-TW-0007325-23337-N-P
		Sample Date:		2024-03-07	2024-01-08	2024-02-22	2024-02-22	2024-01-08	2024-02-01	2024-01-31	2024-01-31
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	390	420	810	810	540	740	370	370
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	90.5	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	90.5	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	0.780	0.690	ND	ND	ND	ND
	Barium	2000	MCL	1.90	1.90	1.90	1.80	1.90	1.80	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	0.550	0.750	ND	ND	0.860	ND	0.670	1.20
	Copper	1300	MCL	17.6	53.6	43.3	42.2	18.1	72.2	55.5	52.8
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.550	0.920	1.60	1.50	1.10	0.850	1.10	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-TINK0105	D2-TINK0106	D2-TINK1604		D2-TINK1701	D2-TINK1722	D2-TINK1734	
				Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	
				Address:	105 Tinker Drive	106 Tinker Drive	1604 Tinker Avenue		1701 Tinker Avenue	1722 Tinker Avenue	1734 Tinker Avenue	
				Field Sample ID:	D2-TW-0008462-23337-N	D2-TW-0008463-23337-N	D2-TW-0008253-23337-N	D2-TW-0008253-23337-3-N	D2-TW-0008264-23337-N	D2-TW-0007312-23337-N	D2-TW-0007325-23337-N	D2-TW-0007325-23337-N-P
				Sample Date:	2024-03-07	2024-01-08	2024-02-22	2024-02-22	2024-01-08	2024-02-01	2024-01-31	2024-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK0105	D2-TINK0106	D2-TINK1604		D2-TINK1701	D2-TINK1722	D2-TINK1734	
		Location Type:	Residence	Residence	Residence		Residence	Residence	Residence	
		Address:	105 Tinker Drive	106 Tinker Drive	1604 Tinker Avenue		1701 Tinker Avenue	1722 Tinker Avenue	1734 Tinker Avenue	
		Field Sample ID:	D2-TW-0008462-23337-N	D2-TW-0008463-23337-N	D2-TW-0008253-23337-N	D2-TW-0008253-23337-3-N	D2-TW-0008264-23337-N	D2-TW-0007312-23337-N	D2-TW-0007325-23337-N	D2-TW-0007325-23337-N-P
		Sample Date:	2024-03-07	2024-01-08	2024-02-22	2024-02-22	2024-01-08	2024-02-01	2024-01-31	2024-01-31
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-TINK1744		D2-TINK1802	D2-TINK1804	D2-TINK1808	D2-TINK1818	D2-TINK1820	D2-TINK1832
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1744 Tinker Avenue		1802 Tinker Avenue	1804 Tinker Avenue	1808 Tinker Avenue	1818 Tinker Avenue	1820 Tinker Avenue	1832 Tinker Avenue
				Field Sample ID:	D2-TW-0007330-23337-N	D2-TW-0007330-23337-3-N	D2-TW-0007332-23337-N	D2-TW-0007334-23337-N	D2-TW-0007338-23337-N	D2-TW-0007343-23337-N	D2-TW-0007344-23337-N	D2-TW-0007350-23337-N
				Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-31	2024-02-12	2024-01-31	2024-01-05	2024-01-31
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	680	680	370	380	770	370	300	120	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	102	ND	ND	ND	ND	93.0	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	64.3	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	166	ND	ND	ND	ND	93.0	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	7.80	2.00	1.90	1.90	1.90	1.90	1.90	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.810	0.900	0.780	0.580	ND	0.600	1.10	0.580	
	Copper	1300	MCL	28.3	29.0	54.7	38.5	19.7	35.3	24.1	42.3	
	Lead	15	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	0.520	1.20	0.480	1.20	0.940	1.20	2.10	0.710	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-TINK1744		D2-TINK1802	D2-TINK1804	D2-TINK1808	D2-TINK1818	D2-TINK1820	D2-TINK1832
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
				Address:	1744 Tinker Avenue		1802 Tinker Avenue	1804 Tinker Avenue	1808 Tinker Avenue	1818 Tinker Avenue	1820 Tinker Avenue	1832 Tinker Avenue
				Field Sample ID:	D2-TW-0007330-23337-N	D2-TW-0007330-23337-3-N	D2-TW-0007332-23337-N	D2-TW-0007334-23337-N	D2-TW-0007338-23337-N	D2-TW-0007343-23337-N	D2-TW-0007344-23337-N	D2-TW-0007350-23337-N
				Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-31	2024-02-12	2024-01-31	2024-01-05	2024-01-31
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND		ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND		ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND		ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK1744		D2-TINK1802	D2-TINK1804	D2-TINK1808	D2-TINK1818	D2-TINK1820	D2-TINK1832
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	1744 Tinker Avenue		1802 Tinker Avenue	1804 Tinker Avenue	1808 Tinker Avenue	1818 Tinker Avenue	1820 Tinker Avenue	1832 Tinker Avenue
		Field Sample ID:	D2-TW-0007330-23337-N	D2-TW-0007330-23337-3-N	D2-TW-0007332-23337-N	D2-TW-0007334-23337-N	D2-TW-0007338-23337-N	D2-TW-0007343-23337-N	D2-TW-0007344-23337-N	D2-TW-0007350-23337-N
		Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-31	2024-02-12	2024-01-31	2024-01-05	2024-01-31
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level							
Method Group	Analyte									
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		D2-TINK1910	D2-TINK1914	D2-TINK2001	D2-TINK2006
		Location Type:		Residence	Residence	Residence	Residence
		Address:		1910 Tinker Avenue	1914 Tinker Avenue	2001 Tinker Avenue	2006 Tinker Avenue
		Field Sample ID:		D2-TW-0007700-23337-N	D2-TW-0007702-23337-N	D2-TW-0007384-23337-N	D2-TW-0007388-23337-N
		Sample Date:		2024-01-31	2024-02-01	2024-02-12	2024-02-01
		Sample Type:		N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level				
Field Test (ppb)	Free Chlorine	4000	MCL	520	300	550	590
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND
	Barium	2000	MCL	1.80	1.80	1.90	1.90
	Beryllium	4	MCL	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND
	Chromium	100	MCL	0.620	ND	ND	0.500
	Copper	1300	MCL	27.4	26.8	163	40.6
	Lead	15	MCL	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND
	Selenium	50	MCL	0.900	1.30	0.460	1.10
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK1910	D2-TINK1914	D2-TINK2001	D2-TINK2006
		Location Type:	Residence	Residence	Residence	Residence
		Address:	1910 Tinker Avenue	1914 Tinker Avenue	2001 Tinker Avenue	2006 Tinker Avenue
		Field Sample ID:	D2-TW-0007700-23337-N	D2-TW-0007702-23337-N	D2-TW-0007384-23337-N	D2-TW-0007388-23337-N
		Sample Date:	2024-01-31	2024-02-01	2024-02-12	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-TINK1910	D2-TINK1914	D2-TINK2001	D2-TINK2006
		Location Type:	Residence	Residence	Residence	Residence
		Address:	1910 Tinker Avenue	1914 Tinker Avenue	2001 Tinker Avenue	2006 Tinker Avenue
		Field Sample ID:	D2-TW-0007700-23337-N	D2-TW-0007702-23337-N	D2-TW-0007384-23337-N	D2-TW-0007388-23337-N
		Sample Date:	2024-01-31	2024-02-01	2024-02-12	2024-02-01
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)
		DOH Project Screening Level	Basis of Project Screening Level			
Method Group	Analyte					
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND
	Bromoform	--	--	ND	ND	ND
	Chloroform	--	--	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Schools in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG641H				
				Location Type:	School				
				Address:	HICKAM ELEM - P1, Building 641H				
				Field Sample ID:	D2-TW-0015498-23337-N-1	D2-TW-0015498-23337-N-3	D2-TW-0015498-23337-N-4	D2-TW-0015498-23337-N-2	D2-TW-0015498-23337-N-5
				Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-08	2024-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Field Test (ppb)	Free Chlorine	4000	MCL	30.0-730	30.0-730	30.0-730	30.0-730	30.0-730	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	68.7	ND	63.5	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	68.7	ND	63.5	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	
	Barium	2000	MCL	2.00	2.10	1.90	1.90	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.830	0.650	0.760	0.780	0.750	
	Copper	1300	MCL	215	129	192	36.7	30.0	
	Lead	15	MCL	0.200	1.50	ND	ND	0.130	
	Mercury	2	MCL	ND	ND	ND	ND	ND	
	Selenium	50	MCL	1.40	0.340	1.20	1.00	0.640	
	Thallium	2	MCL	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Schools in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG641H				
				Location Type:	School				
				Address:	HICKAM ELEM - P1, Building 641H				
				Field Sample ID:	D2-TW-0015498-23337-N-1	D2-TW-0015498-23337-N-3	D2-TW-0015498-23337-N-4	D2-TW-0015498-23337-N-2	D2-TW-0015498-23337-N-5
				Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-08	2024-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Schools in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG641H				
				Location Type:	School				
				Address:	HICKAM ELEM - P1, Building 641H				
				Field Sample ID:	D2-TW-0015498-23337-N-1	D2-TW-0015498-23337-N-3	D2-TW-0015498-23337-N-4	D2-TW-0015498-23337-N-2	D2-TW-0015498-23337-N-5
				Sample Date:	2024-01-08	2024-01-08	2024-01-08	2024-01-08	2024-01-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	
	Bromoform	--	--	1.30	0.940	0.250	ND	ND	
	Chloroform	--	--	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.340	0.330	ND	ND	ND	
	Total Trihalomethanes	80	MCL	1.64	1.27	0.250	ND	ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone D2

Notes:					
ND = Not Detected					
ISP = Incident Specific Parameter					
EAL = DOH Environmental Action Level					
EPA MCL = EPA Maximum Contaminant Level					
All Results shown in Parts per Billion (ppb)					
§ - Exceeds Screening Level					
-- = No Information Available					
N (Normal) = Full compliance sample					
FD (Field Duplicate) = Extra sample taken for quality control					
N (Grab, Resample) = Additional follow-up sample					
			Location ID:	D2-BLDG623H	
			Location Type:	Child Development Center	
			Address:	Building 623H,HARBOR CHILD DEVELOPMENT CENTER	
			Field Sample ID:	D2-TW-0015492-23337-N-1	D2-TW-0015492-23337-N-2
			Sample Date:	2024-02-01	2024-02-01
			Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Field Test (ppb)	Free Chlorine	4000	MCL	430-440	430-440
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.80	2.10
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	0.540	0.540
	Copper	1300	MCL	17.2	10.4
	Lead	15	MCL	ND	ND
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	1.40	1.20
	Thallium	2	MCL	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG623H	
				Location Type:	Child Development Center	
				Address:	Building 623H,HARBOR CHILD DEVELOPMENT CENTER	
				Field Sample ID:	D2-TW-0015492-23337-N-1	D2-TW-0015492-23337-N-2
				Sample Date:	2024-02-01	2024-02-01
				Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	
	1,2-Dichloroethane	5	MCL	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	
	1,2-Dichloropropane	5	MCL	ND	ND	
	1,4-Dichlorobenzene	75	MCL	ND	ND	
	Benzene	5	MCL	ND	ND	
	Carbon Tetrachloride	5	MCL	ND	ND	
	Chlorobenzene	100	MCL	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	ND	ND	
	Ethylbenzene	700	MCL	ND	ND	
	m,p-Xylene	--	--	ND	ND	
	Methylene chloride	5	MCL	ND	ND	
	o-Xylene	--	--	ND	ND	
	Styrene	100	MCL	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	ND	ND	
	Toluene	1000	MCL	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	ND	ND	
	Trichloroethene (TCE)	5	MCL	ND	ND	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Child Development Centers in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-BLDG623H	
				Location Type:	Child Development Center	
				Address:	Building 623H,HARBOR CHILD DEVELOPMENT CENTER	
				Field Sample ID:	D2-TW-0015492-23337-N-1	D2-TW-0015492-23337-N-2
				Sample Date:	2024-02-01	2024-02-01
				Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level			
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND	
	Xylenes, Total	10000	MCL	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	
	Chloroacetic acid	--	--	ND	ND	
	Dibromoacetic acid	--	--	ND	ND	
	Dichloroacetic acid	--	--	ND	ND	
	Trichloroacetic acid	--	--	ND	ND	
	Total Haloacetic acids	60	MCL	ND	ND	
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	
	Bromoform	--	--	0.350	1.30	
	Chloroform	--	--	ND	ND	
	Dibromochloromethane	--	--	ND	0.730	
	Total Trihalomethanes	80	MCL	0.350	2.03	

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone D2

Notes:					
ND = Not Detected					
ISP = Incident Specific Parameter					
EAL = DOH Environmental Action Level					
EPA MCL = EPA Maximum Contaminant Level					
All Results shown in Parts per Billion (ppb)					
§ - Exceeds Screening Level					
-- = No Information Available					
N (Normal) = Full compliance sample					
FD (Field Duplicate) = Extra sample taken for quality control					
N (Grab, Resample) = Additional follow-up sample					
			Location ID:	D2-BLDG554H	D2-BLDG559H
			Location Type:	Medical Building	Medical Building
			Address:	Building 554H,OCCUPATIONA L HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd	Building 559H,MEDICAL/DENT AL CLINIC - AIR FORCE, 755 Scott Circle
			Field Sample ID:	D2-TW-0015474- 23337-N	D2-TW-0015476- 23337-N
			Sample Date:	2024-02-01	2024-02-01
			Sample Type:	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Field Test (ppb)	Free Chlorine	4000	MCL	210	60.0
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.90	1.80
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	ND	ND
	Copper	1300	MCL	53.9	134
	Lead	15	MCL	0.360	0.310
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	1.10	1.20
	Thallium	2	MCL	ND	0.0550
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
	Naphthalene	17	EAL	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	D2-BLDG554H	D2-BLDG559H
				Location Type:	Medical Building	Medical Building
				Address:	Building 554H,OCCUPATIONA L HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd	Building 559H,MEDICAL/DENT AL CLINIC - AIR FORCE, 755 Scott Circle
				Field Sample ID:	D2-TW-0015474- 23337-N	D2-TW-0015476- 23337-N
				Sample Date:	2024-02-01	2024-02-01
				Sample Type:	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND		ND
	1,1,2-Trichloroethane	5	MCL	ND		ND
	1,1-Dichloroethene	7	MCL	ND		ND
	1,2,4-Trichlorobenzene	70	MCL	ND		ND
	1,2-Dichlorobenzene	600	MCL	ND		ND
	1,2-Dichloroethane	5	MCL	ND		ND
	1,2-Dichloroethene (Total)	70	MCL	ND		ND
	1,2-Dichloropropane	5	MCL	ND		ND
	1,4-Dichlorobenzene	75	MCL	ND		ND
	Benzene	5	MCL	ND		ND
	Carbon Tetrachloride	5	MCL	ND		ND
	Chlorobenzene	100	MCL	ND		ND
	cis-1,2-Dichloroethene	70	MCL	ND		ND
	Ethylbenzene	700	MCL	ND		ND
	m,p-Xylene	--	--	ND		ND
	Methylene chloride	5	MCL	ND		ND
	o-Xylene	--	--	ND		ND
	Styrene	100	MCL	ND		ND
	Tetrachloroethene (PCE)	5	MCL	ND		ND
	Toluene	1000	MCL	ND		ND
	trans-1,2-Dichloroethene	100	MCL	ND		ND
	Trichloroethene (TCE)	5	MCL	ND		ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Medical Buildings in Zone D2

Notes:					
ND = Not Detected					
ISP = Incident Specific Parameter					
EAL = DOH Environmental Action Level					
EPA MCL = EPA Maximum Contaminant Level					
All Results shown in Parts per Billion (ppb)					
§ - Exceeds Screening Level					
-- = No Information Available					
N (Normal) = Full compliance sample					
FD (Field Duplicate) = Extra sample taken for quality control					
N (Grab, Resample) = Additional follow-up sample					
				Location ID:	D2-BLDG554H
				Location Type:	Medical Building
				Address:	Building 554H,OCCUPATIONA L HEALTH CLINIC - AIR FORCE, 750 West Signer Blvd
				Field Sample ID:	D2-TW-0015474- 23337-N
				Sample Date:	2024-02-01
				Sample Type:	N (Normal)
					D2-BLDG559H
					Medical Building
					Building 559H,MEDICAL/DENT AL CLINIC - AIR FORCE, 755 Scott Circle
					D2-TW-0015476- 23337-N
					2024-02-01
					N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level		
Volatile Organic Compounds (ppb)	Vinyl chloride	2	MCL	ND	ND
	Xylenes, Total	10000	MCL	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND
	Chloroacetic acid	--	--	ND	ND
	Dibromoacetic acid	--	--	ND	ND
	Dichloroacetic acid	--	--	ND	ND
	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	0.810
	Bromoform	--	--	0.590	4.70
	Chloroform	--	--	ND	0.410
	Dibromochloromethane	--	--	0.270	2.20
	Total Trihalomethanes	80	MCL	0.860	8.12

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-HYD0079		D2-HYD0498		D2-HYD1599	D2-HYD1610	D2-HYD236	D2-HYD321
				Location Type:	Hydrant		Hydrant		Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH:519		FH:509		FH:429	FH:074	FH:236 (Possibly HYD263, HYD-2154)	FH:321
				Field Sample ID:	D2-DL-0017714-23337 -N	D2-DL-0017714-23337 -3-N	D2-DL-0017715-23337 -N	D2-DL-0017715-23337 -3-N	D2-DL-0000574-23337 -N	D2-DL-0000583-23337 -N	D2-DL-0017711-23337 -N	D2-DL-0017709-23337 -N
				Sample Date:	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Field Test (ppb)	Free Chlorine	4000	MCL	590	590	660	660	380	440	520	460	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.820	0.820	0.630	0.910	0.900	0.730	0.770	0.810	
	Barium	2000	MCL	1.90	2.40	1.90	1.90	2.30	1.90	2.00	1.90	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.790	0.710	0.910	1.10	ND	0.880	ND	
	Thallium	2	MCL	ND	ND	ND	0.0500	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-HYD0079		D2-HYD0498		D2-HYD1599	D2-HYD1610	D2-HYD236	D2-HYD321
				Location Type:	Hydrant		Hydrant		Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH:519		FH:509		FH:429	FH:074	FH:236 (Possibly HYD263, HYD-2154)	FH:321
				Field Sample ID:	D2-DL-0017714-23337 -N	D2-DL-0017714-23337 -3-N	D2-DL-0017715-23337 -N	D2-DL-0017715-23337 -3-N	D2-DL-0000574-23337 -N	D2-DL-0000583-23337 -N	D2-DL-0017711-23337 -N	D2-DL-0017709-23337 -N
				Sample Date:	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14
				Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level									
Volatile Organic Compounds (ppb)	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-HYD0079		D2-HYD0498		D2-HYD1599	D2-HYD1610	D2-HYD236	D2-HYD321
		Location Type:	Hydrant		Hydrant		Hydrant	Hydrant	Hydrant	Hydrant
		Address:	FH:519		FH:509		FH:429	FH:074	FH:236 (Possibly HYD263, HYD-2154)	FH:321
		Field Sample ID:	D2-DL-0017714-23337 -N	D2-DL-0017714-23337 -3-N	D2-DL-0017715-23337 -N	D2-DL-0017715-23337 -3-N	D2-DL-0000574-23337 -N	D2-DL-0000583-23337 -N	D2-DL-0017711-23337 -N	D2-DL-0017709-23337 -N
		Sample Date:	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14
		Sample Type:	N (Normal)	FD (Field Duplicate)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	0.300	ND	ND
	Bromoform	--	--	0.290	0.330	ND	ND	1.60	0.260	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	0.270	0.310	ND	ND	0.930	ND	ND
	Total Trihalomethanes	80	MCL	0.560	0.640	ND	ND	2.83	0.260	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	D2-HYD365	D2-HYD420	D2-HYD56	D2-HYD79	D2-HYD84	
		Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant	
		Address:	FH:365	FH:420	FH:056	FH:079	FH:084	
		Field Sample ID:	D2-DL-0017717-23337 -N	D2-DL-0017707-23337 -N	D2-DL-0017708-23337 -N	D2-DL-0017712-23337 -N	D2-DL-0017713-23337 -N	
		Sample Date:	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level					
Field Test (ppb)	Free Chlorine	4000	MCL	130	310	540	280	370
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND
	Arsenic	10	MCL	0.690	0.920	0.730	1.10	0.760
	Barium	2000	MCL	1.80	1.90	2.10	4.00	1.90
	Beryllium	4	MCL	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	ND	ND	ND	ND
	Mercury	2	MCL	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	0.920	ND	0.750	0.870
	Thallium	2	MCL	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND
	Naphthalene	17	EAL	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: D2-HYD365 Location Type: Hydrant Address: FH:365 Field Sample ID: D2-DL-0017717-23337-N Sample Date: 2024-02-14 Sample Type: N (Normal)			D2-HYD420 Hydrant FH:420 D2-DL-0017707-23337-N 2024-02-14 N (Normal)			D2-HYD56 Hydrant FH:056 D2-DL-0017708-23337-N 2024-02-14 N (Normal)			D2-HYD79 Hydrant FH:079 D2-DL-0017712-23337-N 2024-02-14 N (Normal)			D2-HYD84 Hydrant FH:084 D2-DL-0017713-23337-N 2024-02-14 N (Normal)		
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level													
Volatile Organic Compounds (ppb)	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	0.930	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	ND	ND	ND	ND	0.930	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone D2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone D2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				Location ID:	D2-HYD365	D2-HYD420	D2-HYD56	D2-HYD79	D2-HYD84
				Location Type:	Hydrant	Hydrant	Hydrant	Hydrant	Hydrant
				Address:	FH:365	FH:420	FH:056	FH:079	FH:084
				Field Sample ID:	D2-DL-0017717-23337-N	D2-DL-0017707-23337-N	D2-DL-0017708-23337-N	D2-DL-0017712-23337-N	D2-DL-0017713-23337-N
				Sample Date:	2024-02-14	2024-02-14	2024-02-14	2024-02-14	2024-02-14
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.560	ND	
	Bromoform	--	--	5.40	0.470	ND	5.60	ND	
	Chloroform	--	--	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.920	0.280	ND	2.20	ND	
	Total Trihalomethanes	80	MCL	6.32	0.750	ND	8.36	ND	