

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-BALS5221		Location ID: H2-CROS6507					
				Residence	Residence	H2-TW-0011883-23335-A	H2-TW-0011883-23335-A-P	H2-TW-0011883-23335-A-R1	H2-TW-0011883-23335-A-R1-P	H2-TW-0011883-23335-A-1	H2-TW-0011883-23335-A-1-P
				Address: 5221 Balsa Lane		Address: 6507 Crossandra Street					
				Field Sample ID: H2-TW-0013575-23335-A	H2-TW-0011883-23335-A	H2-TW-0011883-23335-A-P	H2-TW-0011883-23335-A-R1	H2-TW-0011883-23335-A-R1-P	H2-TW-0011883-23335-A-1	H2-TW-0011883-23335-A-1-P	H2-TW-0011883-23335-A-2
				Sample Date: 2024-03-05	2024-02-12	2024-02-12	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26
				Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	690	830	830	800-970	800-970	800-970	800-970	800-970
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	--	--	--	--	--
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	--	ND	--	ND
	Arsenic	10	MCL	ND	ND	ND	ND	--	ND	--	ND
	Barium	2000	MCL	1.80	1.50	1.40	1.30	--	1.40	--	1.30
	Beryllium	4	MCL	ND	ND	ND	ND	--	ND	--	ND
	Cadmium	5	MCL	ND	ND	ND	ND	--	ND	--	ND
	Chromium	100	MCL	0.880	ND	1.30	ND	--	ND	--	ND
	Copper	1300	MCL	14.7	6.60	6.50	7.10	--	9.70	--	9.20
	Lead	15	MCL	0.940	0.220	ND	0.200	--	0.340	--	0.330
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	ND	2.30	ND	0.460	--	ND	--	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	--	ND	--	0.0660
	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	--	--	--	--	--
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	--	--	--	--	--
	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	--	--	--	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location Type:							
				H2-BALS5221	H2-CROS6507							
				Residence	Residence							
				Address:	Address:							
				5221 Balsa Lane	6507 Crossandra Street							
				Field Sample ID:	H2-TW-0013575-23335-A	H2-TW-0011883-23335-A	H2-TW-0011883-23335-A-P	H2-TW-0011883-23335-A-R1	H2-TW-0011883-23335-A-R1-P	H2-TW-0011883-23335-A-1	H2-TW-0011883-23335-A-1-P	H2-TW-0011883-23335-A-2
				Sample Date:	2024-03-05	2024-02-12	2024-02-12	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	--	--	--	--	--
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	--	--	--	--	--
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	--	--	--	--	--
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--	--
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	--	--	--	--	--
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	--	--	--	--	--
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	--	--	--	--	--
	Benzene	5	MCL	ND	ND	ND	--	--	--	--	--	--
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--	--	--	--	--	--
	Chlorobenzene	100	MCL	ND	ND	ND	--	--	--	--	--	--
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	--	--	--	--	--
	Ethylbenzene	700	MCL	ND	ND	ND	--	--	--	--	--	--
	m,p-Xylene	--	--	ND	ND	ND	--	--	--	--	--	--
	Methylene chloride	5	MCL	ND	ND	ND	--	--	--	--	--	--
	o-Xylene	--	--	ND	ND	ND	--	--	--	--	--	--
	Styrene	100	MCL	ND	ND	ND	--	--	--	--	--	--
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	--	--	--	--	--
	Toluene	1000	MCL	ND	ND	ND	--	--	--	--	--	--
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	--	--	--	--	--
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	--	--	--	--	--
	Vinyl chloride	2	MCL	ND	ND	ND	--	--	--	--	--	--
	Xylenes, Total	10000	MCL	ND	ND	ND	--	--	--	--	--	--
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	--	--	--	--	--	--
	Chloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--	--

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	Location Type:							
				H2-BALS5221	H2-CROS6507				H2-CROS6507			
				Residence	Residence							
				Address:	Address:							
				5221 Balsa Lane	6507 Crossandra Street							
				Field Sample ID:	H2-TW-0011883-23335-A	H2-TW-0011883-23335-A	H2-TW-0011883-23335-A-P	H2-TW-0011883-23335-A-R1	H2-TW-0011883-23335-A-R1-P	H2-TW-0011883-23335-A-1	H2-TW-0011883-23335-A-1-P	H2-TW-0011883-23335-A-2
				Sample Date:	2024-03-05	2024-02-12	2024-02-12	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	ND	ND	0.770	--	--	--	--	--	--
	Dichloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--	--
	Trichloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--	--
	Total Haloacetic acids	60	MCL	ND	ND	0.770	--	--	--	--	--	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	--	--	--	--	--	--
	Bromoform	--	--	0.380	ND	ND	--	--	--	--	--	--
	Chloroform	--	--	ND	ND	ND	--	--	--	--	--	--
	Dibromochloromethane	--	--	0.400	ND	ND	--	--	--	--	--	--
	Total Trihalomethanes	80	MCL	0.780	ND	ND	--	--	--	--	--	--

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

				H2-CROS6507							H2-CROS6518
				Residence							Residence
				6507 Crossandra Street							6518 Crossandra Street
				H2-TW-0011883-23335-A-2-P	H2-TW-0011883-23335-A-3	H2-TW-0011883-23335-A-3-P	H2-TW-0011883-23335-A-4	H2-TW-0011883-23335-A-4-P	H2-TW-0011883-23335-A-5	H2-TW-0011883-23335-A-5-P	H2-TW-0013468-23335-A
				2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-01-30
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	800-970	800-970	800-970	800-970	800-970	800-970	800-970	720
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	--	--	--	--	--	--	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	--	--	--	--	--	--	ND
	Petroleum Hydrocarbons (as Oil)	--	--	--	--	--	--	--	--	--	ND
	Petroleum Hydrocarbons, Total	266	ISP	--	--	--	--	--	--	--	ND
Metals (ppb)	Antimony	6	MCL	--	ND	--	ND	--	ND	--	ND
	Arsenic	10	MCL	--	ND	--	ND	--	ND	--	ND
	Barium	2000	MCL	--	1.30	--	1.40	--	1.40	--	1.40
	Beryllium	4	MCL	--	ND	--	ND	--	ND	--	ND
	Cadmium	5	MCL	--	ND	--	ND	--	ND	--	ND
	Chromium	100	MCL	--	ND	--	ND	--	ND	--	ND
	Copper	1300	MCL	--	7.40	--	9.50	--	15.0	--	8.70
	Lead	15	MCL	--	0.280	--	0.600	--	1.30	--	0.190
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	--	ND	--	ND	--	0.450	--	0.410
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	--	ND	--	ND	--	ND	--	ND
	1-Methylnaphthalene	10	EAL	--	--	--	--	--	--	--	ND
	2-Methylnaphthalene	10	EAL	--	--	--	--	--	--	--	ND
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	--	--	--	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	--	--	--	--	--	--	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	--	--	--	--	--	--	--	ND
	1,1,1-Trichloroethane	--	--	--	--	--	--	--	--	--	ND
	1,1,2-Trichloroethane	5	MCL	--	--	--	--	--	--	--	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-CROS6507							H2-CROS6518	
		Location Type:	Residence							Residence	
		Address:	6507 Crossandra Street							6518 Crossandra Street	
		Field Sample ID:	H2-TW-0011883-23335-A-2-P	H2-TW-0011883-23335-A-3	H2-TW-0011883-23335-A-3-P	H2-TW-0011883-23335-A-4	H2-TW-0011883-23335-A-4-P	H2-TW-0011883-23335-A-5	H2-TW-0011883-23335-A-5-P	H2-TW-0013468-23335-A	
		Sample Date:	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-01-30	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	--	--	--	--	--	--	ND	
	1,2,4-Trichlorobenzene	70	MCL	--	--	--	--	--	--	ND	
	1,2-Dichlorobenzene	600	MCL	--	--	--	--	--	--	ND	
	1,2-Dichloroethane	5	MCL	--	--	--	--	--	--	ND	
	1,2-Dichloroethene (Total)	70	MCL	--	--	--	--	--	--	ND	
	1,2-Dichloropropane	5	MCL	--	--	--	--	--	--	ND	
	1,4-Dichlorobenzene	75	MCL	--	--	--	--	--	--	ND	
	Benzene	5	MCL	--	--	--	--	--	--	ND	
	Carbon Tetrachloride	5	MCL	--	--	--	--	--	--	ND	
	Chlorobenzene	100	MCL	--	--	--	--	--	--	ND	
	cis-1,2-Dichloroethene	70	MCL	--	--	--	--	--	--	ND	
	Ethylbenzene	700	MCL	--	--	--	--	--	--	ND	
	m,p-Xylene	--	--	--	--	--	--	--	--	--	ND
	Methylene chloride	5	MCL	--	--	--	--	--	--	--	ND
	o-Xylene	--	--	--	--	--	--	--	--	--	ND
	Styrene	100	MCL	--	--	--	--	--	--	--	ND
	Tetrachloroethene (PCE)	5	MCL	--	--	--	--	--	--	--	ND
	Toluene	1000	MCL	--	--	--	--	--	--	--	ND
	trans-1,2-Dichloroethene	100	MCL	--	--	--	--	--	--	--	ND
	Trichloroethene (TCE)	5	MCL	--	--	--	--	--	--	--	ND
Vinyl chloride	2	MCL	--	--	--	--	--	--	--	ND	
Xylenes, Total	10000	MCL	--	--	--	--	--	--	--	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	--	--	--	--	--	--	ND	
	Chloroacetic acid	--	--	--	--	--	--	--	--	ND	

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-CROS6507							H2-CROS6518
		Location Type:	Residence							Residence
		Address:	6507 Crossandra Street							6518 Crossandra Street
		Field Sample ID:	H2-TW-0011883-23335-A-2-P	H2-TW-0011883-23335-A-3	H2-TW-0011883-23335-A-3-P	H2-TW-0011883-23335-A-4	H2-TW-0011883-23335-A-4-P	H2-TW-0011883-23335-A-5	H2-TW-0011883-23335-A-5-P	H2-TW-0013468-23335-A
		Sample Date:	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-02-26	2024-01-30
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	--	--	--	--	--	--	ND
	Dichloroacetic acid	--	--	--	--	--	--	--	--	ND
	Trichloroacetic acid	--	--	--	--	--	--	--	--	ND
	Total Haloacetic acids	60	MCL	--	--	--	--	--	--	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	--	--	--	ND
	Bromoform	--	--	--	--	--	--	--	--	0.380
	Chloroform	--	--	--	--	--	--	--	--	ND
	Dibromochloromethane	--	--	--	--	--	--	--	--	0.370
	Total Trihalomethanes	80	MCL	--	--	--	--	--	--	0.750

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-CROS6518	H2-CROS6536	H2-CROS6542	H2-CROS6558		H2-KOBA4457	H2-KOBA4471	H2-MAHO5420
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	6518 Crossandra Street	6536 Crossandra Street	6542 Crossandra Street	6558 Crossandra Street		4457 Kobashigawa Street	4471 Kobashigawa Street	5420 Mahogany Lane
				Field Sample ID:	H2-TW-0013468-23335-A-P	H2-TW-0013473-23335-A	H2-TW-0013475-23335-A	H2-TW-0013480-23335-A	H2-TW-0013480-23335-3-A	H2-TW-0013483-23335-A	H2-TW-0013487-23335-A	H2-TW-0013591-23335-A
				Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	720	850	680	670	670	750	820	640	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	1.40	1.40	1.50	1.50	1.40	2.00	2.00	1.30	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	1.30	ND	ND	ND	ND	ND	ND	ND	
	Copper	1300	MCL	7.30	13.5	8.50	10.2	9.80	9.60	13.3	11.2	
	Lead	15	MCL	ND	0.300	0.240	0.300	0.310	0.230	0.560	1.30	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	0.620	0.840	0.560	0.450	1.00	1.00	0.960	
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	0.0660	ND	
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	1.40	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-CROS6518	H2-CROS6536	H2-CROS6542	H2-CROS6558		H2-KOBA4457	H2-KOBA4471	H2-MAHO5420
				Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
				Address:	6518 Crossandra Street	6536 Crossandra Street	6542 Crossandra Street	6558 Crossandra Street		4457 Kobashigawa Street	4471 Kobashigawa Street	5420 Mahogany Lane
				Field Sample ID:	H2-TW-0013468-23335-A-P	H2-TW-0013473-23335-A	H2-TW-0013475-23335-A	H2-TW-0013480-23335-A	H2-TW-0013480-23335-3-A	H2-TW-0013483-23335-A	H2-TW-0013487-23335-A	H2-TW-0013591-23335-A
				Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-CROS6518	H2-CROS6536	H2-CROS6542	H2-CROS6558		H2-KOBA4457	H2-KOBA4471	H2-MAHO5420
		Location Type:	Residence	Residence	Residence	Residence		Residence	Residence	Residence
		Address:	6518 Crossandra Street	6536 Crossandra Street	6542 Crossandra Street	6558 Crossandra Street		4457 Kobashigawa Street	4471 Kobashigawa Street	5420 Mahogany Lane
		Field Sample ID:	H2-TW-0013468-23335-A-P	H2-TW-0013473-23335-A	H2-TW-0013475-23335-A	H2-TW-0013480-23335-A	H2-TW-0013480-23335-3-A	H2-TW-0013483-23335-A	H2-TW-0013487-23335-A	H2-TW-0013591-23335-A
		Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	0.790	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	0.790	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.310	ND	ND	ND
	Bromoform	--	--	ND	0.280	ND	1.00	0.410	0.390	0.330
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	0.280	0.260	0.890	0.360	ND	ND
	Total Trihalomethanes	80	MCL	ND	0.560	0.260	2.20	0.770	0.390	0.330

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-MAHO5480		H2-MORI6812	H2-MORI6830	H2-NAUP6211	H2-NAUP6248	H2-NAUP6250	H2-NAUP6260	
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence	
		Address:	5480 Mahogany Lane		6812 Morishige Lane	6830 Morishige Lane	6211 Naupaka Street	6248 Naupaka Street	6250 Naupaka Street	6260 Naupaka Street	
		Field Sample ID:	H2-TW-0013605-23335-A	H2-TW-0013605-23335-A-P	H2-TW-0011898-23335-A	H2-TW-0013619-23335-A	H2-TW-0013498-23335-A	H2-TW-0013515-23335-A	H2-TW-0013516-23335-A	H2-TW-0013519-23335-A	
		Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-03-05	
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	690	690	680	790	610	800	750	590
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Barium	2000	MCL	1.30	1.30	1.50	1.50	1.40	1.50	1.50	1.40
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Chromium	100	MCL	ND	1.40	ND	ND	ND	ND	ND	0.740
	Copper	1300	MCL	10.6	9.70	9.30	13.3	12.7	10.0	9.30	11.6
	Lead	15	MCL	1.10	0.890	0.650	1.10	0.230	0.220	0.260	0.270
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Selenium	50	MCL	0.750	ND	0.460	0.710	0.770	0.560	0.430	ND
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	0.0700	ND	ND	ND	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-MAHO5480		H2-MORI6812	H2-MORI6830	H2-NAUP6211	H2-NAUP6248	H2-NAUP6250	H2-NAUP6260
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5480 Mahogany Lane		6812 Morishige Lane	6830 Morishige Lane	6211 Naupaka Street	6248 Naupaka Street	6250 Naupaka Street	6260 Naupaka Street
		Field Sample ID:	H2-TW-0013605-23335-A	H2-TW-0013605-23335-A-P	H2-TW-0011898-23335-A	H2-TW-0013619-23335-A	H2-TW-0013498-23335-A	H2-TW-0013515-23335-A	H2-TW-0013516-23335-A	H2-TW-0013519-23335-A
		Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-03-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	ND
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	0.610	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:	H2-MAHO5480		H2-MORI6812	H2-MORI6830	H2-NAUP6211	H2-NAUP6248	H2-NAUP6250	H2-NAUP6260
		Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	Residence
		Address:	5480 Mahogany Lane		6812 Morishige Lane	6830 Morishige Lane	6211 Naupaka Street	6248 Naupaka Street	6250 Naupaka Street	6260 Naupaka Street
		Field Sample ID:	H2-TW-0013605-23335-A	H2-TW-0013605-23335-A-P	H2-TW-0011898-23335-A	H2-TW-0013619-23335-A	H2-TW-0013498-23335-A	H2-TW-0013515-23335-A	H2-TW-0013516-23335-A	H2-TW-0013519-23335-A
		Sample Date:	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-01-30	2024-03-05
		Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	0.610	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	0.330	ND	ND	ND
	Bromoform	--	--	ND	ND	0.340	0.910	0.250	0.400	0.340
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	ND	ND	0.300	0.900	ND	0.370	0.360
	Total Trihalomethanes	80	MCL	ND	ND	0.640	2.14	0.250	0.770	0.700

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:		H2-NAUP6260		H2-NIML6322		H2-NIUS6620		H2-NIUS6635		H2-PLUM6627		H2-PLUM6629	
		Location Type:		Residence		Residence		Residence		Residence		Residence		Residence	
		Address:		6260 Naupaka Street		6322 Nim Lane		6620 Niu Street		6635 Niu Street		6627 Plumeria Loop		6629 Plumeria Loop	
		Field Sample ID:		H2-TW-0013519-23335-3-A		H2-TW-0013525-23335-A		H2-TW-0013525-23335-A-P		H2-TW-0013531-23335-A		H2-TW-0013533-23335-A		H2-TW-0013628-23335-A	
		Sample Date:		2024-03-05		2024-02-05		2024-02-05		2024-01-30		2024-01-30		2024-01-30	
		Sample Type:		FD (Field Duplicate)		N (Normal)		N (Normal)		N (Normal)		N (Normal)		N (Normal)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level												
Field Test (ppb)	Free Chlorine	4000	MCL	590	630	630	700	680	700	650	650				
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND				
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	ND				
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	ND				
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Barium	2000	MCL	1.70	1.50	1.50	1.30	1.40	1.70	1.60	1.60				
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Chromium	100	MCL	0.820	ND	1.90	ND	ND	ND	0.740	0.760				
	Copper	1300	MCL	11.0	14.5	14.7	13.1	24.0	9.60	9.50	9.60				
	Lead	15	MCL	0.670	0.350	0.320	0.400	0.440	0.800	0.580	0.560				
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Selenium	50	MCL	ND	0.660	1.10	0.780	0.610	0.400	ND	ND				
Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND					
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND				
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	ND				
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	ND				
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND				
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND				
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	ND				

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-NIML6322		H2-NIUS6620	H2-NIUS6635	H2-PLUM6627	H2-PLUM6629		
				Location Type:	Residence		Residence	Residence	Residence	Residence		
				Address:	6322 Nim Lane		6620 Niu Street	6635 Niu Street	6627 Plumeria Loop	6629 Plumeria Loop		
				Field Sample ID:	H2-TW-0013519-23335-3-A	H2-TW-0013525-23335-A	H2-TW-0013525-23335-A-P	H2-TW-0013531-23335-A	H2-TW-0013533-23335-A	H2-TW-0013628-23335-A	H2-TW-0013629-23335-A	H2-TW-0013629-23335-3-A
				Sample Date:	2024-03-05	2024-02-05	2024-02-05	2024-01-30	2024-01-30	2024-01-30	2024-03-05	2024-03-05
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Volatile Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	0.270	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND	ND	0.270	ND	
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Chloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Dibromoacetic acid	--	--	ND	ND	0.610	ND	ND	ND	ND	ND	ND
	Dichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID:	H2-NIML6322		H2-NIUS6620	H2-NIUS6635	H2-PLUM6627	H2-PLUM6629		
				Location Type:	Residence		Residence	Residence	Residence	Residence	Residence	
				Address:	6322 Nim Lane		6620 Niu Street	6635 Niu Street	6627 Plumeria Loop	6629 Plumeria Loop		
				Field Sample ID:	H2-TW-0013519-23335-3-A	H2-TW-0013525-23335-A	H2-TW-0013525-23335-A-P	H2-TW-0013531-23335-A	H2-TW-0013533-23335-A	H2-TW-0013628-23335-A	H2-TW-0013629-23335-A	H2-TW-0013629-23335-3-A
				Sample Date:	2024-03-05	2024-02-05	2024-02-05	2024-01-30	2024-01-30	2024-01-30	2024-03-05	2024-03-05
				Sample Type:	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND	0.610	ND	ND	ND	ND	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Bromoform	--	--	0.670	0.380	ND	0.250	0.580	0.430	0.420	0.380	
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Dibromochloromethane	--	--	0.530	0.360	ND	ND	0.480	0.320	0.310	0.270	
	Total Trihalomethanes	80	MCL	1.20	0.740	ND	0.250	1.06	0.750	0.730	0.650	

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-PLUM6642				Location ID: H2-PLUM6653			
				860	460	460	690-800	690-800	690-800	690-800	690-800
				Location Type: Residence				Location Type: Residence			
				Address: 6642 Plumeria Loop				Address: 6653 Plumeria Loop			
				Field Sample ID: H2-TW-0013635-23335-A	H2-TW-0013639-23335-A	H2-TW-0013639-23335-A-P	H2-TW-0013639-23335-A-R1	H2-TW-0013639-23335-A-R1-P	H2-TW-0013639-23335-A-1	H2-TW-0013639-23335-A-1-P	H2-TW-0013639-23335-A-2
				Sample Date: 2024-03-05	2024-02-12	2024-02-12	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15
				Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	860	460	460	690-800	690-800	690-800	690-800	690-800
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	--	--	--	--	--
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	--	--	--	--	--
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	--	--	--	--	--
	Arsenic	10	MCL	ND	ND	ND	--	--	--	--	--
	Barium	2000	MCL	1.40	1.60	1.50	--	--	--	--	--
	Beryllium	4	MCL	ND	ND	ND	--	--	--	--	--
	Cadmium	5	MCL	ND	ND	ND	--	--	--	--	--
	Chromium	100	MCL	0.730	ND	1.40	--	--	--	--	--
	Copper	1300	MCL	11.6	6.10	5.30	--	--	--	--	--
	Lead	15	MCL	0.280	0.550	0.400	--	--	--	--	--
	Mercury	2	MCL	ND	ND	ND	--	--	--	--	--
	Selenium	50	MCL	ND	0.880	0.850	--	--	--	--	--
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND	ND	--	--	--	--	--
	1-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--	--
	2-Methylnaphthalene	10	EAL	ND	ND	ND	--	--	--	--	--
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	--	--	--	--	--
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	--	--	--	--	--
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND	ND	--	--	--	--	--
	1,1,1-Trichloroethane	--	--	ND	ND	ND	--	--	--	--	--
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--
	1,1-Dichloroethene	7	MCL	ND	ND	ND	--	--	--	--	--

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-PLUM6642				Location ID: H2-PLUM6653						
				Field Sample ID	Sample Date	Sample Type	DOH Project Screening Level	Basis of Project Screening Level	Field Sample ID	Sample Date	Sample Type	DOH Project Screening Level	Basis of Project Screening Level	
				Residence				Residence						
				6642 Plumeria Loop				6653 Plumeria Loop						
				H2-TW-0013635-23335-A	H2-TW-0013639-23335-A	H2-TW-0013639-23335-A-P	H2-TW-0013639-23335-A-R1	H2-TW-0013639-23335-A-R1-P	H2-TW-0013639-23335-A-1	H2-TW-0013639-23335-A-1-P	H2-TW-0013639-23335-A-2			
				2024-03-05	2024-02-12	2024-02-12	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15			
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)			
Volatil Organic Compounds (ppb)	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	--	--	--	--	--			
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	--	--	--	--	--			
	1,2-Dichloroethane	5	MCL	ND	ND	ND	--	--	--	--	--			
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	--	--	--	--	--			
	1,2-Dichloropropane	5	MCL	ND	ND	ND	--	--	--	--	--			
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	--	--	--	--	--			
	Benzene	5	MCL	ND	ND	ND	--	--	--	--	--			
	Carbon Tetrachloride	5	MCL	ND	ND	ND	--	--	--	--	--			
	Chlorobenzene	100	MCL	ND	ND	ND	--	--	--	--	--			
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	--	--	--	--	--			
	Ethylbenzene	700	MCL	ND	ND	ND	--	--	--	--	--			
	m,p-Xylene	--	--	ND	ND	ND	--	--	--	--	--			
	Methylene chloride	5	MCL	ND	ND	ND	--	--	--	--	--			
	o-Xylene	--	--	ND	ND	ND	--	--	--	--	--			
	Styrene	100	MCL	ND	ND	ND	--	--	--	--	--			
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	--	--	--	--	--			
	Toluene	1000	MCL	ND	ND	ND	--	--	--	--	--			
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	--	--	--	--	--			
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	--	--	--	--	--			
	Vinyl chloride	2	MCL	ND	ND	ND	--	--	--	--	--			
	Xylenes, Total	10000	MCL	ND	ND	ND	--	--	--	--	--			
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	--	--	--	--	--			
	Chloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--			
	Dibromoacetic acid	--	--	ND	ND	0.740	--	--	--	--	--			
	Dichloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--			

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-PLUM6642		Location ID: H2-PLUM6653		Location ID: H2-PLUM6653		Location ID: H2-PLUM6653	
				Residence	Residence	Residence	Residence	Residence	Residence	Residence	Residence
				Address: 6642 Plumeria Loop	Address: 6653 Plumeria Loop		Address: 6653 Plumeria Loop		Address: 6653 Plumeria Loop		
				Field Sample ID: H2-TW-0013635-23335-A	H2-TW-0013639-23335-A	H2-TW-0013639-23335-A-P	H2-TW-0013639-23335-A-R1	H2-TW-0013639-23335-A-R1-P	H2-TW-0013639-23335-A-1	H2-TW-0013639-23335-A-1-P	H2-TW-0013639-23335-A-2
				Sample Date: 2024-03-05	2024-02-12	2024-02-12	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15
				Sample Type: N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND	ND	--	--	--	--	--
	Total Haloacetic acids	60	MCL	ND	ND	0.740	--	--	--	--	--
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND	ND	--	--	--	--	--
	Bromoform	--	--	0.330	ND	ND	--	--	--	--	--
	Chloroform	--	--	ND	ND	ND	--	--	--	--	--
	Dibromochloromethane	--	--	0.330	ND	ND	--	--	--	--	--
	Total Trihalomethanes	80	MCL	0.660	ND	ND	--	--	--	--	--

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-PLUM6653					Location ID: H2-SAND5110		Location ID: H2-SAND5142
				Location Type: Residence					Location Type: Residence		Location Type: Residence
				Address: 6653 Plumeria Loop					Address: 5110 Sandalwood Lane		Address: 5142 Sandalwood Lane
				Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:	Field Sample ID:
				H2-TW-0013639-23335-A-2-P	H2-TW-0013639-23335-A-3	H2-TW-0013639-23335-A-3-P	H2-TW-0013639-23335-A-4	H2-TW-0013639-23335-A-4-P	H2-TW-0013650-23335-A	H2-TW-0013650-23335-A-P	H2-TW-0013654-23335-A
				Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:	Sample Date:
				2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-01-05	2024-01-05	2024-01-30
				Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:	Sample Type:
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	690-800	690-800	690-800	690-800	690-800	490	490	620
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	--	--	--	--	--	104	74.0	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	--	--	--	--	--	ND	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	--	--	--	--	--	68.4	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	--	--	--	--	--	172	74.0	ND
Metals (ppb)	Antimony	6	MCL	--	--	--	--	--	ND	ND	ND
	Arsenic	10	MCL	--	--	--	--	--	0.550	ND	ND
	Barium	2000	MCL	--	--	--	--	--	1.40	1.40	1.40
	Beryllium	4	MCL	--	--	--	--	--	ND	ND	ND
	Cadmium	5	MCL	--	--	--	--	--	ND	ND	ND
	Chromium	100	MCL	--	--	--	--	--	1.20	1.60	ND
	Copper	1300	MCL	--	--	--	--	--	20.7	16.2	11.1
	Lead	15	MCL	--	--	--	--	--	1.20	1.00	0.850
	Mercury	2	MCL	--	--	--	--	--	ND	ND	ND
	Selenium	50	MCL	--	--	--	--	--	3.30	ND	0.670
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	--	--	--	--	--	ND	ND	ND
	1-Methylnaphthalene	10	EAL	--	--	--	--	--	ND	ND	ND
	2-Methylnaphthalene	10	EAL	--	--	--	--	--	ND	ND	ND
	Benzo(a)pyrene	0.2	MCL	--	--	--	--	--	ND	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	--	--	--	--	--	ND	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	--	--	--	--	--	ND	ND	ND
	1,1,1-Trichloroethane	--	--	--	--	--	--	--	ND	ND	ND
	1,1,2-Trichloroethane	5	MCL	--	--	--	--	--	ND	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	Location ID: H2-PLUM6653					Location ID: H2-SAND5110		Location ID: H2-SAND5142	
				Location Type: Residence					Location Type: Residence		Location Type: Residence	
				Address: 6653 Plumeria Loop					Address: 5110 Sandalwood Lane		Address: 5142 Sandalwood Lane	
				Field Sample ID:	H2-TW-0013639-23335-A-2-P	H2-TW-0013639-23335-A-3	H2-TW-0013639-23335-A-3-P	H2-TW-0013639-23335-A-4	H2-TW-0013639-23335-A-4-P	H2-TW-0013650-23335-A	H2-TW-0013650-23335-A-P	H2-TW-0013654-23335-A
				Sample Date:	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-01-05	2024-01-05	2024-01-30
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Volatile Organic Compounds (ppb)	1,1-Dichloroethene	7	MCL	--	--	--	--	--	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	--	--	--	--	--	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	--	--	--	--	--	ND	ND	ND	
	1,2-Dichloroethane	5	MCL	--	--	--	--	--	ND	ND	ND	
	1,2-Dichloroethene (Total)	70	MCL	--	--	--	--	--	ND	ND	ND	
	1,2-Dichloropropane	5	MCL	--	--	--	--	--	ND	ND	ND	
	1,4-Dichlorobenzene	75	MCL	--	--	--	--	--	ND	ND	ND	
	Benzene	5	MCL	--	--	--	--	--	ND	ND	ND	
	Carbon Tetrachloride	5	MCL	--	--	--	--	--	ND	ND	ND	
	Chlorobenzene	100	MCL	--	--	--	--	--	ND	ND	ND	
	cis-1,2-Dichloroethene	70	MCL	--	--	--	--	--	ND	ND	ND	
	Ethylbenzene	700	MCL	--	--	--	--	--	ND	ND	ND	
	m,p-Xylene	--	--	--	--	--	--	--	ND	ND	ND	
	Methylene chloride	5	MCL	--	--	--	--	--	ND	ND	ND	
	o-Xylene	--	--	--	--	--	--	--	ND	ND	ND	
	Styrene	100	MCL	--	--	--	--	--	ND	ND	ND	
	Tetrachloroethene (PCE)	5	MCL	--	--	--	--	--	ND	ND	ND	
	Toluene	1000	MCL	--	--	--	--	--	ND	ND	ND	
	trans-1,2-Dichloroethene	100	MCL	--	--	--	--	--	ND	ND	ND	
Trichloroethene (TCE)	5	MCL	--	--	--	--	--	ND	ND	ND		
Vinyl chloride	2	MCL	--	--	--	--	--	ND	ND	ND		
Xylenes, Total	10000	MCL	--	--	--	--	--	ND	ND	ND		
Haloacetic Acids (ppb)	Bromoacetic acid	--	--	--	--	--	--	--	ND	ND	ND	
	Chloroacetic acid	--	--	--	--	--	--	--	ND	ND	ND	

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		H2-PLUM6653					H2-SAND5110		H2-SAND5142
		Residence					Residence		Residence
		6653 Plumeria Loop					5110 Sandalwood Lane		5142 Sandalwood Lane
		H2-TW-0013639-23335-A-2-P	H2-TW-0013639-23335-A-3	H2-TW-0013639-23335-A-3-P	H2-TW-0013639-23335-A-4	H2-TW-0013639-23335-A-4-P	H2-TW-0013650-23335-A	H2-TW-0013650-23335-A-P	H2-TW-0013654-23335-A
		2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-03-15	2024-01-05	2024-01-05	2024-01-30
		N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Haloacetic Acids (ppb)	Dibromoacetic acid	--	--	--	--	--	ND	1.10	ND
	Dichloroacetic acid	--	--	--	--	--	ND	ND	ND
	Trichloroacetic acid	--	--	--	--	--	ND	ND	ND
	Total Haloacetic acids	60	MCL	--	--	--	ND	1.10	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	--	--	--	ND	ND	ND
	Bromoform	--	--	--	--	--	0.500	ND	0.260
	Chloroform	--	--	--	--	--	ND	ND	ND
	Dibromochloromethane	--	--	--	--	--	0.400	ND	ND
	Total Trihalomethanes	80	MCL	--	--	--	0.900	ND	0.260

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	H2-SKYV0481	H2-VITE6417
				Location ID: H2-SKYV0481	H2-VITE6417
				Location Type: Residence	Residence
				Address: 481 Skyview Loop	6417 Vitex Lane
				Field Sample ID: H2-TW-0013660-23335-A	H2-TW-0013570-23335-A
				Sample Date: 2024-01-30	2024-01-30
				Sample Type: N (Normal)	N (Normal)
Field Test (ppb)	Free Chlorine	4000	MCL	710	680
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND
Metals (ppb)	Antimony	6	MCL	ND	ND
	Arsenic	10	MCL	ND	ND
	Barium	2000	MCL	1.40	1.30
	Beryllium	4	MCL	ND	ND
	Cadmium	5	MCL	ND	ND
	Chromium	100	MCL	ND	ND
	Copper	1300	MCL	7.00	12.0
	Lead	15	MCL	0.440	0.230
	Mercury	2	MCL	ND	ND
	Selenium	50	MCL	0.350	0.660
Synthetic Organic Compounds (ppb)	Thallium	2	MCL	ND	ND
	1-Methylnaphthalene	10	EAL	ND	ND
	2-Methylnaphthalene	10	EAL	ND	ND
	Benzo(a)pyrene	0.2	MCL	ND	ND
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND
Volatile Organic Compounds (ppb)	Naphthalene	17	EAL	ND	ND
	1,1,1-Trichloroethane	--	--	ND	ND
	1,1,2-Trichloroethane	5	MCL	ND	ND
	1,1-Dichloroethene	7	MCL	ND	ND

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Residences in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level	H2-SKYV0481	H2-VITE6417
Haloacetic Acids (ppb)	Trichloroacetic acid	--	--	ND	ND
	Total Haloacetic acids	60	MCL	ND	ND
Trihalomethanes (ppb)	Bromodichloromethane	--	--	ND	ND
	Bromoform	--	--	ND	ND
	Chloroform	--	--	ND	ND
	Dibromochloromethane	--	--	ND	ND
	Total Trihalomethanes	80	MCL	ND	ND

Location ID:	H2-SKYV0481	H2-VITE6417
Location Type:	Residence	Residence
Address:	481 Skyview Loop	6417 Vitex Lane
Field Sample ID:	H2-TW-0013660-23335-A	H2-TW-0013570-23335-A
Sample Date:	2024-01-30	2024-01-30
Sample Type:	N (Normal)	N (Normal)

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID:			H2-HYD0377A			H2-HYD1331A		H2-HYD1646A	
		Location Type:			Hydrant			Hydrant		Hydrant	
		Address:			Hydrant 377			Hydrant 1331		Hydrant 1646	
		Field Sample ID:			H2-DL-0017757-23335 -A	H2-DL-0017757-23335 -A-P	H2-DL-0017757-23335 -3-A-P	H2-DL-0017758-23335 -A	H2-DL-0000688-23335 -A	H2-DL-0000688-23335 -A-P	H2-DL-0000688-23335 -3-A-P
		Sample Date:			2024-03-05	2024-03-05	2024-03-05	2024-03-08	2024-03-08	2024-03-08	2024-03-08
		Sample Type:			N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level								
Field Test (ppb)	Free Chlorine	4000	MCL	530	530	530	640	630	630	630	
General Chemistry (ppb)	Total Organic Carbon	2000	ISP	ND	ND	ND	ND	ND	ND	ND	
Hydrocarbons (ppb)	Petroleum Hydrocarbons (as Diesel)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Gasoline)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons (as Oil)	--	--	ND	ND	ND	ND	ND	ND	ND	
	Petroleum Hydrocarbons, Total	266	ISP	ND	ND	ND	ND	ND	ND	ND	
Metals (ppb)	Antimony	6	MCL	ND	ND	ND	ND	ND	ND	ND	
	Arsenic	10	MCL	ND	ND	ND	ND	ND	ND	ND	
	Barium	2000	MCL	1.90	2.00	1.90	2.50	2.10	2.00	2.00	
	Beryllium	4	MCL	ND	ND	ND	ND	ND	ND	ND	
	Cadmium	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	Chromium	100	MCL	0.770	1.60	1.70	0.860	0.760	1.50	1.50	
	Mercury	2	MCL	ND	ND	ND	ND	ND	ND	ND	
	Selenium	50	MCL	ND	ND	ND	0.400	0.750	1.00	1.00	
	Thallium	2	MCL	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppb)	1-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	
	2-Methylnaphthalene	10	EAL	ND	ND	ND	ND	ND	ND	ND	
	Benzo(a)pyrene	0.2	MCL	ND	ND	ND	ND	ND	ND	ND	
	Bis(2-ethylhexyl)phthalate	6	MCL	ND	ND	ND	ND	ND	ND	ND	
	Naphthalene	17	EAL	ND	ND	ND	ND	ND	ND	ND	
Volatile Organic Compounds (ppb)	1,1,1-Trichloroethane	--	--	ND	ND	ND	ND	ND	ND	ND	
	1,1,2-Trichloroethane	5	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,1-Dichloroethene	7	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2,4-Trichlorobenzene	70	MCL	ND	ND	ND	ND	ND	ND	ND	
	1,2-Dichlorobenzene	600	MCL	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: H2-HYD0377A			H2-HYD1331A		H2-HYD1646A		
		Location Type: Hydrant			Hydrant		Hydrant		
		Address: Hydrant 377			Hydrant 1331		Hydrant 1646		
		Field Sample ID: H2-DL-0017757-23335-A	H2-DL-0017757-23335-A-P	H2-DL-0017757-23335-3-A-P	H2-DL-0017758-23335-A	H2-DL-0000688-23335-A	H2-DL-0000688-23335-A-P	H2-DL-0000688-23335-3-A-P	
		Sample Date: 2024-03-05	2024-03-05	2024-03-05	2024-03-08	2024-03-08	2024-03-08	2024-03-08	
		Sample Type: N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level						
Volatile Organic Compounds (ppb)	1,2-Dichloroethane	5	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloroethene (Total)	70	MCL	ND	ND	ND	ND	ND	ND
	1,2-Dichloropropane	5	MCL	ND	ND	ND	ND	ND	ND
	1,4-Dichlorobenzene	75	MCL	ND	ND	ND	ND	ND	ND
	Benzene	5	MCL	ND	ND	ND	ND	ND	ND
	Carbon Tetrachloride	5	MCL	ND	ND	ND	ND	ND	ND
	Chlorobenzene	100	MCL	ND	ND	ND	ND	ND	ND
	cis-1,2-Dichloroethene	70	MCL	ND	ND	ND	ND	ND	ND
	Ethylbenzene	700	MCL	ND	ND	ND	ND	ND	ND
	m,p-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Methylene chloride	5	MCL	ND	ND	ND	ND	ND	ND
	o-Xylene	--	--	ND	ND	ND	ND	ND	ND
	Styrene	100	MCL	ND	ND	ND	ND	ND	ND
	Tetrachloroethene (PCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Toluene	1000	MCL	ND	ND	ND	ND	ND	ND
	trans-1,2-Dichloroethene	100	MCL	ND	ND	ND	ND	ND	ND
	Trichloroethene (TCE)	5	MCL	ND	ND	ND	ND	ND	ND
	Vinyl chloride	2	MCL	ND	ND	ND	ND	ND	ND
	Xylenes, Total	10000	MCL	ND	ND	ND	ND	ND	ND
	Haloacetic Acids (ppb)	Bromoacetic acid	--	--	ND	ND	ND	ND	ND
Chloroacetic acid		--	--	ND	ND	ND	ND	ND	ND
Dibromoacetic acid		--	--	0.900	1.10	1.10	ND	ND	0.530
Dichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND
Trichloroacetic acid		--	--	ND	ND	ND	ND	ND	ND
Total Haloacetic acids		60	MCL	0.900	1.10	1.10	ND	ND	0.530

Summary of Chemistry Results
Zone H2 Long Term Monitoring
Drinking Water Sampling, Joint Base Pearl Harbor - Hickam, Oahu, Hawaii

Drinking Water Samples Collected in January - March 2024 from Hydrants in Zone H2

Notes:
ND = Not Detected
ISP = Incident Specific Parameter
EAL = DOH Environmental Action Level
EPA MCL = EPA Maximum Contaminant Level
All Results shown in Parts per Billion (ppb)
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample

		Location ID: H2-HYD0377A			H2-HYD1331A		H2-HYD1646A			
		Location Type: Hydrant			Hydrant		Hydrant			
		Address: Hydrant 377			Hydrant 1331		Hydrant 1646			
		Field Sample ID:	H2-DL-0017757-23335 -A	H2-DL-0017757-23335 -A-P	H2-DL-0017757-23335 -3-A-P	H2-DL-0017758-23335 -A	H2-DL-0000688-23335 -A	H2-DL-0000688-23335 -A-P	H2-DL-0000688-23335 -3-A-P	
		Sample Date:	2024-03-05	2024-03-05	2024-03-05	2024-03-08	2024-03-08	2024-03-08	2024-03-08	
		Sample Type:	N (Normal)	N (Normal)	FD (Field Duplicate)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	
Method Group	Analyte	DOH Project Screening Level	Basis of Project Screening Level							
Trihalomethanes (ppb)	Bromodichloromethane	--	--	0.730	ND	ND	0.270	ND	ND	ND
	Bromoform	--	--	1.70	1.70	1.60	0.610	0.380	ND	ND
	Chloroform	--	--	ND	ND	ND	ND	ND	ND	ND
	Dibromochloromethane	--	--	1.70	1.80	1.70	0.700	ND	ND	ND
	Total Trihalomethanes	80	MCL	4.13	3.50	3.30	1.58	0.380	ND	ND