

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	HDMW2253-03							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-HDMW225303-WGN01B-2212W2	AF-HDMW225303-WGN01LF-2212W3	AF-HDMW225303-WGN01LF-2212W4	AF-HDMW225303-WGN01LF-2301W1	AF-HDMW225303-WGN01LF-2301W2	AF-HDMW225303-WGN01LF-2301W3	AF-HDMW225303-WGN01LF-2301W4	AF-HDMW225303-WGN01LF-2301W5
				Sample Date:	2022-12-12	2022-12-20	2022-12-27	2023-01-03	2023-01-10	2023-01-17	2023-01-24	2023-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	7.10	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-HDMW225303-WGN01B-2212W2	AF-HDMW225303-WGN01LF-2212W3	AF-HDMW225303-WGN01LF-2212W4	AF-HDMW225303-WGN01LF-2301W1	AF-HDMW225303-WGN01LF-2301W2	AF-HDMW225303-WGN01LF-2301W3	AF-HDMW225303-WGN01LF-2301W4	AF-HDMW225303-WGN01LF-2301W5
				Sample Date:	2022-12-12	2022-12-20	2022-12-27	2023-01-03	2023-01-10	2023-01-17	2023-01-24	2023-01-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.650	ND	ND	0.0340	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	0.530	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	1.70	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-HDMW225303-WGN01LF-2302W1	AF-HDMW225303-WGN01LF-2302W2	AF-HDMW225303-WGN01LF-2302W3	AF-HDMW225303-WGN01LF-2302W4	AF-HDMW225303-WGN01LF-2303W1	AF-HDMW225303-WGN01LF-2303W2	AF-HDMW225303-WGN01LF-2303W3	AF-HDMW225303-WGN01LF-2303W4
				Sample Date:	2023-02-07	2023-02-14	2023-02-21	2023-02-28	2023-03-07	2023-03-14	2023-03-21	2023-03-28
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-HDMW225303-WGN01LF-2302W1	AF-HDMW225303-WGN01LF-2302W2	AF-HDMW225303-WGN01LF-2302W3	AF-HDMW225303-WGN01LF-2302W4	AF-HDMW225303-WGN01LF-2303W1	AF-HDMW225303-WGN01LF-2303W2	AF-HDMW225303-WGN01LF-2303W3	AF-HDMW225303-WGN01LF-2303W4
				Sample Date:	2023-02-07	2023-02-14	2023-02-21	2023-02-28	2023-03-07	2023-03-14	2023-03-21	2023-03-28
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	0.0590	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	0.460	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	HDMW2253-03							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-HDMW225303-WGN01LF-2304W1	AF-HDMW225303-WGN01LF-2304W2	AF-HDMW225303-WGN01LF-2304W3	AF-HDMW225303-WGN01LF-2304W4	AF-HDMW225303-WGN01LF-2305W1	AF-HDMW225303-WGN01LF-2305W2	AF-HDMW225303-WGN01LF-2305W3	AF-HDMW225303-WGN01LF-2305W4	
				2023-04-04	2023-04-11	2023-04-18	2023-04-25	2023-05-02	2023-05-09	2023-05-16	2023-05-23	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-HDMW225303-WGN01LF-2304W1	AF-HDMW225303-WGN01LF-2304W2	AF-HDMW225303-WGN01LF-2304W3	AF-HDMW225303-WGN01LF-2304W4	AF-HDMW225303-WGN01LF-2305W1	AF-HDMW225303-WGN01LF-2305W2	AF-HDMW225303-WGN01LF-2305W3	AF-HDMW225303-WGN01LF-2305W4
				Sample Date:	2023-04-04	2023-04-11	2023-04-18	2023-04-25	2023-05-02	2023-05-09	2023-05-16	2023-05-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.0970	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.0370	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	0.0880	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	0.660	ND	1.10	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	1.30	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-HDMW225303-WGN01LF-2305W5	AF-HDMW225303-WGN01LF-2306	AF-HDMW225303-WGN01LF-2307	AF-HDMW225303-WGN01LF-2308	AF-HDMW225303-WGN01LF-2309	AF-HDMW225303-WGN01LF-2310	AF-HDMW225303-WGN01LF-2311	AF-HDMW225303-WGN01LF-2312
				Sample Date:	2023-05-30	2023-06-06	2023-07-11	2023-08-11	2023-09-05	2023-10-03	2023-11-07	2023-12-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				HDMW2253-03 Monitoring Well							
				AF-HDMW225303- WGN01LF-2305W5	AF-HDMW225303- WGN01LF-2306	AF-HDMW225303- WGN01LF-2307	AF-HDMW225303- WGN01LF-2308	AF-HDMW225303- WGN01LF-2309	AF-HDMW225303- WGN01LF-2310	AF-HDMW225303- WGN01LF-2311	AF-HDMW225303- WGN01LF-2312
				2023-05-30	2023-06-06	2023-07-11	2023-08-11	2023-09-05	2023-10-03	2023-11-07	2023-12-08
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGFD01LF-2305W1	AF-RHMW02-WGFD01LF-2305W2	AF-RHMW02-WGFD01LF-2307	AF-RHMW02-WGFD01LF-2308	AF-RHMW02-WGFD01LF-2309	AF-RHMW02-WGFD01LF-2310	AF-RHMW02-WGFD01LF-2311	AF-RHMW02-WGFD01LF-2312	
				2023-05-05	2023-05-11	2023-07-05	2023-08-03	2023-09-07	2023-10-06	2023-11-07	2023-12-08	
				FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	4.30	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW02-WGFD01LF-2305W1	AF-RHMW02-WGFD01LF-2305W2	AF-RHMW02-WGFD01LF-2307	AF-RHMW02-WGFD01LF-2308	AF-RHMW02-WGFD01LF-2309	AF-RHMW02-WGFD01LF-2310	AF-RHMW02-WGFD01LF-2311	AF-RHMW02-WGFD01LF-2312
				Sample Date:	2023-05-05	2023-05-11	2023-07-05	2023-08-03	2023-09-07	2023-10-06	2023-11-07	2023-12-08
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	53.4	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.710	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	0.570	ND	ND	ND	ND	0.830	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	1.10	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	0.690	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	36.8	ND	49.0	45.4	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW02-WGN01LF-2212W1	AF-RHMW02-WGN01LF-2212W2	AF-RHMW02-WGN01LF-2212W3	AF-RHMW02-WGN01LF-2212W4	AF-RHMW02-WGN01LF-2301W1	AF-RHMW02-WGN01LF-2301W2	AF-RHMW02-WGN01LF-2301W3	AF-RHMW02-WGN01LF-2301W4
				Sample Date:	2022-12-05	2022-12-12	2022-12-19	2022-12-27	2023-01-05	2023-01-09	2023-01-16	2023-01-23
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	2.10	2.10	10.0	4.10	8.00	ND	ND	ND	3.60
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2212W1	AF-RHMW02-WGN01LF-2212W2	AF-RHMW02-WGN01LF-2212W3	AF-RHMW02-WGN01LF-2212W4	AF-RHMW02-WGN01LF-2301W1	AF-RHMW02-WGN01LF-2301W2	AF-RHMW02-WGN01LF-2301W3	AF-RHMW02-WGN01LF-2301W4	
				2022-12-05	2022-12-12	2022-12-19	2022-12-27	2023-01-05	2023-01-09	2023-01-16	2023-01-23	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.160	0.200	ND	0.240	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	0.0360	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	0.160	0.210	0.240	0.230	0.500	ND	0.600	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	0.130	ND	ND	ND	0.210	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	0.920	0.480	1.40	ND	0.720	ND	5.50	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2301W5	AF-RHMW02-WGN01LF-2302W1	AF-RHMW02-WGN01LF-2302W2	AF-RHMW02-WGN01LF-2302W3	AF-RHMW02-WGN01LF-2302W4	AF-RHMW02-WGN01LF-2303W1	AF-RHMW02-WGN01LF-2303W2	AF-RHMW02-WGN01LF-2303W3	
				2023-01-30	2023-02-06	2023-02-16	2023-02-23	2023-03-02	2023-03-09	2023-03-16	2023-03-23	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	3.80	5.80	5.30	4.30	3.60	6.80	18.2	21.0	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	--	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	--	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2301W5	AF-RHMW02-WGN01LF-2302W1	AF-RHMW02-WGN01LF-2302W2	AF-RHMW02-WGN01LF-2302W3	AF-RHMW02-WGN01LF-2302W4	AF-RHMW02-WGN01LF-2303W1	AF-RHMW02-WGN01LF-2303W2	AF-RHMW02-WGN01LF-2303W3	
				2023-01-30	2023-02-06	2023-02-16	2023-02-23	2023-03-02	2023-03-09	2023-03-16	2023-03-23	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.220	ND	0.440	ND	0.270	0.600	0.620	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	0.280	ND	0.370	ND	0.350	0.520	0.710	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	0.0620	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	1.20	ND	2.50	ND	1.00	7.00	0.650	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2303W4	AF-RHMW02-WGN01LF-2304W1	AF-RHMW02-WGN01LF-2304W2	AF-RHMW02-WGN01LF-2304W3	AF-RHMW02-WGN01LF-2304W4	AF-RHMW02-WGN01LF-2305W1	AF-RHMW02-WGN01LF-2305W2	AF-RHMW02-WGN01LF-2305W3	
				2023-03-30	2023-04-06	2023-04-12	2023-04-17	2023-04-27	2023-05-05	2023-05-11	2023-05-18	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	6.10	6.40	ND	5.50	5.50	ND	ND	6.10	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2303W4	AF-RHMW02-WGN01LF-2304W1	AF-RHMW02-WGN01LF-2304W2	AF-RHMW02-WGN01LF-2304W3	AF-RHMW02-WGN01LF-2304W4	AF-RHMW02-WGN01LF-2305W1	AF-RHMW02-WGN01LF-2305W2	AF-RHMW02-WGN01LF-2305W3	
				2023-03-30	2023-04-06	2023-04-12	2023-04-17	2023-04-27	2023-05-05	2023-05-11	2023-05-18	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	20.0	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.280	ND	1.10	0.560	0.560	ND	0.690	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	1.30	0.340	ND	1.70	ND	ND	ND	1.00	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	0.110	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	0.590	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	1.40	ND	2.70	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	1.30	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2305W4	AF-RHMW02-WGN01LF-2305W5	AF-RHMW02-WGN01LF-2306	AF-RHMW02-WGN01LF-2307	AF-RHMW02-WGN01LF-2308	AF-RHMW02-WGN01LF-2309	AF-RHMW02-WGN01LF-2310	AF-RHMW02-WGN01LF-2311	
				2023-05-26	2023-06-01	2023-06-09	2023-07-05	2023-08-03	2023-09-07	2023-10-06	2023-11-07	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	5.00	ND	ND	ND	ND	4.20	3.80	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW02-WGN01LF-2305W4	AF-RHMW02-WGN01LF-2305W5	AF-RHMW02-WGN01LF-2306	AF-RHMW02-WGN01LF-2307	AF-RHMW02-WGN01LF-2308	AF-RHMW02-WGN01LF-2309	AF-RHMW02-WGN01LF-2310	AF-RHMW02-WGN01LF-2311	
				2023-05-26	2023-06-01	2023-06-09	2023-07-05	2023-08-03	2023-09-07	2023-10-06	2023-11-07	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	66.5	37.9	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.860	0.640	ND	ND	ND	0.520	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	0.950	1.20	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	0.950	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	51.5	34.7	60.9	ND	53.9	36.1	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03				RHMW03								
				Location Type:	AF-RHMW03-WGN01LF-2212W1	AF-RHMW03-WGN01LF-2212W2	AF-RHMW03-WGN01LF-2212W3	AF-RHMW03-WGN01LF-2212W4	AF-RHMW03-WGN01LF-2301W1	AF-RHMW03-WGN01LF-2301W2	AF-RHMW03-WGN01LF-2301W3						
				Field Sample ID:	Sample Date:	Sample Type:											
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	RHMW02 Monitoring Well AF-RHMW02-WGN01LF-2312 2023-12-08 N (Normal)	2022-12-05 N (Normal)	2022-12-12 N (Normal)	2022-12-19 N (Normal)	2022-12-27 N (Normal)	2023-01-05 N (Normal)	2023-01-09 N (Normal)	2023-01-16 N (Normal)	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	8.00	5.20	3.60	2.50	3.70	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW02			RHMW03																						
				Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:																
				RHMW02	Monitoring Well	AF-RHMW02-WGN01LF-2312	2023-12-08	N (Normal)	AF-RHMW03-WGN01LF-2212W1	2022-12-05	N (Normal)	AF-RHMW03-WGN01LF-2212W2	2022-12-12	N (Normal)	AF-RHMW03-WGN01LF-2212W3	2022-12-19	N (Normal)	AF-RHMW03-WGN01LF-2212W4	2022-12-27	N (Normal)	AF-RHMW03-WGN01LF-2301W1	2023-01-05	N (Normal)	AF-RHMW03-WGN01LF-2301W2	2023-01-09	N (Normal)	AF-RHMW03-WGN01LF-2301W3	2023-01-16	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	2.10	2.80	2.90	1.00	1.60	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	0.160	0.120	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	0.120	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.790	0.870	1.10	0.650	0.820	0.800	0.810	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	0.0390	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	1.20	1.50	1.40	0.770	1.40	1.30	1.50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	0.170	0.170	0.170	0.100	0.110	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	0.0690	ND	ND	ND	0.370	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.250	0.300	0.320	0.230	0.270	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	3.10	3.80	3.70	1.50	2.50	2.10	2.20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	0.150	0.180	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW03-WGN01LF-2301W4	AF-RHMW03-WGN01LF-2301W5	AF-RHMW03-WGN01LF-2302W1	AF-RHMW03-WGN01LF-2302W2	AF-RHMW03-WGN01LF-2302W3	AF-RHMW03-WGN01LF-2302W4	AF-RHMW03-WGN01LF-2303W1	AF-RHMW03-WGN01LF-2303W2
				Sample Date:	2023-01-23	2023-01-30	2023-02-06	2023-02-16	2023-02-23	2023-03-02	2023-03-09	2023-03-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	8.30	6.90	27.0	16.3	20.0	6.70	9.90	6.50	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03								
				Location Type:	Monitoring Well								
				Field Sample ID:	AF-RHMW03-WGN01LF-2301W4	AF-RHMW03-WGN01LF-2301W5	AF-RHMW03-WGN01LF-2302W1	AF-RHMW03-WGN01LF-2302W2	AF-RHMW03-WGN01LF-2302W3	AF-RHMW03-WGN01LF-2302W4	AF-RHMW03-WGN01LF-2303W1	AF-RHMW03-WGN01LF-2303W2	AF-RHMW03-WGN01LF-2303W3
				Sample Date:	2023-01-23	2023-01-30	2023-02-06	2023-02-16	2023-02-23	2023-03-02	2023-03-09	2023-03-16	2023-03-16
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	2.20	ND	1.60	ND	1.60	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	0.130	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	1.70	1.80	1.50	1.30	1.60	1.40	1.40	1.40	0.950	0.950
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	2.40	ND	2.20	2.70	1.80	2.00	1.80	1.80	1.40	1.40
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	0.0880	ND	0.0930	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	0.130	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	0.550	ND	0.250	0.580	0.330	0.330	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	5.40	3.60	4.30	3.40	3.10	3.40	3.50	3.50	2.40	2.40
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	RHMW03 Monitoring Well									
				Location ID: Location Type: Field Sample ID: Sample Date: Sample Type:	AF-RHMW03- WGN01LF-2303W3 2023-03-23 N (Normal)	AF-RHMW03- WGN01LF-2303W4 2023-03-30 N (Normal)	AF-RHMW03- WGN01LF-2304W1 2023-04-06 N (Normal)	AF-RHMW03- WGN01LF-2304W2 2023-04-12 N (Normal)	AF-RHMW03- WGN01LF-2304W3 2023-04-17 N (Normal)	AF-RHMW03- WGN01LF-2304W4 2023-04-27 N (Normal)	AF-RHMW03- WGN01LF-2305W1 2023-05-05 N (Normal)	AF-RHMW03- WGN01LF-2305W2 2023-05-11 N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	15.0	10.4	11.0	10.1	ND	15.2	5.30	8.80		
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW03-WGN01LF-2303W3	AF-RHMW03-WGN01LF-2303W4	AF-RHMW03-WGN01LF-2304W1	AF-RHMW03-WGN01LF-2304W2	AF-RHMW03-WGN01LF-2304W3	AF-RHMW03-WGN01LF-2304W4	AF-RHMW03-WGN01LF-2305W1	AF-RHMW03-WGN01LF-2305W2
				Sample Date:	2023-03-23	2023-03-30	2023-04-06	2023-04-12	2023-04-17	2023-04-27	2023-05-05	2023-05-11
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	1.60	ND	1.20	ND	ND	ND	ND	1.80	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	0.150	ND	0.150	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	1.50	1.10	1.30	1.50	0.890	1.60	1.60	1.70	1.70
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.110	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.80	1.20	1.60	1.60	2.00	1.50	2.00	2.00	2.50
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	0.140	ND	0.110	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	1.20	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	0.180	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	0.280	ND	0.310	ND	ND	0.500	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	2.50	2.60	2.20	2.40	ND	2.70	3.30	3.60	3.60
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW03-WGN01LF-2305W3	AF-RHMW03-WGN01LF-2305W4	AF-RHMW03-WGN01LF-2305W5	AF-RHMW03-WGN01LF-2306	AF-RHMW03-WGN01LF-2307	AF-RHMW03-WGN01LF-2308	AF-RHMW03-WGN01LF-2309	AF-RHMW03-WGN01LF-2310	
				2023-05-18	2023-05-26	2023-06-01	2023-06-09	2023-07-05	2023-08-03	2023-09-07	2023-10-06	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	7.60	7.00	8.70	6.60	4.70	ND	25.6	6.70	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW03-WGN01LF-2305W3	AF-RHMW03-WGN01LF-2305W4	AF-RHMW03-WGN01LF-2305W5	AF-RHMW03-WGN01LF-2306	AF-RHMW03-WGN01LF-2307	AF-RHMW03-WGN01LF-2308	AF-RHMW03-WGN01LF-2309	AF-RHMW03-WGN01LF-2310
				Sample Date:	2023-05-18	2023-05-26	2023-06-01	2023-06-09	2023-07-05	2023-08-03	2023-09-07	2023-10-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	0.890	1.10
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	1.90	1.80	1.50	1.40	1.50	ND	2.60	2.00	2.00
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	2.10	2.60	2.00	ND	1.40	ND	5.90	3.60	3.60
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	0.910	0.520
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	3.60	4.30	5.20	3.30	2.90	2.10	4.40	3.40	3.40
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	1.30	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03		RHMW04					
				Location Type:	Monitoring Well		Monitoring Well					
				Field Sample ID:	AF-RHMW03-WGN01LF-2311	AF-RHMW03-WGN01LF-2312	AF-RHMW04-WGN01B-2212W2	AF-RHMW04-WGN01LF-2212W1	AF-RHMW04-WGN01LF-2212W3	AF-RHMW04-WGN01LF-2212W4	AF-RHMW04-WGN01LF-2301W1	AF-RHMW04-WGN01LF-2301W2
				Sample Date:	2023-11-10	2023-12-08	2022-12-15	2022-12-07	2022-12-22	2022-12-29	2023-01-04	2023-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	7.20	4.30	9.60	6.90	0.300	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW03		RHMW04					
				Location Type:	Monitoring Well		Monitoring Well					
				Field Sample ID:	AF-RHMW03-WGN01LF-2311	AF-RHMW03-WGN01LF-2312	AF-RHMW04-WGN01B-2212W2	AF-RHMW04-WGN01LF-2212W1	AF-RHMW04-WGN01LF-2212W3	AF-RHMW04-WGN01LF-2212W4	AF-RHMW04-WGN01LF-2301W1	AF-RHMW04-WGN01LF-2301W2
				Sample Date:	2023-11-10	2023-12-08	2022-12-15	2022-12-07	2022-12-22	2022-12-29	2023-01-04	2023-01-12
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	2.20	0.620	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.920	1.70	0.450	0.250	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	2.60	0.460	0.330	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	1.30	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	0.140	0.160	ND	0.200	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	2.70	1.10	0.720	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW04-WGN01LF-2301W3	AF-RHMW04-WGN01LF-2301W4	AF-RHMW04-WGN01LF-2301W5	AF-RHMW04-WGN01LF-2302W1	AF-RHMW04-WGN01LF-2302W2	AF-RHMW04-WGN01LF-2302W3	AF-RHMW04-WGN01LF-2302W4	AF-RHMW04-WGN01LF-2303W1	
				2023-01-19	2023-01-26	2023-02-02	2023-02-09	2023-02-13	2023-02-20	2023-02-27	2023-03-06	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	0.930	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW04-WGN01LF-2301W3	AF-RHMW04-WGN01LF-2301W4	AF-RHMW04-WGN01LF-2301W5	AF-RHMW04-WGN01LF-2302W1	AF-RHMW04-WGN01LF-2302W2	AF-RHMW04-WGN01LF-2302W3	AF-RHMW04-WGN01LF-2302W4	AF-RHMW04-WGN01LF-2303W1
				Sample Date:	2023-01-19	2023-01-26	2023-02-02	2023-02-09	2023-02-13	2023-02-20	2023-02-27	2023-03-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	0.0530	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	0.290	ND	0.0620	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW04-WGN01LF-2303W2	AF-RHMW04-WGN01LF-2303W3	AF-RHMW04-WGN01LF-2303W4	AF-RHMW04-WGN01LF-2304W1	AF-RHMW04-WGN01LF-2304W2	AF-RHMW04-WGN01LF-2304W3	AF-RHMW04-WGN01LF-2304W4	AF-RHMW04-WGN01LF-2305W1	
				2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-14	2023-04-19	2023-04-24	2023-05-01	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW04-WGN01LF-2303W2	AF-RHMW04-WGN01LF-2303W3	AF-RHMW04-WGN01LF-2303W4	AF-RHMW04-WGN01LF-2304W1	AF-RHMW04-WGN01LF-2304W2	AF-RHMW04-WGN01LF-2304W3	AF-RHMW04-WGN01LF-2304W4	AF-RHMW04-WGN01LF-2305W1
				Sample Date:	2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-14	2023-04-19	2023-04-24	2023-05-01
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW04-WGN01LF-2305W2	AF-RHMW04-WGN01LF-2305W3	AF-RHMW04-WGN01LF-2305W4	AF-RHMW04-WGN01LF-2305W5	AF-RHMW04-WGN01LF-2306	AF-RHMW04-WGN01LF-2307	AF-RHMW04-WGN01LF-2308	AF-RHMW04-WGN01LF-2309
				Sample Date:	2023-05-08	2023-05-15	2023-05-22	2023-05-31	2023-06-05	2023-07-05	2023-08-04	2023-09-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	8.50	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW04 Monitoring Well							
				AF-RHMW04- WGN01LF-2305W2	AF-RHMW04- WGN01LF-2305W3	AF-RHMW04- WGN01LF-2305W4	AF-RHMW04- WGN01LF-2305W5	AF-RHMW04- WGN01LF-2306	AF-RHMW04- WGN01LF-2307	AF-RHMW04- WGN01LF-2308	AF-RHMW04- WGN01LF-2309
				2023-05-08	2023-05-15	2023-05-22	2023-05-31	2023-06-05	2023-07-05	2023-08-04	2023-09-08
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04			RHMW06				
				Location Type:	Monitoring Well			Monitoring Well				
				Field Sample ID:	AF-RHMW04-WGN01LF-2310	AF-RHMW04-WGN01LF-2311	AF-RHMW04-WGN01LF-2312	AF-RHMW06-WGN01B-2212W1	AF-RHMW06-WGN01B-2212W2	AF-RHMW06-WGN01LF-2212W3	AF-RHMW06-WGN01LF-2212W4	AF-RHMW06-WGN01LF-2301W1
				Sample Date:	2023-10-06	2023-11-07	2023-12-05	2022-12-08	2022-12-14	2022-12-22	2022-12-29	2023-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	1.60	2.10	0.910	0.600	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW04			RHMW06				
				Location Type:	Monitoring Well			Monitoring Well				
				Field Sample ID:	AF-RHMW04-WGN01LF-2310	AF-RHMW04-WGN01LF-2311	AF-RHMW04-WGN01LF-2312	AF-RHMW06-WGN01B-2212W1	AF-RHMW06-WGN01B-2212W2	AF-RHMW06-WGN01LF-2212W3	AF-RHMW06-WGN01LF-2212W4	AF-RHMW06-WGN01LF-2301W1
				Sample Date:	2023-10-06	2023-11-07	2023-12-05	2022-12-08	2022-12-14	2022-12-22	2022-12-29	2023-01-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	1.00	1.00	0.790	ND	0.290	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	0.110	0.170	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	0.160	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	1.00	4.90	1.20	0.540	0.640	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	0.670	0.730	0.450	0.200	0.310	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	0.230	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	0.860	ND	ND	0.530	0.200	0.680	ND	0.250	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	0.180	0.410	0.150	0.130	0.140	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	1.90	2.00	1.10	0.320	0.490	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	0.230	0.420	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW06-WGN01LF-2301W2	AF-RHMW06-WGN01LF-2301W3	AF-RHMW06-WGN01LF-2301W4	AF-RHMW06-WGN01LF-2301W5	AF-RHMW06-WGN01LF-2302W1	AF-RHMW06-WGN01LF-2302W2	AF-RHMW06-WGN01LF-2302W3	AF-RHMW06-WGN01LF-2302W4	
				2023-01-12	2023-01-19	2023-01-26	2023-02-02	2023-02-09	2023-02-13	2023-02-20	2023-02-27	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	1.20	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW06-WGN01LF-2301W2	AF-RHMW06-WGN01LF-2301W3	AF-RHMW06-WGN01LF-2301W4	AF-RHMW06-WGN01LF-2301W5	AF-RHMW06-WGN01LF-2302W1	AF-RHMW06-WGN01LF-2302W2	AF-RHMW06-WGN01LF-2302W3	AF-RHMW06-WGN01LF-2302W4	
				2023-01-12	2023-01-19	2023-01-26	2023-02-02	2023-02-09	2023-02-13	2023-02-20	2023-02-27	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	0.350	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	1.30	ND	0.280	ND	0.450	0.650	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	0.440	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	0.260	ND	0.700	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW06-WGN01LF-2303W1	AF-RHMW06-WGN01LF-2303W2	AF-RHMW06-WGN01LF-2303W3	AF-RHMW06-WGN01LF-2303W4	AF-RHMW06-WGN01LF-2304W1	AF-RHMW06-WGN01LF-2304W2	AF-RHMW06-WGN01LF-2304W3	AF-RHMW06-WGN01LF-2304W4
				Sample Date:	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-14	2023-04-19	2023-04-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	1.30	ND	ND	ND	ND	1.70	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW06 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-RHMW06-WGN01LF-2303W1	AF-RHMW06-WGN01LF-2303W2	AF-RHMW06-WGN01LF-2303W3	AF-RHMW06-WGN01LF-2303W4	AF-RHMW06-WGN01LF-2304W1	AF-RHMW06-WGN01LF-2304W2	AF-RHMW06-WGN01LF-2304W3	AF-RHMW06-WGN01LF-2304W4
				Sample Date:	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-14	2023-04-19	2023-04-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	0.0890	ND	0.0530	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	0.410	ND	0.380	ND	0.320	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.840	ND	0.370	ND	0.410	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	0.450	ND	0.310	ND	0.400	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	0.100	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	0.980	ND	0.530	ND	0.890	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW06-WGN01LF-2305W1	AF-RHMW06-WGN01LF-2305W2	AF-RHMW06-WGN01LF-2305W3	AF-RHMW06-WGN01LF-2305W4	AF-RHMW06-WGN01LF-2305W5	AF-RHMW06-WGN01LF-2306	AF-RHMW06-WGN01LF-2307	AF-RHMW06-WGN01LF-2308	
				2023-05-01	2023-05-08	2023-05-15	2023-05-22	2023-05-31	2023-06-05	2023-07-05	2023-08-04	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW06-WGN01LF-2305W1	AF-RHMW06-WGN01LF-2305W2	AF-RHMW06-WGN01LF-2305W3	AF-RHMW06-WGN01LF-2305W4	AF-RHMW06-WGN01LF-2305W5	AF-RHMW06-WGN01LF-2306	AF-RHMW06-WGN01LF-2307	AF-RHMW06-WGN01LF-2308	
				2023-05-01	2023-05-08	2023-05-15	2023-05-22	2023-05-31	2023-06-05	2023-07-05	2023-08-04	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06				RHMW10			
				Location Type:	Monitoring Well				Monitoring Well			
				Field Sample ID:	AF-RHMW06-WGN01LF-2309	AF-RHMW06-WGN01LF-2310	AF-RHMW06-WGN01LF-2311	AF-RHMW06-WGN01LF-2312	AF-RHMW10-WGFD01LF-2212W4	AF-RHMW10-WGFD01LF-2301W1	AF-RHMW10-WGFD01LF-2302W1	AF-RHMW10-WGFD01LF-2304W1
				Sample Date:	2023-09-08	2023-10-06	2023-11-07	2023-12-05	2022-12-27	2023-01-03	2023-02-07	2023-04-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	0.600	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW06				RHMW10			
				Location Type:	Monitoring Well				Monitoring Well			
				Field Sample ID:	AF-RHMW06-WGN01LF-2309	AF-RHMW06-WGN01LF-2310	AF-RHMW06-WGN01LF-2311	AF-RHMW06-WGN01LF-2312	AF-RHMW10-WGFD01LF-2212W4	AF-RHMW10-WGFD01LF-2301W1	AF-RHMW10-WGFD01LF-2302W1	AF-RHMW10-WGFD01LF-2304W1
				Sample Date:	2023-09-08	2023-10-06	2023-11-07	2023-12-05	2022-12-27	2023-01-03	2023-02-07	2023-04-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	0.0630	0.220	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	0.0960	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW10-WGN01B-2212W1	AF-RHMW10-WGN01B-2212W2	AF-RHMW10-WGN01LF-2212W3	AF-RHMW10-WGN01LF-2212W4	AF-RHMW10-WGN01LF-2301W1	AF-RHMW10-WGN01LF-2301W2	AF-RHMW10-WGN01LF-2301W3	AF-RHMW10-WGN01LF-2301W4
				Sample Date:	2022-12-11	2022-12-15	2022-12-20	2022-12-27	2023-01-03	2023-01-10	2023-01-17	2023-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	0.530	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	33.0	130	ND	ND	0.350	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	0.310	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	0.530	0.300	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	0.110	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW10-WGN01B-2212W1	AF-RHMW10-WGN01B-2212W2	AF-RHMW10-WGN01LF-2212W3	AF-RHMW10-WGN01LF-2212W4	AF-RHMW10-WGN01LF-2301W1	AF-RHMW10-WGN01LF-2301W2	AF-RHMW10-WGN01LF-2301W3	AF-RHMW10-WGN01LF-2301W4
				Sample Date:	2022-12-11	2022-12-15	2022-12-20	2022-12-27	2023-01-03	2023-01-10	2023-01-17	2023-01-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.110	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	48.0	36.0	0.530	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	0.790	0.310	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	0.470	0.200	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	2.90	2.00	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.0680	ND	ND	0.0430	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	5.60	7.10	ND	0.0580	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	2.20	0.680	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	0.100	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	0.410	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	1.60	0.750	ND	0.130	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	43.0	30.0	0.130	0.0970	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	0.450	0.480	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	0.990	0.580	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW10-WGN01LF-2301W5	AF-RHMW10-WGN01LF-2302W1	AF-RHMW10-WGN01LF-2302W2	AF-RHMW10-WGN01LF-2302W3	AF-RHMW10-WGN01LF-2302W4	AF-RHMW10-WGN01LF-2303W1	AF-RHMW10-WGN01LF-2303W2	AF-RHMW10-WGN01LF-2303W3	
				2023-02-01	2023-02-07	2023-02-14	2023-02-21	2023-02-28	2023-03-07	2023-03-14	2023-03-21	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW10-WGN01LF-2301W5	AF-RHMW10-WGN01LF-2302W1	AF-RHMW10-WGN01LF-2302W2	AF-RHMW10-WGN01LF-2302W3	AF-RHMW10-WGN01LF-2302W4	AF-RHMW10-WGN01LF-2303W1	AF-RHMW10-WGN01LF-2303W2	AF-RHMW10-WGN01LF-2303W3
				Sample Date:	2023-02-01	2023-02-07	2023-02-14	2023-02-21	2023-02-28	2023-03-07	2023-03-14	2023-03-21
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	0.0420	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	0.110
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	0.0740	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW10-WGN01LF-2303W4	AF-RHMW10-WGN01LF-2304W1	AF-RHMW10-WGN01LF-2304W2	AF-RHMW10-WGN01LF-2304W3	AF-RHMW10-WGN01LF-2304W4	AF-RHMW10-WGN01LF-2305W1	AF-RHMW10-WGN01LF-2305W2	AF-RHMW10-WGN01LF-2305W3	
				2023-03-28	2023-04-04	2023-04-11	2023-04-18	2023-04-25	2023-05-02	2023-05-09	2023-05-16	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW10-WGN01LF-2303W4	AF-RHMW10-WGN01LF-2304W1	AF-RHMW10-WGN01LF-2304W2	AF-RHMW10-WGN01LF-2304W3	AF-RHMW10-WGN01LF-2304W4	AF-RHMW10-WGN01LF-2305W1	AF-RHMW10-WGN01LF-2305W2	AF-RHMW10-WGN01LF-2305W3	
				2023-03-28	2023-04-04	2023-04-11	2023-04-18	2023-04-25	2023-05-02	2023-05-09	2023-05-16	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	0.660	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	1.60	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW10-WGN01LF-2305W4	AF-RHMW10-WGN01LF-2305W5	AF-RHMW10-WGN01LF-2306	AF-RHMW10-WGN01LF-2307	AF-RHMW10-WGN01LF-2308	AF-RHMW10-WGN01LF-2309	AF-RHMW10-WGN01LF-2310	AF-RHMW10-WGN01LF-2311	
				2023-05-23	2023-05-30	2023-06-05	2023-07-05	2023-08-01	2023-09-05	2023-10-05	2023-11-10	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW10							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW10-WGN01LF-2305W4	AF-RHMW10-WGN01LF-2305W5	AF-RHMW10-WGN01LF-2306	AF-RHMW10-WGN01LF-2307	AF-RHMW10-WGN01LF-2308	AF-RHMW10-WGN01LF-2309	AF-RHMW10-WGN01LF-2310	AF-RHMW10-WGN01LF-2311	
				2023-05-23	2023-05-30	2023-06-05	2023-07-05	2023-08-01	2023-09-05	2023-10-05	2023-11-10	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Monitoring Well	Monitoring Well	Monitoring Well	Monitoring Well
				RHMW10	AF-RHMW12A-WGN01LF-2312	AF-RHMW12A-WGFD01LF-2212W3	AF-RHMW12A-WGFD01LF-2301W1	AF-RHMW12A-WGFD01LF-2301W2	AF-RHMW12A-WGFD01LF-2301W3	AF-RHMW12A-WGFD01LF-2301W5	AF-RHMW12A-WGFD01LF-2302W1	AF-RHMW12A-WGFD01LF-2302W2
				Monitoring Well	2023-12-05	2022-12-21	2023-01-04	2023-01-10	2023-01-17	2023-01-30	2023-02-08	2023-02-14
				N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Monitoring Well	Monitoring Well	Monitoring Well	Monitoring Well
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	4.00	0.510	0.580	ND	ND	ND	1.80	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				RHMW10	Monitoring Well				Monitoring Well			
				Location Type:	AF-RHMW12A- WGN01LF-2312	AF-RHMW12A- WGFD01LF-2212W3	AF-RHMW12A- WGFD01LF-2301W1	AF-RHMW12A- WGFD01LF-2301W2	AF-RHMW12A- WGFD01LF-2301W3	AF-RHMW12A- WGFD01LF-2301W5	AF-RHMW12A- WGFD01LF-2302W1	AF-RHMW12A- WGFD01LF-2302W2
				Field Sample ID:	2023-12-05	2022-12-21	2023-01-04	2023-01-10	2023-01-17	2023-01-30	2023-02-08	2023-02-14
				Sample Date:	N (Normal)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
				Sample Type:								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	2.50	2.40	ND	ND	ND	1.70	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.250	0.300	ND	ND	ND	0.440	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	1.40	1.40	1.30	1.10	1.20	1.40	1.60	1.60
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	0.280	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	0.160	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	5.00	5.30	4.60	4.10	4.80	4.70	5.30	5.30
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGFD01LF-2302W3	AF-RHMW12A-WGFD01LF-2302W4	AF-RHMW12A-WGFD01LF-2303W1	AF-RHMW12A-WGFD01LF-2303W2	AF-RHMW12A-WGFD01LF-2303W3	AF-RHMW12A-WGFD01LF-2303W4	AF-RHMW12A-WGFD01LF-2304W1	AF-RHMW12A-WGFD01LF-2304W2
				Sample Date:	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-13
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	1.50	ND	0.800	ND	1.70	ND	1.40	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGFD01LF-2302W3	AF-RHMW12A-WGFD01LF-2302W4	AF-RHMW12A-WGFD01LF-2303W1	AF-RHMW12A-WGFD01LF-2303W2	AF-RHMW12A-WGFD01LF-2303W3	AF-RHMW12A-WGFD01LF-2303W4	AF-RHMW12A-WGFD01LF-2304W1	AF-RHMW12A-WGFD01LF-2304W2
				Sample Date:	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03	2023-04-13
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	1.70	ND	1.50	ND	1.30	ND	1.30	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.350	ND	0.470	ND	0.350	ND	0.320	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.50	1.40	1.50	1.20	1.30	1.20	1.40	1.30	1.30
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	0.480	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	0.130	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	5.10	5.00	4.70	3.70	4.70	4.30	4.60	4.50	4.50
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGFD01LF-2304W3	AF-RHMW12A-WGFD01LF-2304W4	AF-RHMW12A-WGFD01LF-2305W1	AF-RHMW12A-WGFD01LF-2305W2	AF-RHMW12A-WGFD01LF-2305W3	AF-RHMW12A-WGFD01LF-2305W4	AF-RHMW12A-WGFD01LF-2305W5	AF-RHMW12A-WGFD01LF-2306
				Sample Date:	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	2023-05-31	2023-06-06
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	RHMW12A Monitoring Well																																				
				Location ID:	Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:																										
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	AF-RHMW12A-WGFD01LF-2304W3	AF-RHMW12A-WGFD01LF-2304W4	AF-RHMW12A-WGFD01LF-2305W1	AF-RHMW12A-WGFD01LF-2305W2	AF-RHMW12A-WGFD01LF-2305W3	AF-RHMW12A-WGFD01LF-2305W4	AF-RHMW12A-WGFD01LF-2305W5	AF-RHMW12A-WGFD01LF-2306	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	2023-05-31	2023-06-06	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.20	1.10	ND	1.00	1.00	1.00	0.940	0.870	0.630	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	4.00	4.10	3.20	3.30	3.10	3.40	2.70	1.80	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	1.30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGFD01LF-2307	AF-RHMW12A-WGFD01LF-2308	AF-RHMW12A-WGFD01LF-2309	AF-RHMW12A-WGFD01LF-2310	AF-RHMW12A-WGFD01LF-2311	AF-RHMW12A-WGFD01LF-2312	AF-RHMW12A-WGN01B-2212W1	AF-RHMW12A-WGN01B-2212W2
				Sample Date:	2023-07-07	2023-08-03	2023-09-07	2023-10-03	2023-11-09	2023-12-07	2022-12-09	2022-12-14
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	16.0	18.0
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGFD01LF-2307	AF-RHMW12A-WGFD01LF-2308	AF-RHMW12A-WGFD01LF-2309	AF-RHMW12A-WGFD01LF-2310	AF-RHMW12A-WGFD01LF-2311	AF-RHMW12A-WGFD01LF-2312	AF-RHMW12A-WGN01B-2212W1	AF-RHMW12A-WGN01B-2212W2
				Sample Date:	2023-07-07	2023-08-03	2023-09-07	2023-10-03	2023-11-09	2023-12-07	2022-12-09	2022-12-14
				Sample Type:	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	FD (Field Duplicate)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	0.0550	0.0510
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	19.0	13.0
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	1.50	1.20
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	0.720	ND	ND	ND	ND	ND	7.70	5.50
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	0.140	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	0.890	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	0.400	0.350
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	1.70	1.70	ND	ND	ND	ND	ND	34.0	22.0
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGN01LF-2212W3	AF-RHMW12A-WGN01LF-2212W4	AF-RHMW12A-WGN01LF-2301W1	AF-RHMW12A-WGN01LF-2301W2	AF-RHMW12A-WGN01LF-2301W3	AF-RHMW12A-WGN01LF-2301W4	AF-RHMW12A-WGN01LF-2301W5	AF-RHMW12A-WGN01LF-2302W1
				Sample Date:	2022-12-21	2022-12-28	2023-01-04	2023-01-10	2023-01-17	2023-01-25	2023-01-30	2023-02-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	2.30	0.550	0.570	ND	ND	3.20	ND	2.20	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGN01LF-2212W3	AF-RHMW12A-WGN01LF-2212W4	AF-RHMW12A-WGN01LF-2301W1	AF-RHMW12A-WGN01LF-2301W2	AF-RHMW12A-WGN01LF-2301W3	AF-RHMW12A-WGN01LF-2301W4	AF-RHMW12A-WGN01LF-2301W5	AF-RHMW12A-WGN01LF-2302W1
				Sample Date:	2022-12-21	2022-12-28	2023-01-04	2023-01-10	2023-01-17	2023-01-25	2023-01-30	2023-02-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	2.70	2.90	2.50	ND	ND	ND	ND	ND	1.70
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.290	0.260	0.340	ND	ND	ND	ND	ND	0.360
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.30	1.60	1.60	1.20	1.20	1.20	1.30	1.50	1.60
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.200	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	5.00	5.60	5.30	4.60	4.70	5.00	5.00	5.00	5.10
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGN01LF-2302W2	AF-RHMW12A-WGN01LF-2302W3	AF-RHMW12A-WGN01LF-2302W4	AF-RHMW12A-WGN01LF-2303W1	AF-RHMW12A-WGN01LF-2303W2	AF-RHMW12A-WGN01LF-2303W3	AF-RHMW12A-WGN01LF-2303W4	AF-RHMW12A-WGN01LF-2304W1
				Sample Date:	2023-02-14	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	1.50	ND	1.10	ND	1.80	ND	0.920	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGN01LF-2302W2	AF-RHMW12A-WGN01LF-2302W3	AF-RHMW12A-WGN01LF-2302W4	AF-RHMW12A-WGN01LF-2303W1	AF-RHMW12A-WGN01LF-2303W2	AF-RHMW12A-WGN01LF-2303W3	AF-RHMW12A-WGN01LF-2303W4	AF-RHMW12A-WGN01LF-2304W1
				Sample Date:	2023-02-14	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27	2023-04-03
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	1.80	ND	1.60	ND	1.40	ND	1.40	1.40
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	0.160	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.400	ND	0.330	ND	0.350	ND	0.320	0.320
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.40	1.60	1.60	1.50	1.10	1.40	1.40	1.40	1.40
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	0.540	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	0.950	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	5.30	5.40	5.50	4.60	3.80	4.70	4.80	5.00	5.00
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW12A-WGN01LF-2304W2	AF-RHMW12A-WGN01LF-2304W3	AF-RHMW12A-WGN01LF-2304W4	AF-RHMW12A-WGN01LF-2305W1	AF-RHMW12A-WGN01LF-2305W2	AF-RHMW12A-WGN01LF-2305W3	AF-RHMW12A-WGN01LF-2305W4	AF-RHMW12A-WGN01LF-2305W5
				Sample Date:	2023-04-13	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	2023-05-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW12A Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-RHMW12A-WGN01LF-2304W2	AF-RHMW12A-WGN01LF-2304W3	AF-RHMW12A-WGN01LF-2304W4	AF-RHMW12A-WGN01LF-2305W1	AF-RHMW12A-WGN01LF-2305W2	AF-RHMW12A-WGN01LF-2305W3	AF-RHMW12A-WGN01LF-2305W4	AF-RHMW12A-WGN01LF-2305W5
				Sample Date:	2023-04-13	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	2023-05-31
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	2.00	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	1.30	1.10	1.30	ND	0.890	0.980	1.00	0.780	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	4.70	3.90	3.80	3.20	3.20	3.20	3.40	3.30	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	1.30	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A						RHMW16
				Location Type:	Monitoring Well						Monitoring Well
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW12A-WGN01LF-2306	AF-RHMW12A-WGN01LF-2307	AF-RHMW12A-WGN01LF-2308	AF-RHMW12A-WGN01LF-2309	AF-RHMW12A-WGN01LF-2310	AF-RHMW12A-WGN01LF-2311	AF-RHMW12A-WGN01LF-2312	AF-RHMW16-WGN01B-2212W1
				2023-06-06	2023-07-07	2023-08-03	2023-09-07	2023-10-03	2023-11-09	2023-12-07	2022-12-10
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	48.0
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW12A						RHMW16
				Location Type:	Monitoring Well						Monitoring Well
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW12A-WGN01LF-2306	AF-RHMW12A-WGN01LF-2307	AF-RHMW12A-WGN01LF-2308	AF-RHMW12A-WGN01LF-2309	AF-RHMW12A-WGN01LF-2310	AF-RHMW12A-WGN01LF-2311	AF-RHMW12A-WGN01LF-2312	AF-RHMW16-WGN01B-2212W1
				2023-06-06	2023-07-07	2023-08-03	2023-09-07	2023-10-03	2023-11-09	2023-12-07	2022-12-10
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	15.0
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	0.100
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	0.110
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	1.70
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	0.0440
	Perfluorohexanoic acid (PFHxA)	990	1920	0.700	0.660	0.580	ND	ND	ND	ND	4.40
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	0.150
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	0.130
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	0.400
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	2.00	2.00	1.50	ND	ND	ND	ND	25.0
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01B-2212W2	AF-RHMW16-WGN01LF-2212W3	AF-RHMW16-WGN01LF-2212W4	AF-RHMW16-WGN01LF-2301W1	AF-RHMW16-WGN01LF-2301W2	AF-RHMW16-WGN01LF-2301W3	AF-RHMW16-WGN01LF-2301W4	AF-RHMW16-WGN01LF-2301W5	
				2022-12-16	2022-12-21	2022-12-28	2023-01-04	2023-01-10	2023-01-17	2023-01-25	2023-02-02	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	22.0	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01B-2212W2	AF-RHMW16-WGN01LF-2212W3	AF-RHMW16-WGN01LF-2212W4	AF-RHMW16-WGN01LF-2301W1	AF-RHMW16-WGN01LF-2301W2	AF-RHMW16-WGN01LF-2301W3	AF-RHMW16-WGN01LF-2301W4	AF-RHMW16-WGN01LF-2301W5	
				2022-12-16	2022-12-21	2022-12-28	2023-01-04	2023-01-10	2023-01-17	2023-01-25	2023-02-02	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.0590	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	8.50	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	1.50	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	2.80	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	0.0850	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	0.380	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	0.320	ND	0.160	0.200	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	15.0	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND		

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01LF-2302W1	AF-RHMW16-WGN01LF-2302W2	AF-RHMW16-WGN01LF-2302W3	AF-RHMW16-WGN01LF-2302W4	AF-RHMW16-WGN01LF-2303W1	AF-RHMW16-WGN01LF-2303W2	AF-RHMW16-WGN01LF-2303W3	AF-RHMW16-WGN01LF-2303W4	
				2023-02-08	2023-02-14	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW16 Monitoring Well							
				AF-RHMW16- WGN01LF-2302W1	AF-RHMW16- WGN01LF-2302W2	AF-RHMW16- WGN01LF-2302W3	AF-RHMW16- WGN01LF-2302W4	AF-RHMW16- WGN01LF-2303W1	AF-RHMW16- WGN01LF-2303W2	AF-RHMW16- WGN01LF-2303W3	AF-RHMW16- WGN01LF-2303W4
				2023-02-08	2023-02-14	2023-02-21	2023-02-28	2023-03-06	2023-03-13	2023-03-20	2023-03-27
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	0.150	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	0.280	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	0.120	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01LF-2304W1	AF-RHMW16-WGN01LF-2304W2	AF-RHMW16-WGN01LF-2304W3	AF-RHMW16-WGN01LF-2304W4	AF-RHMW16-WGN01LF-2305W1	AF-RHMW16-WGN01LF-2305W2	AF-RHMW16-WGN01LF-2305W3	AF-RHMW16-WGN01LF-2305W4	
				2023-04-03	2023-04-12	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01LF-2304W1	AF-RHMW16-WGN01LF-2304W2	AF-RHMW16-WGN01LF-2304W3	AF-RHMW16-WGN01LF-2304W4	AF-RHMW16-WGN01LF-2305W1	AF-RHMW16-WGN01LF-2305W2	AF-RHMW16-WGN01LF-2305W3	AF-RHMW16-WGN01LF-2305W4	
				2023-04-03	2023-04-12	2023-04-19	2023-04-24	2023-05-01	2023-05-09	2023-05-15	2023-05-22	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	1.40	1.30	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW16-WGN01LF-2305W5	AF-RHMW16-WGN01LF-2306	AF-RHMW16-WGN01LF-2307	AF-RHMW16-WGN01LF-2308	AF-RHMW16-WGN01LF-2309	AF-RHMW16-WGN01LF-2310	AF-RHMW16-WGN01LF-2311	AF-RHMW16-WGN01LF-2312	
				2023-05-31	2023-06-05	2023-07-07	2023-08-03	2023-09-07	2023-10-05	2023-11-06	2023-12-04	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW16							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW16-WGN01LF-2305W5	AF-RHMW16-WGN01LF-2306	AF-RHMW16-WGN01LF-2307	AF-RHMW16-WGN01LF-2308	AF-RHMW16-WGN01LF-2309	AF-RHMW16-WGN01LF-2310	AF-RHMW16-WGN01LF-2311	AF-RHMW16-WGN01LF-2312
				Sample Date:	2023-05-31	2023-06-05	2023-07-07	2023-08-03	2023-09-07	2023-10-05	2023-11-06	2023-12-04
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW17-WGN01B-2212W2	AF-RHMW17-WGN01LF-2212W1	AF-RHMW17-WGN01LF-2212W3	AF-RHMW17-WGN01LF-2212W4	AF-RHMW17-WGN01LF-2301W1	AF-RHMW17-WGN01LF-2301W2	AF-RHMW17-WGN01LF-2301W3	AF-RHMW17-WGN01LF-2301W4
				Sample Date:	2022-12-13	2022-12-07	2022-12-22	2022-12-28	2023-01-06	2023-01-13	2023-01-20	2023-01-27
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	25.0	13.0	8.60	4.30	12.0	22.9	26.1	14.8	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW17-WGN01B-2212W2	AF-RHMW17-WGN01LF-2212W1	AF-RHMW17-WGN01LF-2212W3	AF-RHMW17-WGN01LF-2212W4	AF-RHMW17-WGN01LF-2301W1	AF-RHMW17-WGN01LF-2301W2	AF-RHMW17-WGN01LF-2301W3	AF-RHMW17-WGN01LF-2301W4
				Sample Date:	2022-12-13	2022-12-07	2022-12-22	2022-12-28	2023-01-06	2023-01-13	2023-01-20	2023-01-27
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.230	0.190	0.160	0.190	0.200	ND	ND	ND	ND
	Perfluorobutanoic acid (PFBA)	1800	14600	6.70	4.60	2.80	3.10	2.70	5.80	2.90	2.80	2.80
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	0.220	ND	0.100	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	2.10	0.980	0.830	0.860	0.720	0.960	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.0480	0.0530	0.0540	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	5.10	2.90	2.50	2.60	2.00	3.60	2.90	3.40	3.40
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	0.260	ND	0.110	0.120	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	0.720	0.110	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	0.190	ND	0.710	0.120	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	0.510	0.230	0.390	0.550	0.410	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	14.0	7.60	5.00	6.20	4.90	8.60	5.70	6.20	6.20
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	0.180	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17-WGN01LF-2301W5	AF-RHMW17-WGN01LF-2302W1	AF-RHMW17-WGN01LF-2302W2	AF-RHMW17-WGN01LF-2302W3	AF-RHMW17-WGN01LF-2302W4	AF-RHMW17-WGN01LF-2303W1	AF-RHMW17-WGN01LF-2303W2	AF-RHMW17-WGN01LF-2303W3	
				2023-02-01	2023-02-10	2023-02-17	2023-02-24	2023-03-03	2023-03-10	2023-03-17	2023-03-24	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	0.830	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	5.40	0.490	269	84.0	28.4	12.0	ND	6.00	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17								
				Location Type:	Monitoring Well								
				Field Sample ID:	AF-RHMW17-WGN01LF-2301W5	AF-RHMW17-WGN01LF-2302W1	AF-RHMW17-WGN01LF-2302W2	AF-RHMW17-WGN01LF-2302W3	AF-RHMW17-WGN01LF-2302W4	AF-RHMW17-WGN01LF-2303W1	AF-RHMW17-WGN01LF-2303W2	AF-RHMW17-WGN01LF-2303W3	AF-RHMW17-WGN01LF-2303W3
				Sample Date:	2023-02-01	2023-02-10	2023-02-17	2023-02-24	2023-03-03	2023-03-10	2023-03-17	2023-03-17	2023-03-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	0.220	ND	0.190	ND	0.210	ND	0.180		
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	2.10	3.80	3.30	3.50	2.60	3.20	4.30		
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	0.110	ND	ND	ND	ND	0.0950	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.440	1.30	1.20	0.990	0.900	1.00	1.10		
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	0.0410	ND	0.440	ND	0.0440		
	Perfluorohexanoic acid (PFHxA)	990	1920	2.00	2.50	7.60	6.80	6.20	5.60	5.60	4.80		
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	0.140	ND	ND	ND	0.120		
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	0.100	ND	0.350	ND	0.320		
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	0.190	ND	ND	ND	1.10	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.270	ND	0.390	0.630	0.330	ND	0.390		
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	4.50	5.30	9.30	9.70	10.6	13.0	9.60	9.40		
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17-WGN01LF-2303W4	AF-RHMW17-WGN01LF-2304W1	AF-RHMW17-WGN01LF-2304W2	AF-RHMW17-WGN01LF-2304W3	AF-RHMW17-WGN01LF-2304W4	AF-RHMW17-WGN01LF-2305W1	AF-RHMW17-WGN01LF-2305W2	AF-RHMW17-WGN01LF-2305W3	
				2023-03-31	2023-04-07	2023-04-14	2023-04-20	2023-04-28	2023-05-03	2023-05-12	2023-05-19	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	4.70	19.2	ND	ND	4.20	ND	16.5	8.00	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17-WGN01LF-2303W4	AF-RHMW17-WGN01LF-2304W1	AF-RHMW17-WGN01LF-2304W2	AF-RHMW17-WGN01LF-2304W3	AF-RHMW17-WGN01LF-2304W4	AF-RHMW17-WGN01LF-2305W1	AF-RHMW17-WGN01LF-2305W2	AF-RHMW17-WGN01LF-2305W3	
				2023-03-31	2023-04-07	2023-04-14	2023-04-20	2023-04-28	2023-05-03	2023-05-12	2023-05-19	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	2.80	4.70	3.60	ND	2.50	2.90	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	1.00	0.920	ND	ND	0.530	0.760	0.920	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	3.90	4.10	2.10	ND	1.70	1.90	2.40	1.40	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	0.460	ND	ND	0.580	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	7.00	7.90	4.00	2.00	2.40	3.00	3.70	2.90	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17-WGN01LF-2305W4	AF-RHMW17-WGN01LF-2305W5	AF-RHMW17-WGN01LF-2306	AF-RHMW17-WGN01LF-2307	AF-RHMW17-WGN01LF-2308	AF-RHMW17-WGN01LF-2309	AF-RHMW17-WGN01LF-2310	AF-RHMW17-WGN01LF-2311	
				2023-05-26	2023-06-02	2023-06-08	2023-07-07	2023-08-04	2023-09-08	2023-10-04	2023-11-08	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	10.0	13.0	10.7	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17-WGN01LF-2305W4	AF-RHMW17-WGN01LF-2305W5	AF-RHMW17-WGN01LF-2306	AF-RHMW17-WGN01LF-2307	AF-RHMW17-WGN01LF-2308	AF-RHMW17-WGN01LF-2309	AF-RHMW17-WGN01LF-2310	AF-RHMW17-WGN01LF-2311	
				2023-05-26	2023-06-02	2023-06-08	2023-07-07	2023-08-04	2023-09-08	2023-10-04	2023-11-08	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	3.00	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.890	0.570	0.670	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	1.90	1.70	2.10	1.10	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.830	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	4.00	2.60	2.60	1.90	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D				RHMW17D																						
				Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Field Sample ID:	Sample Date:	Sample Type:																
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	RHMW17	Monitoring Well	AF-RHMW17-WGN01LF-2312	2023-12-06	N (Normal)	AF-RHMW17D-WGN01B-2212W2	2022-12-16	N (Normal)	AF-RHMW17D-WGN01LF-2212W3	2022-12-22	N (Normal)	AF-RHMW17D-WGN01LF-2212W4	2022-12-28	N (Normal)	AF-RHMW17D-WGN01LF-2301W1	2023-01-06	N (Normal)	AF-RHMW17D-WGN01LF-2301W2	2023-01-13	N (Normal)	AF-RHMW17D-WGN01LF-2301W3	2023-01-20	N (Normal)	AF-RHMW17D-WGN01LF-2301W4	2023-01-27	N (Normal)		
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	120	6.40	2.20	2.70	ND	22.6	6.40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D				RHMW17D																							
				Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Field Sample ID:	Sample Date:	Sample Type:	Monitoring Well	Field Sample ID:	Sample Date:	Sample Type:																	
				RHMW17	Monitoring Well	AF-RHMW17-WGN01LF-2312	2023-12-06	N (Normal)	AF-RHMW17D-WGN01B-2212W2	2022-12-16	N (Normal)	AF-RHMW17D-WGN01LF-2212W3	2022-12-22	N (Normal)	AF-RHMW17D-WGN01LF-2212W4	2022-12-28	N (Normal)	AF-RHMW17D-WGN01LF-2301W1	2023-01-06	N (Normal)	AF-RHMW17D-WGN01LF-2301W2	2023-01-13	N (Normal)	AF-RHMW17D-WGN01LF-2301W3	2023-01-20	N (Normal)	AF-RHMW17D-WGN01LF-2301W4	2023-01-27	N (Normal)			
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	0.160	0.100	0.100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	0.690	0.940	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	0.430	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	0.270	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.640	0.290	0.120	0.0650	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	0.150	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	0.990	1.60	0.290	0.220	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	0.330	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	0.110	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	1.10	0.850	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.790	0.220	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	1.50	0.940	0.150	0.110	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	0.230	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17D-WGN01LF-2301W5	AF-RHMW17D-WGN01LF-2302W1	AF-RHMW17D-WGN01LF-2302W2	AF-RHMW17D-WGN01LF-2302W3	AF-RHMW17D-WGN01LF-2302W4	AF-RHMW17D-WGN01LF-2303W1	AF-RHMW17D-WGN01LF-2303W2	AF-RHMW17D-WGN01LF-2303W3	
				2023-02-01	2023-02-10	2023-02-17	2023-02-24	2023-03-03	2023-03-10	2023-03-17	2023-03-24	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	25.6	6.10	5.30	5.20	ND	2.90	ND	2.80	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	0.250	ND	0.490	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D								
				Location Type:	Monitoring Well								
				Field Sample ID:	AF-RHMW17D-WGN01LF-2301W5	AF-RHMW17D-WGN01LF-2302W1	AF-RHMW17D-WGN01LF-2302W2	AF-RHMW17D-WGN01LF-2302W3	AF-RHMW17D-WGN01LF-2302W4	AF-RHMW17D-WGN01LF-2303W1	AF-RHMW17D-WGN01LF-2303W2	AF-RHMW17D-WGN01LF-2303W3	AF-RHMW17D-WGN01LF-2303W3
				Sample Date:	2023-02-01	2023-02-10	2023-02-17	2023-02-24	2023-03-03	2023-03-10	2023-03-17	2023-03-17	2023-03-24
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	0.0810	ND	0.0650	ND	ND	ND	ND	0.0780	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	0.600	ND	0.650	--	0.780	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.0450	ND	0.0910	ND	0.0690	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	0.0520	ND	0.0640	ND	0.250	ND	0.0770	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	0.270	ND	0.280	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	0.170	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	0.340	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	0.130	ND	0.160	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17D-WGN01LF-2303W4	AF-RHMW17D-WGN01LF-2304W1	AF-RHMW17D-WGN01LF-2304W2	AF-RHMW17D-WGN01LF-2304W3	AF-RHMW17D-WGN01LF-2304W4	AF-RHMW17D-WGN01LF-2305W1	AF-RHMW17D-WGN01LF-2305W2	AF-RHMW17D-WGN01LF-2305W3	
				2023-03-31	2023-04-07	2023-04-14	2023-04-20	2023-04-28	2023-05-03	2023-05-12	2023-05-19	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	--	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	--	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17D-WGN01LF-2303W4	AF-RHMW17D-WGN01LF-2304W1	AF-RHMW17D-WGN01LF-2304W2	AF-RHMW17D-WGN01LF-2304W3	AF-RHMW17D-WGN01LF-2304W4	AF-RHMW17D-WGN01LF-2305W1	AF-RHMW17D-WGN01LF-2305W2	AF-RHMW17D-WGN01LF-2305W3	
				2023-03-31	2023-04-07	2023-04-14	2023-04-20	2023-04-28	2023-05-03	2023-05-12	2023-05-19	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	--	--	ND	--	ND	--	--	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	7.10	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17D-WGN01LF-2305W4	AF-RHMW17D-WGN01LF-2305W5	AF-RHMW17D-WGN01LF-2306	AF-RHMW17D-WGN01LF-2307	AF-RHMW17D-WGN01LF-2308	AF-RHMW17D-WGN01LF-2309	AF-RHMW17D-WGN01LF-2310	AF-RHMW17D-WGN01LF-2311	
				2023-05-26	2023-06-02	2023-06-08	2023-07-07	2023-08-04	2023-09-08	2023-10-04	2023-11-08	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	3.80	ND	ND	ND	ND	ND	3.70	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17D-WGN01LF-2305W4	AF-RHMW17D-WGN01LF-2305W5	AF-RHMW17D-WGN01LF-2306	AF-RHMW17D-WGN01LF-2307	AF-RHMW17D-WGN01LF-2308	AF-RHMW17D-WGN01LF-2309	AF-RHMW17D-WGN01LF-2310	AF-RHMW17D-WGN01LF-2311	
				2023-05-26	2023-06-02	2023-06-08	2023-07-07	2023-08-04	2023-09-08	2023-10-04	2023-11-08	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	--	ND	ND	ND	ND	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D		RHMW17S					
				Location Type:	Monitoring Well		Monitoring Well					
				Field Sample ID:	AF-RHMW17D-WGN01LF-2312	AF-RHMW17D-WGN02B-2212W2	AF-RHMW17S-WGN01B-2302W3	AF-RHMW17S-WGN01LF-2302W4	AF-RHMW17S-WGN01LF-2303W1	AF-RHMW17S-WGN01LF-2304W1	AF-RHMW17S-WGN01LF-2304W3	AF-RHMW17S-WGN01LF-2304W4
				Sample Date:	2023-12-06	2022-12-16	2023-02-24	2023-03-03	2023-03-10	2023-04-07	2023-04-20	2023-04-28
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	54.0	16.0	17.1	1.60	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17D		RHMW17S					
				Location Type:	Monitoring Well		Monitoring Well					
				Field Sample ID:	AF-RHMW17D-WGN01LF-2312	AF-RHMW17D-WGN02B-2212W2	AF-RHMW17S-WGN01B-2302W3	AF-RHMW17S-WGN01LF-2302W4	AF-RHMW17S-WGN01LF-2303W1	AF-RHMW17S-WGN01LF-2304W1	AF-RHMW17S-WGN01LF-2304W3	AF-RHMW17S-WGN01LF-2304W4
				Sample Date:	2023-12-06	2022-12-16	2023-02-24	2023-03-03	2023-03-10	2023-04-07	2023-04-20	2023-04-28
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	0.110	0.710	ND	0.430	0.760	0.630	0.890	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	4.20	ND	3.70	4.70	ND	ND	
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	0.160	0.230	ND	ND	ND	ND	ND	
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.200	1.10	ND	0.800	1.60	1.00	1.10	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	0.0910	0.530	ND	0.400	ND	ND	ND	
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	0.830	1.90	ND	1.40	3.10	ND	2.10	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	0.140	0.270	ND	0.280	0.740	ND	ND	
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	0.250	ND	0.120	ND	ND	ND	
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	0.530	1.20	ND	1.10	1.30	1.30	1.30	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.360	1.60	0.740	0.960	1.00	1.20	1.10	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	0.700	1.40	ND	1.00	ND	ND	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	
Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND		
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17S							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW17S-WGN01LF-2305W1	AF-RHMW17S-WGN01LF-2305W2	AF-RHMW17S-WGN01LF-2305W3	AF-RHMW17S-WGN01LF-2305W4	AF-RHMW17S-WGN01LF-2305W5	AF-RHMW17S-WGN01LF-2306	AF-RHMW17S-WGN01LF-2308	AF-RHMW17S-WGN01LF-2309	
				2023-05-03	2023-05-12	2023-05-19	2023-05-26	2023-06-02	2023-06-08	2023-08-04	2023-09-08	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	5.30	ND	4.10	3.20	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17S							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW17S-WGN01LF-2305W1	AF-RHMW17S-WGN01LF-2305W2	AF-RHMW17S-WGN01LF-2305W3	AF-RHMW17S-WGN01LF-2305W4	AF-RHMW17S-WGN01LF-2305W5	AF-RHMW17S-WGN01LF-2306	AF-RHMW17S-WGN01LF-2308	AF-RHMW17S-WGN01LF-2309
				Sample Date:	2023-05-03	2023-05-12	2023-05-19	2023-05-26	2023-06-02	2023-06-08	2023-08-04	2023-09-08
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700		0.630	0.690	0.650	0.730	0.560	0.480	ND	0.500
	Perfluorobutanoic acid (PFBA)	1800	14600		ND	ND	ND	ND	ND	13.7	6.80	9.60
	Perfluorodecanesulfonic acid (PFDS)	--	38.5		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5		ND	0.750	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9		1.30	1.10	1.10	1.00	0.780	0.770	ND	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorohexanoic acid (PFHxA)	990	1920		2.00	1.80	1.80	2.00	1.90	1.70	1.40	0.970
	Perfluorononanesulfonic acid (PFNS)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69		ND	1.40	1.30	1.20	1.00	ND	1.00	1.20
	Perfluorooctanoic acid (PFOA)	6	11.5		1.10	0.890	1.00	0.930	1.40	0.940	ND	1.00
	Perfluoropentanesulfonic acid (PFPeS)	--	--		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540		9.50	1.60	ND	ND	13.3	16.6	ND	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6		ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2		ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--		ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17S			RHMW2254-01				
				Location Type:	Monitoring Well			Monitoring Well				
				Field Sample ID:	AF-RHMW17S-WGN01LF-2310	AF-RHMW17S-WGN01LF-2311	AF-RHMW17S-WGN01LF-2312	AF-RHMW225401-WGN01B-2212W1	AF-RHMW225401-WGN01B-2212W2	AF-RHMW225401-WGN01B-2212W3	AF-RHMW225401-WGN01B-2212W4	AF-RHMW225401-WGN01B-2301W1
				Sample Date:	2023-10-04	2023-11-08	2023-12-06	2022-12-02	2022-12-13	2022-12-19	2022-12-29	2023-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	0.470	0.470	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW17S			RHMW2254-01				
				Location Type:	Monitoring Well			Monitoring Well				
				Field Sample ID:	AF-RHMW17S-WGN01LF-2310	AF-RHMW17S-WGN01LF-2311	AF-RHMW17S-WGN01LF-2312	AF-RHMW225401-WGN01B-2212W1	AF-RHMW225401-WGN01B-2212W2	AF-RHMW225401-WGN01B-2212W3	AF-RHMW225401-WGN01B-2212W4	AF-RHMW225401-WGN01B-2301W1
				Sample Date:	2023-10-04	2023-11-08	2023-12-06	2022-12-02	2022-12-13	2022-12-19	2022-12-29	2023-01-05
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	ND	ND	ND	ND	0.660	0.710	0.680	0.770	0.660
	Perfluorobutanoic acid (PFBA)	1800	14600	6.10	ND	ND	ND	0.540	0.410	0.600	0.710	0.600
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	0.0550	ND	ND	0.0610	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	ND	ND	ND	0.820	0.590	0.730	1.10	0.750
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	ND	ND	ND	1.10	0.880	1.20	1.40	1.10
	Perfluorohexanoic acid (PFHxA)	990	1920	ND	ND	ND	ND	0.950	0.850	0.960	1.20	0.960
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	0.150	0.120	0.180	0.200	0.160
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	0.960	0.910	ND	1.10	0.930	0.980	0.890	0.480
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	0.530	ND	ND	1.20	1.10	1.00	1.20	0.840
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	0.130	0.130	0.110	0.230	0.120
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	ND	ND	ND	1.20	1.00	1.20	1.50	1.20
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	RHMW2254-01 Monitoring Well							
				Location ID:	Location Type:	Field Sample ID:	Sample Date:	Sample Type:	Field Sample ID:	Sample Date:	Sample Type:
				AF-RHMW225401-WGN01B-2301W2	AF-RHMW225401-WGN01B-2301W3	AF-RHMW225401-WGN01B-2301W4	AF-RHMW225401-WGN01B-2302W1	AF-RHMW225401-WGN01B-2302W2	AF-RHMW225401-WGN01B-2302W3	AF-RHMW225401-WGN01B-2302W4	AF-RHMW225401-WGN01B-2303W1
				2023-01-11	2023-01-18	2023-01-26	2023-02-10	2023-02-15	2023-02-22	2023-03-01	2023-03-08
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	0.370
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW2254-01 Monitoring Well							
				AF-RHMW225401- WGN01B-2301W2	AF-RHMW225401- WGN01B-2301W3	AF-RHMW225401- WGN01B-2301W4	AF-RHMW225401- WGN01B-2302W1	AF-RHMW225401- WGN01B-2302W2	AF-RHMW225401- WGN01B-2302W3	AF-RHMW225401- WGN01B-2302W4	AF-RHMW225401- WGN01B-2303W1
				2023-01-11	2023-01-18	2023-01-26	2023-02-10	2023-02-15	2023-02-22	2023-03-01	2023-03-08
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.700	0.600	ND	0.760	0.760	0.710	0.770	0.760
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	0.600	ND	0.710	ND	0.760
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.800	0.540	ND	0.830	0.940	0.760	1.40	0.930
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	1.60	1.10	1.00	1.20	1.30	1.10	1.30	1.20
	Perfluorohexanoic acid (PFHxA)	990	1920	1.00	0.880	0.860	1.00	1.10	1.00	1.20	1.20
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	0.170	ND	0.160	ND	0.190
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	1.10	1.10	ND	1.10	1.40	1.10	ND	1.00
	Perfluorooctanoic acid (PFOA)	6	11.5	1.00	0.880	0.930	1.00	1.50	1.10	1.00	1.10
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	0.160	ND	0.130	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	1.00	ND	1.30	1.70	1.40	1.70	1.50
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW2254-01							
				Location Type:	Monitoring Well							
Field Sample ID:	Sample Date:	Sample Type:		AF-RHMW225401-WGN01B-2303W2	AF-RHMW225401-WGN01B-2303W3	AF-RHMW225401-WGN01B-2303W4	AF-RHMW225401-WGN01B-2304W1	AF-RHMW225401-WGN01B-2304W2	AF-RHMW225401-WGN01B-2304W3	AF-RHMW225401-WGN01B-2304W4	AF-RHMW225401-WGN01B-2305W1	
				2023-03-16	2023-03-22	2023-03-29	2023-04-05	2023-04-13	2023-04-21	2023-04-26	2023-05-04	
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW2254-01 Monitoring Well							
				AF-RHMW225401- WGN01B-2303W2	AF-RHMW225401- WGN01B-2303W3	AF-RHMW225401- WGN01B-2303W4	AF-RHMW225401- WGN01B-2304W1	AF-RHMW225401- WGN01B-2304W2	AF-RHMW225401- WGN01B-2304W3	AF-RHMW225401- WGN01B-2304W4	AF-RHMW225401- WGN01B-2305W1
				2023-03-16	2023-03-22	2023-03-29	2023-04-05	2023-04-13	2023-04-21	2023-04-26	2023-05-04
				N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL								
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.690	0.760	0.750	0.750	0.890	0.740	ND	0.580
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	0.840	ND	0.660	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.790	0.910	0.920	0.680	0.940	1.20	0.700	0.680
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	1.30	1.40	1.20	1.10	1.40	1.50	1.00	1.10
	Perfluorohexanoic acid (PFHxA)	990	1920	0.920	1.10	1.10	0.940	1.30	1.40	0.860	0.920
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	0.120	ND	0.140	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	1.10	1.50	1.60	1.10	0.980	2.20	1.10	1.30
	Perfluorooctanoic acid (PFOA)	6	11.5	1.60	1.00	1.30	0.960	1.10	1.80	1.80	0.800
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	0.150	ND	0.110	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	1.40	1.50	1.40	1.10	1.60	1.80	ND	1.30
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:	RHMW2254-01							
				Location Type:	Monitoring Well							
				Field Sample ID:	AF-RHMW225401-WGN01B-2305W2	AF-RHMW225401-WGN01B-2305W3	AF-RHMW225401-WGN01B-2305W4	AF-RHMW225401-WGN01B-2305W5	AF-RHMW225401-WGN01B-2306	AF-RHMW225401-WGN01B-2307	AF-RHMW225401-WGN01B-2308	AF-RHMW225401-WGN01B-2309
				Sample Date:	2023-05-08	2023-05-16	2023-05-23	2023-05-30	2023-06-08	2023-07-03	2023-08-02	2023-09-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND

Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

				RHMW2254-01 Monitoring Well								
				Location ID:								
				Location Type:								
				Field Sample ID:	AF-RHMW225401-WGN01B-2305W2	AF-RHMW225401-WGN01B-2305W3	AF-RHMW225401-WGN01B-2305W4	AF-RHMW225401-WGN01B-2305W5	AF-RHMW225401-WGN01B-2306	AF-RHMW225401-WGN01B-2307	AF-RHMW225401-WGN01B-2308	AF-RHMW225401-WGN01B-2309
				Sample Date:	2023-05-08	2023-05-16	2023-05-23	2023-05-30	2023-06-08	2023-07-03	2023-08-02	2023-09-06
				Sample Type:	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)	N (Normal)
Method Group	Analyte	EPA RSL	DOH EAL									
Per- and polyfluoroalkyl substances (ppt)	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.660	0.660	0.640	0.680	0.580	0.580	0.690	0.670	
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	0.810	0.830	0.560	0.780	0.600	0.680	0.700	0.620	
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	0.890	1.10	0.790	0.790	0.920	1.10	1.40	1.20	
	Perfluorohexanoic acid (PFHxA)	990	1920	0.890	0.880	0.880	1.20	0.790	0.910	0.700	0.910	
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	ND	ND	1.30	0.870	0.990	ND	1.40	
	Perfluorooctanoic acid (PFOA)	6	11.5	ND	1.50	1.20	1.40	0.920	0.970	1.30	ND	
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	1.30	1.20	1.70	1.00	ND	1.30	ND	
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	ND	ND	ND	ND	ND	

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:			Location Type:						
				AF-RHMMW225401-WGN01B-2310	AF-RHMMW225401-WGN01B-2311	AF-RHMMW225401-WGN01B-2312	RHSF-PUMP Faucet/Tap	RHS-TRAIN01 Treatability Unit Effluent					
				Sample Date:	Sample Type:								
				2023-10-05	N (Normal)	2023-11-07	N (Normal)	2023-12-05	N (Normal)	2023-03-15	N (Normal)	2023-03-15	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	2H,2H,3H,3H-Perfluorooctanoic acid (5:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoroheptyl propanoic acid (7:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	3-Perfluoropropyl propanoic acid (3:3FTCA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	--	1150	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	4:2 Fluorotelomer sulfonic acid (4:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	6:2 Fluorotelomer sulfonic acid (6:2 FTS)	--	1500	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	8:2 Fluorotelomer sulfonic acid (8:2 FTS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	0.140	ND
	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Hexafluoropropylene oxide dimer acid (HFPO-DA)	1.5	11.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamide (NEtFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Ethyl perfluorooctanesulfonamidoethanol (NEtFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl heptadecafluorooctanesulfonamide (NMeFOSA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	N-Methyl perfluorooctanesulfonamidoethanol (NMeFOSE)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Perfluoro-3-methoxypropanoic acid (PFMPA)	--	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

**Summary of Chemistry Results
Adit 6 - AFFF Release Response
PFAS Sampling, Red Hill, JBPHH**

Groundwater Samples collected December 2022 - December 2023 from Monitoring Wells surrounding Red Hill

Notes:
ND = Not Detected
PPT = Parts per Trillion
PPB = Parts per Billion
PPM = Parts per Million
§ - Exceeds Screening Level
-- = No Information Available
N (Normal) = Full compliance sample
FD (Field Duplicate) = Extra sample taken for quality control
N (Grab, Resample) = Additional follow-up sample
FT (Field Triplicate) = Field Triplicate
FR (Field Replicate) = Field Replicate

Method Group	Analyte	EPA RSL	DOH EAL	Location ID:			Location Type:	
				AF-RHMMW225401-WGN01B-2310	AF-RHMMW225401-WGN01B-2311	AF-RHMMW225401-WGN01B-2312	RHSF-PUMP Faucet/Tap	RHS-TRAIN01 Treatability Unit Effluent
				Field Sample ID:	Sample Date:	Sample Type:		
				RHMW2254-01			RHSF-PUMP	RHS-TRAIN01
				Monitoring Well			Faucet/Tap	Treatability Unit Effluent
							RHSF-PUMP-PR-01-031523-N	RHS-EF-TRAIN-01-031523-N
							2023-03-15	2023-03-15
							N (Normal)	N (Normal)
Per- and polyfluoroalkyl substances (ppt)	Perfluoro-4-methoxybutanoic acid (PFMBA)	--	--	ND	ND	ND	ND	ND
	Perfluorobutanesulfonic acid (PFBS)	600	1700	0.610	0.590	0.630	0.600	0.0370
	Perfluorobutanoic acid (PFBA)	1800	14600	ND	ND	ND	0.650	0.630
	Perfluorodecanesulfonic acid (PFDS)	--	38.5	ND	ND	ND	ND	ND
	Perfluorodecanoic acid (PFDA)	--	7.69	ND	ND	ND	ND	ND
	Perfluorododecanesulfonic acid (PFDoS)	--	--	ND	ND	ND	ND	ND
	Perfluorododecanoic acid (PFDoA)	100	25.6	ND	ND	ND	ND	ND
	Perfluoroheptanesulfonic acid (PFHpS)	--	38.5	ND	ND	ND	ND	ND
	Perfluoroheptanoic acid (PFHpA)	--	76.9	ND	0.610	0.590	0.480	ND
	Perfluorohexanesulfonic acid (PFHxS)	39	76.9	ND	0.810	1.20	0.830	ND
	Perfluorohexanoic acid (PFHxA)	990	1920	0.740	0.830	0.700	0.720	ND
	Perfluorononanesulfonic acid (PFNS)	--	--	ND	ND	ND	ND	ND
	Perfluorononanoic acid (PFNA)	5.9	11.5	ND	ND	ND	ND	ND
	Perfluorooctanesulfonamide (PFOSA)	--	46.2	ND	ND	ND	ND	ND
	Perfluorooctanesulfonic acid (PFOS)	4	7.69	ND	1.10	ND	0.760	ND
	Perfluorooctanoic acid (PFOA)	6	11.5	0.740	1.20	1.00	0.730	ND
	Perfluoropentanesulfonic acid (PFPeS)	--	--	ND	ND	ND	0.0930	ND
	Perfluoropentanoic acid (PFPeA)	--	1540	ND	0.940	1.00	0.920	ND
	Perfluorotetradecanoic acid (PFTeDA)	2000	256	ND	ND	ND	ND	ND
	Perfluorotridecanoic acid (PFTrDA)	--	25.6	ND	ND	ND	ND	ND
	Perfluoroundecanoic acid (PFUnA)	600	19.2	ND	ND	ND	ND	ND
Synthetic Organic Compounds (ppm)	2-(2-Butoxyethoxy)ethanol	--	--	ND	ND	ND	--	--